

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P584355

Luminaire Tested: **HC830D010-HM82555940-81MDH**

Issue Date: 10/21/2021

Test Information

Test Method: LM-41-14
Report Number: P584355
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2109-368-5)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 10/21/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC830D010-HM82555940-81MDH
Description: HALO COMMERCIAL 8" ROUND, NEW CONSTRUCTION FRAME, WITH 8" MEDIUM DISTRIBUTION, HAZE TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3501.6 lumens
Efficiency: N/A
Efficacy: 125.1 lumens/watt
Spacing Criteria (0/90/45): 0.68 / 0.68 / 0.81
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P584355

CATALOG NUMBER: HC830D010-HM82555940-81MDH

Luminous Intensity Polar Plot





TEST NUMBER: P584355

CATALOG NUMBER: HC830D010-HM82555940-81MDH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94			
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87			
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81			
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76			
5	93	84	79	74	91	83	78	74	82	77	73	80	76	73	78	75	72	71			
6	88	79	73	69	87	78	73	69	77	72	68	76	71	68	74	70	67	66			
7	84	75	69	64	82	74	68	64	73	68	64	71	67	64	70	66	63	62			
8	80	70	64	60	79	70	64	60	69	64	60	68	63	60	67	63	60	58			
9	76	67	61	57	75	66	61	57	65	60	56	64	60	56	63	59	56	55			
10	73	63	57	54	72	63	57	53	62	57	53	61	56	53	60	56	53	52			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	160136
5°	145927
10°	124678
15°	108730
20°	96910
25°	85965
30°	70384
35°	40419
40°	17937
45°	10436
50°	6030
55°	3441
60°	1900
65°	1211
70°	857
75°	572
80°	426
85°	849



TEST NUMBER: P584355

CATALOG NUMBER: HC830D010-HM82555940-81MDH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	426.7	12.2
10°-20°	957.4	27.3
20°-30°	1146.0	32.7
30°-40°	693.3	19.8
40°-50°	194.3	5.5
50°-60°	60.4	1.7
60°-70°	17.2	0.5
70°-80°	4.7	0.1
80°-90°	1.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2530.1	72.3
0°-40°	3223.4	92.1
0°-60°	3478.0	99.3
0°-90°	3501.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3501.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5193	
5°	4714	427
15°	3406	957
25°	2527	1146
35°	1074	693
45°	239	194
55°	64	60
65°	17	17
75°	5	5
85°	2	2
90°	0	



TEST NUMBER: P584355

CATALOG NUMBER: HC830D010-HM82555940-81MDH

CANDELA DISTRIBUTION (FULL):

	0°
0°	5193.1
2.5°	5046.1
5°	4714.3
7.5°	4339.7
10°	3981.8
12.5°	3669.0
15°	3405.9
17.5°	3173.7
20°	2953.2
22.5°	2749.4
25°	2526.6
27.5°	2275.4
30°	1976.7
32.5°	1590.4
35°	1073.7
37.5°	668.3
40°	445.6
42.5°	320.0
45°	239.3
47.5°	175.4
50°	125.7
52.5°	87.7
55°	64.0
57.5°	42.7
60°	30.8
62.5°	21.3
65°	16.6
67.5°	11.9
70°	9.5
72.5°	4.8
75°	4.8
77.5°	2.4
80°	2.4
82.5°	2.4
85°	2.4
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)