

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P582312

Luminaire Tested: **HCC6W35D010SL-HM63040835-61NDW**

Issue Date: 9/16/2021

**Test Information**

Test Method: LM-41-14  
Report Number: P582312  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-3)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 9/16/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: HALO COMMERCIAL  
Catalog Number: HCC6W35D010SL-HM63040835-61NDW  
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" NARROW DISTRIBUTION, WHITE TRIM  
Light Source: (1) HIGH LUMEN LED 80CRI / 3500K CCT  
CYLINDER  
Ballast/Driver: ELECTRONIC DRIVER


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3685.4 lumens  
Efficiency: N/A  
Efficacy: 109.4 lumens/watt  
Spacing Criteria (0/90/45): 1.06 / 1.06 / 1.03  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 33.7  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P582312  
CATALOG NUMBER: HCC6W35D010SL-HM63040835-61NDW

### Luminous Intensity Polar Plot





TEST NUMBER: P582312  
 CATALOG NUMBER: HCC6W35D010SL-HM63040835-61NDW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89		
2	104	97	92	87	101	95	90	86	92	88	84	89	85	83	86	83	81	79		
3	97	88	82	77	94	87	81	76	84	79	75	81	77	73	79	75	72	70		
4	90	81	73	68	88	79	73	68	77	71	67	75	70	66	73	69	65	63		
5	84	74	67	61	83	73	66	61	71	65	60	69	64	60	67	63	59	57		
6	79	68	61	55	77	67	60	55	66	59	55	64	59	54	63	58	54	52		
7	74	63	56	50	73	62	55	50	61	55	50	60	54	50	58	53	49	48		
8	70	59	51	46	69	58	51	46	57	50	46	56	50	46	54	49	46	44		
9	66	55	48	43	65	54	47	43	53	47	42	52	46	42	51	46	42	41		
10	62	51	44	40	61	51	44	40	50	44	39	49	43	39	48	43	39	38		

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	139589
5°	138933
10°	135864
15°	132674
20°	127685
25°	120757
30°	109745
35°	88827
40°	59905
45°	41167
50°	33730
55°	29514
60°	27914
65°	26358
70°	24748
75°	23532
80°	21373
85°	18744



TEST NUMBER: P582312  
 CATALOG NUMBER: HCC6W35D010SL-HM63040835-61NDW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	238.3	6.5
10°-20°	656.5	17.8
20°-30°	912.1	24.7
30°-40°	812.1	22.0
40°-50°	431.1	11.7
50°-60°	281.9	7.6
60°-70°	202.0	5.5
70°-80°	117.2	3.2
80°-90°	34.3	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1806.9	49.0
0°-40°	2619.0	71.1
0°-60°	3332.0	90.4
0°-90°	3685.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3685.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2546	
5°	2525	238
15°	2338	656
25°	1996	912
35°	1327	812
45°	531	431
55°	309	282
65°	203	202
75°	111	117
85°	30	34
90°	0	



TEST NUMBER: P582312  
CATALOG NUMBER: HCC6W35D010SL-HM63040835-61NDW

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2546.3
2.5°	2532.7
5°	2524.7
7.5°	2494.8
10°	2440.7
12.5°	2391.9
15°	2337.7
17.5°	2270.0
20°	2188.7
22.5°	2096.6
25°	1996.4
27.5°	1879.9
30°	1733.7
32.5°	1557.6
35°	1327.3
37.5°	1072.7
40°	837.1
42.5°	650.1
45°	531.0
47.5°	452.3
50°	395.5
52.5°	349.4
55°	308.8
57.5°	279.0
60°	254.6
62.5°	230.2
65°	203.2
67.5°	178.8
70°	154.4
72.5°	132.7
75°	111.1
77.5°	89.4
80°	67.7
82.5°	48.8
85°	29.8
87.5°	13.5
90°	0.0

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)