

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P583771

Luminaire Tested: **HCC8W10D010SL-HM80520927-81RWWH**

Issue Date: 10/21/2021

**Test Information**

Test Method: LM-41-14  
Report Number: P583771  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2109-368-15)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 10/21/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: HALO COMMERCIAL  
Catalog Number: HCC8W10D010SL-HM80520927-81RWWH  
Description: HALO COMMERCIAL 8" ROUND, NEW CONSTRUCTION FRAME, WITH 8" WALLWASH DISTRIBUTION, HAZE TRIM  
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT  
CYLINDER  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 875.1 lumens  
Efficiency: N/A  
Efficacy: 88.4 lumens/watt  
Spacing Criteria (0/90/45): 1.13 / 1.07 / 1.16  
Luminous Opening: Circular (Dia: 0.67' x H: 0')  
CIE Type: Direct

Input Watts (W): 9.9  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P583771  
CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

### Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab  
 1121 Highway 74 South  
 Peachtree City, GA 30269



TEST NUMBER: P583771

CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20					
RC	80					70					50					30					10					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																										
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100					100			
1	111	107	104	100	108	105	102	99	101	98	96	97	95	93	93	92	90	88					88			
2	103	96	90	85	100	94	89	84	90	86	82	87	84	80	84	81	79	77					77			
3	95	86	79	73	92	84	78	73	81	76	71	79	74	70	76	72	69	67					67			
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59					59			
5	81	70	62	56	79	69	62	56	67	60	55	65	59	55	63	58	54	52					52			
6	76	64	56	50	74	63	55	50	61	54	49	60	54	49	58	53	49	47					47			
7	71	58	51	45	69	58	50	45	56	49	45	55	49	44	54	48	44	42					42			
8	66	54	46	41	65	53	46	41	52	45	40	51	45	40	50	44	40	38					38			
9	62	50	42	37	61	49	42	37	48	41	37	47	41	37	46	41	36	35					35			
10	58	46	39	34	57	46	39	34	45	38	34	44	38	34	43	38	34	32					32			

**AVERAGE LUMINANCE (cd/sqm):**

	0°	90°	180°
0°	14397	14397	14397
5°	14663	14332	13997
10°	14892	14081	13489
15°	15043	13731	12904
20°	14983	13202	12306
25°	14593	12439	11623
30°	13897	11529	10946
35°	12547	10525	10168
40°	11026	9444	9419
45°	9516	8303	8661
50°	8285	7282	7767
55°	7349	6328	6763
60°	6556	5347	5618
65°	5910	4341	4429
70°	5247	3255	2624
75°	4527	1894	1132
80°	3481	675	337
85°	2264	212	212



TEST NUMBER: P583771  
 CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	43.8	5.0
10°-20°	122.0	13.9
20°-30°	172.5	19.7
30°-40°	181.8	20.8
40°-50°	154.5	17.7
50°-60°	111.3	12.7
60°-70°	64.2	7.3
70°-80°	21.9	2.5
80°-90°	3.0	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	338.3	38.7
0°-40°	520.2	59.4
0°-60°	785.9	89.8
0°-90°	875.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	875.1	100.0

**CANDELA DISTRIBUTION:**

	0°	45°	90°	135°	180°	Flux
0°	467	467	467	467	467	
5°	474	471	463	455	452	45
15°	471	457	430	411	404	133
25°	429	407	366	347	342	197
35°	333	314	280	270	270	208
45°	218	208	190	192	199	170
55°	137	126	118	122	126	123
65°	81	70	60	58	61	81
75°	38	28	16	10	10	40
85°	6	4	1	1	1	9
90°	0	0	0	0	0	



TEST NUMBER: P583771

CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**CANDELA DISTRIBUTION (FULL):**

	0°	5°	15°	25°	35°	45°	55°	65°	75°	85°	90°
0°	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9
2.5°	471.2	471.9	471.2	471.2	470.6	470.0	469.4	468.7	467.5	466.1	466.1
5°	473.7	475.0	473.7	473.7	471.9	470.6	469.4	467.5	464.9	463.0	463.0
7.5°	475.6	475.6	475.6	473.7	472.5	470.6	467.5	464.2	461.1	458.0	456.6
10°	475.6	475.6	475.0	472.5	471.2	467.5	464.2	459.9	455.4	451.0	449.7
12.5°	473.7	474.4	473.1	470.6	467.5	463.0	458.6	452.9	447.9	442.8	440.2
15°	471.2	470.6	469.4	466.1	462.4	456.6	452.2	445.9	439.0	432.6	430.1
17.5°	464.9	464.9	463.0	459.9	454.8	448.5	441.5	434.5	427.0	420.0	416.9
20°	456.6	456.6	454.1	450.4	445.3	437.0	429.5	421.3	412.4	405.4	402.3
22.5°	444.6	445.3	442.1	437.6	432.0	422.5	414.9	404.8	395.9	387.8	385.2
25°	428.9	430.1	427.0	422.5	414.9	406.8	397.3	387.8	377.7	369.4	365.6
27.5°	410.5	411.1	408.0	403.5	395.9	387.0	377.7	367.5	358.0	349.2	345.3
30°	390.3	387.8	386.4	380.8	372.5	364.9	354.2	345.9	335.8	328.3	323.8
32.5°	361.8	363.1	359.3	354.8	348.5	339.7	330.8	321.3	311.8	306.1	303.0
35°	333.3	334.6	332.7	328.3	321.3	313.7	304.8	297.9	289.7	282.7	279.6
37.5°	303.6	303.6	302.3	299.8	294.7	287.8	279.0	272.0	265.0	259.4	257.5
40°	273.9	272.6	272.0	270.1	265.6	259.4	253.6	248.0	241.0	237.2	234.6
42.5°	244.7	244.7	243.5	241.6	237.2	234.0	228.4	222.0	217.0	213.1	213.1
45°	218.2	218.9	217.0	215.6	213.1	208.1	203.0	198.6	194.1	191.6	190.4
47.5°	194.8	194.8	192.9	191.6	189.1	184.7	180.3	176.5	173.3	171.4	170.8
50°	172.7	172.7	172.7	169.5	166.4	163.2	160.0	155.7	153.7	152.4	151.8
52.5°	153.7	153.0	153.0	150.5	147.4	143.6	140.4	136.7	134.7	133.4	134.1
55°	136.7	136.7	135.9	132.8	129.7	125.8	122.7	119.6	118.3	117.1	117.7
56°	129.7	129.7	129.0	126.5	122.7	119.6	115.8	112.6	110.7	111.3	111.3
57°	124.6	123.3	123.3	120.2	117.1	112.6	109.4	106.3	105.1	104.3	104.3
58°	118.3	117.7	117.1	113.8	110.7	106.9	103.7	100.6	98.7	98.7	98.1
59°	111.9	111.9	110.7	108.2	105.1	101.2	98.1	94.8	93.0	92.3	92.3
60°	106.3	106.9	105.1	102.4	99.9	95.6	91.7	89.2	87.3	86.7	86.7
61°	101.2	101.2	99.9	96.8	93.6	90.4	86.7	83.5	82.2	81.0	81.0
62°	96.8	95.6	94.8	91.7	88.6	84.7	81.6	78.5	76.6	75.2	75.8
63°	91.1	90.4	89.2	86.7	83.5	79.7	75.8	73.3	71.5	69.6	70.2
64°	86.7	86.1	84.1	81.6	78.5	74.6	70.8	68.3	67.1	65.1	64.5
65°	81.0	80.3	79.7	76.6	73.3	69.6	66.5	63.8	62.0	60.7	59.5
66°	75.8	76.6	75.2	72.7	69.0	65.7	61.3	58.8	57.6	55.7	54.5
67°	71.5	71.5	70.2	67.7	63.8	60.7	57.6	54.5	52.5	50.6	50.0
67.5°	69.0	69.0	67.7	64.5	62.0	58.2	55.1	52.5	50.0	48.7	47.5
68°	66.5	66.5	65.7	63.2	60.1	56.3	53.1	50.0	47.5	45.6	45.0
69°	62.0	62.6	61.3	58.8	55.7	51.9	48.7	46.2	43.6	41.7	40.5
70°	58.2	57.6	56.3	53.7	50.6	48.1	45.0	41.7	39.2	36.7	36.1
71°	53.1	53.1	51.9	50.0	46.8	43.6	40.5	38.0	35.5	32.2	31.6
72°	49.3	49.3	48.1	45.6	43.0	39.9	36.7	33.5	31.6	28.5	27.2
72.5°	46.8	47.5	46.2	43.6	41.1	37.3	34.7	32.2	29.1	26.6	25.2
73°	45.6	45.0	44.2	41.7	38.6	36.1	32.9	30.4	27.2	24.6	23.4



TEST NUMBER: P583771  
CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**CANDELA DISTRIBUTION (continued):**

	0°	5°	15°	25°	35°	45°	55°	65°	75°	85°	90°
77.5°	28.5	28.5	27.9	25.2	22.7	20.2	17.7	15.1	12.6	10.1	8.9
80°	19.6	20.2	19.0	17.7	15.9	13.3	10.7	8.9	6.4	5.0	3.8
82.5°	12.6	12.6	12.0	10.7	9.5	7.6	6.4	4.4	3.1	2.5	1.9
85°	6.4	7.0	6.4	5.6	4.4	3.8	3.1	1.9	1.3	0.6	0.6
87.5°	2.5	2.5	2.5	1.9	1.9	1.3	0.6	0.6	0.6	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab  
 1121 Highway 74 South  
 Peachtree City, GA 30269



TEST NUMBER: P583771

CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**CANDELA DISTRIBUTION (continued):**

	95°	105°	115°	125°	135°	145°	155°	165°	175°	180°
0°	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9	466.9
2.5°	464.9	464.9	463.6	463.0	462.4	461.7	461.1	460.5	460.5	461.1
5°	461.1	459.9	457.4	456.6	454.8	454.1	452.9	452.2	452.9	452.2
7.5°	455.4	452.9	449.7	448.5	445.9	444.6	442.8	442.8	441.5	442.1
10°	447.9	444.0	440.2	437.6	435.8	433.9	432.6	431.4	430.8	430.8
12.5°	438.4	433.9	430.1	426.3	423.1	421.9	419.4	419.4	418.1	417.5
15°	427.6	421.9	417.5	413.6	411.1	408.6	406.8	405.4	404.2	404.2
17.5°	413.6	408.6	404.2	399.8	395.9	394.0	392.2	390.3	390.3	389.0
20°	398.5	392.8	389.0	384.5	381.4	378.3	375.7	375.7	374.4	375.0
22.5°	381.4	374.4	370.7	367.5	364.3	361.8	359.3	359.3	358.7	358.0
25°	362.4	356.8	352.3	348.5	346.7	344.1	343.4	342.2	341.6	341.6
27.5°	342.2	337.8	332.1	330.2	327.7	326.3	326.3	325.7	324.5	325.1
30°	320.7	315.6	312.5	311.2	308.7	308.7	308.1	306.8	306.8	307.4
32.5°	299.8	294.7	292.2	291.6	289.1	289.1	288.5	289.1	289.1	289.7
35°	277.1	272.6	272.0	270.1	269.5	269.5	269.5	270.7	272.0	270.1
37.5°	255.5	252.4	250.5	249.9	250.5	250.5	251.1	253.0	252.4	251.7
40°	233.4	230.9	229.6	229.6	230.9	232.1	232.1	234.0	234.6	234.0
42.5°	211.3	209.4	209.4	210.0	211.3	211.9	213.8	215.6	216.4	217.0
45°	190.4	190.4	190.4	191.0	191.6	192.9	195.4	197.4	198.0	198.6
47.5°	170.2	169.5	171.4	172.0	173.9	174.5	176.5	179.0	179.6	180.3
50°	151.2	152.4	153.0	154.9	156.3	156.3	158.8	160.0	161.9	161.9
52.5°	133.4	135.3	135.9	137.9	138.5	139.2	140.4	142.3	143.6	143.6
55°	117.7	118.3	119.6	120.2	122.1	122.7	123.9	124.6	126.5	125.8
56°	110.7	111.9	112.6	113.8	115.2	115.8	117.1	117.7	118.9	119.6
57°	104.3	105.1	106.9	107.6	108.8	108.8	109.4	111.3	111.3	111.9
58°	98.1	99.3	99.9	100.6	101.8	102.4	103.7	104.3	105.1	104.3
59°	92.3	93.0	93.6	93.6	94.8	94.8	96.8	98.1	98.7	98.7
60°	86.7	86.7	87.3	87.9	89.2	89.8	89.8	91.1	91.1	91.1
61°	81.0	81.0	81.6	82.2	82.8	82.8	84.1	84.1	84.7	85.3
62°	75.8	75.2	75.2	75.8	75.8	77.2	77.8	78.5	79.1	78.5
63°	70.2	69.6	69.6	69.6	69.6	70.8	70.8	71.5	72.7	72.1
64°	63.8	63.8	63.8	63.8	64.5	64.5	65.7	66.5	67.1	67.7
65°	59.5	58.2	57.6	57.6	58.2	58.8	59.5	60.1	60.7	60.7
66°	54.5	53.1	52.5	52.5	52.5	52.5	53.7	53.7	55.1	55.1
67°	48.7	47.5	46.8	46.2	46.2	46.2	48.1	47.5	47.5	47.5
67.5°	46.8	45.0	44.2	43.6	43.0	44.2	43.6	44.2	44.2	43.6
68°	44.2	43.0	41.7	40.5	40.5	40.5	41.1	41.7	41.1	40.5
69°	39.2	38.6	36.7	35.5	34.7	35.5	34.7	35.5	34.7	35.5
70°	34.7	32.9	31.0	30.4	29.7	29.7	29.7	29.1	29.7	29.1
71°	30.4	28.5	26.6	25.2	24.6	24.6	24.0	24.6	24.0	24.6
72°	26.0	24.0	21.5	20.2	20.2	20.2	20.2	19.6	20.2	19.6
72.5°	24.0	21.5	19.6	18.4	17.7	17.7	17.7	17.7	17.1	17.7
73°	22.1	19.6	17.1	16.5	16.5	16.5	15.9	15.1	15.9	15.9





TEST NUMBER: P583771  
CATALOG NUMBER: HCC8W10D010SL-HM80520927-81RWWH

**CANDELA DISTRIBUTION (continued):**

	95°	105°	115°	125°	135°	145°	155°	165°	175°	180°
77.5°	7.6	5.6	5.0	5.0	5.0	5.0	5.0	5.0	4.4	4.4
80°	3.1	2.5	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
82.5°	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
85°	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°    - - 45°-225°    - - - - 90°-270°

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



74°	41.1	41.1	39.9	38.0	34.7	31.6	29.1	26.6	23.4	20.2	19.0
75°	38.0	37.3	36.1	34.1	31.6	28.5	26.0	22.7	20.2	17.1	15.9

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



74°	18.4	15.1	13.9	12.6	12.6	12.6	12.0	12.0	12.0	12.6
75°	14.5	12.0	10.7	9.5	10.1	9.5	10.1	9.5	9.5	9.5

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)