

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P584995

Luminaire Tested: **HCC8W55D010MW-HM82555927-81WDW**

Issue Date: 10/21/2021

**Test Information**

Test Method: LM-41-14  
Report Number: P584995  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2109-368-9)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 10/21/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: HALO COMMERCIAL  
Catalog Number: HCC8W55D010MW-HM82555927-81WDW  
Description: HALO COMMERCIAL 8" ROUND, NEW CONSTRUCTION FRAME, WITH 8" WIDE DISTRIBUTION, WHITE TRIM  
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT CYLINDER  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 4496.9 lumens  
Efficiency: N/A  
Efficacy: 86.5 lumens/watt  
Spacing Criteria (0/90/45): 1.17 / 1.17 / 1.06  
Luminous Opening: Circular (Dia: 0.67' x H: 0')  
CIE Type: Direct

Input Watts (W): 52  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P584995  
CATALOG NUMBER: HCC8W55D010MW-HM82555927-81WDW

### Luminous Intensity Polar Plot





TEST NUMBER: P584995  
 CATALOG NUMBER: HCC8W55D010MW-HM82555927-81WDW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89																			
2	104	97	92	87	101	95	90	86	92	88	84	89	85	82	86	83	81	79																			
3	97	88	82	76	94	87	81	76	84	79	75	81	77	73	79	75	72	70																			
4	90	80	73	68	88	79	73	67	77	71	67	75	70	66	73	68	65	63																			
5	84	74	66	61	82	73	66	61	71	65	60	69	64	59	67	63	59	57																			
6	79	68	61	55	77	67	60	55	65	59	55	64	58	54	62	58	54	52																			
7	74	63	56	50	73	62	55	50	61	54	50	59	54	50	58	53	49	48																			
8	70	58	51	46	69	58	51	46	57	50	46	55	50	46	54	49	45	44																			
9	66	54	47	43	65	54	47	42	53	47	42	52	46	42	51	46	42	40																			
10	62	51	44	39	61	50	44	39	49	43	39	49	43	39	48	43	39	37																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	89903
5°	89792
10°	88907
15°	87839
20°	87026
25°	86050
30°	81190
35°	66118
40°	36530
45°	24378
50°	21626
55°	20300
60°	20037
65°	19868
70°	17942
75°	16048
80°	14029
85°	12454



TEST NUMBER: P584995  
 CATALOG NUMBER: HCC8W55D010MW-HM82555927-81WDW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	274.9	6.1
10°-20°	776.9	17.3
20°-30°	1154.4	25.7
30°-40°	1039.6	23.1
40°-50°	460.9	10.2
50°-60°	341.3	7.6
60°-70°	265.5	5.9
70°-80°	143.9	3.2
80°-90°	39.4	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2206.3	49.1
0°-40°	3245.9	72.2
0°-60°	4048.1	90.0
0°-90°	4496.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4496.9	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2916	
5°	2901	275
15°	2752	777
25°	2529	1154
35°	1756	1040
45°	559	461
55°	378	341
65°	272	265
75°	135	144
85°	35	39
90°	0	



TEST NUMBER: P584995

CATALOG NUMBER: HCC8W55D010MW-HM82555927-81WDW

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2915.5
2.5°	2909.6
5°	2900.8
7.5°	2877.4
10°	2839.4
12.5°	2795.5
15°	2751.5
17.5°	2707.7
20°	2652.0
22.5°	2596.4
25°	2529.1
27.5°	2426.6
30°	2280.2
32.5°	2069.5
35°	1756.4
37.5°	1311.4
40°	907.5
42.5°	670.3
45°	559.0
47.5°	494.7
50°	450.8
52.5°	409.8
55°	377.6
57.5°	351.2
60°	324.9
62.5°	301.6
65°	272.3
67.5°	237.1
70°	199.0
72.5°	166.9
75°	134.7
77.5°	105.4
80°	79.0
82.5°	55.7
85°	35.2
87.5°	14.6
90°	0.0

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Classified  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)