

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P886388

Luminaire Tested: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMBB-550LM-4000K

Issue Date: 6/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P886388
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2402-314-88)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 6/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMBB-550LM-4000K
Description: 2IN ROUND ML FLEX, SELECTABLE CCT, WITH 55D TIR, MATTE BLACK BAFFLED TRIM
Light Source: (1) STANDARD SELECTABLE LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 604.8 lumens
Efficiency: N/A
Efficacy: 76.6 lumens/watt
Spacing Criteria (0/90/45): 0.87 / 0.87 / 0.82
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct

Input Watts (W): 7.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P886388
CATALOG NUMBER: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMMB-550LM-4000K

Luminous Intensity Polar Plot





TEST NUMBER: P886388

CATALOG NUMBER: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMMB-550LM-4000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|---|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | | | |
| 1 | 114 | 111 | 109 | 107 | 111 | 109 | 107 | 105 | 105 | 103 | 102 | 101 | 100 | 99 | 98 | 97 | 96 | 94 | | | |
| 2 | 109 | 104 | 100 | 97 | 107 | 102 | 99 | 96 | 99 | 96 | 94 | 96 | 94 | 92 | 94 | 92 | 90 | 88 | | | |
| 3 | 104 | 98 | 93 | 89 | 102 | 96 | 92 | 89 | 94 | 90 | 87 | 91 | 88 | 86 | 89 | 87 | 84 | 83 | | | |
| 4 | 99 | 92 | 87 | 83 | 97 | 91 | 86 | 82 | 89 | 84 | 81 | 87 | 83 | 80 | 85 | 82 | 79 | 78 | | | |
| 5 | 94 | 86 | 81 | 77 | 93 | 85 | 80 | 77 | 84 | 79 | 76 | 82 | 78 | 75 | 81 | 77 | 75 | 73 | | | |
| 6 | 90 | 81 | 76 | 72 | 88 | 81 | 75 | 72 | 79 | 75 | 71 | 78 | 74 | 71 | 77 | 73 | 70 | 69 | | | |
| 7 | 86 | 77 | 71 | 67 | 84 | 76 | 71 | 67 | 75 | 70 | 67 | 74 | 70 | 67 | 73 | 69 | 66 | 65 | | | |
| 8 | 82 | 73 | 67 | 63 | 81 | 72 | 67 | 63 | 71 | 66 | 63 | 70 | 66 | 63 | 69 | 65 | 63 | 61 | | | |
| 9 | 78 | 69 | 64 | 60 | 77 | 69 | 63 | 60 | 68 | 63 | 60 | 67 | 62 | 59 | 66 | 62 | 59 | 58 | | | |
| 10 | 75 | 66 | 60 | 57 | 74 | 65 | 60 | 56 | 64 | 60 | 56 | 64 | 59 | 56 | 63 | 59 | 56 | 55 | | | |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|--------|
| | 0° |
| 0° | 391497 |
| 5° | 389723 |
| 10° | 379300 |
| 15° | 355097 |
| 20° | 316234 |
| 25° | 253302 |
| 30° | 175697 |
| 35° | 97212 |
| 40° | 42701 |
| 45° | 16188 |
| 50° | 5066 |
| 55° | 946 |
| 60° | 0 |
| 65° | 0 |
| 70° | 0 |
| 75° | 0 |
| 80° | 0 |
| 85° | 0 |

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 16188 cd/sqm



TEST NUMBER: P886388

CATALOG NUMBER: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMMB-550LM-4000K

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 74.2 | 12.3 |
| 10°-20° | 193.3 | 32.0 |
| 20°-30° | 209.5 | 34.6 |
| 30°-40° | 104.9 | 17.4 |
| 40°-50° | 21.2 | 3.5 |
| 50°-60° | 1.7 | 0.3 |
| 60°-70° | 0.0 | 0.0 |
| 70°-80° | 0.0 | 0.0 |
| 80°-90° | 0.0 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 477.0 | 78.9 |
| 0°-40° | 581.9 | 96.2 |
| 0°-60° | 604.8 | 100.0 |
| 0°-90° | 604.8 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 604.8 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|-----|------|
| 0° | 794 | |
| 5° | 787 | 74 |
| 15° | 695 | 193 |
| 25° | 465 | 209 |
| 35° | 161 | 105 |
| 45° | 23 | 21 |
| 55° | 1 | 2 |
| 65° | 0 | 0 |
| 75° | 0 | 0 |
| 85° | 0 | 0 |
| 90° | 0 | |



TEST NUMBER: P886388

CATALOG NUMBER: ML204LSFL9FS1E-TIR1D55WFL-TL2RDMMB-550LM-4000K

CANDELA DISTRIBUTION (FULL):

| | 0° |
|-------|-------|
| 0° | 793.5 |
| 2.5° | 793.5 |
| 5° | 786.9 |
| 7.5° | 774.8 |
| 10° | 757.1 |
| 12.5° | 728.3 |
| 15° | 695.2 |
| 17.5° | 655.4 |
| 20° | 602.3 |
| 22.5° | 541.6 |
| 25° | 465.3 |
| 27.5° | 383.5 |
| 30° | 308.4 |
| 32.5° | 237.6 |
| 35° | 161.4 |
| 37.5° | 101.7 |
| 40° | 66.3 |
| 42.5° | 40.9 |
| 45° | 23.2 |
| 47.5° | 12.2 |
| 50° | 6.6 |
| 52.5° | 3.3 |
| 55° | 1.1 |
| 57.5° | 0.0 |
| 60° | 0.0 |
| 62.5° | 0.0 |
| 65° | 0.0 |
| 67.5° | 0.0 |
| 70° | 0.0 |
| 72.5° | 0.0 |
| 75° | 0.0 |
| 77.5° | 0.0 |
| 80° | 0.0 |
| 82.5° | 0.0 |
| 85° | 0.0 |
| 87.5° | 0.0 |
| 90° | 0.0 |

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)