

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P640830

Luminaire Tested: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K

Issue Date: 2/17/2023

**Test Information**

Test Method: LM-79-2019  
Report Number: P640830  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-40)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/17/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: HALO  
Catalog Number: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K  
Description: ML56 RR, 40D TIR OPTIC, 6" WHITE BAFFLE TRIM  
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 5000K CCT  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1718.3 lumens  
Efficiency: N/A  
Efficacy: 104.1 lumens/watt  
Spacing Criteria (0/90/45): 0.64 / 0.64 / 0.69  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct

Input Watts (W): 16.5  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P640830  
CATALOG NUMBER: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K

### Luminous Intensity Polar Plot





TEST NUMBER: P640830

CATALOG NUMBER: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	114	111	108	106	111	109	106	104	105	103	101	101	100	98	97	96	95	94																			
2	108	103	99	96	106	102	98	95	98	95	93	95	93	91	93	91	89	87																			
3	103	96	92	88	101	95	91	87	92	89	86	90	87	84	88	85	83	81																			
4	98	90	85	81	96	89	84	80	87	83	79	85	81	78	83	80	78	76																			
5	93	85	79	75	91	84	79	75	82	77	74	80	76	73	79	75	73	71																			
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67																			
7	84	75	70	65	83	75	69	65	73	69	65	72	68	65	71	67	64	63																			
8	81	71	66	62	79	71	65	61	70	65	61	69	64	61	68	64	61	59																			
9	77	68	62	58	76	67	62	58	66	61	58	65	61	58	65	60	57	56																			
10	74	64	59	55	73	64	58	55	63	58	55	62	58	55	62	57	54	53																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	153261
5°	148558
10°	129367
15°	106402
20°	82992
25°	63246
30°	45836
35°	31467
40°	20424
45°	12691
50°	6789
55°	2867
60°	1974
65°	1167
70°	721
75°	635
80°	947
85°	943

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 12691 cd/sqm



TEST NUMBER: P640830

CATALOG NUMBER: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	245.3	14.3
10°-20°	517.8	30.1
20°-30°	478.8	27.9
30°-40°	298.3	17.4
40°-50°	131.2	7.6
50°-60°	32.1	1.9
60°-70°	9.4	0.5
70°-80°	3.8	0.2
80°-90°	1.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1242.0	72.3
0°-40°	1540.2	89.6
0°-60°	1703.5	99.1
0°-90°	1718.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1718.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2796	
5°	2700	245
15°	1875	518
25°	1046	479
35°	470	298
45°	164	131
55°	30	32
65°	9	9
75°	3	4
85°	2	2
90°	0	



TEST NUMBER: P640830

CATALOG NUMBER: ML5612LSFL4097FS1E - 693WB - 1200LM - 5000K

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	2795.7
2.5°	2777.7
5°	2699.6
7.5°	2538.8
10°	2324.0
12.5°	2100.2
15°	1874.8
17.5°	1643.5
20°	1422.6
22.5°	1222.8
25°	1045.6
27.5°	877.3
30°	724.1
32.5°	588.9
35°	470.2
37.5°	369.6
40°	285.4
42.5°	220.8
45°	163.7
47.5°	121.7
50°	79.6
52.5°	42.1
55°	30.0
57.5°	24.0
60°	18.0
62.5°	13.5
65°	9.0
67.5°	4.5
70°	4.5
72.5°	4.5
75°	3.0
77.5°	3.0
80°	3.0
82.5°	1.5
85°	1.5
87.5°	1.5
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)