

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P641237

Luminaire Tested: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-2019
Report Number: P641237
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-70)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K
Description: ML56 RR, 75D TIR OPTIC, 5" DEADFRONT TRIM
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 951.6 lumens
Efficiency: N/A
Efficacy: 92.4 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.09
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P641237

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K

Luminous Intensity Polar Plot





TEST NUMBER: P641237

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	110	107	104	110	107	105	103	103	101	99	99	98	96	96	95	94	92			
2	106	101	96	92	104	99	95	91	95	92	89	92	90	87	90	87	85	83			
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	78	76			
4	94	85	79	74	92	84	78	73	82	77	73	80	75	72	78	74	71	69			
5	88	79	72	67	86	78	71	67	76	70	66	74	69	65	72	68	65	63			
6	83	73	66	61	81	72	65	61	70	65	60	69	64	60	67	63	60	58			
7	78	68	61	56	77	67	60	56	65	60	55	64	59	55	63	58	55	53			
8	74	63	56	51	72	62	56	51	61	55	51	60	55	51	59	54	51	49			
9	69	59	52	48	68	58	52	47	57	51	47	56	51	47	55	50	47	45			
10	66	55	48	44	65	54	48	44	54	48	44	53	47	44	52	47	44	42			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	35107
5°	35676
10°	36817
15°	38332
20°	38789
25°	36782
30°	33062
35°	26756
40°	18721
45°	10986
50°	6567
55°	4100
60°	2785
65°	1583
70°	833
75°	741
80°	821
85°	1069

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 10986 cd/sqm



TEST NUMBER: P641237

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	62.3	6.5
10°-20°	190.3	20.0
20°-30°	277.1	29.1
30°-40°	245.9	25.8
40°-50°	116.4	12.2
50°-60°	40.7	4.3
60°-70°	13.2	1.4
70°-80°	4.0	0.4
80°-90°	1.8	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	529.7	55.7
0°-40°	775.6	81.5
0°-60°	932.6	98.0
0°-90°	951.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	951.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	640	
5°	648	62
15°	675	190
25°	608	277
35°	400	246
45°	142	116
55°	43	41
65°	12	13
75°	4	4
85°	2	2
90°	0	



TEST NUMBER: P641237

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 591WB - 600LM - 3000K

CANDELA DISTRIBUTION (FULL):

	0°
0°	640.4
2.5°	643.0
5°	648.3
7.5°	655.3
10°	661.4
12.5°	669.3
15°	675.4
17.5°	675.4
20°	664.9
22.5°	641.3
25°	608.1
27.5°	568.7
30°	522.3
32.5°	465.4
35°	399.8
37.5°	329.0
40°	261.6
42.5°	196.0
45°	141.7
47.5°	104.1
50°	77.0
52.5°	56.0
55°	42.9
57.5°	33.2
60°	25.4
62.5°	18.4
65°	12.2
67.5°	7.9
70°	5.2
72.5°	4.4
75°	3.5
77.5°	3.5
80°	2.6
82.5°	2.6
85°	1.7
87.5°	0.9
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)