

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P641296

Luminaire Tested: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-2019
Report Number: P641296
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-75)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K
Description: ML56 RR, 75D TIR OPTIC, 5" BLACK BAFFLE TRIM
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 873.4 lumens
Efficiency: N/A
Efficacy: 84.8 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.09
Luminous Opening: Circular (Dia: 0.42' x H: 0')
CIE Type: Direct

Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P641296
CATALOG NUMBER: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K

Luminous Intensity Polar Plot





TEST NUMBER: P641296

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	92			92
2	107	101	97	93	104	100	96	92	96	93	90	93	91	88	91	88	86	85			85
3	101	94	88	84	99	92	87	83	90	85	82	87	83	81	85	82	79	78			78
4	95	87	80	76	93	85	80	75	83	78	74	81	77	74	79	76	73	71			71
5	89	80	74	69	88	79	73	69	77	72	68	76	71	67	74	70	67	65			65
6	84	74	68	63	83	74	67	63	72	66	62	70	66	62	69	65	61	60			60
7	79	69	63	58	78	68	62	58	67	62	57	66	61	57	65	60	57	55			55
8	75	64	58	53	74	64	58	53	63	57	53	62	57	53	61	56	53	51			51
9	71	60	54	49	70	60	54	49	59	53	49	58	53	49	57	52	49	47			47
10	67	56	50	46	66	56	50	46	55	50	46	54	49	46	54	49	45	44			44

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	48967
5°	49693
10°	51221
15°	53269
20°	53966
25°	51364
30°	46069
35°	37150
40°	24907
45°	12448
50°	7000
55°	4211
60°	1484
65°	168
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 12448 cd/sqm



TEST NUMBER: P641296

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	60.2	6.9
10°-20°	183.7	21.0
20°-30°	268.5	30.7
30°-40°	235.1	26.9
40°-50°	95.5	10.9
50°-60°	27.8	3.2
60°-70°	2.6	0.3
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	512.4	58.7
0°-40°	747.5	85.6
0°-60°	870.8	99.7
0°-90°	873.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	873.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	620	
5°	627	60
15°	652	184
25°	590	268
35°	386	235
45°	112	95
55°	31	28
65°	1	3
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P641296

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 593BB - 600LM - 2700K

CANDELA DISTRIBUTION (FULL):

	0°
0°	620.3
2.5°	622.0
5°	627.1
7.5°	633.1
10°	639.0
12.5°	645.8
15°	651.8
17.5°	651.8
20°	642.4
22.5°	621.2
25°	589.7
27.5°	551.4
30°	505.4
32.5°	448.4
35°	385.5
37.5°	310.6
40°	241.7
42.5°	168.5
45°	111.5
47.5°	74.0
50°	57.0
52.5°	42.5
55°	30.6
57.5°	19.6
60°	9.4
62.5°	5.1
65°	0.9
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)