

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P641488

Luminaire Tested: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K

Issue Date: 2/17/2023

**Test Information**

Test Method: LM-79-2019  
Report Number: P641488  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-88)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/17/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: HALO  
Catalog Number: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K  
Description: ML56 RR, 75D TIR OPTIC, 6" SATIN NICKLE BAFFLE TRIM  
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 3500K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1498.7 lumens  
Efficiency: N/A  
Efficacy: 90.8 lumens/watt  
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.09  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct


Input Watts (W): 16.5  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P641488

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K

### Luminous Intensity Polar Plot





TEST NUMBER: P641488

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	96	95	94	92	92	92	92
2	107	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84	84	84	84
3	100	93	88	83	98	92	87	83	89	85	81	87	83	80	84	81	79	77	77	77	77
4	94	86	80	75	92	85	79	75	83	78	74	81	76	73	79	75	72	70	70	70	70
5	89	80	73	68	87	79	72	68	77	71	67	75	70	67	73	69	66	64	64	64	64
6	84	74	67	62	82	73	67	62	71	66	62	70	65	61	68	64	61	59	59	59	59
7	79	68	62	57	77	68	61	57	66	61	57	65	60	56	64	59	56	54	54	54	54
8	74	64	57	53	73	63	57	52	62	56	52	61	56	52	60	55	52	50	50	50	50
9	70	60	53	49	69	59	53	49	58	52	48	57	52	48	56	51	48	46	46	46	46
10	66	56	49	45	65	55	49	45	54	49	45	54	48	45	53	48	45	43	43	43	43

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	57265
5°	58177
10°	59941
15°	62140
20°	62737
25°	59556
30°	53217
35°	42804
40°	29384
45°	17110
50°	9765
55°	5868
60°	3212
65°	908
70°	224
75°	0
80°	0
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 17110 cd/sqm



TEST NUMBER: P641488

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	101.6	6.8
10°-20°	308.4	20.6
20°-30°	448.0	29.9
30°-40°	393.2	26.2
40°-50°	180.7	12.1
50°-60°	57.4	3.8
60°-70°	9.2	0.6
70°-80°	0.2	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	858.0	57.3
0°-40°	1251.2	83.5
0°-60°	1489.3	99.4
0°-90°	1498.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1498.7	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1045	
5°	1057	102
15°	1095	308
25°	985	448
35°	640	393
45°	221	181
55°	61	57
65°	7	9
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P641488

CATALOG NUMBER: ML5612LSVWFL7597FS1E - 693SNB - 1200LM - 3500K

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1044.6
2.5°	1048.8
5°	1057.2
7.5°	1068.4
10°	1076.8
12.5°	1086.5
15°	1094.9
17.5°	1093.5
20°	1075.4
22.5°	1036.3
25°	984.6
27.5°	920.3
30°	840.7
32.5°	748.6
35°	639.6
37.5°	523.7
40°	410.6
42.5°	307.2
45°	220.7
47.5°	159.2
50°	114.5
52.5°	81.0
55°	61.4
57.5°	44.7
60°	29.3
62.5°	14.0
65°	7.0
67.5°	1.4
70°	1.4
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)