

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P641727

Luminaire Tested: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-2019
Report Number: P641727
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-101)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K
Description: ML56 RR, MILKY OPTIC, 5" WHITE GIMBAL TRIM
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1490.2 lumens
Efficiency: N/A
Efficacy: 90.3 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.21 / 1.28
Luminous Opening: Circular (Dia: 0.42' x H: 0')
CIE Type: Direct

Input Watts (W): 16.5
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P641727
CATALOG NUMBER: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K

Luminous Intensity Polar Plot





TEST NUMBER: P641727

CATALOG NUMBER: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	110	106	102	99	107	104	100	97	99	97	94	96	93	91	92	90	88	86																			
2	101	94	88	82	99	92	86	82	88	84	80	85	81	78	82	79	76	74																			
3	93	83	76	70	91	82	75	69	79	73	68	76	71	67	74	70	66	64																			
4	86	75	67	60	84	73	66	60	71	64	59	69	63	58	67	62	58	56																			
5	79	67	59	53	77	66	58	53	64	57	52	62	56	51	60	55	51	49																			
6	74	61	53	47	72	60	52	46	58	51	46	57	50	46	55	50	45	43																			
7	68	56	47	42	67	55	47	41	53	46	41	52	46	41	51	45	41	39																			
8	64	51	43	37	62	50	43	37	49	42	37	48	41	37	47	41	37	35																			
9	60	47	39	34	58	46	39	34	45	38	34	44	38	33	43	37	33	31																			
10	56	43	36	31	55	43	36	31	42	35	31	41	35	31	40	34	30	29																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	51469
5°	51452
10°	51286
15°	50956
20°	50556
25°	49691
30°	48411
35°	46604
40°	43951
45°	40637
50°	36536
55°	32150
60°	27235
65°	23087
70°	19434
75°	16562
80°	14820
85°	13496

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 40637 cd/sqm



TEST NUMBER: P641727

CATALOG NUMBER: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	61.7	4.1
10°-20°	176.0	11.8
20°-30°	262.5	17.6
30°-40°	301.1	20.2
40°-50°	279.6	18.8
50°-60°	208.8	14.0
60°-70°	123.7	8.3
70°-80°	59.4	4.0
80°-90°	17.4	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	500.2	33.6
0°-40°	801.3	53.8
0°-60°	1289.8	86.5
0°-90°	1490.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1490.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	652	
5°	649	62
15°	624	176
25°	570	263
35°	484	301
45°	364	280
55°	234	209
65°	124	124
75°	54	59
85°	15	17
90°	0	



TEST NUMBER: P641727

CATALOG NUMBER: ML5612LSVWFL97FS1E - 594WB - 1200LM - 3000K

CANDELA DISTRIBUTION (FULL):

	0°
0°	652.0
2.5°	652.0
5°	649.3
7.5°	645.2
10°	639.8
12.5°	633.0
15°	623.5
17.5°	614.0
20°	601.8
22.5°	586.8
25°	570.5
27.5°	552.9
30°	531.1
32.5°	508.0
35°	483.6
37.5°	455.1
40°	426.5
42.5°	395.3
45°	364.0
47.5°	330.1
50°	297.5
52.5°	264.9
55°	233.6
57.5°	202.4
60°	172.5
62.5°	146.7
65°	123.6
67.5°	101.9
70°	84.2
72.5°	69.3
75°	54.3
77.5°	43.5
80°	32.6
82.5°	23.1
85°	14.9
87.5°	9.5
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)