

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P642218

Luminaire Tested: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-2019
Report Number: P642218
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-63)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K
Description: ML56 RR, 55D TIR OPTIC, 6" WHITE BAFFLE TRIM
Light Source: (1) HCL SELECTABLE LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1301.5 lumens
Efficiency: N/A
Efficacy: 97.9 lumens/watt
Spacing Criteria (0/90/45): 0.86 / 0.86 / 0.89
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 13.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P642218

CATALOG NUMBER: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K

Luminous Intensity Polar Plot





TEST NUMBER: P642218

CATALOG NUMBER: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	108	105	111	108	106	103	104	102	100	100	99	97	97	96	94	93																			
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85																			
3	101	94	89	85	99	93	88	84	90	86	83	88	84	81	85	83	80	78																			
4	96	87	82	77	94	86	81	77	84	79	76	82	78	75	80	77	74	72																			
5	90	81	75	71	89	80	75	70	79	73	70	77	72	69	75	71	68	67																			
6	85	76	69	65	84	75	69	65	73	68	64	72	67	64	71	67	63	62																			
7	81	71	64	60	79	70	64	60	69	63	59	68	63	59	66	62	59	57																			
8	77	66	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55	53																			
9	73	62	56	52	71	62	56	52	61	55	52	60	55	51	59	55	51	50																			
10	69	59	53	49	68	58	52	48	57	52	48	57	52	48	56	51	48	47																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	74928
5°	71792
10°	68129
15°	64166
20°	58158
25°	49497
30°	40487
35°	31701
40°	23508
45°	15459
50°	6686
55°	2753
60°	1513
65°	752
70°	737
75°	741
80°	726
85°	755

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 15459 cd/sqm



TEST NUMBER: P642218

CATALOG NUMBER: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	122.0	9.4
10°-20°	314.9	24.2
20°-30°	374.1	28.7
30°-40°	296.5	22.8
40°-50°	151.2	11.6
50°-60°	30.8	2.4
60°-70°	6.8	0.5
70°-80°	3.7	0.3
80°-90°	1.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	811.0	62.3
0°-40°	1107.5	85.1
0°-60°	1289.4	99.1
0°-90°	1301.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1301.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1367	
5°	1305	122
15°	1131	315
25°	818	374
35°	474	296
45°	199	151
55°	29	31
65°	6	7
75°	4	4
85°	1	2
90°	0	



TEST NUMBER: P642218

CATALOG NUMBER: ML5612LSWFL5597FS1E - 693WB - 900LM - 3500K

CANDELA DISTRIBUTION (FULL):

0°	
0°	1366.8
2.5°	1349.5
5°	1304.6
7.5°	1262.0
10°	1223.9
12.5°	1180.1
15°	1130.6
17.5°	1068.3
20°	996.9
22.5°	912.8
25°	818.3
27.5°	726.1
30°	639.6
32.5°	555.5
35°	473.7
37.5°	398.8
40°	328.5
42.5°	261.6
45°	199.4
47.5°	130.2
50°	78.4
52.5°	43.8
55°	28.8
57.5°	20.7
60°	13.8
62.5°	8.1
65°	5.8
67.5°	4.6
70°	4.6
72.5°	3.5
75°	3.5
77.5°	3.5
80°	2.3
82.5°	2.3
85°	1.2
87.5°	1.2
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)