

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P642598

Luminaire Tested: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K

Issue Date: 2/17/2023

**Test Information**

Test Method: LM-79-2019  
Report Number: P642598  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-41)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/17/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: HALO  
Catalog Number: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K  
Description: ML56 RR, 40D TIR OPTIC, 6" BLACK BAFFLE TRIM  
Light Source: (1) STANDARD SELECTABLE LUMEN LED 90CRI / 3500K CCT  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1504.6 lumens  
Efficiency: N/A  
Efficacy: 112.3 lumens/watt  
Spacing Criteria (0/90/45): 0.64 / 0.64 / 0.69  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct

Input Watts (W): 13.4  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P642598  
CATALOG NUMBER: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K

### Luminous Intensity Polar Plot





TEST NUMBER: P642598

CATALOG NUMBER: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	114	111	109	106	111	109	107	105	105	103	102	101	100	99	98	97	96	94				94
2	108	104	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88				88
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	86	83	82				82
4	98	91	85	81	96	90	85	81	88	83	80	86	82	79	84	81	78	77				77
5	93	85	80	76	92	84	79	75	83	78	75	81	77	74	79	76	73	72				72
6	89	80	75	70	88	80	74	70	78	73	70	77	73	69	75	72	69	67				67
7	85	76	70	66	84	75	70	66	74	69	66	73	68	65	72	68	65	63				63
8	81	72	66	62	80	71	66	62	70	65	62	69	65	61	68	64	61	60				60
9	77	68	62	59	76	68	62	59	67	62	58	66	61	58	65	61	58	57				57
10	74	65	59	55	73	64	59	55	64	59	55	63	58	55	62	58	55	54				54

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	135992
5°	131735
10°	114878
15°	94217
20°	73611
25°	55945
30°	40614
35°	27639
40°	17790
45°	10877
50°	5475
55°	2170
60°	1316
65°	519
70°	0
75°	0
80°	0
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 10877 cd/sqm



TEST NUMBER: P642598

CATALOG NUMBER: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	217.7	14.5
10°-20°	459.1	30.5
20°-30°	424.1	28.2
30°-40°	262.4	17.4
40°-50°	112.7	7.5
50°-60°	24.3	1.6
60°-70°	4.4	0.3
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1100.8	73.2
0°-40°	1363.2	90.6
0°-60°	1500.3	99.7
0°-90°	1504.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1504.6	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2481	
5°	2394	218
15°	1660	459
25°	925	424
35°	413	262
45°	140	113
55°	23	24
65°	4	4
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P642598

CATALOG NUMBER: ML5615LSFL409FS1E - 693BB - 1200LM - 3500K

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	2480.7
2.5°	2467.4
5°	2393.9
7.5°	2252.2
10°	2063.7
12.5°	1861.9
15°	1660.1
17.5°	1456.9
20°	1261.8
22.5°	1084.0
25°	924.9
27.5°	776.6
30°	641.6
32.5°	519.9
35°	413.0
37.5°	323.5
40°	248.6
42.5°	192.5
45°	140.3
47.5°	102.9
50°	64.2
52.5°	33.4
55°	22.7
57.5°	16.0
60°	12.0
62.5°	8.0
65°	4.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)