

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P642675

Luminaire Tested: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K

Issue Date: 2/17/2023

**Test Information**

Test Method: LM-79-2019  
Report Number: P642675  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-44)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/17/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: HALO  
Catalog Number: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K  
Description: ML56 RR, 40D TIR OPTIC, 6" WHITE GIMBAL TRIM  
Light Source: (1) STANDARD SELECTABLE LUMEN LED 90CRI / 5000K CCT  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1655.5 lumens  
Efficiency: N/A  
Efficacy: 123.5 lumens/watt  
Spacing Criteria (0/90/45): 0.64 / 0.64 / 0.69  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct

Input Watts (W): 13.4  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P642675  
CATALOG NUMBER: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K

### Luminous Intensity Polar Plot





TEST NUMBER: P642675

CATALOG NUMBER: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	93																			
2	108	103	99	96	106	101	98	95	98	95	92	95	93	91	92	90	89	87																			
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	87	85	83	81																			
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76																			
5	93	84	79	74	91	84	78	74	82	77	73	80	76	73	79	75	72	71																			
6	88	79	74	69	87	79	73	69	77	72	69	76	71	68	74	71	68	66																			
7	84	75	69	65	83	74	69	65	73	68	64	72	67	64	71	67	64	62																			
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59																			
9	77	67	61	58	76	67	61	57	66	61	57	65	60	57	64	60	57	56																			
10	73	64	58	55	72	63	58	54	63	58	54	62	57	54	61	57	54	53																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	147165
5°	142422
10°	123968
15°	101817
20°	79480
25°	60306
30°	43348
35°	29460
40°	18943
45°	12273
50°	7113
55°	3986
60°	2686
65°	1868
70°	1378
75°	1228
80°	442
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 12273 cd/sqm



TEST NUMBER: P642675

CATALOG NUMBER: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	235.2	14.2
10°-20°	496.1	30.0
20°-30°	456.8	27.6
30°-40°	279.6	16.9
40°-50°	125.1	7.6
50°-60°	41.3	2.5
60°-70°	15.4	0.9
70°-80°	5.5	0.3
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1188.1	71.8
0°-40°	1467.7	88.7
0°-60°	1634.1	98.7
0°-90°	1655.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1655.5	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2684	
5°	2588	235
15°	1794	496
25°	997	457
35°	440	280
45°	158	125
55°	42	41
65°	14	15
75°	6	5
85°	0	1
90°	0	



TEST NUMBER: P642675

CATALOG NUMBER: ML5615LSFL409FS1E - 694WB - 1200LM - 5000K

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	2684.5
2.5°	2667.2
5°	2588.1
7.5°	2432.8
10°	2227.0
12.5°	2014.1
15°	1794.0
17.5°	1575.3
20°	1362.4
22.5°	1169.6
25°	997.0
27.5°	835.9
30°	684.8
32.5°	552.4
35°	440.2
37.5°	345.3
40°	264.7
42.5°	207.2
45°	158.3
47.5°	116.5
50°	83.4
52.5°	59.0
55°	41.7
57.5°	31.7
60°	24.5
62.5°	20.1
65°	14.4
67.5°	11.5
70°	8.6
72.5°	7.2
75°	5.8
77.5°	2.9
80°	1.4
82.5°	1.4
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)