

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P643900

Luminaire Tested: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K

Issue Date: 2/17/2023

**Test Information**

Test Method: LM-79-2019  
Report Number: P643900  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-55)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/17/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: HALO  
Catalog Number: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K  
Description: ML56 RR, 55D TIR OPTIC, 5" WHITE GIMBAL TRIM  
Light Source: (1) STANDARD SELECTABLE LUMEN LED 90CRI / 5000K CCT  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1293.1 lumens  
Efficiency: N/A  
Efficacy: 123.1 lumens/watt  
Spacing Criteria (0/90/45): 0.86 / 0.86 / 0.88  
Luminous Opening: Circular (Dia: 0.42' x H: 0')  
CIE Type: Direct

Input Watts (W): 10.5  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P643900  
CATALOG NUMBER: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K

### Luminous Intensity Polar Plot





TEST NUMBER: P643900  
 CATALOG NUMBER: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	97	95	94	92																			
2	107	101	97	93	105	100	96	92	96	93	90	93	91	88	91	88	87	85																			
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78																			
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72																			
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66																			
6	85	75	69	64	83	74	68	64	73	68	64	71	67	63	70	66	63	61																			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57																			
8	76	66	59	55	75	65	59	55	64	59	55	63	58	54	62	58	54	53																			
9	72	62	56	51	71	61	55	51	60	55	51	59	54	51	59	54	51	49																			
10	69	58	52	48	68	58	52	48	57	52	48	56	51	48	55	51	47	46																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	106397
5°	101755
10°	96639
15°	91369
20°	82747
25°	69943
30°	56606
35°	43954
40°	32461
45°	21334
50°	10193
55°	5478
60°	3773
65°	2970
70°	2631
75°	1739
80°	1046
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 21334 cd/sqm



TEST NUMBER: P643900

CATALOG NUMBER: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	120.2	9.3
10°-20°	311.2	24.1
20°-30°	366.9	28.4
30°-40°	285.7	22.1
40°-50°	145.9	11.3
50°-60°	39.8	3.1
60°-70°	16.4	1.3
70°-80°	6.3	0.5
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	798.3	61.7
0°-40°	1084.0	83.8
0°-60°	1269.7	98.2
0°-90°	1293.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1293.1	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1348	
5°	1284	120
15°	1118	311
25°	803	367
35°	456	286
45°	191	146
55°	40	40
65°	16	16
75°	6	6
85°	0	1
90°	0	



TEST NUMBER: P643900

CATALOG NUMBER: ML5615LSWFL559FS1E - 594WB - 900LM - 5000K

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	1347.8
2.5°	1330.7
5°	1284.1
7.5°	1243.1
10°	1205.6
12.5°	1165.8
15°	1118.0
17.5°	1056.6
20°	985.0
22.5°	898.5
25°	803.0
27.5°	709.7
30°	621.0
32.5°	535.7
35°	456.1
37.5°	383.3
40°	315.0
42.5°	251.4
45°	191.1
47.5°	125.1
50°	83.0
52.5°	56.9
55°	39.8
57.5°	29.6
60°	23.9
62.5°	19.3
65°	15.9
67.5°	13.6
70°	11.4
72.5°	8.0
75°	5.7
77.5°	3.4
80°	2.3
82.5°	1.1
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)