

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: HALO

Report Number: P643940

Luminaire Tested: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-2019
Report Number: P643940
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2212-866-61)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: HALO
Catalog Number: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K
Description: ML56 RR, 55D TIR OPTIC, 6" HAZE TRIM
Light Source: (1) STANDARD SELECTABLE LUMEN LED 90CRI / 5000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1992.9 lumens
Efficiency: N/A
Efficacy: 116.5 lumens/watt
Spacing Criteria (0/90/45): 0.86 / 0.86 / 0.89
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 17.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P643940

CATALOG NUMBER: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K

Luminous Intensity Polar Plot





TEST NUMBER: P643940

CATALOG NUMBER: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	108	105	111	108	106	104	104	102	101	100	99	98	97	96	95	93																			
2	107	102	98	94	105	100	97	93	97	94	91	94	92	89	91	89	87	86																			
3	101	95	89	85	99	93	88	85	91	87	83	88	85	82	86	83	81	79																			
4	96	88	82	78	94	87	81	77	85	80	76	83	79	75	81	77	74	73																			
5	91	82	76	71	89	81	75	71	79	74	70	77	73	70	76	72	69	67																			
6	86	76	70	66	84	76	70	65	74	69	65	73	68	64	71	67	64	62																			
7	81	71	65	61	80	71	65	60	69	64	60	68	63	60	67	63	59	58																			
8	77	67	61	56	76	66	60	56	65	60	56	64	59	56	63	59	55	54																			
9	73	63	57	52	72	62	56	52	61	56	52	60	56	52	60	55	52	50																			
10	69	59	53	49	68	59	53	49	58	53	49	57	52	49	56	52	49	47																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	117162
5°	112354
10°	106066
15°	99808
20°	90209
25°	76625
30°	62491
35°	48780
40°	36082
45°	23452
50°	9654
55°	3718
60°	1743
65°	454
70°	289
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 23452 cd/sqm



TEST NUMBER: P643940

CATALOG NUMBER: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	190.6	9.6
10°-20°	489.5	24.6
20°-30°	579.1	29.1
30°-40°	456.0	22.9
40°-50°	229.6	11.5
50°-60°	42.3	2.1
60°-70°	5.2	0.3
70°-80°	0.7	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1259.2	63.2
0°-40°	1715.2	86.1
0°-60°	1987.0	99.7
0°-90°	1992.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1992.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2137	
5°	2042	191
15°	1759	490
25°	1267	579
35°	729	456
45°	302	230
55°	39	42
65°	4	5
75°	0	1
85°	0	0
90°	0	



TEST NUMBER: P643940

CATALOG NUMBER: ML5615LSWFL559FS1E - 692H - 1500LM - 5000K

CANDELA DISTRIBUTION (FULL):

	0°
0°	2137.2
2.5°	2112.4
5°	2041.7
7.5°	1969.1
10°	1905.4
12.5°	1836.4
15°	1758.6
17.5°	1659.5
20°	1546.3
22.5°	1413.6
25°	1266.8
27.5°	1123.5
30°	987.2
32.5°	856.3
35°	728.9
37.5°	610.4
40°	504.2
42.5°	399.8
45°	302.5
47.5°	196.4
50°	113.2
52.5°	61.9
55°	38.9
57.5°	26.5
60°	15.9
62.5°	7.1
65°	3.5
67.5°	1.8
70°	1.8
72.5°	1.8
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)