

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: HALO

Report Number: P645294

Luminaire Tested: **RLNL6109FSD2W1EWH-5000K**

Issue Date: 02/28/2023

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

**Test Information**

Test Method: LM-79-08  
 Report Number: P645294  
 Test Lab: ETA Testing Technology  
 Issue Date: 02/28/2023  
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
 Product Line: HALO  
 Catalog Number: RLNL6109FSD2W1EWH-5000K  
 Description: 6" 90 CRI COLOR TUNING RECESSED DOWNLIGHT RETROFIT DIM TO WARM  
 FIXTURE w/ NIGHTLIGHT  
 Light Source: 90 CRI 5000K LEDS  
 Ballast/Driver: ELECTRICAL DRIVER

**Summary**


Lumens per Lamp: N/A  
 Luminaire Lumens: 1050.5 lumens  
 Efficiency: N/A  
 Efficacy: 101.0 lumens/watt  
 Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33  
 Luminous Opening: Circular (Dia: 0.35' x H: 0')  
 CIE Type: Direct

Input Watts (W): 10.4  
 Input Voltage (V): 120  
 Input Current (Ain): NR  
 Voltage Rise (V): NR  
 Power Factor: NR  
 Total Harmonic Distortion (THDi): NR  
 Frequency (hertz): 60  
 Stabilization Time: NR  
 Operation Time: NR  
 Ambient Temperature (°C): NR  
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021

TEST NUMBER: P645294  
CATALOG NUMBER: RLNL6109FSD2W1EWH-5000K

### Luminous Intensity Polar Plot





TEST NUMBER: P645294

CATALOG NUMBER: RLNL6109FSD2W1EWH-5000K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	109	105	101	97	107	103	99	96	98	95	93		94	92	90		91	89	87	85
2	100	92	85	80	97	90	84	79	87	82	77		83	79	75		80	77	74	72
3	91	81	73	67	89	80	72	66	77	70	65		74	69	64		71	67	63	61
4	84	72	64	57	82	71	63	57	68	61	56		66	60	55		64	59	54	52
5	77	65	56	49	75	64	55	49	61	54	49		59	53	48		58	52	48	45
6	71	58	50	43	69	57	49	43	56	48	43		54	47	42		52	47	42	40
7	66	53	44	38	65	52	44	38	51	43	38		49	43	38		48	42	37	35
8	62	48	40	34	60	48	40	34	46	39	34		45	39	34		44	38	34	32
9	58	44	36	31	56	44	36	31	43	36	31		42	35	31		41	35	30	29
10	54	41	33	28	53	41	33	28	40	33	28		39	32	28		38	32	28	26

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	44414
5°	44310
10°	44068
15°	43753
20°	43347
25°	42930
30°	42277
35°	41482
40°	40378
45°	39047
50°	37413
55°	35203
60°	32516
65°	29292
70°	25972
75°	22585
80°	18876
85°	13915

TEST NUMBER: P645294  
 CATALOG NUMBER: RLNL6109FSD2W1EWH-5000K

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	38.4	3.7
10°-20°	109.1	10.4
20°-30°	163.9	15.6
30°-40°	194.3	18.5
40°-50°	194.7	18.5
50°-60°	165.1	15.7
60°-70°	113.0	10.8
70°-80°	57.6	5.5
80°-90°	14.4	1.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	311.4	29.6
0°-40°	505.6	48.1
0°-60°	865.5	82.4
0°-90°	1050.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1050.5	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	406	
5°	404	38
15°	387	109
25°	356	164
35°	311	194
45°	253	195
55°	185	165
65°	113	113
75°	54	58
85°	11	14
90°	1	

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

  
NVLAP Lab Code: 200050-0



TEST NUMBER: P645294  
CATALOG NUMBER: RLNL6109FSD2W1EWH-5000K

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	406.5
5°	404.0
10°	397.2
15°	386.8
20°	372.8
25°	356.1
30°	335.1
35°	311.0
40°	283.1
45°	252.7
50°	220.1
55°	184.8
60°	148.8
65°	113.3
70°	81.3
75°	53.5
80°	30.0
85°	11.1
90°	0.6

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

  
NVLAP Lab Code: 200050-0



Report Generated By 670245763 / DESKTOP-DVLU35A

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



NVLAP Lab Code: 200050-0



Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021
------------------	--------------	-----------	-----------



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

  
NVLAP Lab Code: 200050-0



(END OF REPORT)