

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930993

Luminaire Tested: DFN2DS-SQ3F0-090DS830-FLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930993
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333812)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-SQ3F0-090DS830-FLL
Description: 3 foot, Square Define Geo, with Direct Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8393.2 lumens
Efficiency: N/A
Efficacy: 89.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular (W 3.06' x L: 3.06' x H: 0')
CIE Type: Direct

Input Watts (W): 93.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.996
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930993

CATALOG NUMBER: DFN2DS-SQ3F0-090DS830-FLL

Luminous Intensity Polar Plot



TEST NUMBER: P930993

CATALOG NUMBER: DFN2DS-SQ3F0-090DS830-FLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	109	104	100	96	106	102	98	95	98	95	92		94	91	89		90
2	99	91	85	79	97	89	83	78	86	81	76		83	78	74		80
3	91	80	72	66	88	79	71	65	76	69	64		73	68	63		71
4	83	71	63	56	81	70	62	56	68	61	55		65	59	54		63
5	77	64	55	49	75	63	55	48	61	53	48		59	52	47		57
6	71	58	49	43	69	57	48	42	55	48	42		53	47	42		52
7	66	52	44	38	64	52	43	38	50	43	37		49	42	37		47
8	61	48	40	34	60	47	39	34	46	39	33		45	38	33		44
9	57	44	36	30	56	43	36	30	42	35	30		41	35	30		40
10	54	41	33	28	53	40	33	28	39	32	27		38	32	27		37

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3780	3780	3780
5°	3794	3740	3762
10°	3772	3702	3720
15°	3725	3654	3650
20°	3659	3582	3578
25°	3593	3493	3493
30°	3509	3412	3383
35°	3430	3315	3266
40°	3331	3217	3155
45°	3233	3120	3043
50°	3127	3019	2912
55°	3017	2902	2795
60°	2893	2763	2661
65°	2761	2623	2503
70°	2593	2455	2338
75°	2359	2260	2205
80°	2094	2030	1925
85°	1708	1629	1461

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3233 cd/sqm

TEST NUMBER: P930993

CATALOG NUMBER: DFN2DS-SQ3F0-090DS830-FLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	310.5	3.7
10°-20°	873.6	10.4
20°-30°	1283.8	15.3
30°-40°	1491.1	17.8
40°-50°	1489.3	17.7
50°-60°	1298.6	15.5
60°-70°	959.9	11.4
70°-80°	543.1	6.5
80°-90°	143.4	1.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2467.9	29.4
0°-40°	3959.0	47.2
0°-60°	6746.8	80.4
0°-90°	8393.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8393.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3299	3299	3299	3299	3299	
5°	3299	3286	3251	3277	3270	313
15°	3140	3122	3080	3093	3077	884
25°	2842	2817	2763	2769	2763	1308
35°	2452	2420	2370	2350	2335	1531
45°	1995	1973	1925	1891	1878	1540
55°	1510	1491	1453	1415	1399	1350
65°	1018	999	968	939	923	1007
75°	533	527	511	492	498	569
85°	130	127	124	114	111	153
90°	0	0	0	0	0	

TEST NUMBER: P930993

CATALOG NUMBER: DFN2DS-SQ3F0-090DS830-FLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3298.8	3298.8	3298.8	3298.8	3298.8
2.5°	3318.0	3302.2	3267.2	3298.8	3292.8
5°	3298.8	3286.4	3251.4	3276.7	3270.5
7.5°	3276.7	3257.8	3222.8	3248.4	3242.0
10°	3242.0	3219.8	3181.7	3206.9	3197.5
12.5°	3194.1	3175.3	3137.3	3153.1	3146.8
15°	3140.3	3121.5	3080.1	3092.9	3077.0
17.5°	3073.7	3054.8	3013.5	3029.3	3013.5
20°	3000.6	2981.8	2937.3	2946.8	2934.3
22.5°	2927.9	2899.4	2857.9	2857.9	2851.5
25°	2842.1	2816.9	2763.1	2769.1	2763.1
27.5°	2746.9	2724.6	2683.7	2674.2	2658.4
30°	2652.0	2626.4	2578.9	2569.5	2556.8
32.5°	2550.4	2531.5	2480.7	2461.5	2448.7
35°	2452.1	2420.5	2369.6	2350.5	2334.7
37.5°	2341.1	2312.4	2261.6	2239.4	2223.6
40°	2226.9	2201.4	2150.5	2122.2	2109.5
42.5°	2115.8	2090.3	2039.8	2007.9	1989.0
45°	1995.3	1973.2	1925.4	1890.7	1878.0
47.5°	1878.0	1855.7	1804.9	1769.9	1751.1
50°	1754.1	1738.3	1693.8	1649.4	1633.6
52.5°	1633.6	1611.4	1570.3	1535.4	1513.1
55°	1510.1	1490.9	1452.8	1414.9	1399.1
57.5°	1386.2	1370.4	1329.1	1291.0	1278.2
60°	1262.4	1249.9	1205.5	1170.5	1161.1
62.5°	1141.9	1119.7	1088.0	1056.5	1043.6
65°	1018.4	999.2	967.5	939.0	923.2
67.5°	891.5	875.4	847.0	824.9	812.1
70°	774.0	761.2	732.7	710.5	698.0
72.5°	653.6	640.7	624.9	602.8	593.4
75°	532.8	526.7	510.6	491.7	498.1
77.5°	425.0	412.3	405.9	396.5	387.1
80°	317.4	314.0	307.6	298.1	291.8
82.5°	215.7	215.7	212.7	199.9	199.9
85°	129.9	126.9	123.9	114.1	111.1
87.5°	57.2	50.8	44.5	35.0	31.7
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930993

CATALOG NUMBER: DFN2DS-SQ3F0-090DS830-FLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.90	17.51	16.27	17.83	18.14	15.46	17.07	15.82	17.38	17.70
	3H	17.65	19.11	18.03	19.43	19.79	17.16	18.62	17.54	18.94	19.30
	4H	18.30	19.67	18.70	20.02	20.39	17.80	19.17	18.20	19.52	19.90
	6H	18.77	20.04	19.18	20.40	20.79	18.27	19.54	18.68	19.90	20.29
	8H	18.91	20.12	19.34	20.51	20.91	18.41	19.62	18.83	20.01	20.41
	12H	19.00	20.16	19.43	20.54	20.97	18.49	19.65	18.92	20.03	20.46
4H	2H	16.46	17.83	16.86	18.18	18.56	16.11	17.48	16.51	17.83	18.20
	3H	18.44	19.58	18.85	19.98	20.38	18.03	19.18	18.44	19.58	19.98
	4H	19.21	20.25	19.65	20.66	21.10	18.79	19.83	19.22	20.24	20.68
	6H	19.81	20.72	20.27	21.16	21.61	19.38	20.28	19.83	20.72	21.18
	8H	20.00	20.85	20.46	21.29	21.75	19.56	20.41	20.02	20.85	21.32
	12H	20.13	20.89	20.61	21.37	21.84	19.68	20.44	20.16	20.92	21.39
8H	4H	19.49	20.33	19.95	20.78	21.24	19.11	19.96	19.57	20.40	20.87
	6H	20.20	20.91	20.70	21.39	21.87	19.82	20.52	20.31	21.01	21.49
	8H	20.46	21.09	20.97	21.60	22.08	20.07	20.70	20.58	21.21	21.69
	12H	20.66	21.22	21.17	21.71	22.27	20.25	20.81	20.76	21.30	21.86
12H	4H	19.51	20.27	19.99	20.75	21.22	19.15	19.91	19.63	20.38	20.85
	6H	20.25	20.88	20.76	21.39	21.87	19.88	20.51	20.39	21.02	21.50
	8H	20.56	21.12	21.07	21.61	22.17	20.18	20.74	20.69	21.23	21.79