

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P331457-840

Luminaire Tested: **S122DIP-S1005D1080U840-4F0-1E-UDD-A1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P331457-840
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-8,
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: NEO-RAY
Catalog Number: S122DIP-S1005D1080U840-4F0-1E-UDD-A1
Description: DEFINE 2 DIRECT-INDIRECT PENDANT LED LUMINAIRE
DOWNLIGHT 1005 LUMENS PER FOOT, ASYMMETRIC DIFFUSER
UPLIGHT 1080 LUMENS PER FOOT, FLUSH SATIN WHITE DIFFUSER
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8335.0 lumens
Efficiency: N/A
Efficacy: 116.2 lumens/watt
Spacing Criteria (0/90/45): 1.08 / 1.16 / 1.23
Luminous Opening: Rectangular (W 4' x L: 0.17' x H: 0')
CIE Type: General Diffuse


Input Watts (W): 71.7
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

Luminous Intensity Polar Plot





TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	108	108	108	108	100	100	100	100	85	85	85	72	72	72	59	59	59	53
1	99	95	91	88	92	88	85	82	75	73	71	64	62	61	53	52	51	46
2	91	83	78	73	84	78	72	68	67	63	60	57	54	51	47	45	44	39
3	83	74	67	61	77	69	63	58	59	55	51	51	47	44	42	40	38	34
4	76	66	58	52	70	61	55	49	53	48	44	45	41	38	38	35	33	30
5	70	59	51	45	65	55	48	43	48	42	38	41	37	34	35	32	29	26
6	65	53	45	39	60	50	43	37	43	38	34	37	33	30	32	28	26	23
7	60	48	40	35	56	45	38	33	39	34	30	34	30	26	29	26	23	21
8	56	44	36	31	52	41	34	29	36	31	27	31	27	24	27	23	21	19
9	52	40	33	28	48	38	31	26	33	28	24	29	25	22	25	22	19	17
10	49	37	30	25	45	35	28	24	31	25	22	27	23	20	23	20	17	16

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	32513	32513	32513	32513
5°	36451	32725	29000	32725
10°	41769	32455	25097	32455
15°	46208	31861	22173	31861
20°	45505	31223	20213	31223
25°	41031	30375	18971	30375
30°	33907	29015	18066	29015
35°	24711	27595	17420	27595
40°	19736	25918	17062	25918
45°	17249	23980	16575	23980
50°	16211	22102	16252	22102
55°	14945	20194	15817	20194
60°	13695	18167	15145	18167
65°	12478	16351	14487	16351
70°	11325	14578	13520	14578
75°	10044	12601	11977	12601
80°	8638	10432	9642	10432
85°	7744	7744	5743	7744



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	191.8	2.3
10°-20°	557.5	6.7
20°-30°	809.1	9.7
30°-40°	853.9	10.2
40°-50°	756.0	9.1
50°-60°	603.3	7.2
60°-70°	410.1	4.9
70°-80°	210.2	2.5
80°-90°	56.2	0.7
90°-100°	88.1	1.1
100°-110°	273.6	3.3
110°-120°	467.6	5.6
120°-130°	614.9	7.4
130°-140°	690.2	8.3
140°-150°	676.7	8.1
150°-160°	567.6	6.8
160°-170°	376.5	4.5
170°-180°	131.6	1.6
0°-30°	1558.5	18.7
0°-40°	2412.3	28.9
0°-60°	3771.7	45.3
0°-90°	4448.2	53.4
90°-120°	829.3	9.9
90°-150°	2811.1	33.7
90°-180°	3887.0	46.6
0°-180°	8335.0	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	2014	2014	2014	2014	2014	
5°	2249	2019	1789	2019	2249	225
15°	2764	1906	1326	1906	2764	763
25°	2303	1705	1065	1705	2303	1041
35°	1254	1400	884	1400	1254	815
45°	755	1050	726	1050	755	594
55°	531	717	562	717	531	476
65°	327	428	379	428	327	325
75°	161	202	192	202	161	172
85°	42	42	31	42	42	47
90°	40	1	40	1	40	19
95°	73	61	73	61	73	81
105°	260	252	260	252	260	274
115°	469	469	469	469	469	463
125°	685	683	685	683	685	611
135°	894	883	894	883	894	688
145°	1084	1072	1084	1072	1084	677
155°	1235	1226	1235	1226	1235	568
165°	1335	1334	1335	1334	1335	376
175°	1383	1388	1383	1388	1383	131
180°	1390	1390	1390	1390	1390	



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	2106.6	2107.2	2108.4	2098.5	2097.3	2097.3	2088.6	2081.2	2072.5	2060.7	2062.0
5°	2249.0	2257.5	2260.6	2251.3	2237.4	2235.8	2222.7	2201.0	2180.9	2164.6	2153.0
7.5°	2418.9	2422.4	2414.8	2402.6	2392.2	2373.6	2349.1	2325.1	2291.6	2260.8	2237.9
10°	2547.7	2552.3	2539.2	2521.4	2506.7	2485.1	2449.4	2413.1	2368.9	2326.4	2292.3
12.5°	2645.5	2657.0	2640.1	2637.8	2612.6	2582.8	2540.4	2522.0	2459.9	2400.7	2364.2
15°	2764.4	2763.6	2765.2	2750.5	2731.9	2727.2	2682.4	2633.6	2546.2	2511.3	2450.9
17.5°	2730.1	2741.8	2747.2	2747.0	2746.6	2743.7	2729.3	2698.5	2654.6	2598.2	2528.5
20°	2648.4	2663.8	2666.1	2683.9	2694.0	2707.1	2712.6	2704.0	2677.0	2629.8	2569.4
22.5°	2522.0	2526.4	2533.7	2561.3	2583.1	2616.2	2633.3	2661.9	2651.6	2628.5	2578.1
25°	2303.2	2295.4	2322.5	2336.4	2386.7	2439.3	2477.3	2519.1	2556.3	2578.7	2563.9
27.5°	2040.3	2028.7	2069.3	2106.3	2147.2	2204.1	2263.2	2333.0	2391.1	2463.7	2488.6
30°	1818.7	1825.6	1864.3	1903.8	1965.7	2046.2	2112.7	2189.4	2272.2	2353.5	2409.9
32.5°	1579.7	1606.5	1630.9	1691.4	1746.0	1835.7	1933.2	2029.0	2132.3	2224.7	2312.2
35°	1253.7	1284.6	1318.8	1362.8	1439.5	1528.4	1623.7	1752.9	1893.8	2019.9	2123.6
37.5°	1055.3	1050.4	1069.9	1101.8	1163.8	1235.7	1345.2	1472.9	1638.7	1787.0	1933.2
40°	936.4	933.3	947.3	976.6	1023.9	1076.5	1172.5	1284.6	1438.7	1619.8	1793.9
42.5°	854.7	856.6	864.3	885.0	917.4	960.7	1032.6	1128.0	1269.1	1439.7	1626.8
45°	755.4	760.7	769.3	779.3	797.9	833.5	873.7	941.9	1053.3	1195.7	1379.9
47.5°	683.8	684.0	692.7	701.5	712.5	732.6	765.4	808.1	886.8	1002.7	1161.0
50°	645.4	640.1	646.2	653.2	664.8	678.7	700.3	740.6	793.2	886.9	1019.3
52.5°	598.3	598.5	604.1	606.7	617.1	631.1	650.9	678.7	726.4	799.6	908.4
55°	530.9	534.7	537.9	542.5	551.8	561.9	577.3	595.9	633.1	688.0	768.5
57.5°	467.5	468.7	471.8	480.6	486.5	495.7	510.5	527.4	551.5	592.2	652.7
60°	424.1	424.1	430.3	434.1	441.9	451.2	462.8	479.1	500.7	534.0	582.8
62.5°	384.5	383.8	386.4	392.6	398.6	407.3	418.8	432.6	453.0	482.6	522.7
65°	326.6	325.1	329.7	331.2	337.4	346.0	355.3	369.9	386.2	407.9	443.4
67.5°	270.8	272.8	275.2	278.1	281.6	290.5	296.7	307.1	320.8	338.8	362.9
70°	239.9	239.9	239.9	242.3	246.9	251.6	257.7	266.2	279.4	294.9	316.5
72.5°	205.2	207.7	210.2	208.8	214.7	217.4	224.9	229.7	242.3	252.2	271.4
75°	161.0	161.0	161.0	164.8	167.1	169.5	174.1	178.7	185.0	197.3	207.4
77.5°	120.1	119.8	120.6	121.5	124.0	126.7	128.2	132.3	138.0	143.8	152.3
80°	92.9	94.4	95.2	96.7	96.7	98.3	99.1	104.5	108.4	112.2	117.6
82.5°	71.8	72.1	72.3	72.6	73.2	74.1	76.1	77.9	79.3	82.5	86.6
85°	41.8	41.0	41.0	42.5	41.8	41.8	43.3	44.8	44.8	45.6	48.0
87.5°	24.0	24.0	24.5	23.9	23.8	24.5	24.6	24.1	24.8	25.5	25.0
90°	39.9	39.6	39.4	39.1	38.9	39.0	39.5	40.0	40.5	41.1	35.3
92.5°	38.0	38.0	37.9	37.9	37.8	37.8	37.6	37.5	37.4	37.3	36.0
95°	72.7	73.2	73.8	74.3	74.8	75.0	75.0	75.0	75.0	75.0	74.5
97.5°	126.0	126.0	126.1	126.1	126.2	126.2	126.2	126.2	126.2	126.2	125.2
100°	160.7	161.0	161.3	161.5	161.8	161.9	161.9	161.9	161.9	161.9	161.1
102.5°	200.2	200.4	200.7	200.9	201.2	201.2	201.0	200.8	200.6	200.4	199.3
105°	260.4	260.4	260.4	260.4	260.4	260.1	259.6	259.1	258.6	258.0	257.5
107.5°	317.2	318.4	319.6	320.8	321.9	322.4	322.2	322.0	321.8	321.6	321.6
110°	361.3	362.0	362.8	363.7	364.5	364.9	364.9	364.9	364.9	364.9	364.9



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	403.5	404.1	404.7	405.3	405.9	406.5	407.1	407.7	408.3	408.9	409.1
115°	469.2	470.0	470.8	471.6	472.3	472.8	473.1	473.4	473.6	473.9	474.4
117.5°	531.9	532.6	533.4	534.2	535.0	535.7	536.3	536.9	537.6	538.2	539.7
120°	575.9	576.7	577.5	578.3	579.1	579.5	579.5	579.5	579.5	579.5	581.6
122.5°	619.1	619.8	620.3	620.9	621.5	622.0	622.7	623.3	623.9	624.5	626.0
125°	685.1	685.3	685.6	685.8	686.1	686.6	687.4	688.2	688.9	689.7	690.5
127.5°	745.1	746.0	746.8	747.6	748.4	749.3	750.2	751.2	752.1	753.1	754.1
130°	788.3	789.3	790.3	791.4	792.4	793.2	793.8	794.3	794.8	795.4	795.9
132.5°	829.6	830.4	831.2	832.1	832.9	833.9	835.1	836.2	837.4	838.5	838.4
135°	893.8	894.6	895.4	896.2	897.0	897.5	897.8	898.1	898.3	898.6	898.1
137.5°	952.0	953.1	954.1	955.1	956.2	956.8	957.0	957.3	957.5	957.7	956.9
140°	992.4	993.4	994.5	995.5	996.5	997.0	997.0	997.0	997.0	997.0	995.8
142.5°	1029.0	1030.1	1031.1	1032.1	1033.2	1033.6	1033.4	1033.2	1033.0	1032.8	1031.9
145°	1083.9	1084.9	1086.0	1087.0	1088.0	1088.4	1088.2	1087.9	1087.6	1087.4	1085.8
147.5°	1133.0	1133.9	1134.9	1135.9	1136.9	1137.1	1136.5	1136.0	1135.4	1134.8	1133.8
150°	1164.9	1165.6	1166.4	1167.2	1168.0	1168.0	1167.2	1166.4	1165.6	1164.9	1163.8
152.5°	1194.9	1195.9	1196.9	1197.8	1198.8	1198.8	1197.8	1196.9	1195.9	1194.9	1193.7
155°	1235.2	1236.0	1236.8	1237.6	1238.3	1238.1	1236.8	1235.5	1234.2	1232.8	1232.1
157.5°	1269.9	1271.2	1272.4	1273.6	1275.0	1274.7	1272.9	1271.1	1269.4	1267.6	1267.1
160°	1291.5	1292.5	1293.6	1294.6	1295.7	1295.5	1293.8	1292.3	1290.7	1289.2	1288.9
162.5°	1310.3	1311.5	1312.8	1314.0	1315.2	1315.0	1313.2	1311.5	1309.7	1308.0	1307.7
165°	1334.9	1336.3	1337.6	1338.9	1340.1	1339.9	1338.1	1336.3	1334.4	1332.6	1332.6
167.5°	1355.1	1356.5	1357.8	1359.2	1360.5	1360.3	1358.5	1356.7	1354.8	1353.0	1353.0
170°	1365.4	1367.0	1368.6	1370.1	1371.7	1371.5	1369.7	1367.9	1366.0	1364.2	1364.5
172.5°	1373.8	1375.4	1377.0	1378.6	1380.1	1380.0	1378.2	1376.3	1374.5	1372.7	1372.9
175°	1383.0	1384.6	1386.1	1387.8	1389.3	1389.2	1387.4	1385.5	1383.7	1381.8	1382.4
177.5°	1387.3	1388.5	1389.8	1391.0	1392.2	1392.2	1391.0	1389.8	1388.5	1387.3	1387.7
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	2066.4	2061.4	2058.3	2047.2	2037.2	2027.3	2024.3	2025.5	2011.9	1998.8	1993.3
5°	2146.9	2131.3	2116.7	2095.8	2071.0	2043.9	2029.9	2019.1	1992.1	1962.7	1945.6
7.5°	2219.0	2196.9	2168.5	2129.2	2093.1	2050.5	2023.5	1999.4	1959.8	1918.3	1893.0
10°	2262.9	2232.7	2196.4	2148.4	2104.3	2052.4	2016.0	1979.6	1933.2	1883.7	1852.7
12.5°	2300.7	2260.0	2224.2	2162.6	2110.4	2045.6	2002.5	1951.2	1902.3	1843.4	1813.1
15°	2390.7	2315.5	2247.5	2177.8	2113.5	2023.0	1975.0	1906.1	1841.9	1769.2	1734.3
17.5°	2460.1	2375.7	2268.5	2180.0	2105.1	2004.8	1934.3	1851.8	1775.8	1692.7	1645.4
20°	2499.7	2403.0	2287.6	2182.4	2092.6	1978.1	1901.5	1817.2	1728.2	1634.5	1583.5
22.5°	2523.2	2421.6	2307.5	2173.1	2067.9	1956.4	1860.0	1767.6	1677.4	1576.3	1522.8
25°	2530.7	2437.8	2317.1	2165.5	2036.9	1910.8	1794.7	1705.0	1595.8	1501.4	1423.2
27.5°	2493.9	2427.3	2311.2	2150.8	2001.1	1853.7	1724.2	1622.6	1507.4	1404.9	1326.4
30°	2448.6	2409.9	2296.9	2136.0	1972.7	1814.0	1671.6	1556.3	1441.8	1338.1	1257.6
32.5°	2378.7	2370.4	2271.0	2115.0	1942.4	1763.9	1616.6	1500.0	1373.1	1271.2	1194.5
35°	2241.3	2278.4	2215.7	2067.9	1885.2	1692.5	1533.1	1400.0	1268.5	1170.9	1098.9
37.5°	2057.1	2149.3	2132.9	1999.0	1808.2	1614.9	1438.9	1299.7	1174.4	1075.9	1005.3
40°	1930.2	2047.8	2064.8	1946.4	1753.7	1554.8	1368.3	1229.7	1107.4	1017.7	946.4
42.5°	1793.9	1931.4	1978.1	1883.2	1694.3	1491.7	1305.1	1161.6	1040.6	953.3	890.2
45°	1565.6	1747.5	1831.9	1777.7	1595.1	1387.7	1195.7	1050.2	940.3	858.3	809.5
47.5°	1352.2	1551.0	1664.4	1645.2	1484.7	1279.3	1089.5	949.9	842.9	777.5	733.9
50°	1201.1	1405.4	1542.4	1548.6	1405.4	1201.8	1011.5	879.9	781.6	720.5	684.9
52.5°	1069.9	1264.9	1414.2	1447.0	1316.9	1121.4	941.5	810.6	724.1	667.9	636.0
55°	898.5	1063.4	1229.0	1289.3	1184.9	999.2	832.7	717.4	636.1	597.4	569.6
57.5°	747.0	884.4	1037.3	1104.1	1039.7	880.7	724.7	624.5	558.7	524.7	503.3
60°	667.1	775.5	911.7	991.4	935.6	794.1	657.8	562.6	508.5	478.3	458.2
62.5°	592.8	688.8	804.0	876.9	846.5	713.0	591.0	507.0	460.2	431.8	417.3
65°	489.1	564.9	654.0	721.2	701.1	599.8	500.0	428.0	390.8	368.4	356.8
67.5°	402.7	457.6	519.3	578.2	562.0	490.2	410.0	354.0	326.3	306.9	299.9
70°	348.3	390.0	445.0	492.2	479.1	420.2	356.8	308.8	284.8	268.5	261.6
72.5°	296.3	330.6	372.5	411.1	402.2	353.4	300.4	264.2	245.8	230.8	225.1
75°	223.7	249.9	275.5	301.0	298.7	260.8	229.8	202.0	187.3	175.7	173.4
77.5°	165.1	179.9	197.2	212.4	208.1	186.5	162.2	146.2	135.4	127.6	126.4
80°	126.1	134.6	147.0	157.8	152.5	143.2	123.8	112.2	104.5	96.7	93.6
82.5°	91.5	100.0	107.4	113.3	109.2	100.5	88.6	80.7	76.0	70.7	69.5
85°	48.0	52.6	55.7	57.3	55.7	50.3	44.8	41.8	38.0	35.6	34.8
87.5°	24.5	23.3	22.2	22.5	20.1	19.5	16.4	13.8	13.8	13.8	13.2
90°	29.6	23.8	18.1	13.7	10.6	7.5	4.3	1.2	4.3	7.5	10.6
92.5°	34.6	33.2	31.9	30.1	27.8	25.4	23.1	20.9	23.1	25.4	27.8
95°	74.0	73.5	73.0	71.4	68.8	66.2	63.6	61.0	63.6	66.2	68.8
97.5°	124.2	123.2	122.3	120.6	118.4	116.0	113.7	111.5	113.7	116.0	118.4
100°	160.3	159.6	158.8	157.3	155.2	153.2	151.1	149.0	151.1	153.2	155.2
102.5°	198.3	197.4	196.4	195.1	193.4	191.8	190.1	188.4	190.1	191.8	193.4
105°	257.0	256.5	256.0	255.3	254.6	253.8	253.0	252.2	253.0	253.8	254.6
107.5°	321.6	321.6	321.6	321.0	319.9	318.8	317.6	316.5	317.6	318.8	319.9
110°	364.9	364.9	364.9	364.1	362.4	360.9	359.3	357.8	359.3	360.9	362.4



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	409.3	409.5	409.8	409.1	407.5	406.0	404.3	402.8	404.3	406.0	407.5
115°	474.9	475.4	475.9	475.4	473.9	472.3	470.8	469.2	470.8	472.3	473.9
117.5°	541.1	542.6	544.0	543.7	541.6	539.6	537.5	535.3	537.5	539.6	541.6
120°	583.7	585.7	587.8	587.8	585.7	583.7	581.6	579.5	581.6	583.7	585.7
122.5°	627.4	628.9	630.4	629.9	627.3	624.8	622.4	619.9	622.4	624.8	627.3
125°	691.4	692.1	692.9	692.1	689.7	687.4	685.1	682.7	685.1	687.4	689.7
127.5°	755.0	755.9	756.9	755.8	752.9	749.9	746.9	744.0	746.9	749.9	752.9
130°	796.4	796.9	797.4	796.0	792.5	789.2	785.8	782.4	785.8	789.2	792.5
132.5°	838.3	838.2	838.1	836.7	833.8	831.1	828.4	825.6	828.4	831.1	833.8
135°	897.5	897.0	896.5	894.7	891.9	889.1	886.2	883.3	886.2	889.1	891.9
137.5°	956.3	955.6	954.9	953.4	951.1	948.8	946.4	944.0	946.4	948.8	951.1
140°	994.5	993.2	991.9	990.1	987.7	985.3	983.0	980.7	983.0	985.3	987.7
142.5°	1031.0	1030.1	1029.2	1027.5	1025.2	1022.9	1020.6	1018.2	1020.6	1022.9	1025.2
145°	1084.3	1082.7	1081.2	1079.4	1077.6	1075.8	1074.0	1072.2	1074.0	1075.8	1077.6
147.5°	1132.8	1131.7	1130.6	1129.0	1126.8	1124.6	1122.5	1120.2	1122.5	1124.6	1126.8
150°	1162.8	1161.7	1160.6	1159.3	1157.8	1156.2	1154.7	1153.1	1154.7	1156.2	1157.8
152.5°	1192.3	1191.1	1189.8	1188.4	1186.9	1185.3	1183.8	1182.1	1183.8	1185.3	1186.9
155°	1231.3	1230.5	1229.7	1229.0	1228.2	1227.4	1226.6	1225.9	1226.6	1227.4	1228.2
157.5°	1266.7	1266.2	1265.7	1265.3	1264.7	1264.1	1263.6	1263.1	1263.6	1264.1	1264.7
160°	1288.7	1288.4	1288.1	1287.8	1287.2	1286.7	1286.2	1285.7	1286.2	1286.7	1287.2
162.5°	1307.4	1307.2	1306.9	1306.8	1306.6	1306.5	1306.4	1306.3	1306.4	1306.5	1306.6
165°	1332.6	1332.6	1332.6	1332.7	1332.9	1333.2	1333.5	1333.7	1333.5	1333.2	1332.9
167.5°	1353.1	1353.1	1353.2	1353.6	1354.4	1355.1	1355.9	1356.8	1355.9	1355.1	1354.4
170°	1364.7	1365.0	1365.3	1365.8	1366.5	1367.4	1368.2	1369.0	1368.2	1367.4	1366.5
172.5°	1373.2	1373.5	1373.7	1374.2	1375.0	1375.8	1376.6	1377.4	1376.6	1375.8	1375.0
175°	1382.9	1383.4	1383.9	1384.6	1385.3	1386.1	1386.9	1387.8	1386.9	1386.1	1385.3
177.5°	1388.1	1388.5	1388.9	1389.5	1390.1	1390.7	1391.3	1391.9	1391.3	1390.7	1390.1
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	1987.1	1983.4	1970.3	1963.6	1952.5	1941.9	1935.1	1938.2	1940.7	1939.4	1937.5
5°	1930.2	1915.4	1893.0	1873.6	1859.7	1834.2	1823.3	1818.0	1813.3	1807.9	1802.4
7.5°	1862.3	1839.2	1807.0	1779.4	1753.3	1721.6	1703.5	1692.7	1681.5	1669.3	1658.5
10°	1814.0	1781.5	1747.5	1708.8	1677.9	1649.2	1623.7	1606.6	1591.1	1576.5	1565.6
12.5°	1763.3	1725.9	1683.7	1630.8	1596.7	1555.7	1551.9	1521.9	1497.6	1488.5	1475.8
15°	1682.4	1629.8	1576.5	1513.8	1486.7	1449.6	1426.3	1403.1	1382.2	1367.5	1363.6
17.5°	1590.7	1522.6	1469.5	1424.4	1380.1	1342.0	1320.6	1302.0	1284.9	1265.2	1262.5
20°	1520.8	1461.9	1403.9	1364.4	1318.8	1280.0	1253.7	1235.2	1220.4	1208.8	1198.8
22.5°	1454.5	1390.1	1337.0	1293.8	1248.8	1217.5	1196.8	1178.8	1166.6	1153.8	1144.3
25°	1348.2	1297.9	1239.8	1191.0	1153.9	1133.8	1116.7	1101.3	1093.6	1085.0	1074.2
27.5°	1255.2	1199.2	1144.9	1107.1	1074.5	1056.7	1044.6	1034.1	1026.8	1021.9	1015.7
30°	1189.5	1133.0	1090.5	1053.3	1026.2	1008.5	1000.7	994.5	985.9	982.9	979.8
32.5°	1126.3	1075.4	1039.1	1006.8	981.0	969.4	962.3	956.7	950.1	947.0	940.8
35°	1037.0	994.5	958.9	941.1	920.2	910.1	904.7	897.0	890.8	887.7	886.9
37.5°	953.0	916.0	892.6	869.7	860.9	854.7	847.3	842.0	840.2	839.7	838.9
40°	898.5	868.3	847.5	828.9	825.0	815.7	809.5	804.9	804.9	805.7	804.9
42.5°	849.0	821.9	803.4	787.4	782.8	777.3	771.1	770.8	772.0	774.7	772.0
45°	774.0	754.6	741.4	733.7	725.2	719.7	718.9	721.2	722.1	722.9	725.2
47.5°	704.9	692.1	680.1	671.6	667.9	666.9	666.0	670.0	673.8	675.2	678.7
50°	664.0	649.3	639.2	633.8	630.8	629.1	630.8	635.4	638.4	642.4	644.7
52.5°	618.2	607.8	600.9	596.7	595.4	596.4	596.7	602.0	606.9	608.3	609.4
55°	554.9	547.1	545.6	538.7	541.7	541.0	544.8	548.0	552.6	557.2	558.0
57.5°	491.7	485.5	481.4	482.0	482.9	486.4	489.6	495.0	500.0	504.9	505.3
60°	449.7	446.6	444.2	444.2	445.8	450.4	454.2	459.7	462.8	465.9	468.2
62.5°	411.2	408.2	405.9	407.1	411.1	413.8	418.4	421.3	424.4	427.5	428.6
65°	350.6	349.0	351.3	352.9	353.7	357.6	362.9	365.3	368.4	369.9	375.4
67.5°	294.7	295.0	294.7	296.9	301.3	302.3	307.4	312.9	313.5	316.4	319.9
70°	256.9	258.5	260.0	261.6	265.5	267.0	270.8	273.2	276.3	278.6	280.9
72.5°	222.3	222.6	224.1	223.8	227.0	230.5	233.7	236.0	239.1	242.1	244.4
75°	171.1	171.1	172.6	173.4	177.2	181.1	180.4	181.9	185.0	188.0	189.7
77.5°	124.9	123.2	124.9	125.7	126.9	130.2	130.8	133.0	136.5	135.4	137.1
80°	95.2	92.9	95.2	95.9	95.9	99.9	99.9	101.4	103.7	101.4	103.7
82.5°	68.0	66.9	68.6	68.8	70.0	70.1	71.4	71.7	74.0	72.9	74.0
85°	34.0	33.3	34.0	33.3	34.0	34.8	34.8	34.0	34.0	35.6	33.3
87.5°	13.2	13.5	14.0	15.2	15.8	16.3	15.6	15.5	15.3	13.9	13.9
90°	13.7	18.1	23.8	29.6	35.3	41.1	40.5	40.0	39.5	39.0	38.9
92.5°	30.1	31.9	33.2	34.6	36.0	37.3	37.4	37.5	37.6	37.8	37.8
95°	71.4	73.0	73.5	74.0	74.5	75.0	75.0	75.0	75.0	75.0	74.8
97.5°	120.6	122.3	123.2	124.2	125.2	126.2	126.2	126.2	126.2	126.2	126.2
100°	157.3	158.8	159.6	160.3	161.1	161.9	161.9	161.9	161.9	161.9	161.8
102.5°	195.1	196.4	197.4	198.3	199.3	200.4	200.6	200.8	201.0	201.2	201.2
105°	255.3	256.0	256.5	257.0	257.5	258.0	258.6	259.1	259.6	260.1	260.4
107.5°	321.0	321.6	321.6	321.6	321.6	321.6	321.8	322.0	322.2	322.4	321.9
110°	364.1	364.9	364.9	364.9	364.9	364.9	364.9	364.9	364.9	364.9	364.5



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	409.1	409.8	409.5	409.3	409.1	408.9	408.3	407.7	407.1	406.5	405.9
115°	475.4	475.9	475.4	474.9	474.4	473.9	473.6	473.4	473.1	472.8	472.3
117.5°	543.7	544.0	542.6	541.1	539.7	538.2	537.6	536.9	536.3	535.7	535.0
120°	587.8	587.8	585.7	583.7	581.6	579.5	579.5	579.5	579.5	579.5	579.1
122.5°	629.9	630.4	628.9	627.4	626.0	624.5	623.9	623.3	622.7	622.0	621.5
125°	692.1	692.9	692.1	691.4	690.5	689.7	688.9	688.2	687.4	686.6	686.1
127.5°	755.8	756.9	755.9	755.0	754.1	753.1	752.1	751.2	750.2	749.3	748.4
130°	796.0	797.4	796.9	796.4	795.9	795.4	794.8	794.3	793.8	793.2	792.4
132.5°	836.7	838.1	838.2	838.3	838.4	838.5	837.4	836.2	835.1	833.9	832.9
135°	894.7	896.5	897.0	897.5	898.1	898.6	898.3	898.1	897.8	897.5	897.0
137.5°	953.4	954.9	955.6	956.3	956.9	957.7	957.5	957.3	957.0	956.8	956.2
140°	990.1	991.9	993.2	994.5	995.8	997.0	997.0	997.0	997.0	997.0	996.5
142.5°	1027.5	1029.2	1030.1	1031.0	1031.9	1032.8	1033.0	1033.2	1033.4	1033.6	1033.2
145°	1079.4	1081.2	1082.7	1084.3	1085.8	1087.4	1087.6	1087.9	1088.2	1088.4	1088.0
147.5°	1129.0	1130.6	1131.7	1132.8	1133.8	1134.8	1135.4	1136.0	1136.5	1137.1	1136.9
150°	1159.3	1160.6	1161.7	1162.8	1163.8	1164.9	1165.6	1166.4	1167.2	1168.0	1168.0
152.5°	1188.4	1189.8	1191.1	1192.3	1193.7	1194.9	1195.9	1196.9	1197.8	1198.8	1198.8
155°	1229.0	1229.7	1230.5	1231.3	1232.1	1232.8	1234.2	1235.5	1236.8	1238.1	1238.3
157.5°	1265.3	1265.7	1266.2	1266.7	1267.1	1267.6	1269.4	1271.1	1272.9	1274.7	1275.0
160°	1287.8	1288.1	1288.4	1288.7	1288.9	1289.2	1290.7	1292.3	1293.8	1295.5	1295.7
162.5°	1306.8	1306.9	1307.2	1307.4	1307.7	1308.0	1309.7	1311.5	1313.2	1315.0	1315.2
165°	1332.7	1332.6	1332.6	1332.6	1332.6	1332.6	1334.4	1336.3	1338.1	1339.9	1340.1
167.5°	1353.6	1353.2	1353.1	1353.1	1353.0	1353.0	1354.8	1356.7	1358.5	1360.3	1360.5
170°	1365.8	1365.3	1365.0	1364.7	1364.5	1364.2	1366.0	1367.9	1369.7	1371.5	1371.7
172.5°	1374.2	1373.7	1373.5	1373.2	1372.9	1372.7	1374.5	1376.3	1378.2	1380.0	1380.1
175°	1384.6	1383.9	1383.4	1382.9	1382.4	1381.8	1383.7	1385.5	1387.4	1389.2	1389.3
177.5°	1389.5	1388.9	1388.5	1388.1	1387.7	1387.3	1388.5	1389.8	1391.0	1392.2	1392.2
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	1931.4	1930.2	1930.2	1924.6	1930.2	1930.2	1931.4	1937.5	1939.4	1940.7	1938.2
5°	1791.6	1789.3	1785.4	1789.3	1785.4	1789.3	1791.6	1802.4	1807.9	1813.3	1818.0
7.5°	1653.4	1644.1	1642.7	1633.6	1642.7	1644.1	1653.4	1658.5	1669.3	1681.5	1692.7
10°	1552.5	1546.3	1545.5	1530.8	1545.5	1546.3	1552.5	1565.6	1576.5	1591.1	1606.6
12.5°	1475.7	1460.9	1463.8	1455.2	1463.8	1460.9	1475.7	1475.8	1488.5	1497.6	1521.9
15°	1342.7	1342.7	1339.7	1326.5	1339.7	1342.7	1342.7	1363.6	1367.5	1382.2	1403.1
17.5°	1247.3	1245.7	1238.3	1241.9	1238.3	1245.7	1247.3	1262.5	1265.2	1284.9	1302.0
20°	1190.2	1185.7	1176.4	1176.4	1176.4	1185.7	1190.2	1198.8	1208.8	1220.4	1235.2
22.5°	1136.4	1136.1	1126.2	1129.3	1126.2	1136.1	1136.4	1144.3	1153.8	1166.6	1178.8
25°	1073.4	1067.2	1062.6	1064.9	1062.6	1067.2	1073.4	1074.2	1085.0	1093.6	1101.3
27.5°	1013.7	1010.3	1010.0	1003.6	1010.0	1010.3	1013.7	1015.7	1021.9	1026.8	1034.1
30°	979.0	971.3	972.8	969.0	972.8	971.3	979.0	979.8	982.9	985.9	994.5
32.5°	939.4	936.5	935.0	931.8	935.0	936.5	939.4	940.8	947.0	950.1	956.7
35°	885.3	886.2	882.2	883.8	882.2	886.2	885.3	886.9	887.7	890.8	897.0
37.5°	838.2	840.6	838.8	839.2	838.8	840.6	838.2	838.9	839.7	840.2	842.0
40°	807.2	807.2	807.2	809.5	807.2	807.2	807.2	804.9	805.7	804.9	804.9
42.5°	777.5	776.3	775.0	774.9	775.0	776.3	777.5	772.0	774.7	772.0	770.8
45°	726.7	729.0	729.8	725.9	729.8	729.0	726.7	725.2	722.9	722.1	721.2
47.5°	680.8	681.1	680.8	684.2	680.8	681.1	680.8	678.7	675.2	673.8	670.0
50°	648.5	647.0	648.5	647.0	648.5	647.0	648.5	644.7	642.4	638.4	635.4
52.5°	614.5	614.8	613.9	613.6	613.9	614.8	614.5	609.4	608.3	606.9	602.0
55°	561.1	562.6	561.9	561.9	561.9	562.6	561.1	558.0	557.2	552.6	548.0
57.5°	505.8	507.3	508.3	504.9	508.3	507.3	505.8	505.3	504.9	500.0	495.0
60°	467.5	471.3	470.5	469.0	470.5	471.3	467.5	468.2	465.9	462.8	459.7
62.5°	432.1	433.5	433.4	433.1	433.4	433.5	432.1	428.6	427.5	424.4	421.3
65°	377.7	379.2	376.9	379.2	376.9	379.2	377.7	375.4	369.9	368.4	365.3
67.5°	319.0	319.5	321.1	322.2	321.1	319.5	319.0	319.9	316.4	313.5	312.9
70°	282.5	281.8	284.1	286.4	284.1	281.8	282.5	280.9	278.6	276.3	273.2
72.5°	244.1	245.8	245.0	246.7	245.0	245.8	244.1	244.4	242.1	239.1	236.0
75°	188.0	190.4	189.7	192.0	189.7	190.4	188.0	189.7	188.0	185.0	181.9
77.5°	135.9	136.2	135.9	137.1	135.9	136.2	135.9	137.1	135.4	136.5	133.0
80°	103.7	102.2	100.6	103.7	100.6	102.2	103.7	103.7	101.4	103.7	101.4
82.5°	72.1	73.0	71.5	71.5	71.5	73.0	72.1	74.0	72.9	74.0	71.7
85°	33.3	32.5	31.0	31.0	31.0	32.5	33.3	33.3	35.6	34.0	34.0
87.5°	14.0	13.4	13.5	12.9	13.5	13.4	14.0	13.9	13.9	15.3	15.5
90°	39.1	39.4	39.6	39.9	39.6	39.4	39.1	38.9	39.0	39.5	40.0
92.5°	37.9	37.9	38.0	38.0	38.0	37.9	37.9	37.8	37.8	37.6	37.5
95°	74.3	73.8	73.2	72.7	73.2	73.8	74.3	74.8	75.0	75.0	75.0
97.5°	126.1	126.1	126.0	126.0	126.0	126.1	126.1	126.2	126.2	126.2	126.2
100°	161.5	161.3	161.0	160.7	161.0	161.3	161.5	161.8	161.9	161.9	161.9
102.5°	200.9	200.7	200.4	200.2	200.4	200.7	200.9	201.2	201.2	201.0	200.8
105°	260.4	260.4	260.4	260.4	260.4	260.4	260.4	260.4	260.1	259.6	259.1
107.5°	320.8	319.6	318.4	317.2	318.4	319.6	320.8	321.9	322.4	322.2	322.0
110°	363.7	362.8	362.0	361.3	362.0	362.8	363.7	364.5	364.9	364.9	364.9



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	405.3	404.7	404.1	403.5	404.1	404.7	405.3	405.9	406.5	407.1	407.7
115°	471.6	470.8	470.0	469.2	470.0	470.8	471.6	472.3	472.8	473.1	473.4
117.5°	534.2	533.4	532.6	531.9	532.6	533.4	534.2	535.0	535.7	536.3	536.9
120°	578.3	577.5	576.7	575.9	576.7	577.5	578.3	579.1	579.5	579.5	579.5
122.5°	620.9	620.3	619.8	619.1	619.8	620.3	620.9	621.5	622.0	622.7	623.3
125°	685.8	685.6	685.3	685.1	685.3	685.6	685.8	686.1	686.6	687.4	688.2
127.5°	747.6	746.8	746.0	745.1	746.0	746.8	747.6	748.4	749.3	750.2	751.2
130°	791.4	790.3	789.3	788.3	789.3	790.3	791.4	792.4	793.2	793.8	794.3
132.5°	832.1	831.2	830.4	829.6	830.4	831.2	832.1	832.9	833.9	835.1	836.2
135°	896.2	895.4	894.6	893.8	894.6	895.4	896.2	897.0	897.5	897.8	898.1
137.5°	955.1	954.1	953.1	952.0	953.1	954.1	955.1	956.2	956.8	957.0	957.3
140°	995.5	994.5	993.4	992.4	993.4	994.5	995.5	996.5	997.0	997.0	997.0
142.5°	1032.1	1031.1	1030.1	1029.0	1030.1	1031.1	1032.1	1033.2	1033.6	1033.4	1033.2
145°	1087.0	1086.0	1084.9	1083.9	1084.9	1086.0	1087.0	1088.0	1088.4	1088.2	1087.9
147.5°	1135.9	1134.9	1133.9	1133.0	1133.9	1134.9	1135.9	1136.9	1137.1	1136.5	1136.0
150°	1167.2	1166.4	1165.6	1164.9	1165.6	1166.4	1167.2	1168.0	1168.0	1167.2	1166.4
152.5°	1197.8	1196.9	1195.9	1194.9	1195.9	1196.9	1197.8	1198.8	1198.8	1197.8	1196.9
155°	1237.6	1236.8	1236.0	1235.2	1236.0	1236.8	1237.6	1238.3	1238.1	1236.8	1235.5
157.5°	1273.6	1272.4	1271.2	1269.9	1271.2	1272.4	1273.6	1275.0	1274.7	1272.9	1271.1
160°	1294.6	1293.6	1292.5	1291.5	1292.5	1293.6	1294.6	1295.7	1295.5	1293.8	1292.3
162.5°	1314.0	1312.8	1311.5	1310.3	1311.5	1312.8	1314.0	1315.2	1315.0	1313.2	1311.5
165°	1338.9	1337.6	1336.3	1334.9	1336.3	1337.6	1338.9	1340.1	1339.9	1338.1	1336.3
167.5°	1359.2	1357.8	1356.5	1355.1	1356.5	1357.8	1359.2	1360.5	1360.3	1358.5	1356.7
170°	1370.1	1368.6	1367.0	1365.4	1367.0	1368.6	1370.1	1371.7	1371.5	1369.7	1367.9
172.5°	1378.6	1377.0	1375.4	1373.8	1375.4	1377.0	1378.6	1380.1	1380.0	1378.2	1376.3
175°	1387.8	1386.1	1384.6	1383.0	1384.6	1386.1	1387.8	1389.3	1389.2	1387.4	1385.5
177.5°	1391.0	1389.8	1388.5	1387.3	1388.5	1389.8	1391.0	1392.2	1392.2	1391.0	1389.8
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	1935.1	1941.9	1952.5	1963.6	1970.3	1983.4	1987.1	1993.3	1998.8	2011.9	2025.5
5°	1823.3	1834.2	1859.7	1873.6	1893.0	1915.4	1930.2	1945.6	1962.7	1992.1	2019.1
7.5°	1703.5	1721.6	1753.3	1779.4	1807.0	1839.2	1862.3	1893.0	1918.3	1959.8	1999.4
10°	1623.7	1649.2	1677.9	1708.8	1747.5	1781.5	1814.0	1852.7	1883.7	1933.2	1979.6
12.5°	1551.9	1555.7	1596.7	1630.8	1683.7	1725.9	1763.3	1813.1	1843.4	1902.3	1951.2
15°	1426.3	1449.6	1486.7	1513.8	1576.5	1629.8	1682.4	1734.3	1769.2	1841.9	1906.1
17.5°	1320.6	1342.0	1380.1	1424.4	1469.5	1522.6	1590.7	1645.4	1692.7	1775.8	1851.8
20°	1253.7	1280.0	1318.8	1364.4	1403.9	1461.9	1520.8	1583.5	1634.5	1728.2	1817.2
22.5°	1196.8	1217.5	1248.8	1293.8	1337.0	1390.1	1454.5	1522.8	1576.3	1677.4	1767.6
25°	1116.7	1133.8	1153.9	1191.0	1239.8	1297.9	1348.2	1423.2	1501.4	1595.8	1705.0
27.5°	1044.6	1056.7	1074.5	1107.1	1144.9	1199.2	1255.2	1326.4	1404.9	1507.4	1622.6
30°	1000.7	1008.5	1026.2	1053.3	1090.5	1133.0	1189.5	1257.6	1338.1	1441.8	1556.3
32.5°	962.3	969.4	981.0	1006.8	1039.1	1075.4	1126.3	1194.5	1271.2	1373.1	1500.0
35°	904.7	910.1	920.2	941.1	958.9	994.5	1037.0	1098.9	1170.9	1268.5	1400.0
37.5°	847.3	854.7	860.9	869.7	892.6	916.0	953.0	1005.3	1075.9	1174.4	1299.7
40°	809.5	815.7	825.0	828.9	847.5	868.3	898.5	946.4	1017.7	1107.4	1229.7
42.5°	771.1	777.3	782.8	787.4	803.4	821.9	849.0	890.2	953.3	1040.6	1161.6
45°	718.9	719.7	725.2	733.7	741.4	754.6	774.0	809.5	858.3	940.3	1050.2
47.5°	666.0	666.9	667.9	671.6	680.1	692.1	704.9	733.9	777.5	842.9	949.9
50°	630.8	629.1	630.8	633.8	639.2	649.3	664.0	684.9	720.5	781.6	879.9
52.5°	596.7	596.4	595.4	596.7	600.9	607.8	618.2	636.0	667.9	724.1	810.6
55°	544.8	541.0	541.7	538.7	545.6	547.1	554.9	569.6	597.4	636.1	717.4
57.5°	489.6	486.4	482.9	482.0	481.4	485.5	491.7	503.3	524.7	558.7	624.5
60°	454.2	450.4	445.8	444.2	444.2	446.6	449.7	458.2	478.3	508.5	562.6
62.5°	418.4	413.8	411.1	407.1	405.9	408.2	411.2	417.3	431.8	460.2	507.0
65°	362.9	357.6	353.7	352.9	351.3	349.0	350.6	356.8	368.4	390.8	428.0
67.5°	307.4	302.3	301.3	296.9	294.7	295.0	294.7	299.9	306.9	326.3	354.0
70°	270.8	267.0	265.5	261.6	260.0	258.5	256.9	261.6	268.5	284.8	308.8
72.5°	233.7	230.5	227.0	223.8	224.1	222.6	222.3	225.1	230.8	245.8	264.2
75°	180.4	181.1	177.2	173.4	172.6	171.1	171.1	173.4	175.7	187.3	202.0
77.5°	130.8	130.2	126.9	125.7	124.9	123.2	124.9	126.4	127.6	135.4	146.2
80°	99.9	99.9	95.9	95.9	95.2	92.9	95.2	93.6	96.7	104.5	112.2
82.5°	71.4	70.1	70.0	68.8	68.6	66.9	68.0	69.5	70.7	76.0	80.7
85°	34.8	34.8	34.0	33.3	34.0	33.3	34.0	34.8	35.6	38.0	41.8
87.5°	15.6	16.3	15.8	15.2	14.0	13.5	13.2	13.2	13.8	13.8	13.8
90°	40.5	41.1	35.3	29.6	23.8	18.1	13.7	10.6	7.5	4.3	1.2
92.5°	37.4	37.3	36.0	34.6	33.2	31.9	30.1	27.8	25.4	23.1	20.9
95°	75.0	75.0	74.5	74.0	73.5	73.0	71.4	68.8	66.2	63.6	61.0
97.5°	126.2	126.2	125.2	124.2	123.2	122.3	120.6	118.4	116.0	113.7	111.5
100°	161.9	161.9	161.1	160.3	159.6	158.8	157.3	155.2	153.2	151.1	149.0
102.5°	200.6	200.4	199.3	198.3	197.4	196.4	195.1	193.4	191.8	190.1	188.4
105°	258.6	258.0	257.5	257.0	256.5	256.0	255.3	254.6	253.8	253.0	252.2
107.5°	321.8	321.6	321.6	321.6	321.6	321.6	321.0	319.9	318.8	317.6	316.5
110°	364.9	364.9	364.9	364.9	364.9	364.9	364.1	362.4	360.9	359.3	357.8



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	408.3	408.9	409.1	409.3	409.5	409.8	409.1	407.5	406.0	404.3	402.8
115°	473.6	473.9	474.4	474.9	475.4	475.9	475.4	473.9	472.3	470.8	469.2
117.5°	537.6	538.2	539.7	541.1	542.6	544.0	543.7	541.6	539.6	537.5	535.3
120°	579.5	579.5	581.6	583.7	585.7	587.8	587.8	585.7	583.7	581.6	579.5
122.5°	623.9	624.5	626.0	627.4	628.9	630.4	629.9	627.3	624.8	622.4	619.9
125°	688.9	689.7	690.5	691.4	692.1	692.9	692.1	689.7	687.4	685.1	682.7
127.5°	752.1	753.1	754.1	755.0	755.9	756.9	755.8	752.9	749.9	746.9	744.0
130°	794.8	795.4	795.9	796.4	796.9	797.4	796.0	792.5	789.2	785.8	782.4
132.5°	837.4	838.5	838.4	838.3	838.2	838.1	836.7	833.8	831.1	828.4	825.6
135°	898.3	898.6	898.1	897.5	897.0	896.5	894.7	891.9	889.1	886.2	883.3
137.5°	957.5	957.7	956.9	956.3	955.6	954.9	953.4	951.1	948.8	946.4	944.0
140°	997.0	997.0	995.8	994.5	993.2	991.9	990.1	987.7	985.3	983.0	980.7
142.5°	1033.0	1032.8	1031.9	1031.0	1030.1	1029.2	1027.5	1025.2	1022.9	1020.6	1018.2
145°	1087.6	1087.4	1085.8	1084.3	1082.7	1081.2	1079.4	1077.6	1075.8	1074.0	1072.2
147.5°	1135.4	1134.8	1133.8	1132.8	1131.7	1130.6	1129.0	1126.8	1124.6	1122.5	1120.2
150°	1165.6	1164.9	1163.8	1162.8	1161.7	1160.6	1159.3	1157.8	1156.2	1154.7	1153.1
152.5°	1195.9	1194.9	1193.7	1192.3	1191.1	1189.8	1188.4	1186.9	1185.3	1183.8	1182.1
155°	1234.2	1232.8	1232.1	1231.3	1230.5	1229.7	1229.0	1228.2	1227.4	1226.6	1225.9
157.5°	1269.4	1267.6	1267.1	1266.7	1266.2	1265.7	1265.3	1264.7	1264.1	1263.6	1263.1
160°	1290.7	1289.2	1288.9	1288.7	1288.4	1288.1	1287.8	1287.2	1286.7	1286.2	1285.7
162.5°	1309.7	1308.0	1307.7	1307.4	1307.2	1306.9	1306.8	1306.6	1306.5	1306.4	1306.3
165°	1334.4	1332.6	1332.6	1332.6	1332.6	1332.6	1332.7	1332.9	1333.2	1333.5	1333.7
167.5°	1354.8	1353.0	1353.0	1353.1	1353.1	1353.2	1353.6	1354.4	1355.1	1355.9	1356.8
170°	1366.0	1364.2	1364.5	1364.7	1365.0	1365.3	1365.8	1366.5	1367.4	1368.2	1369.0
172.5°	1374.5	1372.7	1372.9	1373.2	1373.5	1373.7	1374.2	1375.0	1375.8	1376.6	1377.4
175°	1383.7	1381.8	1382.4	1382.9	1383.4	1383.9	1384.6	1385.3	1386.1	1386.9	1387.8
177.5°	1388.5	1387.3	1387.7	1388.1	1388.5	1388.9	1389.5	1390.1	1390.7	1391.3	1391.9
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	2024.3	2027.3	2037.2	2047.2	2058.3	2061.4	2066.4	2062.0	2060.7	2072.5	2081.2
5°	2029.9	2043.9	2071.0	2095.8	2116.7	2131.3	2146.9	2153.0	2164.6	2180.9	2201.0
7.5°	2023.5	2050.5	2093.1	2129.2	2168.5	2196.9	2219.0	2237.9	2260.8	2291.6	2325.1
10°	2016.0	2052.4	2104.3	2148.4	2196.4	2232.7	2262.9	2292.3	2326.4	2368.9	2413.1
12.5°	2002.5	2045.6	2110.4	2162.6	2224.2	2260.0	2300.7	2364.2	2400.7	2459.9	2522.0
15°	1975.0	2023.0	2113.5	2177.8	2247.5	2315.5	2390.7	2450.9	2511.3	2546.2	2633.6
17.5°	1934.3	2004.8	2105.1	2180.0	2268.5	2375.7	2460.1	2528.5	2598.2	2654.6	2698.5
20°	1901.5	1978.1	2092.6	2182.4	2287.6	2403.0	2499.7	2569.4	2629.8	2677.0	2704.0
22.5°	1860.0	1956.4	2067.9	2173.1	2307.5	2421.6	2523.2	2578.1	2628.5	2651.6	2661.9
25°	1794.7	1910.8	2036.9	2165.5	2317.1	2437.8	2530.7	2563.9	2578.7	2556.3	2519.1
27.5°	1724.2	1853.7	2001.1	2150.8	2311.2	2427.3	2493.9	2488.6	2463.7	2391.1	2333.0
30°	1671.6	1814.0	1972.7	2136.0	2296.9	2409.9	2448.6	2409.9	2353.5	2272.2	2189.4
32.5°	1616.6	1763.9	1942.4	2115.0	2271.0	2370.4	2378.7	2312.2	2224.7	2132.3	2029.0
35°	1533.1	1692.5	1885.2	2067.9	2215.7	2278.4	2241.3	2123.6	2019.9	1893.8	1752.9
37.5°	1438.9	1614.9	1808.2	1999.0	2132.9	2149.3	2057.1	1933.2	1787.0	1638.7	1472.9
40°	1368.3	1554.8	1753.7	1946.4	2064.8	2047.8	1930.2	1793.9	1619.8	1438.7	1284.6
42.5°	1305.1	1491.7	1694.3	1883.2	1978.1	1931.4	1793.9	1626.8	1439.7	1269.1	1128.0
45°	1195.7	1387.7	1595.1	1777.7	1831.9	1747.5	1565.6	1379.9	1195.7	1053.3	941.9
47.5°	1089.5	1279.3	1484.7	1645.2	1664.4	1551.0	1352.2	1161.0	1002.7	886.8	808.1
50°	1011.5	1201.8	1405.4	1548.6	1542.4	1405.4	1201.1	1019.3	886.9	793.2	740.6
52.5°	941.5	1121.4	1316.9	1447.0	1414.2	1264.9	1069.9	908.4	799.6	726.4	678.7
55°	832.7	999.2	1184.9	1289.3	1229.0	1063.4	898.5	768.5	688.0	633.1	595.9
57.5°	724.7	880.7	1039.7	1104.1	1037.3	884.4	747.0	652.7	592.2	551.5	527.4
60°	657.8	794.1	935.6	991.4	911.7	775.5	667.1	582.8	534.0	500.7	479.1
62.5°	591.0	713.0	846.5	876.9	804.0	688.8	592.8	522.7	482.6	453.0	432.6
65°	500.0	599.8	701.1	721.2	654.0	564.9	489.1	443.4	407.9	386.2	369.9
67.5°	410.0	490.2	562.0	578.2	519.3	457.6	402.7	362.9	338.8	320.8	307.1
70°	356.8	420.2	479.1	492.2	445.0	390.0	348.3	316.5	294.9	279.4	266.2
72.5°	300.4	353.4	402.2	411.1	372.5	330.6	296.3	271.4	252.2	242.3	229.7
75°	229.8	260.8	298.7	301.0	275.5	249.9	223.7	207.4	197.3	185.0	178.7
77.5°	162.2	186.5	208.1	212.4	197.2	179.9	165.1	152.3	143.8	138.0	132.3
80°	123.8	143.2	152.5	157.8	147.0	134.6	126.1	117.6	112.2	108.4	104.5
82.5°	88.6	100.5	109.2	113.3	107.4	100.0	91.5	86.6	82.5	79.3	77.9
85°	44.8	50.3	55.7	57.3	55.7	52.6	48.0	48.0	45.6	44.8	44.8
87.5°	16.4	19.5	20.1	22.5	22.2	23.3	24.5	25.0	25.5	24.8	24.1
90°	4.3	7.5	10.6	13.7	18.1	23.8	29.6	35.3	41.1	40.5	40.0
92.5°	23.1	25.4	27.8	30.1	31.9	33.2	34.6	36.0	37.3	37.4	37.5
95°	63.6	66.2	68.8	71.4	73.0	73.5	74.0	74.5	75.0	75.0	75.0
97.5°	113.7	116.0	118.4	120.6	122.3	123.2	124.2	125.2	126.2	126.2	126.2
100°	151.1	153.2	155.2	157.3	158.8	159.6	160.3	161.1	161.9	161.9	161.9
102.5°	190.1	191.8	193.4	195.1	196.4	197.4	198.3	199.3	200.4	200.6	200.8
105°	253.0	253.8	254.6	255.3	256.0	256.5	257.0	257.5	258.0	258.6	259.1
107.5°	317.6	318.8	319.9	321.0	321.6	321.6	321.6	321.6	321.6	321.8	322.0
110°	359.3	360.9	362.4	364.1	364.9	364.9	364.9	364.9	364.9	364.9	364.9



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	404.3	406.0	407.5	409.1	409.8	409.5	409.3	409.1	408.9	408.3	407.7
115°	470.8	472.3	473.9	475.4	475.9	475.4	474.9	474.4	473.9	473.6	473.4
117.5°	537.5	539.6	541.6	543.7	544.0	542.6	541.1	539.7	538.2	537.6	536.9
120°	581.6	583.7	585.7	587.8	587.8	585.7	583.7	581.6	579.5	579.5	579.5
122.5°	622.4	624.8	627.3	629.9	630.4	628.9	627.4	626.0	624.5	623.9	623.3
125°	685.1	687.4	689.7	692.1	692.9	692.1	691.4	690.5	689.7	688.9	688.2
127.5°	746.9	749.9	752.9	755.8	756.9	755.9	755.0	754.1	753.1	752.1	751.2
130°	785.8	789.2	792.5	796.0	797.4	796.9	796.4	795.9	795.4	794.8	794.3
132.5°	828.4	831.1	833.8	836.7	838.1	838.2	838.3	838.4	838.5	837.4	836.2
135°	886.2	889.1	891.9	894.7	896.5	897.0	897.5	898.1	898.6	898.3	898.1
137.5°	946.4	948.8	951.1	953.4	954.9	955.6	956.3	956.9	957.7	957.5	957.3
140°	983.0	985.3	987.7	990.1	991.9	993.2	994.5	995.8	997.0	997.0	997.0
142.5°	1020.6	1022.9	1025.2	1027.5	1029.2	1030.1	1031.0	1031.9	1032.8	1033.0	1033.2
145°	1074.0	1075.8	1077.6	1079.4	1081.2	1082.7	1084.3	1085.8	1087.4	1087.6	1087.9
147.5°	1122.5	1124.6	1126.8	1129.0	1130.6	1131.7	1132.8	1133.8	1134.8	1135.4	1136.0
150°	1154.7	1156.2	1157.8	1159.3	1160.6	1161.7	1162.8	1163.8	1164.9	1165.6	1166.4
152.5°	1183.8	1185.3	1186.9	1188.4	1189.8	1191.1	1192.3	1193.7	1194.9	1195.9	1196.9
155°	1226.6	1227.4	1228.2	1229.0	1229.7	1230.5	1231.3	1232.1	1232.8	1234.2	1235.5
157.5°	1263.6	1264.1	1264.7	1265.3	1265.7	1266.2	1266.7	1267.1	1267.6	1269.4	1271.1
160°	1286.2	1286.7	1287.2	1287.8	1288.1	1288.4	1288.7	1288.9	1289.2	1290.7	1292.3
162.5°	1306.4	1306.5	1306.6	1306.8	1306.9	1307.2	1307.4	1307.7	1308.0	1309.7	1311.5
165°	1333.5	1333.2	1332.9	1332.7	1332.6	1332.6	1332.6	1332.6	1332.6	1334.4	1336.3
167.5°	1355.9	1355.1	1354.4	1353.6	1353.2	1353.1	1353.1	1353.0	1353.0	1354.8	1356.7
170°	1368.2	1367.4	1366.5	1365.8	1365.3	1365.0	1364.7	1364.5	1364.2	1366.0	1367.9
172.5°	1376.6	1375.8	1375.0	1374.2	1373.7	1373.5	1373.2	1372.9	1372.7	1374.5	1376.3
175°	1386.9	1386.1	1385.3	1384.6	1383.9	1383.4	1382.9	1382.4	1381.8	1383.7	1385.5
177.5°	1391.3	1390.7	1390.1	1389.5	1388.9	1388.5	1388.1	1387.7	1387.3	1388.5	1389.8
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
0°	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7	2013.7
2.5°	2088.6	2097.3	2097.3	2098.5	2108.4	2107.2	2106.6
5°	2222.7	2235.8	2237.4	2251.3	2260.6	2257.5	2249.0
7.5°	2349.1	2373.6	2392.2	2402.6	2414.8	2422.4	2418.9
10°	2449.4	2485.1	2506.7	2521.4	2539.2	2552.3	2547.7
12.5°	2540.4	2582.8	2612.6	2637.8	2640.1	2657.0	2645.5
15°	2682.4	2727.2	2731.9	2750.5	2765.2	2763.6	2764.4
17.5°	2729.3	2743.7	2746.6	2747.0	2747.2	2741.8	2730.1
20°	2712.6	2707.1	2694.0	2683.9	2666.1	2663.8	2648.4
22.5°	2633.3	2616.2	2583.1	2561.3	2533.7	2526.4	2522.0
25°	2477.3	2439.3	2386.7	2336.4	2322.5	2295.4	2303.2
27.5°	2263.2	2204.1	2147.2	2106.3	2069.3	2028.7	2040.3
30°	2112.7	2046.2	1965.7	1903.8	1864.3	1825.6	1818.7
32.5°	1933.2	1835.7	1746.0	1691.4	1630.9	1606.5	1579.7
35°	1623.7	1528.4	1439.5	1362.8	1318.8	1284.6	1253.7
37.5°	1345.2	1235.7	1163.8	1101.8	1069.9	1050.4	1055.3
40°	1172.5	1076.5	1023.9	976.6	947.3	933.3	936.4
42.5°	1032.6	960.7	917.4	885.0	864.3	856.6	854.7
45°	873.7	833.5	797.9	779.3	769.3	760.7	755.4
47.5°	765.4	732.6	712.5	701.5	692.7	684.0	683.8
50°	700.3	678.7	664.8	653.2	646.2	640.1	645.4
52.5°	650.9	631.1	617.1	606.7	604.1	598.5	598.3
55°	577.3	561.9	551.8	542.5	537.9	534.7	530.9
57.5°	510.5	495.7	486.5	480.6	471.8	468.7	467.5
60°	462.8	451.2	441.9	434.1	430.3	424.1	424.1
62.5°	418.8	407.3	398.6	392.6	386.4	383.8	384.5
65°	355.3	346.0	337.4	331.2	329.7	325.1	326.6
67.5°	296.7	290.5	281.6	278.1	275.2	272.8	270.8
70°	257.7	251.6	246.9	242.3	239.9	239.9	239.9
72.5°	224.9	217.4	214.7	208.8	210.2	207.7	205.2
75°	174.1	169.5	167.1	164.8	161.0	161.0	161.0
77.5°	128.2	126.7	124.0	121.5	120.6	119.8	120.1
80°	99.1	98.3	96.7	96.7	95.2	94.4	92.9
82.5°	76.1	74.1	73.2	72.6	72.3	72.1	71.8
85°	43.3	41.8	41.8	42.5	41.0	41.0	41.8
87.5°	24.6	24.5	23.8	23.9	24.5	24.0	24.0
90°	39.5	39.0	38.9	39.1	39.4	39.6	39.9
92.5°	37.6	37.8	37.8	37.9	37.9	38.0	38.0
95°	75.0	75.0	74.8	74.3	73.8	73.2	72.7
97.5°	126.2	126.2	126.2	126.1	126.1	126.0	126.0
100°	161.9	161.9	161.8	161.5	161.3	161.0	160.7
102.5°	201.0	201.2	201.2	200.9	200.7	200.4	200.2
105°	259.6	260.1	260.4	260.4	260.4	260.4	260.4
107.5°	322.2	322.4	321.9	320.8	319.6	318.4	317.2
110°	364.9	364.9	364.5	363.7	362.8	362.0	361.3



TEST NUMBER: P331457-840

CATALOG NUMBER: S122DIP-S1005D1080U840-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
112.5°	407.1	406.5	405.9	405.3	404.7	404.1	403.5
115°	473.1	472.8	472.3	471.6	470.8	470.0	469.2
117.5°	536.3	535.7	535.0	534.2	533.4	532.6	531.9
120°	579.5	579.5	579.1	578.3	577.5	576.7	575.9
122.5°	622.7	622.0	621.5	620.9	620.3	619.8	619.1
125°	687.4	686.6	686.1	685.8	685.6	685.3	685.1
127.5°	750.2	749.3	748.4	747.6	746.8	746.0	745.1
130°	793.8	793.2	792.4	791.4	790.3	789.3	788.3
132.5°	835.1	833.9	832.9	832.1	831.2	830.4	829.6
135°	897.8	897.5	897.0	896.2	895.4	894.6	893.8
137.5°	957.0	956.8	956.2	955.1	954.1	953.1	952.0
140°	997.0	997.0	996.5	995.5	994.5	993.4	992.4
142.5°	1033.4	1033.6	1033.2	1032.1	1031.1	1030.1	1029.0
145°	1088.2	1088.4	1088.0	1087.0	1086.0	1084.9	1083.9
147.5°	1136.5	1137.1	1136.9	1135.9	1134.9	1133.9	1133.0
150°	1167.2	1168.0	1168.0	1167.2	1166.4	1165.6	1164.9
152.5°	1197.8	1198.8	1198.8	1197.8	1196.9	1195.9	1194.9
155°	1236.8	1238.1	1238.3	1237.6	1236.8	1236.0	1235.2
157.5°	1272.9	1274.7	1275.0	1273.6	1272.4	1271.2	1269.9
160°	1293.8	1295.5	1295.7	1294.6	1293.6	1292.5	1291.5
162.5°	1313.2	1315.0	1315.2	1314.0	1312.8	1311.5	1310.3
165°	1338.1	1339.9	1340.1	1338.9	1337.6	1336.3	1334.9
167.5°	1358.5	1360.3	1360.5	1359.2	1357.8	1356.5	1355.1
170°	1369.7	1371.5	1371.7	1370.1	1368.6	1367.0	1365.4
172.5°	1378.2	1380.0	1380.1	1378.6	1377.0	1375.4	1373.8
175°	1387.4	1389.2	1389.3	1387.8	1386.1	1384.6	1383.0
177.5°	1391.0	1392.2	1392.2	1391.0	1389.8	1388.5	1387.3
180°	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1	1390.1

(END OF REPORT)