

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P332019-930

Luminaire Tested: **S123DIP-S1000D805U930-4F0-1E-UDD-A1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P332019-930
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-9,
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: NEO-RAY
Catalog Number: S123DIP-S1000D805U930-4F0-1E-UDD-A1
Description: DEFINE 3 DIRECT-INDIRECT PENDANT LED LUMINAIRE
DOWNLIGHT 1000 LUMENS PER FOOT, ASYMMETRIC DIFFUSER
UPLIGHT 805 LUMENS PER FOOT, FLUSH SATIN WHITE DIFFUSER
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5706.8 lumens
Efficiency: N/A
Efficacy: 104.9 lumens/watt
Spacing Criteria (0/90/45): 1.37 / 1.23 / 1.49
Luminous Opening: Rectangular (W 4' x L: 0.25' x H: 0')
CIE Type: Semi-Direct

Input Watts (W): 54.4
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P332019-930
CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

Luminous Intensity Polar Plot





TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	110	110	110	110	103	103	103	103	89	89	89	77	77	77	66	66	66	61
1	101	96	92	89	94	90	87	84	79	76	74	68	67	65	59	57	56	52
2	92	84	78	73	86	79	74	69	69	65	62	60	57	55	52	50	48	44
3	84	74	67	61	78	70	63	58	62	56	52	54	50	47	46	44	41	37
4	77	66	58	52	72	62	55	50	55	49	45	48	44	40	42	38	36	32
5	71	59	51	45	66	56	48	43	49	43	39	43	39	35	38	34	31	28
6	65	53	45	39	61	50	43	37	44	38	34	39	34	31	34	30	28	25
7	60	48	40	34	56	45	38	33	40	34	30	36	31	27	31	27	25	22
8	56	44	36	31	52	41	34	29	37	31	27	33	28	24	29	25	22	20
9	52	40	32	27	49	38	31	26	34	28	24	30	25	22	27	23	20	18
10	49	37	29	25	46	35	28	24	31	26	22	28	23	20	25	21	18	16

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	12326	12326	12326	12326
5°	14699	12379	10970	12379
10°	18398	12316	9908	12316
15°	22566	12217	9225	12217
20°	26882	12062	8782	12062
25°	28544	11873	8684	11873
30°	24467	11737	8730	11737
35°	17015	11540	8821	11540
40°	12816	11311	8793	11311
45°	10641	10971	8681	10971
50°	9532	10275	8602	10275
55°	8912	9526	8496	9526
60°	8359	8742	8409	8742
65°	7857	7969	8140	7969
70°	7371	7091	7751	7091
75°	6600	6209	7107	6209
80°	5777	5089	6118	5089
85°	4520	3693	4113	3693



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	112.8	2.0
10°-20°	361.7	6.3
20°-30°	607.1	10.6
30°-40°	687.4	12.0
40°-50°	616.4	10.8
50°-60°	497.4	8.7
60°-70°	346.6	6.1
70°-80°	182.2	3.2
80°-90°	47.0	0.8
90°-100°	52.9	0.9
100°-110°	158.2	2.8
110°-120°	269.1	4.7
120°-130°	354.0	6.2
130°-140°	397.9	7.0
140°-150°	391.1	6.9
150°-160°	329.2	5.8
160°-170°	219.2	3.8
170°-180°	76.7	1.3
0°-30°	1081.6	19.0
0°-40°	1768.9	31.0
0°-60°	2882.8	50.5
0°-90°	3458.6	60.6
90°-120°	480.2	8.4
90°-150°	1623.1	28.4
90°-180°	2248.0	39.4
0°-180°	5706.8	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1145	1145	1145	1145	1145	
5°	1360	1146	1015	1146	1360	141
15°	2025	1096	828	1096	2025	585
25°	2403	1000	731	1000	2403	1054
35°	1295	878	671	878	1295	841
45°	699	721	570	721	699	553
55°	475	508	453	508	475	426
65°	308	313	320	313	308	307
75°	159	149	171	149	159	170
85°	37	30	33	30	37	44
90°	19	1	19	1	19	11
95°	50	38	50	38	50	51
105°	152	143	152	143	152	161
115°	272	271	272	271	272	269
125°	392	396	392	396	392	350
135°	514	514	514	514	514	395
145°	624	624	624	624	624	390
155°	713	714	713	714	713	328
165°	776	778	776	778	776	219
175°	806	810	806	810	806	77
180°	812	812	812	812	812	



TEST NUMBER: P332019-930
 CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1215.2	1214.4	1212.1	1213.9	1210.4	1205.5	1205.0	1200.6	1187.7	1186.8	1183.3
5°	1360.4	1355.9	1355.4	1354.9	1347.0	1336.5	1316.5	1314.9	1288.3	1275.0	1258.8
7.5°	1548.3	1550.7	1542.5	1535.5	1511.7	1496.1	1474.6	1447.2	1414.5	1381.4	1359.3
10°	1683.3	1701.6	1678.9	1663.3	1648.9	1621.7	1590.1	1550.7	1511.3	1465.3	1430.3
12.5°	1828.0	1837.0	1832.4	1817.8	1795.4	1754.0	1697.9	1654.6	1618.3	1541.6	1510.6
15°	2025.0	2058.9	2037.3	1987.3	1988.4	1949.1	1875.8	1795.4	1752.6	1685.5	1594.0
17.5°	2235.0	2239.2	2230.0	2188.3	2160.6	2106.5	2038.9	1961.8	1875.3	1794.0	1697.0
20°	2346.8	2343.5	2324.1	2302.4	2254.7	2212.6	2138.8	2052.8	1941.8	1861.9	1756.0
22.5°	2409.0	2403.4	2394.2	2376.1	2336.4	2291.2	2224.9	2130.9	2025.3	1915.2	1792.8
25°	2403.4	2410.6	2411.7	2406.8	2392.9	2365.7	2313.5	2238.6	2133.2	1991.8	1864.2
27.5°	2185.9	2196.2	2225.8	2252.1	2281.5	2311.5	2307.5	2270.3	2192.3	2070.0	1914.1
30°	1968.5	1946.3	2001.2	2070.5	2117.7	2200.9	2247.5	2250.3	2206.4	2101.6	1949.5
32.5°	1666.6	1691.0	1715.3	1800.7	1903.7	1997.2	2089.9	2164.6	2173.2	2103.4	1970.4
35°	1294.9	1325.4	1369.8	1414.2	1525.2	1620.6	1783.7	1925.7	2038.9	2053.9	1972.3
37.5°	1043.5	1058.6	1086.6	1131.1	1203.7	1316.9	1443.1	1622.6	1786.6	1908.5	1913.8
40°	912.1	916.6	948.2	982.0	1040.8	1134.0	1247.7	1406.4	1602.8	1773.2	1844.2
42.5°	813.6	823.3	836.7	869.3	916.1	986.2	1091.9	1223.1	1403.1	1599.1	1738.1
45°	699.0	710.1	718.4	740.1	773.4	820.5	894.4	1014.2	1151.2	1353.7	1540.7
47.5°	623.4	624.3	630.5	646.8	669.4	704.8	757.0	834.0	959.8	1124.1	1316.0
50°	569.2	578.1	580.3	593.0	610.8	636.9	680.2	745.7	848.9	993.1	1169.5
52.5°	531.1	533.7	540.0	549.2	564.7	585.0	622.5	673.8	754.7	877.7	1039.9
55°	474.9	474.9	481.0	488.2	497.1	515.4	540.4	578.1	639.7	735.2	869.4
57.5°	423.0	425.7	430.1	432.3	439.9	451.9	472.8	501.4	547.4	620.9	727.6
60°	388.3	393.4	392.8	397.2	403.9	413.4	431.0	454.4	495.5	554.2	644.2
62.5°	358.2	357.8	357.8	363.1	369.7	378.7	390.3	410.4	445.3	497.4	574.0
65°	308.5	307.4	311.3	314.5	316.8	323.4	332.3	350.1	373.4	412.2	471.6
67.5°	264.3	261.1	263.2	264.3	268.1	273.3	281.6	292.6	311.1	342.3	387.0
70°	234.2	231.4	230.8	231.9	235.2	239.1	245.2	255.8	273.0	297.9	330.7
72.5°	203.1	201.1	201.1	203.5	205.0	207.6	211.9	221.6	235.2	254.0	284.5
75°	158.7	158.7	158.7	159.2	160.9	163.1	166.4	171.5	182.0	195.3	215.8
77.5°	119.0	118.9	118.1	118.1	120.5	121.5	122.3	126.9	132.8	141.8	156.8
80°	93.2	90.4	91.6	93.2	94.3	94.9	96.5	97.7	102.6	107.6	118.1
82.5°	69.2	66.9	67.1	69.7	69.9	70.4	72.2	73.7	75.6	80.1	85.8
85°	36.6	36.6	37.2	37.2	37.7	37.2	38.8	39.4	39.4	42.2	45.5
87.5°	17.1	16.2	16.6	17.0	16.5	16.8	17.1	17.5	17.9	18.2	18.3
90°	19.2	18.8	18.6	18.3	18.0	17.5	17.0	16.5	15.9	15.3	13.5
92.5°	25.8	25.9	26.1	26.3	26.4	26.3	25.8	25.4	24.9	24.5	23.4
95°	49.7	49.7	49.7	49.7	49.7	49.4	48.8	48.3	47.8	47.2	46.1
97.5°	76.5	76.6	76.6	76.6	76.7	76.4	75.7	75.1	74.4	73.8	73.0
100°	96.9	96.6	96.3	96.0	95.8	95.4	95.0	94.6	94.2	93.7	93.0
102.5°	117.8	117.9	117.9	118.0	118.1	117.8	117.4	117.0	116.6	116.2	115.2
105°	151.7	151.4	151.2	150.8	150.6	150.4	150.4	150.4	150.4	150.4	149.2
107.5°	187.0	187.2	187.4	187.5	187.7	187.6	187.1	186.6	186.2	185.7	185.2
110°	211.0	211.2	211.6	211.8	212.1	212.0	211.4	210.8	210.3	209.7	209.5



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	236.5	236.5	236.6	236.7	236.7	236.4	235.7	235.1	234.4	233.7	233.7
115°	271.6	271.7	271.8	272.0	272.1	272.1	272.0	271.8	271.7	271.6	271.8
117.5°	307.1	307.5	307.9	308.3	308.7	308.9	308.9	309.0	309.0	309.0	309.4
120°	332.1	332.4	332.6	333.0	333.2	333.5	333.6	333.7	333.9	334.0	334.8
122.5°	356.0	356.4	356.9	357.3	357.7	358.1	358.4	358.8	359.1	359.5	359.9
125°	392.0	392.6	393.1	393.7	394.3	394.8	395.4	396.0	396.6	397.1	397.4
127.5°	427.9	428.5	429.2	429.8	430.5	431.2	431.9	432.8	433.6	434.3	434.6
130°	451.3	452.3	453.3	454.3	455.3	456.1	456.6	457.2	457.7	458.3	458.8
132.5°	475.8	476.5	477.3	478.1	478.8	479.6	480.2	480.9	481.6	482.2	482.6
135°	513.8	514.0	514.4	514.6	514.9	515.4	515.9	516.5	517.1	517.6	517.7
137.5°	547.3	547.9	548.4	548.9	549.4	550.0	550.7	551.2	551.8	552.4	552.0
140°	569.2	570.2	571.2	572.2	573.2	573.7	573.9	574.1	574.2	574.3	574.2
142.5°	591.7	592.4	593.2	593.9	594.8	595.2	595.3	595.5	595.6	595.7	595.5
145°	624.0	624.6	625.2	625.7	626.3	626.6	626.8	627.0	627.1	627.2	626.8
147.5°	652.9	653.7	654.5	655.4	656.2	656.7	656.7	656.7	656.7	656.7	656.3
150°	671.2	672.1	672.9	673.8	674.7	675.1	675.1	675.1	675.1	675.1	674.7
152.5°	689.1	689.8	690.6	691.3	692.0	692.3	692.0	691.8	691.6	691.4	691.2
155°	713.3	714.3	715.3	716.2	717.2	717.5	716.9	716.3	715.8	715.2	715.1
157.5°	735.3	736.1	736.9	737.8	738.5	738.6	738.0	737.4	736.9	736.2	736.1
160°	749.6	750.2	750.7	751.3	751.9	751.8	751.1	750.4	749.7	749.0	749.0
162.5°	760.3	761.2	762.1	763.0	763.9	764.1	763.4	762.6	761.9	761.2	761.1
165°	775.8	776.7	777.7	778.8	779.8	779.8	778.9	778.1	777.2	776.4	776.4
167.5°	788.9	789.8	790.7	791.5	792.4	792.4	791.5	790.7	789.8	788.9	788.8
170°	795.5	796.5	797.5	798.5	799.5	799.5	798.5	797.5	796.5	795.5	795.5
172.5°	800.6	801.6	802.6	803.6	804.6	804.6	803.8	802.9	802.0	801.1	801.1
175°	806.3	807.3	808.4	809.3	810.3	810.4	809.5	808.7	807.9	807.0	807.0
177.5°	809.4	810.2	811.0	811.8	812.6	812.6	812.0	811.3	810.6	809.9	809.9
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1180.6	1177.0	1173.5	1167.3	1162.0	1154.5	1152.2	1149.6	1141.6	1134.5	1129.1
5°	1252.7	1239.4	1220.0	1202.2	1187.8	1168.4	1157.3	1145.7	1129.0	1114.0	1101.9
7.5°	1328.2	1302.0	1271.9	1239.2	1208.8	1179.5	1155.8	1134.8	1111.5	1089.4	1072.2
10°	1388.1	1350.4	1308.2	1262.7	1223.9	1186.2	1154.5	1126.8	1096.8	1070.7	1049.1
12.5°	1456.5	1400.5	1342.4	1287.1	1241.2	1188.9	1150.6	1115.2	1081.3	1049.9	1025.6
15°	1537.3	1466.3	1397.6	1321.5	1251.6	1186.2	1140.7	1096.3	1056.9	1024.7	993.7
17.5°	1611.0	1530.6	1439.9	1347.5	1263.1	1185.5	1121.9	1071.6	1022.4	983.0	952.0
20°	1652.8	1561.2	1458.6	1362.6	1269.4	1182.8	1113.0	1053.0	999.7	958.1	923.2
22.5°	1688.7	1581.6	1475.4	1372.8	1268.9	1175.7	1096.5	1034.9	977.1	936.4	899.2
25°	1726.0	1597.8	1491.3	1370.9	1255.0	1158.5	1069.7	999.7	942.1	894.4	856.1
27.5°	1757.9	1596.8	1470.3	1340.8	1233.0	1136.2	1041.5	966.5	905.2	853.4	814.6
30°	1779.2	1599.0	1448.6	1320.5	1211.7	1111.8	1019.7	944.3	880.0	827.2	790.6
32.5°	1792.6	1597.6	1428.6	1292.0	1177.9	1089.6	996.2	918.1	852.0	800.1	764.8
35°	1800.3	1587.9	1394.2	1233.3	1123.5	1037.5	959.3	878.2	808.9	760.7	720.7
37.5°	1784.8	1567.3	1354.3	1176.7	1056.5	971.8	906.0	837.0	770.6	717.5	683.1
40°	1760.4	1554.0	1323.2	1136.8	1010.3	928.7	872.7	805.0	739.6	689.1	656.9
42.5°	1713.8	1526.9	1289.1	1092.4	962.4	880.8	829.2	772.7	710.7	663.3	631.1
45°	1600.0	1468.0	1237.8	1025.8	891.5	807.2	761.7	720.7	664.6	618.6	590.8
47.5°	1442.3	1379.3	1163.7	955.6	817.7	736.5	689.3	656.2	615.3	578.1	551.5
50°	1332.6	1306.6	1113.5	907.7	768.4	689.1	643.6	613.6	584.2	547.1	522.6
52.5°	1206.2	1222.2	1054.9	857.9	718.3	640.3	597.5	573.6	546.9	516.4	495.1
55°	1028.1	1086.3	953.7	774.5	643.6	569.2	528.7	507.6	492.1	469.4	451.0
57.5°	861.3	935.4	844.3	688.5	570.2	506.1	467.2	444.3	434.3	422.4	408.0
60°	762.3	835.5	766.2	630.8	521.0	459.9	425.5	406.1	396.2	387.8	375.6
62.5°	674.0	748.1	689.8	572.3	472.5	416.0	386.0	367.0	359.3	355.0	344.5
65°	552.6	616.4	577.6	481.0	403.3	353.4	326.2	312.9	305.7	304.0	297.3
67.5°	449.7	498.3	470.0	399.0	337.9	294.7	271.7	260.3	254.8	254.2	249.2
70°	382.3	427.8	406.1	341.8	289.0	255.2	235.2	225.3	221.9	221.4	218.6
72.5°	329.9	361.6	344.4	290.7	250.0	219.2	204.6	194.2	190.4	191.2	189.3
75°	244.1	268.0	258.0	220.8	188.1	168.1	155.9	149.3	145.9	147.6	145.4
77.5°	175.6	190.8	181.7	156.0	135.8	121.4	112.4	108.3	105.3	105.2	104.2
80°	132.6	141.5	136.5	120.9	104.3	92.1	84.9	82.1	80.5	79.9	79.3
82.5°	94.4	102.0	96.1	85.4	74.1	66.8	62.7	59.0	57.8	58.1	57.6
85°	47.7	50.5	48.3	41.6	37.2	33.8	31.6	29.9	28.9	29.4	28.3
87.5°	18.8	18.8	17.1	15.0	13.9	12.2	12.0	10.8	10.2	10.4	10.3
90°	11.6	9.8	7.9	6.3	4.9	3.5	2.0	0.7	2.0	3.5	4.9
92.5°	22.4	21.4	20.3	19.2	18.3	17.4	16.4	15.4	16.4	17.4	18.3
95°	44.9	43.8	42.6	41.6	40.6	39.6	38.6	37.6	38.6	39.6	40.6
97.5°	72.2	71.3	70.5	69.8	69.0	68.2	67.5	66.8	67.5	68.2	69.0
100°	92.3	91.6	90.9	90.1	89.3	88.4	87.6	86.7	87.6	88.4	89.3
102.5°	114.3	113.3	112.4	111.7	111.2	110.6	110.1	109.7	110.1	110.6	111.2
105°	147.9	146.6	145.4	144.6	144.3	144.0	143.7	143.4	143.7	144.0	144.3
107.5°	184.7	184.3	183.7	183.4	183.2	183.0	182.9	182.7	182.9	183.0	183.2
110°	209.1	208.9	208.6	208.3	208.0	207.7	207.4	207.2	207.4	207.7	208.0



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	233.6	233.5	233.4	233.3	233.2	233.0	232.8	232.7	232.8	233.0	233.2
115°	272.1	272.4	272.7	272.6	272.1	271.7	271.3	270.9	271.3	271.7	272.1
117.5°	309.7	310.1	310.5	310.5	310.2	310.0	309.7	309.4	309.7	310.0	310.2
120°	335.4	336.1	336.9	336.8	335.9	335.1	334.2	333.4	334.2	335.1	335.9
122.5°	360.3	360.6	361.0	360.9	360.2	359.6	359.0	358.4	359.0	359.6	360.2
125°	397.7	397.9	398.3	398.2	397.8	397.3	396.9	396.5	396.9	397.3	397.8
127.5°	435.0	435.3	435.6	435.3	434.4	433.5	432.6	431.7	432.6	433.5	434.4
130°	459.2	459.6	460.0	459.7	458.5	457.4	456.2	455.1	456.2	457.4	458.5
132.5°	482.9	483.2	483.6	483.1	482.0	480.9	479.7	478.6	479.7	480.9	482.0
135°	517.9	518.0	518.2	517.8	517.0	516.1	515.3	514.4	515.3	516.1	517.0
137.5°	551.6	551.3	550.9	550.4	549.7	548.9	548.3	547.6	548.3	548.9	549.7
140°	574.1	573.9	573.7	573.3	572.7	571.9	571.2	570.5	571.2	571.9	572.7
142.5°	595.3	595.0	594.8	594.3	593.5	592.8	592.2	591.4	592.2	592.8	593.5
145°	626.4	626.0	625.5	625.2	624.9	624.6	624.4	624.0	624.4	624.6	624.9
147.5°	655.9	655.5	655.1	654.7	654.1	653.6	653.1	652.6	653.1	653.6	654.1
150°	674.5	674.2	673.9	673.6	673.4	673.0	672.8	672.5	672.8	673.0	673.4
152.5°	691.0	690.9	690.7	690.4	690.0	689.6	689.2	688.8	689.2	689.6	690.0
155°	714.9	714.8	714.6	714.5	714.5	714.5	714.5	714.5	714.5	714.5	714.5
157.5°	736.1	735.9	735.8	735.8	736.0	736.1	736.3	736.5	736.3	736.1	736.0
160°	749.0	749.0	749.0	749.1	749.4	749.7	750.0	750.2	750.0	749.7	749.4
162.5°	761.0	760.9	760.8	760.9	761.3	761.7	762.1	762.5	762.1	761.7	761.3
165°	776.4	776.4	776.4	776.6	777.1	777.5	777.9	778.3	777.9	777.5	777.1
167.5°	788.6	788.6	788.5	788.6	789.2	789.8	790.4	790.9	790.4	789.8	789.2
170°	795.5	795.5	795.5	795.8	796.4	797.0	797.5	798.1	797.5	797.0	796.4
172.5°	801.1	801.1	801.1	801.4	802.0	802.6	803.2	803.6	803.2	802.6	802.0
175°	807.0	807.0	807.0	807.3	807.9	808.5	808.9	809.5	808.9	808.5	807.9
177.5°	809.9	809.9	809.9	810.2	810.6	811.1	811.5	812.0	811.5	811.1	810.6
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930
 CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1126.0	1122.9	1118.5	1111.8	1106.5	1098.0	1098.0	1099.4	1099.4	1098.9	1098.0
5°	1091.8	1083.5	1073.6	1061.9	1049.7	1037.5	1035.3	1030.9	1027.5	1025.2	1022.5
7.5°	1055.8	1041.1	1026.5	1010.2	995.3	983.0	974.4	967.4	962.8	957.9	954.4
10°	1031.4	1013.1	995.9	978.7	959.8	944.9	935.4	928.7	923.7	919.3	917.1
12.5°	1002.5	981.5	962.6	946.2	925.6	910.2	901.2	898.1	892.3	882.9	878.0
15°	960.3	940.9	918.2	893.2	883.2	864.4	853.9	848.9	845.5	838.3	836.1
17.5°	924.3	898.9	873.3	854.8	836.2	820.9	815.0	808.8	804.4	798.5	796.7
20°	895.4	872.7	849.4	829.4	810.0	793.4	788.4	783.9	779.5	776.7	774.5
22.5°	866.2	843.4	824.1	805.4	784.7	773.8	768.4	763.5	760.4	758.6	756.3
25°	825.0	805.0	783.4	766.7	750.1	742.9	739.6	736.8	734.6	731.8	731.2
27.5°	788.1	766.4	748.9	733.4	721.4	715.3	712.2	710.8	711.3	712.2	712.9
30°	760.7	740.7	726.3	712.9	701.8	696.3	695.7	695.7	698.0	698.5	699.6
32.5°	735.3	718.9	704.5	691.6	683.2	679.4	681.5	681.5	683.3	684.8	686.7
35°	698.5	684.0	672.9	661.9	654.7	656.3	657.5	658.5	661.3	664.6	666.9
37.5°	663.3	650.8	639.3	630.6	627.3	630.2	632.9	635.3	638.5	641.0	643.3
40°	638.1	628.6	617.5	609.8	610.8	612.5	614.7	617.5	620.3	621.9	624.2
42.5°	614.5	604.6	596.2	589.8	591.3	593.5	594.8	596.2	599.4	602.4	603.7
45°	578.7	570.9	563.1	559.2	560.4	561.5	562.6	564.3	567.0	569.2	569.8
47.5°	538.3	533.0	527.7	524.0	525.7	525.3	526.8	530.3	531.2	532.5	535.6
50°	512.7	507.6	501.6	500.4	500.4	500.4	501.0	505.4	505.4	507.6	509.9
52.5°	484.2	481.0	477.1	475.2	474.3	474.3	476.5	478.8	479.7	482.8	485.0
55°	442.2	438.9	435.5	433.8	432.8	433.8	438.3	439.4	442.2	443.8	445.5
57.5°	398.4	395.8	393.1	392.2	392.0	393.5	395.9	399.3	399.9	405.0	407.6
60°	369.5	365.6	363.4	363.4	362.3	367.3	366.2	371.7	372.8	376.2	380.0
62.5°	339.7	334.5	333.6	333.6	335.3	336.6	338.2	340.6	343.6	347.7	350.7
65°	291.8	289.0	292.9	292.4	291.3	294.6	294.6	297.3	300.7	304.6	310.7
67.5°	246.5	245.0	245.3	245.3	247.0	248.9	250.5	252.9	256.9	261.0	265.0
70°	215.8	217.5	214.7	217.0	218.6	219.2	220.3	223.6	228.0	230.8	235.2
72.5°	186.1	186.0	186.3	187.2	188.8	189.9	190.9	194.8	199.6	201.9	205.5
75°	143.2	142.6	144.2	144.2	147.0	148.1	149.3	150.9	155.3	158.7	161.4
77.5°	104.5	105.2	104.8	106.7	106.0	106.2	109.7	111.3	111.8	118.3	119.8
80°	78.8	79.9	80.5	81.0	81.5	80.5	84.3	86.0	86.0	89.8	92.6
82.5°	56.6	57.2	58.7	59.3	59.4	60.5	60.8	62.0	63.3	65.1	68.6
85°	28.3	29.9	30.5	29.9	30.5	29.4	31.1	31.6	32.2	32.2	32.2
87.5°	10.1	10.9	10.8	11.7	11.6	12.4	12.5	11.7	11.8	13.3	11.6
90°	6.3	7.9	9.8	11.6	13.5	15.3	15.9	16.5	17.0	17.5	18.0
92.5°	19.2	20.3	21.4	22.4	23.4	24.5	24.9	25.4	25.8	26.3	26.4
95°	41.6	42.6	43.8	44.9	46.1	47.2	47.8	48.3	48.8	49.4	49.7
97.5°	69.8	70.5	71.3	72.2	73.0	73.8	74.4	75.1	75.7	76.4	76.7
100°	90.1	90.9	91.6	92.3	93.0	93.7	94.2	94.6	95.0	95.4	95.8
102.5°	111.7	112.4	113.3	114.3	115.2	116.2	116.6	117.0	117.4	117.8	118.1
105°	144.6	145.4	146.6	147.9	149.2	150.4	150.4	150.4	150.4	150.4	150.6
107.5°	183.4	183.7	184.3	184.7	185.2	185.7	186.2	186.6	187.1	187.6	187.7
110°	208.3	208.6	208.9	209.1	209.5	209.7	210.3	210.8	211.4	212.0	212.1



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	233.3	233.4	233.5	233.6	233.7	233.7	234.4	235.1	235.7	236.4	236.7
115°	272.6	272.7	272.4	272.1	271.8	271.6	271.7	271.8	272.0	272.1	272.1
117.5°	310.5	310.5	310.1	309.7	309.4	309.0	309.0	309.0	308.9	308.9	308.7
120°	336.8	336.9	336.1	335.4	334.8	334.0	333.9	333.7	333.6	333.5	333.2
122.5°	360.9	361.0	360.6	360.3	359.9	359.5	359.1	358.8	358.4	358.1	357.7
125°	398.2	398.3	397.9	397.7	397.4	397.1	396.6	396.0	395.4	394.8	394.3
127.5°	435.3	435.6	435.3	435.0	434.6	434.3	433.6	432.8	431.9	431.2	430.5
130°	459.7	460.0	459.6	459.2	458.8	458.3	457.7	457.2	456.6	456.1	455.3
132.5°	483.1	483.6	483.2	482.9	482.6	482.2	481.6	480.9	480.2	479.6	478.8
135°	517.8	518.2	518.0	517.9	517.7	517.6	517.1	516.5	515.9	515.4	514.9
137.5°	550.4	550.9	551.3	551.6	552.0	552.4	551.8	551.2	550.7	550.0	549.4
140°	573.3	573.7	573.9	574.1	574.2	574.3	574.2	574.1	573.9	573.7	573.2
142.5°	594.3	594.8	595.0	595.3	595.5	595.7	595.6	595.5	595.3	595.2	594.8
145°	625.2	625.5	626.0	626.4	626.8	627.2	627.1	627.0	626.8	626.6	626.3
147.5°	654.7	655.1	655.5	655.9	656.3	656.7	656.7	656.7	656.7	656.7	656.2
150°	673.6	673.9	674.2	674.5	674.7	675.1	675.1	675.1	675.1	675.1	674.7
152.5°	690.4	690.7	690.9	691.0	691.2	691.4	691.6	691.8	692.0	692.3	692.0
155°	714.5	714.6	714.8	714.9	715.1	715.2	715.8	716.3	716.9	717.5	717.2
157.5°	735.8	735.8	735.9	736.1	736.1	736.2	736.9	737.4	738.0	738.6	738.5
160°	749.1	749.0	749.0	749.0	749.0	749.0	749.7	750.4	751.1	751.8	751.9
162.5°	760.9	760.8	760.9	761.0	761.1	761.2	761.9	762.6	763.4	764.1	763.9
165°	776.6	776.4	776.4	776.4	776.4	776.4	777.2	778.1	778.9	779.8	779.8
167.5°	788.6	788.5	788.6	788.6	788.8	788.9	789.8	790.7	791.5	792.4	792.4
170°	795.8	795.5	795.5	795.5	795.5	795.5	796.5	797.5	798.5	799.5	799.5
172.5°	801.4	801.1	801.1	801.1	801.1	801.1	802.0	802.9	803.8	804.6	804.6
175°	807.3	807.0	807.0	807.0	807.0	807.0	807.9	808.7	809.5	810.4	810.3
177.5°	810.2	809.9	809.9	809.9	809.9	809.9	810.6	811.3	812.0	812.6	812.6
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930
 CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1094.9	1094.5	1097.6	1095.4	1097.6	1094.5	1094.9	1098.0	1098.9	1099.4	1099.4
5°	1019.2	1020.8	1015.3	1015.3	1015.3	1020.8	1019.2	1022.5	1025.2	1027.5	1030.9
7.5°	951.7	949.3	949.5	946.5	949.5	949.3	951.7	954.4	957.9	962.8	967.4
10°	910.4	907.1	906.0	906.5	906.0	907.1	910.4	917.1	919.3	923.7	928.7
12.5°	876.3	875.6	868.3	868.4	868.3	875.6	876.3	878.0	882.9	892.3	898.1
15°	836.1	825.6	824.4	827.8	824.4	825.6	836.1	836.1	838.3	845.5	848.9
17.5°	795.8	790.3	790.6	789.0	790.6	790.3	795.8	796.7	798.5	804.4	808.8
20°	774.5	771.2	770.6	766.7	770.6	771.2	774.5	774.5	776.7	779.5	783.9
22.5°	755.0	753.9	754.2	749.9	754.2	753.9	755.0	756.3	758.6	760.4	763.5
25°	730.7	733.4	731.2	731.2	731.2	733.4	730.7	731.2	731.8	734.6	736.8
27.5°	714.3	714.1	713.1	713.1	713.1	714.1	714.3	712.9	712.2	711.3	710.8
30°	701.8	701.2	702.4	702.4	702.4	701.2	701.8	699.6	698.5	698.0	695.7
32.5°	689.4	690.2	690.4	690.8	690.4	690.2	689.4	686.7	684.8	683.3	681.5
35°	670.2	670.7	672.5	671.3	672.5	670.7	670.2	666.9	664.6	661.3	658.5
37.5°	644.2	646.8	646.2	647.1	646.2	646.8	644.2	643.3	641.0	638.5	635.3
40°	624.7	626.4	625.8	625.8	625.8	626.4	624.7	624.2	621.9	620.3	617.5
42.5°	604.7	605.9	604.5	603.6	604.5	605.9	604.7	603.7	602.4	599.4	596.2
45°	572.0	570.9	572.6	570.3	572.6	570.9	572.0	569.8	569.2	567.0	564.3
47.5°	535.4	536.5	537.0	538.6	537.0	536.5	535.4	535.6	532.5	531.2	530.3
50°	510.9	514.3	514.3	513.7	514.3	514.3	510.9	509.9	507.6	505.4	505.4
52.5°	487.0	488.5	490.8	490.6	490.8	488.5	487.0	485.0	482.8	479.7	478.8
55°	450.0	451.0	452.2	452.7	452.2	451.0	450.0	445.5	443.8	442.2	439.4
57.5°	411.6	411.1	413.8	414.6	413.8	411.1	411.6	407.6	405.0	399.9	399.3
60°	384.5	384.5	388.9	390.6	388.9	384.5	384.5	380.0	376.2	372.8	371.7
62.5°	355.6	357.4	361.8	359.5	361.8	357.4	355.6	350.7	347.7	343.6	340.6
65°	313.5	317.9	317.3	319.6	317.3	317.9	313.5	310.7	304.6	300.7	297.3
67.5°	269.4	272.1	276.1	276.5	276.1	272.1	269.4	265.0	261.0	256.9	252.9
70°	239.7	242.5	244.7	246.3	244.7	242.5	239.7	235.2	230.8	228.0	223.6
72.5°	210.8	212.3	217.6	215.2	217.6	212.3	210.8	205.5	201.9	199.6	194.8
75°	165.3	169.2	172.5	170.9	172.5	169.2	165.3	161.4	158.7	155.3	150.9
77.5°	122.3	126.1	127.7	126.3	127.7	126.1	122.3	119.8	118.3	111.8	111.3
80°	96.5	96.0	99.3	98.7	99.3	96.0	96.5	92.6	89.8	86.0	86.0
82.5°	70.8	70.3	71.8	72.2	71.8	70.3	70.8	68.6	65.1	63.3	62.0
85°	34.4	36.0	33.8	33.3	33.8	36.0	34.4	32.2	32.2	32.2	31.6
87.5°	11.7	11.7	11.3	10.9	11.3	11.7	11.7	11.6	13.3	11.8	11.7
90°	18.3	18.6	18.8	19.2	18.8	18.6	18.3	18.0	17.5	17.0	16.5
92.5°	26.3	26.1	25.9	25.8	25.9	26.1	26.3	26.4	26.3	25.8	25.4
95°	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.4	48.8	48.3
97.5°	76.6	76.6	76.6	76.5	76.6	76.6	76.6	76.7	76.4	75.7	75.1
100°	96.0	96.3	96.6	96.9	96.6	96.3	96.0	95.8	95.4	95.0	94.6
102.5°	118.0	117.9	117.9	117.8	117.9	117.9	118.0	118.1	117.8	117.4	117.0
105°	150.8	151.2	151.4	151.7	151.4	151.2	150.8	150.6	150.4	150.4	150.4
107.5°	187.5	187.4	187.2	187.0	187.2	187.4	187.5	187.7	187.6	187.1	186.6
110°	211.8	211.6	211.2	211.0	211.2	211.6	211.8	212.1	212.0	211.4	210.8



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	236.7	236.6	236.5	236.5	236.5	236.6	236.7	236.7	236.4	235.7	235.1
115°	272.0	271.8	271.7	271.6	271.7	271.8	272.0	272.1	272.1	272.0	271.8
117.5°	308.3	307.9	307.5	307.1	307.5	307.9	308.3	308.7	308.9	308.9	309.0
120°	333.0	332.6	332.4	332.1	332.4	332.6	333.0	333.2	333.5	333.6	333.7
122.5°	357.3	356.9	356.4	356.0	356.4	356.9	357.3	357.7	358.1	358.4	358.8
125°	393.7	393.1	392.6	392.0	392.6	393.1	393.7	394.3	394.8	395.4	396.0
127.5°	429.8	429.2	428.5	427.9	428.5	429.2	429.8	430.5	431.2	431.9	432.8
130°	454.3	453.3	452.3	451.3	452.3	453.3	454.3	455.3	456.1	456.6	457.2
132.5°	478.1	477.3	476.5	475.8	476.5	477.3	478.1	478.8	479.6	480.2	480.9
135°	514.6	514.4	514.0	513.8	514.0	514.4	514.6	514.9	515.4	515.9	516.5
137.5°	548.9	548.4	547.9	547.3	547.9	548.4	548.9	549.4	550.0	550.7	551.2
140°	572.2	571.2	570.2	569.2	570.2	571.2	572.2	573.2	573.7	573.9	574.1
142.5°	593.9	593.2	592.4	591.7	592.4	593.2	593.9	594.8	595.2	595.3	595.5
145°	625.7	625.2	624.6	624.0	624.6	625.2	625.7	626.3	626.6	626.8	627.0
147.5°	655.4	654.5	653.7	652.9	653.7	654.5	655.4	656.2	656.7	656.7	656.7
150°	673.8	672.9	672.1	671.2	672.1	672.9	673.8	674.7	675.1	675.1	675.1
152.5°	691.3	690.6	689.8	689.1	689.8	690.6	691.3	692.0	692.3	692.0	691.8
155°	716.2	715.3	714.3	713.3	714.3	715.3	716.2	717.2	717.5	716.9	716.3
157.5°	737.8	736.9	736.1	735.3	736.1	736.9	737.8	738.5	738.6	738.0	737.4
160°	751.3	750.7	750.2	749.6	750.2	750.7	751.3	751.9	751.8	751.1	750.4
162.5°	763.0	762.1	761.2	760.3	761.2	762.1	763.0	763.9	764.1	763.4	762.6
165°	778.8	777.7	776.7	775.8	776.7	777.7	778.8	779.8	779.8	778.9	778.1
167.5°	791.5	790.7	789.8	788.9	789.8	790.7	791.5	792.4	792.4	791.5	790.7
170°	798.5	797.5	796.5	795.5	796.5	797.5	798.5	799.5	799.5	798.5	797.5
172.5°	803.6	802.6	801.6	800.6	801.6	802.6	803.6	804.6	804.6	803.8	802.9
175°	809.3	808.4	807.3	806.3	807.3	808.4	809.3	810.3	810.4	809.5	808.7
177.5°	811.8	811.0	810.2	809.4	810.2	811.0	811.8	812.6	812.6	812.0	811.3
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1098.0	1098.0	1106.5	1111.8	1118.5	1122.9	1126.0	1129.1	1134.5	1141.6	1149.6
5°	1035.3	1037.5	1049.7	1061.9	1073.6	1083.5	1091.8	1101.9	1114.0	1129.0	1145.7
7.5°	974.4	983.0	995.3	1010.2	1026.5	1041.1	1055.8	1072.2	1089.4	1111.5	1134.8
10°	935.4	944.9	959.8	978.7	995.9	1013.1	1031.4	1049.1	1070.7	1096.8	1126.8
12.5°	901.2	910.2	925.6	946.2	962.6	981.5	1002.5	1025.6	1049.9	1081.3	1115.2
15°	853.9	864.4	883.2	893.2	918.2	940.9	960.3	993.7	1024.7	1056.9	1096.3
17.5°	815.0	820.9	836.2	854.8	873.3	898.9	924.3	952.0	983.0	1022.4	1071.6
20°	788.4	793.4	810.0	829.4	849.4	872.7	895.4	923.2	958.1	999.7	1053.0
22.5°	768.4	773.8	784.7	805.4	824.1	843.4	866.2	899.2	936.4	977.1	1034.9
25°	739.6	742.9	750.1	766.7	783.4	805.0	825.0	856.1	894.4	942.1	999.7
27.5°	712.2	715.3	721.4	733.4	748.9	766.4	788.1	814.6	853.4	905.2	966.5
30°	695.7	696.3	701.8	712.9	726.3	740.7	760.7	790.6	827.2	880.0	944.3
32.5°	681.5	679.4	683.2	691.6	704.5	718.9	735.3	764.8	800.1	852.0	918.1
35°	657.5	656.3	654.7	661.9	672.9	684.0	698.5	720.7	760.7	808.9	878.2
37.5°	632.9	630.2	627.3	630.6	639.3	650.8	663.3	683.1	717.5	770.6	837.0
40°	614.7	612.5	610.8	609.8	617.5	628.6	638.1	656.9	689.1	739.6	805.0
42.5°	594.8	593.5	591.3	589.8	596.2	604.6	614.5	631.1	663.3	710.7	772.7
45°	562.6	561.5	560.4	559.2	563.1	570.9	578.7	590.8	618.6	664.6	720.7
47.5°	526.8	525.3	525.7	524.0	527.7	533.0	538.3	551.5	578.1	615.3	656.2
50°	501.0	500.4	500.4	500.4	501.6	507.6	512.7	522.6	547.1	584.2	613.6
52.5°	476.5	474.3	474.3	475.2	477.1	481.0	484.2	495.1	516.4	546.9	573.6
55°	438.3	433.8	432.8	433.8	435.5	438.9	442.2	451.0	469.4	492.1	507.6
57.5°	395.9	393.5	392.0	392.2	393.1	395.8	398.4	408.0	422.4	434.3	444.3
60°	366.2	367.3	362.3	363.4	363.4	365.6	369.5	375.6	387.8	396.2	406.1
62.5°	338.2	336.6	335.3	333.6	333.6	334.5	339.7	344.5	355.0	359.3	367.0
65°	294.6	294.6	291.3	292.4	292.9	289.0	291.8	297.3	304.0	305.7	312.9
67.5°	250.5	248.9	247.0	245.3	245.3	245.0	246.5	249.2	254.2	254.8	260.3
70°	220.3	219.2	218.6	217.0	214.7	217.5	215.8	218.6	221.4	221.9	225.3
72.5°	190.9	189.9	188.8	187.2	186.3	186.0	186.1	189.3	191.2	190.4	194.2
75°	149.3	148.1	147.0	144.2	144.2	142.6	143.2	145.4	147.6	145.9	149.3
77.5°	109.7	106.2	106.0	106.7	104.8	105.2	104.5	104.2	105.2	105.3	108.3
80°	84.3	80.5	81.5	81.0	80.5	79.9	78.8	79.3	79.9	80.5	82.1
82.5°	60.8	60.5	59.4	59.3	58.7	57.2	56.6	57.6	58.1	57.8	59.0
85°	31.1	29.4	30.5	29.9	30.5	29.9	28.3	28.3	29.4	28.9	29.9
87.5°	12.5	12.4	11.6	11.7	10.8	10.9	10.1	10.3	10.4	10.2	10.8
90°	15.9	15.3	13.5	11.6	9.8	7.9	6.3	4.9	3.5	2.0	0.7
92.5°	24.9	24.5	23.4	22.4	21.4	20.3	19.2	18.3	17.4	16.4	15.4
95°	47.8	47.2	46.1	44.9	43.8	42.6	41.6	40.6	39.6	38.6	37.6
97.5°	74.4	73.8	73.0	72.2	71.3	70.5	69.8	69.0	68.2	67.5	66.8
100°	94.2	93.7	93.0	92.3	91.6	90.9	90.1	89.3	88.4	87.6	86.7
102.5°	116.6	116.2	115.2	114.3	113.3	112.4	111.7	111.2	110.6	110.1	109.7
105°	150.4	150.4	149.2	147.9	146.6	145.4	144.6	144.3	144.0	143.7	143.4
107.5°	186.2	185.7	185.2	184.7	184.3	183.7	183.4	183.2	183.0	182.9	182.7
110°	210.3	209.7	209.5	209.1	208.9	208.6	208.3	208.0	207.7	207.4	207.2



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	234.4	233.7	233.7	233.6	233.5	233.4	233.3	233.2	233.0	232.8	232.7
115°	271.7	271.6	271.8	272.1	272.4	272.7	272.6	272.1	271.7	271.3	270.9
117.5°	309.0	309.0	309.4	309.7	310.1	310.5	310.5	310.2	310.0	309.7	309.4
120°	333.9	334.0	334.8	335.4	336.1	336.9	336.8	335.9	335.1	334.2	333.4
122.5°	359.1	359.5	359.9	360.3	360.6	361.0	360.9	360.2	359.6	359.0	358.4
125°	396.6	397.1	397.4	397.7	397.9	398.3	398.2	397.8	397.3	396.9	396.5
127.5°	433.6	434.3	434.6	435.0	435.3	435.6	435.3	434.4	433.5	432.6	431.7
130°	457.7	458.3	458.8	459.2	459.6	460.0	459.7	458.5	457.4	456.2	455.1
132.5°	481.6	482.2	482.6	482.9	483.2	483.6	483.1	482.0	480.9	479.7	478.6
135°	517.1	517.6	517.7	517.9	518.0	518.2	517.8	517.0	516.1	515.3	514.4
137.5°	551.8	552.4	552.0	551.6	551.3	550.9	550.4	549.7	548.9	548.3	547.6
140°	574.2	574.3	574.2	574.1	573.9	573.7	573.3	572.7	571.9	571.2	570.5
142.5°	595.6	595.7	595.5	595.3	595.0	594.8	594.3	593.5	592.8	592.2	591.4
145°	627.1	627.2	626.8	626.4	626.0	625.5	625.2	624.9	624.6	624.4	624.0
147.5°	656.7	656.7	656.3	655.9	655.5	655.1	654.7	654.1	653.6	653.1	652.6
150°	675.1	675.1	674.7	674.5	674.2	673.9	673.6	673.4	673.0	672.8	672.5
152.5°	691.6	691.4	691.2	691.0	690.9	690.7	690.4	690.0	689.6	689.2	688.8
155°	715.8	715.2	715.1	714.9	714.8	714.6	714.5	714.5	714.5	714.5	714.5
157.5°	736.9	736.2	736.1	736.1	735.9	735.8	735.8	736.0	736.1	736.3	736.5
160°	749.7	749.0	749.0	749.0	749.0	749.0	749.1	749.4	749.7	750.0	750.2
162.5°	761.9	761.2	761.1	761.0	760.9	760.8	760.9	761.3	761.7	762.1	762.5
165°	777.2	776.4	776.4	776.4	776.4	776.4	776.6	777.1	777.5	777.9	778.3
167.5°	789.8	788.9	788.8	788.6	788.6	788.5	788.6	789.2	789.8	790.4	790.9
170°	796.5	795.5	795.5	795.5	795.5	795.5	795.8	796.4	797.0	797.5	798.1
172.5°	802.0	801.1	801.1	801.1	801.1	801.1	801.4	802.0	802.6	803.2	803.6
175°	807.9	807.0	807.0	807.0	807.0	807.0	807.3	807.9	808.5	808.9	809.5
177.5°	810.6	809.9	809.9	809.9	809.9	809.9	810.2	810.6	811.1	811.5	812.0
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930
 CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1152.2	1154.5	1162.0	1167.3	1173.5	1177.0	1180.6	1183.3	1186.8	1187.7	1200.6
5°	1157.3	1168.4	1187.8	1202.2	1220.0	1239.4	1252.7	1258.8	1275.0	1288.3	1314.9
7.5°	1155.8	1179.5	1208.8	1239.2	1271.9	1302.0	1328.2	1359.3	1381.4	1414.5	1447.2
10°	1154.5	1186.2	1223.9	1262.7	1308.2	1350.4	1388.1	1430.3	1465.3	1511.3	1550.7
12.5°	1150.6	1188.9	1241.2	1287.1	1342.4	1400.5	1456.5	1510.6	1541.6	1618.3	1654.6
15°	1140.7	1186.2	1251.6	1321.5	1397.6	1466.3	1537.3	1594.0	1685.5	1752.6	1795.4
17.5°	1121.9	1185.5	1263.1	1347.5	1439.9	1530.6	1611.0	1697.0	1794.0	1875.3	1961.8
20°	1113.0	1182.8	1269.4	1362.6	1458.6	1561.2	1652.8	1756.0	1861.9	1941.8	2052.8
22.5°	1096.5	1175.7	1268.9	1372.8	1475.4	1581.6	1688.7	1792.8	1915.2	2025.3	2130.9
25°	1069.7	1158.5	1255.0	1370.9	1491.3	1597.8	1726.0	1864.2	1991.8	2133.2	2238.6
27.5°	1041.5	1136.2	1233.0	1340.8	1470.3	1596.8	1757.9	1914.1	2070.0	2192.3	2270.3
30°	1019.7	1111.8	1211.7	1320.5	1448.6	1599.0	1779.2	1949.5	2101.6	2206.4	2250.3
32.5°	996.2	1089.6	1177.9	1292.0	1428.6	1597.6	1792.6	1970.4	2103.4	2173.2	2164.6
35°	959.3	1037.5	1123.5	1233.3	1394.2	1587.9	1800.3	1972.3	2053.9	2038.9	1925.7
37.5°	906.0	971.8	1056.5	1176.7	1354.3	1567.3	1784.8	1913.8	1908.5	1786.6	1622.6
40°	872.7	928.7	1010.3	1136.8	1323.2	1554.0	1760.4	1844.2	1773.2	1602.8	1406.4
42.5°	829.2	880.8	962.4	1092.4	1289.1	1526.9	1713.8	1738.1	1599.1	1403.1	1223.1
45°	761.7	807.2	891.5	1025.8	1237.8	1468.0	1600.0	1540.7	1353.7	1151.2	1014.2
47.5°	689.3	736.5	817.7	955.6	1163.7	1379.3	1442.3	1316.0	1124.1	959.8	834.0
50°	643.6	689.1	768.4	907.7	1113.5	1306.6	1332.6	1169.5	993.1	848.9	745.7
52.5°	597.5	640.3	718.3	857.9	1054.9	1222.2	1206.2	1039.9	877.7	754.7	673.8
55°	528.7	569.2	643.6	774.5	953.7	1086.3	1028.1	869.4	735.2	639.7	578.1
57.5°	467.2	506.1	570.2	688.5	844.3	935.4	861.3	727.6	620.9	547.4	501.4
60°	425.5	459.9	521.0	630.8	766.2	835.5	762.3	644.2	554.2	495.5	454.4
62.5°	386.0	416.0	472.5	572.3	689.8	748.1	674.0	574.0	497.4	445.3	410.4
65°	326.2	353.4	403.3	481.0	577.6	616.4	552.6	471.6	412.2	373.4	350.1
67.5°	271.7	294.7	337.9	399.0	470.0	498.3	449.7	387.0	342.3	311.1	292.6
70°	235.2	255.2	289.0	341.8	406.1	427.8	382.3	330.7	297.9	273.0	255.8
72.5°	204.6	219.2	250.0	290.7	344.4	361.6	329.9	284.5	254.0	235.2	221.6
75°	155.9	168.1	188.1	220.8	258.0	268.0	244.1	215.8	195.3	182.0	171.5
77.5°	112.4	121.4	135.8	156.0	181.7	190.8	175.6	156.8	141.8	132.8	126.9
80°	84.9	92.1	104.3	120.9	136.5	141.5	132.6	118.1	107.6	102.6	97.7
82.5°	62.7	66.8	74.1	85.4	96.1	102.0	94.4	85.8	80.1	75.6	73.7
85°	31.6	33.8	37.2	41.6	48.3	50.5	47.7	45.5	42.2	39.4	39.4
87.5°	12.0	12.2	13.9	15.0	17.1	18.8	18.8	18.3	18.2	17.9	17.5
90°	2.0	3.5	4.9	6.3	7.9	9.8	11.6	13.5	15.3	15.9	16.5
92.5°	16.4	17.4	18.3	19.2	20.3	21.4	22.4	23.4	24.5	24.9	25.4
95°	38.6	39.6	40.6	41.6	42.6	43.8	44.9	46.1	47.2	47.8	48.3
97.5°	67.5	68.2	69.0	69.8	70.5	71.3	72.2	73.0	73.8	74.4	75.1
100°	87.6	88.4	89.3	90.1	90.9	91.6	92.3	93.0	93.7	94.2	94.6
102.5°	110.1	110.6	111.2	111.7	112.4	113.3	114.3	115.2	116.2	116.6	117.0
105°	143.7	144.0	144.3	144.6	145.4	146.6	147.9	149.2	150.4	150.4	150.4
107.5°	182.9	183.0	183.2	183.4	183.7	184.3	184.7	185.2	185.7	186.2	186.6
110°	207.4	207.7	208.0	208.3	208.6	208.9	209.1	209.5	209.7	210.3	210.8



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	232.8	233.0	233.2	233.3	233.4	233.5	233.6	233.7	233.7	234.4	235.1
115°	271.3	271.7	272.1	272.6	272.7	272.4	272.1	271.8	271.6	271.7	271.8
117.5°	309.7	310.0	310.2	310.5	310.5	310.1	309.7	309.4	309.0	309.0	309.0
120°	334.2	335.1	335.9	336.8	336.9	336.1	335.4	334.8	334.0	333.9	333.7
122.5°	359.0	359.6	360.2	360.9	361.0	360.6	360.3	359.9	359.5	359.1	358.8
125°	396.9	397.3	397.8	398.2	398.3	397.9	397.7	397.4	397.1	396.6	396.0
127.5°	432.6	433.5	434.4	435.3	435.6	435.3	435.0	434.6	434.3	433.6	432.8
130°	456.2	457.4	458.5	459.7	460.0	459.6	459.2	458.8	458.3	457.7	457.2
132.5°	479.7	480.9	482.0	483.1	483.6	483.2	482.9	482.6	482.2	481.6	480.9
135°	515.3	516.1	517.0	517.8	518.2	518.0	517.9	517.7	517.6	517.1	516.5
137.5°	548.3	548.9	549.7	550.4	550.9	551.3	551.6	552.0	552.4	551.8	551.2
140°	571.2	571.9	572.7	573.3	573.7	573.9	574.1	574.2	574.3	574.2	574.1
142.5°	592.2	592.8	593.5	594.3	594.8	595.0	595.3	595.5	595.7	595.6	595.5
145°	624.4	624.6	624.9	625.2	625.5	626.0	626.4	626.8	627.2	627.1	627.0
147.5°	653.1	653.6	654.1	654.7	655.1	655.5	655.9	656.3	656.7	656.7	656.7
150°	672.8	673.0	673.4	673.6	673.9	674.2	674.5	674.7	675.1	675.1	675.1
152.5°	689.2	689.6	690.0	690.4	690.7	690.9	691.0	691.2	691.4	691.6	691.8
155°	714.5	714.5	714.5	714.5	714.6	714.8	714.9	715.1	715.2	715.8	716.3
157.5°	736.3	736.1	736.0	735.8	735.8	735.9	736.1	736.1	736.2	736.9	737.4
160°	750.0	749.7	749.4	749.1	749.0	749.0	749.0	749.0	749.0	749.7	750.4
162.5°	762.1	761.7	761.3	760.9	760.8	760.9	761.0	761.1	761.2	761.9	762.6
165°	777.9	777.5	777.1	776.6	776.4	776.4	776.4	776.4	776.4	777.2	778.1
167.5°	790.4	789.8	789.2	788.6	788.5	788.6	788.6	788.8	788.9	789.8	790.7
170°	797.5	797.0	796.4	795.8	795.5	795.5	795.5	795.5	795.5	796.5	797.5
172.5°	803.2	802.6	802.0	801.4	801.1	801.1	801.1	801.1	801.1	802.0	802.9
175°	808.9	808.5	807.9	807.3	807.0	807.0	807.0	807.0	807.0	807.9	808.7
177.5°	811.5	811.1	810.6	810.2	809.9	809.9	809.9	809.9	809.9	810.6	811.3
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5	811.5



TEST NUMBER: P332019-930
 CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
0°	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1	1145.1
2.5°	1205.0	1205.5	1210.4	1213.9	1212.1	1214.4	1215.2
5°	1316.5	1336.5	1347.0	1354.9	1355.4	1355.9	1360.4
7.5°	1474.6	1496.1	1511.7	1535.5	1542.5	1550.7	1548.3
10°	1590.1	1621.7	1648.9	1663.3	1678.9	1701.6	1683.3
12.5°	1697.9	1754.0	1795.4	1817.8	1832.4	1837.0	1828.0
15°	1875.8	1949.1	1988.4	1987.3	2037.3	2058.9	2025.0
17.5°	2038.9	2106.5	2160.6	2188.3	2230.0	2239.2	2235.0
20°	2138.8	2212.6	2254.7	2302.4	2324.1	2343.5	2346.8
22.5°	2224.9	2291.2	2336.4	2376.1	2394.2	2403.4	2409.0
25°	2313.5	2365.7	2392.9	2406.8	2411.7	2410.6	2403.4
27.5°	2307.5	2311.5	2281.5	2252.1	2225.8	2196.2	2185.9
30°	2247.5	2200.9	2117.7	2070.5	2001.2	1946.3	1968.5
32.5°	2089.9	1997.2	1903.7	1800.7	1715.3	1691.0	1666.6
35°	1783.7	1620.6	1525.2	1414.2	1369.8	1325.4	1294.9
37.5°	1443.1	1316.9	1203.7	1131.1	1086.6	1058.6	1043.5
40°	1247.7	1134.0	1040.8	982.0	948.2	916.6	912.1
42.5°	1091.9	986.2	916.1	869.3	836.7	823.3	813.6
45°	894.4	820.5	773.4	740.1	718.4	710.1	699.0
47.5°	757.0	704.8	669.4	646.8	630.5	624.3	623.4
50°	680.2	636.9	610.8	593.0	580.3	578.1	569.2
52.5°	622.5	585.0	564.7	549.2	540.0	533.7	531.1
55°	540.4	515.4	497.1	488.2	481.0	474.9	474.9
57.5°	472.8	451.9	439.9	432.3	430.1	425.7	423.0
60°	431.0	413.4	403.9	397.2	392.8	393.4	388.3
62.5°	390.3	378.7	369.7	363.1	357.8	357.8	358.2
65°	332.3	323.4	316.8	314.5	311.3	307.4	308.5
67.5°	281.6	273.3	268.1	264.3	263.2	261.1	264.3
70°	245.2	239.1	235.2	231.9	230.8	231.4	234.2
72.5°	211.9	207.6	205.0	203.5	201.1	201.1	203.1
75°	166.4	163.1	160.9	159.2	158.7	158.7	158.7
77.5°	122.3	121.5	120.5	118.1	118.1	118.9	119.0
80°	96.5	94.9	94.3	93.2	91.6	90.4	93.2
82.5°	72.2	70.4	69.9	69.7	67.1	66.9	69.2
85°	38.8	37.2	37.7	37.2	37.2	36.6	36.6
87.5°	17.1	16.8	16.5	17.0	16.6	16.2	17.1
90°	17.0	17.5	18.0	18.3	18.6	18.8	19.2
92.5°	25.8	26.3	26.4	26.3	26.1	25.9	25.8
95°	48.8	49.4	49.7	49.7	49.7	49.7	49.7
97.5°	75.7	76.4	76.7	76.6	76.6	76.6	76.5
100°	95.0	95.4	95.8	96.0	96.3	96.6	96.9
102.5°	117.4	117.8	118.1	118.0	117.9	117.9	117.8
105°	150.4	150.4	150.6	150.8	151.2	151.4	151.7
107.5°	187.1	187.6	187.7	187.5	187.4	187.2	187.0
110°	211.4	212.0	212.1	211.8	211.6	211.2	211.0



TEST NUMBER: P332019-930

CATALOG NUMBER: S123DIP-S1000D805U930-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
112.5°	235.7	236.4	236.7	236.7	236.6	236.5	236.5
115°	272.0	272.1	272.1	272.0	271.8	271.7	271.6
117.5°	308.9	308.9	308.7	308.3	307.9	307.5	307.1
120°	333.6	333.5	333.2	333.0	332.6	332.4	332.1
122.5°	358.4	358.1	357.7	357.3	356.9	356.4	356.0
125°	395.4	394.8	394.3	393.7	393.1	392.6	392.0
127.5°	431.9	431.2	430.5	429.8	429.2	428.5	427.9
130°	456.6	456.1	455.3	454.3	453.3	452.3	451.3
132.5°	480.2	479.6	478.8	478.1	477.3	476.5	475.8
135°	515.9	515.4	514.9	514.6	514.4	514.0	513.8
137.5°	550.7	550.0	549.4	548.9	548.4	547.9	547.3
140°	573.9	573.7	573.2	572.2	571.2	570.2	569.2
142.5°	595.3	595.2	594.8	593.9	593.2	592.4	591.7
145°	626.8	626.6	626.3	625.7	625.2	624.6	624.0
147.5°	656.7	656.7	656.2	655.4	654.5	653.7	652.9
150°	675.1	675.1	674.7	673.8	672.9	672.1	671.2
152.5°	692.0	692.3	692.0	691.3	690.6	689.8	689.1
155°	716.9	717.5	717.2	716.2	715.3	714.3	713.3
157.5°	738.0	738.6	738.5	737.8	736.9	736.1	735.3
160°	751.1	751.8	751.9	751.3	750.7	750.2	749.6
162.5°	763.4	764.1	763.9	763.0	762.1	761.2	760.3
165°	778.9	779.8	779.8	778.8	777.7	776.7	775.8
167.5°	791.5	792.4	792.4	791.5	790.7	789.8	788.9
170°	798.5	799.5	799.5	798.5	797.5	796.5	795.5
172.5°	803.8	804.6	804.6	803.6	802.6	801.6	800.6
175°	809.5	810.4	810.3	809.3	808.4	807.3	806.3
177.5°	812.0	812.6	812.6	811.8	811.0	810.2	809.4
180°	811.5	811.5	811.5	811.5	811.5	811.5	811.5

(END OF REPORT)