

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P332330-930

Luminaire Tested: **S123RDIP-S1000D365U930-4F0-1E-UDD-A**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P332330-930
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-5,
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: NEO-RAY
Catalog Number: S123RDIP-S1000D365U930-4F0-1E-UDD-A
Description: DEFINE 3 DIRECT-INDIRECT PENDANT LED LUMINAIRE
DOWNLIGHT 1000 LUMENS PER FOOT, ASYMMETRIC DIFFUSER, REGRESSED HOUSING
UPLIGHT 365 LUMENS PER FOOT, NO LENS
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4410.7 lumens
Efficiency: N/A
Efficacy: 101.4 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.22 / 1.36
Luminous Opening: Rectangular (W 4' x L: 0.25' x H: 0')
CIE Type: Semi-Direct


Input Watts (W): 43.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

Luminous Intensity Polar Plot





TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	113	113	113	113	107	107	107	107	96	96	96	86	86	86	77	77	77	73
1	104	100	96	93	98	95	92	89	86	83	81	77	76	74	70	68	67	63
2	95	88	82	77	90	84	79	74	76	72	69	69	66	63	62	60	58	54
3	88	78	71	65	83	75	68	63	68	63	59	62	58	54	56	53	50	47
4	81	70	62	56	76	67	60	54	61	55	51	56	51	47	51	47	44	41
5	74	63	55	49	70	60	53	47	55	49	44	50	46	42	46	42	39	36
6	69	57	49	43	65	55	47	42	50	44	39	46	41	37	42	38	35	32
7	64	52	44	38	61	50	42	37	46	40	35	42	37	33	39	34	31	29
8	60	47	39	34	57	45	38	33	42	36	32	39	34	30	36	31	28	26
9	56	43	36	31	53	42	35	30	39	33	29	36	31	27	33	29	26	24
10	52	40	33	28	50	39	32	27	36	30	26	33	28	25	31	26	23	22

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	13951	13951	13951	13951
5°	16630	14011	12337	14011
10°	20764	13930	11146	13930
15°	24373	13788	10165	13788
20°	27202	13575	9330	13575
25°	26766	13351	8817	13351
30°	19240	13144	8289	13144
35°	12846	12875	7947	12875
40°	9465	12552	7593	12552
45°	7939	11985	7247	11985
50°	7005	11241	6764	11241
55°	6142	10393	6101	10393
60°	5470	9580	5591	9580
65°	4806	8706	5201	8706
70°	3770	7928	4749	7928
75°	3323	6924	4338	6924
80°	2889	5883	4265	5883
85°	2322	4730	4520	4730



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	127.5	2.9
10°-20°	398.2	9.0
20°-30°	625.6	14.2
30°-40°	652.7	14.8
40°-50°	558.6	12.7
50°-60°	425.7	9.7
60°-70°	272.9	6.2
70°-80°	131.3	3.0
80°-90°	35.8	0.8
90°-100°	14.1	0.3
100°-110°	67.2	1.5
110°-120°	161.4	3.7
120°-130°	205.5	4.7
130°-140°	219.6	5.0
140°-150°	205.4	4.7
150°-160°	165.6	3.8
160°-170°	106.9	2.4
170°-180°	36.8	0.8
0°-30°	1151.2	26.1
0°-40°	1803.9	40.9
0°-60°	2788.2	63.2
0°-90°	3228.2	73.2
90°-120°	242.7	5.5
90°-150°	873.2	19.8
90°-180°	1183.0	26.8
0°-180°	4410.7	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1296	1296	1296	1296	1296	
5°	1539	1297	1142	1297	1539	159
15°	2187	1237	912	1237	2187	620
25°	2254	1124	742	1124	2254	969
35°	978	980	605	980	978	641
45°	522	787	476	787	522	410
55°	327	554	325	554	327	296
65°	189	342	204	342	189	186
75°	80	166	104	166	80	86
85°	19	38	37	38	19	22
90°	9	0	9	0	9	5
95°	11	18	11	18	11	9
105°	13	86	13	86	13	29
115°	169	161	169	161	169	157
125°	232	227	232	227	232	207
135°	286	283	286	283	286	220
145°	329	326	329	326	329	206
155°	359	359	359	359	359	165
165°	378	379	378	379	378	107
175°	386	388	386	388	386	37
180°	388	388	388	388	388	



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1380.5	1382.2	1376.5	1375.6	1368.9	1367.1	1367.1	1357.8	1352.0	1344.5	1340.0
5°	1539.1	1548.0	1543.5	1533.6	1516.9	1513.0	1502.5	1485.9	1467.0	1443.7	1432.6
7.5°	1737.3	1749.4	1744.7	1729.3	1711.9	1697.8	1668.1	1640.5	1601.7	1567.7	1538.7
10°	1899.7	1887.0	1877.0	1862.1	1845.9	1819.8	1788.8	1746.0	1696.7	1657.8	1614.6
12.5°	2021.4	2019.3	2006.6	1991.2	1968.5	1943.7	1905.5	1853.5	1796.1	1740.0	1690.4
15°	2187.2	2190.5	2182.1	2166.1	2133.9	2090.1	2032.4	2010.8	1928.6	1867.6	1806.5
17.5°	2301.9	2301.3	2300.1	2277.9	2245.0	2213.8	2160.3	2103.4	2029.0	1943.0	1860.8
20°	2374.7	2369.2	2370.2	2345.3	2320.9	2284.8	2232.7	2150.0	2089.0	1989.7	1904.8
22.5°	2372.9	2371.8	2376.0	2367.5	2349.8	2322.1	2281.0	2211.3	2133.3	2033.1	1937.6
25°	2253.7	2249.3	2275.4	2282.6	2310.9	2315.9	2303.7	2265.4	2191.6	2088.4	1970.3
27.5°	1886.2	1883.7	1932.2	1992.8	2069.6	2129.2	2187.0	2214.8	2191.6	2117.7	1999.3
30°	1548.0	1600.2	1624.6	1712.2	1809.9	1926.4	2028.5	2125.6	2149.5	2117.3	2020.1
32.5°	1285.2	1330.7	1351.1	1426.4	1517.4	1653.8	1807.0	1944.5	2041.6	2066.2	2007.8
35°	977.6	978.2	1024.7	1058.1	1142.4	1282.8	1431.5	1615.7	1798.8	1937.5	1951.9
37.5°	780.1	782.9	811.1	844.2	907.5	981.7	1112.6	1265.8	1477.3	1690.3	1815.1
40°	673.6	678.6	699.7	732.4	777.9	833.9	936.0	1080.3	1256.7	1493.6	1687.3
42.5°	605.2	613.3	624.2	649.4	677.6	730.0	812.6	924.1	1084.5	1308.6	1531.9
45°	521.5	525.9	534.3	545.9	571.4	608.1	663.6	738.5	871.6	1052.0	1275.5
47.5°	460.1	457.7	466.5	476.0	492.9	517.9	555.1	616.2	711.2	855.9	1045.5
50°	418.3	417.8	423.9	431.1	447.2	465.5	496.0	542.1	617.5	737.4	911.0
52.5°	379.3	381.4	385.7	394.7	406.3	421.1	448.5	481.7	546.5	650.0	794.8
55°	327.3	329.1	335.1	340.1	348.5	363.4	380.6	408.4	452.7	524.9	644.2
57.5°	283.4	282.7	288.5	289.8	299.1	311.4	324.7	346.3	378.4	432.0	512.3
60°	254.1	252.4	257.5	261.3	266.4	276.3	287.4	308.5	334.0	373.4	442.2
62.5°	227.5	226.7	230.4	234.2	238.4	247.4	256.8	273.0	293.2	326.4	381.0
65°	188.7	190.3	192.0	193.6	195.8	201.4	210.3	221.4	235.2	258.5	297.9
67.5°	148.2	149.9	150.5	153.9	158.7	162.2	167.5	177.4	187.1	206.8	229.2
70°	119.8	119.3	119.8	121.5	127.6	133.7	141.0	148.1	154.3	168.1	186.9
72.5°	103.0	102.0	103.5	103.8	106.7	108.4	113.0	119.8	127.6	137.1	150.6
75°	79.9	79.9	79.9	79.9	82.1	83.2	84.9	86.6	89.4	93.8	103.8
77.5°	59.0	59.1	59.9	60.5	60.9	61.6	62.6	64.2	65.2	67.6	71.9
80°	46.6	47.1	46.6	47.1	47.1	48.3	48.8	50.5	51.0	53.8	55.5
82.5°	35.1	34.7	35.1	35.6	35.6	36.8	36.9	38.1	38.2	39.6	41.3
85°	18.8	17.8	18.8	18.3	19.4	18.3	18.8	20.0	20.0	20.5	22.7
87.5°	6.2	7.0	6.1	6.5	6.5	6.9	6.8	6.8	7.7	7.2	7.4
90°	8.6	8.5	8.4	8.2	8.2	7.9	7.7	7.4	7.2	6.9	6.1
92.5°	9.5	9.5	9.4	9.3	9.3	9.0	8.6	8.2	7.7	7.3	6.8
95°	10.9	10.9	10.9	10.9	10.9	10.8	10.3	9.9	9.4	9.0	8.2
97.5°	11.9	11.8	11.7	11.7	11.6	11.3	10.8	10.3	9.8	9.3	13.9
100°	12.1	12.1	12.0	11.9	11.8	11.6	11.0	10.5	10.0	9.5	19.5
102.5°	12.3	12.2	12.1	12.0	11.9	12.6	14.2	15.8	17.4	19.0	29.8
105°	12.6	12.6	12.4	12.3	12.1	17.8	29.1	40.4	51.8	63.1	68.9
107.5°	39.8	48.3	56.9	65.5	73.9	82.4	90.7	99.1	107.3	115.6	114.7
110°	79.2	88.4	97.5	106.7	115.9	121.5	123.6	125.7	127.8	130.0	129.2



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	135.9	137.9	139.8	141.7	143.7	144.6	144.6	144.6	144.5	144.5	143.7
115°	169.4	169.2	168.9	168.6	168.4	168.0	167.3	166.6	166.0	165.3	164.8
117.5°	188.2	188.2	188.1	188.0	188.0	187.7	187.2	186.7	186.1	185.6	185.4
120°	201.1	201.1	201.1	201.1	201.1	200.8	200.3	199.8	199.3	198.8	198.6
122.5°	213.8	213.7	213.7	213.6	213.5	213.4	213.0	212.6	212.3	211.9	211.7
125°	231.6	231.5	231.4	231.2	231.1	231.0	230.9	230.7	230.6	230.5	230.2
127.5°	248.8	248.9	249.1	249.2	249.3	249.3	249.1	248.8	248.7	248.4	248.2
130°	259.8	260.0	260.2	260.2	260.4	260.3	260.1	259.8	259.5	259.3	259.0
132.5°	270.0	270.2	270.4	270.5	270.8	270.7	270.4	270.2	269.9	269.7	269.5
135°	285.5	285.7	285.9	286.1	286.3	286.3	286.1	285.9	285.7	285.5	285.3
137.5°	300.1	300.2	300.4	300.4	300.6	300.5	300.2	299.9	299.6	299.3	299.1
140°	308.8	309.0	309.1	309.2	309.3	309.3	309.0	308.8	308.5	308.3	308.1
142.5°	316.9	317.1	317.2	317.5	317.6	317.6	317.4	317.2	317.0	316.8	316.6
145°	329.3	329.3	329.3	329.3	329.3	329.2	329.1	329.0	328.9	328.7	328.6
147.5°	338.5	338.8	339.1	339.4	339.7	339.8	339.7	339.5	339.4	339.2	339.2
150°	345.4	345.6	345.8	346.0	346.2	346.3	346.1	346.0	345.8	345.7	345.6
152.5°	351.0	351.2	351.6	351.9	352.1	352.2	352.0	351.7	351.5	351.2	351.1
155°	358.7	359.1	359.5	359.9	360.2	360.3	360.0	359.6	359.3	359.0	358.9
157.5°	365.2	365.7	366.2	366.7	367.2	367.3	366.9	366.5	366.1	365.7	365.7
160°	369.3	369.8	370.2	370.7	371.1	371.2	370.8	370.4	370.0	369.7	369.7
162.5°	373.2	373.7	374.1	374.5	374.9	374.8	374.4	374.0	373.5	373.1	373.2
165°	378.0	378.5	378.9	379.4	379.8	379.8	379.3	378.7	378.2	377.7	377.7
167.5°	381.4	381.9	382.4	382.9	383.4	383.4	382.9	382.4	381.9	381.4	381.4
170°	383.4	384.0	384.5	385.0	385.5	385.5	385.0	384.5	384.0	383.4	383.4
172.5°	384.6	385.1	385.7	386.3	386.9	386.9	386.4	385.9	385.4	384.8	384.8
175°	386.4	386.9	387.3	387.9	388.4	388.4	388.0	387.5	387.1	386.6	386.5
177.5°	386.9	387.3	387.9	388.4	388.9	389.0	388.6	388.2	387.8	387.3	387.3
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1338.2	1336.9	1330.7	1323.6	1314.3	1308.1	1303.2	1300.6	1292.6	1282.8	1276.1
5°	1420.9	1404.3	1386.6	1364.9	1344.9	1324.4	1311.7	1296.7	1278.3	1257.8	1243.4
7.5°	1509.5	1476.8	1441.7	1405.4	1369.5	1337.4	1309.0	1284.7	1255.5	1226.0	1205.4
10°	1577.4	1529.7	1480.3	1429.8	1383.7	1340.5	1307.2	1274.5	1239.5	1205.7	1180.1
12.5°	1639.1	1576.3	1519.4	1457.3	1398.4	1346.7	1298.8	1260.3	1218.2	1182.1	1153.1
15°	1717.2	1652.9	1584.0	1489.7	1411.5	1346.1	1287.8	1237.3	1186.3	1141.8	1113.5
17.5°	1790.2	1693.4	1600.9	1522.2	1420.6	1338.8	1267.7	1207.3	1151.3	1104.2	1069.4
20°	1820.4	1726.6	1626.2	1525.8	1426.0	1334.4	1251.7	1185.1	1126.9	1073.6	1041.5
22.5°	1838.6	1732.4	1626.7	1518.7	1412.6	1317.5	1235.7	1162.5	1099.3	1048.7	1009.0
25°	1859.8	1733.3	1616.8	1510.3	1402.1	1298.9	1201.8	1124.1	1055.9	1002.0	959.9
27.5°	1873.8	1725.0	1587.3	1468.8	1359.1	1256.4	1167.3	1085.0	1015.8	958.9	913.6
30°	1876.5	1718.3	1564.6	1436.5	1324.9	1230.6	1136.3	1057.5	984.3	923.8	881.7
32.5°	1880.0	1701.9	1534.0	1397.8	1283.7	1190.3	1104.8	1029.6	954.6	895.0	851.9
35°	1865.4	1692.8	1487.5	1331.1	1216.8	1126.3	1049.2	979.8	906.0	848.3	804.5
37.5°	1802.3	1656.8	1439.3	1255.8	1136.3	1052.6	989.7	929.3	861.5	799.3	758.0
40°	1738.9	1621.2	1402.1	1210.1	1085.2	999.2	942.6	893.3	827.9	769.6	725.2
42.5°	1644.3	1572.9	1366.6	1162.1	1027.5	944.7	896.9	850.7	793.2	734.0	692.4
45°	1470.9	1480.3	1293.9	1085.8	947.6	864.5	819.5	787.3	736.3	687.5	644.7
47.5°	1253.4	1341.6	1208.5	1004.4	863.4	785.3	746.0	718.0	683.5	635.6	596.6
50°	1111.3	1237.3	1140.2	949.9	810.7	733.0	694.1	671.3	641.4	603.6	566.5
52.5°	980.4	1115.7	1057.6	889.1	753.3	682.3	644.4	625.7	601.9	566.4	532.7
55°	799.5	936.5	923.2	797.3	667.5	603.6	574.8	553.8	537.6	511.0	484.4
57.5°	646.7	776.7	783.5	695.2	591.8	528.7	503.9	488.0	477.5	457.4	432.8
60°	550.4	669.7	693.0	626.4	537.6	482.2	457.7	445.0	436.7	420.5	401.7
62.5°	470.5	572.0	598.4	550.5	485.7	433.7	414.7	402.4	396.7	382.9	366.2
65°	360.1	444.4	469.9	443.3	409.4	367.9	352.3	341.8	336.8	329.1	316.8
67.5°	270.8	332.2	360.2	341.4	329.2	303.0	293.1	287.4	283.0	277.6	267.4
70°	217.5	263.0	291.9	286.8	276.9	263.0	255.8	251.9	247.4	243.0	234.2
72.5°	174.9	206.2	233.3	235.8	227.6	224.9	218.5	216.9	214.2	208.9	204.0
75°	115.9	137.6	156.5	163.7	167.0	169.7	167.0	166.5	165.9	161.4	158.7
77.5°	76.0	87.6	99.5	111.9	117.1	120.8	121.7	123.8	122.3	119.9	118.6
80°	58.3	61.1	69.4	79.9	88.2	91.6	93.8	94.9	94.3	93.8	91.6
82.5°	42.3	44.6	48.5	55.9	62.9	68.5	69.8	69.5	70.8	71.1	69.4
85°	22.7	23.3	24.4	25.5	29.4	35.5	37.2	38.3	39.4	39.4	36.0
87.5°	8.2	7.6	8.2	8.2	9.3	9.6	12.1	14.3	14.8	13.2	13.3
90°	5.2	4.4	3.6	2.9	2.2	1.5	0.9	0.3	0.9	1.5	2.2
92.5°	6.1	5.5	4.9	4.6	4.8	5.0	5.2	5.4	5.2	5.0	4.8
95°	7.5	6.8	6.1	7.1	9.7	12.3	14.9	17.6	14.9	12.3	9.7
97.5°	18.5	23.1	27.7	30.6	31.8	32.9	34.2	35.3	34.2	32.9	31.8
100°	29.5	39.5	49.5	53.8	52.5	51.3	50.0	48.7	50.0	51.3	52.5
102.5°	40.8	51.7	62.6	67.6	66.7	65.7	64.8	63.9	64.8	65.7	66.7
105°	74.6	80.4	86.2	88.7	88.0	87.2	86.6	85.9	86.6	87.2	88.0
107.5°	113.8	112.9	112.0	111.3	110.7	110.1	109.6	109.0	109.6	110.1	110.7
110°	128.5	127.8	127.1	126.5	126.0	125.5	125.0	124.5	125.0	125.5	126.0



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	143.1	142.4	141.6	141.0	140.6	140.1	139.7	139.2	139.7	140.1	140.6
115°	164.2	163.6	163.1	162.6	162.2	161.8	161.4	161.0	161.4	161.8	162.2
117.5°	185.1	184.7	184.5	184.1	183.6	183.1	182.7	182.2	182.7	183.1	183.6
120°	198.4	198.2	198.0	197.6	197.1	196.5	195.9	195.3	195.9	196.5	197.1
122.5°	211.4	211.2	210.9	210.6	210.1	209.6	209.2	208.7	209.2	209.6	210.1
125°	230.0	229.8	229.4	229.1	228.5	228.0	227.6	227.1	227.6	228.0	228.5
127.5°	247.9	247.5	247.2	246.8	246.3	245.8	245.3	244.8	245.3	245.8	246.3
130°	258.8	258.5	258.3	257.9	257.4	256.8	256.3	255.8	256.3	256.8	257.4
132.5°	269.3	269.0	268.8	268.5	268.0	267.5	266.9	266.4	266.9	267.5	268.0
135°	285.0	284.7	284.5	284.1	283.8	283.4	283.0	282.7	283.0	283.4	283.8
137.5°	299.0	298.9	298.7	298.4	297.9	297.4	296.9	296.4	296.9	297.4	297.9
140°	307.9	307.7	307.5	307.2	306.8	306.5	306.1	305.7	306.1	306.5	306.8
142.5°	316.4	316.3	316.0	315.8	315.4	315.0	314.6	314.2	314.6	315.0	315.4
145°	328.5	328.3	328.2	327.9	327.5	327.0	326.6	326.1	326.6	327.0	327.5
147.5°	339.0	338.9	338.8	338.5	338.3	337.9	337.7	337.4	337.7	337.9	338.3
150°	345.4	345.4	345.2	345.0	344.9	344.6	344.5	344.3	344.5	344.6	344.9
152.5°	351.1	351.0	351.0	350.8	350.7	350.7	350.6	350.5	350.6	350.7	350.7
155°	358.8	358.8	358.7	358.7	358.9	359.0	359.1	359.3	359.1	359.0	358.9
157.5°	365.8	365.9	366.0	366.0	366.0	366.1	366.1	366.1	366.1	366.1	366.0
160°	369.7	369.8	369.9	370.0	370.0	370.1	370.1	370.2	370.1	370.1	370.0
162.5°	373.2	373.2	373.3	373.5	373.7	373.8	374.0	374.1	374.0	373.8	373.7
165°	377.8	377.9	378.0	378.1	378.3	378.5	378.6	378.9	378.6	378.5	378.3
167.5°	381.4	381.4	381.4	381.5	381.8	382.0	382.3	382.5	382.3	382.0	381.8
170°	383.4	383.4	383.4	383.6	383.8	384.1	384.3	384.6	384.3	384.1	383.8
172.5°	384.7	384.7	384.7	384.7	385.1	385.4	385.7	386.0	385.7	385.4	385.1
175°	386.5	386.5	386.4	386.5	386.9	387.1	387.4	387.8	387.4	387.1	386.9
177.5°	387.2	387.2	387.1	387.2	387.5	387.8	388.0	388.2	388.0	387.8	387.5
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1273.9	1268.1	1264.1	1255.2	1249.5	1243.2	1237.1	1241.0	1240.6	1240.2	1240.2
5°	1231.2	1218.4	1206.8	1191.8	1182.3	1170.7	1161.8	1160.7	1162.9	1155.2	1150.7
7.5°	1188.8	1171.3	1154.9	1138.3	1120.8	1106.8	1098.0	1093.9	1088.3	1083.5	1078.5
10°	1159.0	1138.6	1122.4	1101.9	1083.0	1066.4	1055.9	1048.6	1044.7	1040.9	1033.6
12.5°	1128.5	1108.3	1087.9	1064.6	1046.7	1027.4	1019.5	1011.4	1004.0	999.6	989.7
15°	1083.6	1057.5	1035.9	1011.5	991.5	972.7	961.6	945.4	943.2	937.7	927.7
17.5°	1038.7	1010.3	980.5	962.5	939.9	920.2	903.4	898.0	882.1	876.1	867.4
20°	1003.1	977.1	954.3	930.5	897.7	879.4	866.1	858.9	846.1	838.4	832.8
22.5°	972.5	946.0	919.7	891.9	864.9	844.3	834.6	823.4	816.4	805.5	799.5
25°	928.8	899.9	868.3	838.4	819.0	803.4	787.9	777.9	767.9	762.9	751.8
27.5°	878.0	847.8	818.2	795.5	771.7	756.4	742.2	733.4	721.4	713.0	706.9
30°	850.0	814.5	789.0	768.4	737.9	723.5	713.0	701.9	693.0	684.1	678.0
32.5°	817.6	785.2	761.0	735.6	712.2	696.4	682.8	673.0	665.4	657.0	650.9
35°	766.8	739.6	714.6	689.1	671.9	655.8	639.8	631.4	624.2	616.4	610.9
37.5°	720.8	695.5	671.7	647.5	626.1	613.1	600.1	593.8	584.0	578.8	573.2
40°	692.4	667.5	642.0	618.6	596.5	586.4	574.8	565.4	556.5	552.6	546.5
42.5°	661.4	636.4	614.9	589.8	571.6	558.1	547.3	537.0	530.4	524.6	521.2
45°	615.3	593.1	572.0	547.1	529.9	518.2	506.0	496.6	490.5	486.6	480.5
47.5°	570.6	548.4	527.0	505.2	488.6	475.2	463.1	456.5	448.4	443.7	439.5
50°	538.2	518.2	495.5	475.5	458.9	445.6	435.5	427.2	420.0	413.9	411.2
52.5°	508.4	487.1	467.5	448.9	431.3	416.2	407.2	398.4	393.0	386.0	382.7
55°	459.4	438.9	422.2	403.9	386.7	374.0	362.9	355.1	349.5	341.8	337.4
57.5°	413.4	394.9	375.0	359.2	341.4	330.7	321.5	311.0	304.2	298.1	293.8
60°	382.3	361.2	344.0	329.1	313.5	299.6	291.3	283.0	275.7	269.6	265.8
62.5°	349.8	331.5	315.1	298.8	284.6	272.6	262.9	255.9	249.6	245.6	241.8
65°	300.2	285.8	269.1	255.8	242.5	233.6	225.8	219.7	215.2	212.5	209.2
67.5°	254.5	240.4	225.9	212.9	204.0	197.2	192.1	186.9	184.7	181.1	178.9
70°	224.7	210.3	197.5	187.5	178.6	173.7	170.3	166.5	164.2	159.8	157.6
72.5°	192.3	181.9	172.7	164.4	157.4	152.8	148.5	143.8	140.2	135.3	133.1
75°	151.5	142.0	134.9	129.3	124.8	118.7	112.6	107.6	106.0	104.3	103.8
77.5°	112.2	106.2	101.0	96.3	90.7	86.3	85.0	83.9	83.6	82.7	82.7
80°	88.2	82.7	78.8	73.2	69.9	69.9	69.9	68.8	69.4	69.4	69.4
82.5°	65.6	60.5	58.4	56.3	55.7	56.2	56.2	56.3	56.0	56.9	56.5
85°	33.8	34.4	35.5	35.0	35.5	35.5	36.6	36.0	36.6	35.5	36.6
87.5°	13.0	14.5	15.1	15.7	16.3	16.1	16.6	16.6	17.0	17.1	17.1
90°	2.9	3.6	4.4	5.2	6.1	6.9	7.2	7.4	7.7	7.9	8.2
92.5°	4.6	4.9	5.5	6.1	6.8	7.3	7.7	8.2	8.6	9.0	9.3
95°	7.1	6.1	6.8	7.5	8.2	9.0	9.4	9.9	10.3	10.8	10.9
97.5°	30.6	27.7	23.1	18.5	13.9	9.3	9.8	10.3	10.8	11.3	11.6
100°	53.8	49.5	39.5	29.5	19.5	9.5	10.0	10.5	11.0	11.6	11.8
102.5°	67.6	62.6	51.7	40.8	29.8	19.0	17.4	15.8	14.2	12.6	11.9
105°	88.7	86.2	80.4	74.6	68.9	63.1	51.8	40.4	29.1	17.8	12.1
107.5°	111.3	112.0	112.9	113.8	114.7	115.6	107.3	99.1	90.7	82.4	73.9
110°	126.5	127.1	127.8	128.5	129.2	130.0	127.8	125.7	123.6	121.5	115.9



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	141.0	141.6	142.4	143.1	143.7	144.5	144.5	144.6	144.6	144.6	143.7
115°	162.6	163.1	163.6	164.2	164.8	165.3	166.0	166.6	167.3	168.0	168.4
117.5°	184.1	184.5	184.7	185.1	185.4	185.6	186.1	186.7	187.2	187.7	188.0
120°	197.6	198.0	198.2	198.4	198.6	198.8	199.3	199.8	200.3	200.8	201.1
122.5°	210.6	210.9	211.2	211.4	211.7	211.9	212.3	212.6	213.0	213.4	213.5
125°	229.1	229.4	229.8	230.0	230.2	230.5	230.6	230.7	230.9	231.0	231.1
127.5°	246.8	247.2	247.5	247.9	248.2	248.4	248.7	248.8	249.1	249.3	249.3
130°	257.9	258.3	258.5	258.8	259.0	259.3	259.5	259.8	260.1	260.3	260.4
132.5°	268.5	268.8	269.0	269.3	269.5	269.7	269.9	270.2	270.4	270.7	270.8
135°	284.1	284.5	284.7	285.0	285.3	285.5	285.7	285.9	286.1	286.3	286.3
137.5°	298.4	298.7	298.9	299.0	299.1	299.3	299.6	299.9	300.2	300.5	300.6
140°	307.2	307.5	307.7	307.9	308.1	308.3	308.5	308.8	309.0	309.3	309.3
142.5°	315.8	316.0	316.3	316.4	316.6	316.8	317.0	317.2	317.4	317.6	317.6
145°	327.9	328.2	328.3	328.5	328.6	328.7	328.9	329.0	329.1	329.2	329.3
147.5°	338.5	338.8	338.9	339.0	339.2	339.2	339.4	339.5	339.7	339.8	339.7
150°	345.0	345.2	345.4	345.4	345.6	345.7	345.8	346.0	346.1	346.3	346.2
152.5°	350.8	351.0	351.0	351.1	351.1	351.2	351.5	351.7	352.0	352.2	352.1
155°	358.7	358.7	358.8	358.8	358.9	359.0	359.3	359.6	360.0	360.3	360.2
157.5°	366.0	366.0	365.9	365.8	365.7	365.7	366.1	366.5	366.9	367.3	367.2
160°	370.0	369.9	369.8	369.7	369.7	369.7	370.0	370.4	370.8	371.2	371.1
162.5°	373.5	373.3	373.2	373.2	373.2	373.1	373.5	374.0	374.4	374.8	374.9
165°	378.1	378.0	377.9	377.8	377.7	377.7	378.2	378.7	379.3	379.8	379.8
167.5°	381.5	381.4	381.4	381.4	381.4	381.4	381.9	382.4	382.9	383.4	383.4
170°	383.6	383.4	383.4	383.4	383.4	383.4	384.0	384.5	385.0	385.5	385.5
172.5°	384.7	384.7	384.7	384.7	384.8	384.8	385.4	385.9	386.4	386.9	386.9
175°	386.5	386.4	386.5	386.5	386.5	386.6	387.1	387.5	388.0	388.4	388.4
177.5°	387.2	387.1	387.2	387.2	387.3	387.3	387.8	388.2	388.6	389.0	388.9
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1234.9	1234.4	1234.9	1233.1	1234.9	1234.4	1234.9	1240.2	1240.2	1240.6	1241.0
5°	1149.1	1148.5	1146.9	1141.8	1146.9	1148.5	1149.1	1150.7	1155.2	1162.9	1160.7
7.5°	1074.2	1073.4	1068.5	1068.6	1068.5	1073.4	1074.2	1078.5	1083.5	1088.3	1093.9
10°	1029.8	1030.3	1023.7	1019.8	1023.7	1030.3	1029.8	1033.6	1040.9	1044.7	1048.6
12.5°	986.8	984.1	978.8	974.5	978.8	984.1	986.8	989.7	999.6	1004.0	1011.4
15°	929.9	924.4	911.0	912.2	911.0	924.4	929.9	927.7	937.7	943.2	945.4
17.5°	863.0	858.9	858.7	850.9	858.7	858.9	863.0	867.4	876.1	882.1	898.0
20°	823.9	821.2	822.2	814.5	822.2	821.2	823.9	832.8	838.4	846.1	858.9
22.5°	793.3	790.5	785.9	783.4	785.9	790.5	793.3	799.5	805.5	816.4	823.4
25°	748.4	744.0	739.6	742.4	739.6	744.0	748.4	751.8	762.9	767.9	777.9
27.5°	703.7	700.3	695.9	695.3	695.9	700.3	703.7	706.9	713.0	721.4	733.4
30°	675.2	671.9	669.7	666.9	669.7	671.9	675.2	678.0	684.1	693.0	701.9
32.5°	646.4	645.7	641.7	641.2	641.7	645.7	646.4	650.9	657.0	665.4	673.0
35°	608.6	605.4	604.2	604.8	604.2	605.4	608.6	610.9	616.4	624.2	631.4
37.5°	572.8	568.3	566.4	564.4	566.4	568.3	572.8	573.2	578.8	584.0	593.8
40°	547.1	542.7	541.5	540.4	541.5	542.7	547.1	546.5	552.6	556.5	565.4
42.5°	518.2	516.4	515.8	513.8	515.8	516.4	518.2	521.2	524.6	530.4	537.0
45°	478.8	478.3	474.9	476.1	474.9	478.3	478.8	480.5	486.6	490.5	496.6
47.5°	437.3	434.9	432.5	434.1	432.5	434.9	437.3	439.5	443.7	448.4	456.5
50°	409.0	407.8	402.8	403.9	402.8	407.8	409.0	411.2	413.9	420.0	427.2
52.5°	380.5	376.3	374.4	373.7	374.4	376.3	380.5	382.7	386.0	393.0	398.4
55°	333.5	328.5	326.3	325.1	326.3	328.5	333.5	337.4	341.8	349.5	355.1
57.5°	287.3	285.9	284.2	285.4	284.2	285.9	287.3	293.8	298.1	304.2	311.0
60°	260.2	260.2	260.2	259.7	260.2	260.2	260.2	265.8	269.6	275.7	283.0
62.5°	239.4	238.0	237.6	238.4	237.6	238.0	239.4	241.8	245.6	249.6	255.9
65°	207.5	206.9	204.7	204.2	204.7	206.9	207.5	209.2	212.5	215.2	219.7
67.5°	177.4	175.5	174.8	174.0	174.8	175.5	177.4	178.9	181.1	184.7	186.9
70°	154.8	153.7	150.3	150.9	150.3	153.7	154.8	157.6	159.8	164.2	166.5
72.5°	130.4	129.3	128.6	127.8	128.6	129.3	130.4	133.1	135.3	140.2	143.8
75°	103.2	102.6	102.1	104.3	102.1	102.6	103.2	103.8	104.3	106.0	107.6
77.5°	82.7	82.7	83.0	82.1	83.0	82.7	82.7	82.7	82.7	83.6	83.9
80°	69.4	69.4	68.8	68.8	68.8	69.4	69.4	69.4	69.4	69.4	68.8
82.5°	55.6	56.0	56.3	55.5	56.3	56.0	55.6	56.5	56.9	56.0	56.3
85°	36.6	36.0	37.2	36.6	37.2	36.0	36.6	36.6	35.5	36.6	36.0
87.5°	18.1	17.2	17.2	17.7	17.2	17.2	18.1	17.1	17.1	17.0	16.6
90°	8.2	8.4	8.5	8.6	8.5	8.4	8.2	8.2	7.9	7.7	7.4
92.5°	9.3	9.4	9.5	9.5	9.5	9.4	9.3	9.3	9.0	8.6	8.2
95°	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.8	10.3	9.9
97.5°	11.7	11.7	11.8	11.9	11.8	11.7	11.7	11.6	11.3	10.8	10.3
100°	11.9	12.0	12.1	12.1	12.1	12.0	11.9	11.8	11.6	11.0	10.5
102.5°	12.0	12.1	12.2	12.3	12.2	12.1	12.0	11.9	12.6	14.2	15.8
105°	12.3	12.4	12.6	12.6	12.6	12.4	12.3	12.1	17.8	29.1	40.4
107.5°	65.5	56.9	48.3	39.8	48.3	56.9	65.5	73.9	82.4	90.7	99.1
110°	106.7	97.5	88.4	79.2	88.4	97.5	106.7	115.9	121.5	123.6	125.7



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	141.7	139.8	137.9	135.9	137.9	139.8	141.7	143.7	144.6	144.6	144.6
115°	168.6	168.9	169.2	169.4	169.2	168.9	168.6	168.4	168.0	167.3	166.6
117.5°	188.0	188.1	188.2	188.2	188.2	188.1	188.0	188.0	187.7	187.2	186.7
120°	201.1	201.1	201.1	201.1	201.1	201.1	201.1	201.1	200.8	200.3	199.8
122.5°	213.6	213.7	213.7	213.8	213.7	213.7	213.6	213.5	213.4	213.0	212.6
125°	231.2	231.4	231.5	231.6	231.5	231.4	231.2	231.1	231.0	230.9	230.7
127.5°	249.2	249.1	248.9	248.8	248.9	249.1	249.2	249.3	249.3	249.1	248.8
130°	260.2	260.2	260.0	259.8	260.0	260.2	260.2	260.4	260.3	260.1	259.8
132.5°	270.5	270.4	270.2	270.0	270.2	270.4	270.5	270.8	270.7	270.4	270.2
135°	286.1	285.9	285.7	285.5	285.7	285.9	286.1	286.3	286.3	286.1	285.9
137.5°	300.4	300.4	300.2	300.1	300.2	300.4	300.4	300.6	300.5	300.2	299.9
140°	309.2	309.1	309.0	308.8	309.0	309.1	309.2	309.3	309.3	309.0	308.8
142.5°	317.5	317.2	317.1	316.9	317.1	317.2	317.5	317.6	317.6	317.4	317.2
145°	329.3	329.3	329.3	329.3	329.3	329.3	329.3	329.3	329.2	329.1	329.0
147.5°	339.4	339.1	338.8	338.5	338.8	339.1	339.4	339.7	339.8	339.7	339.5
150°	346.0	345.8	345.6	345.4	345.6	345.8	346.0	346.2	346.3	346.1	346.0
152.5°	351.9	351.6	351.2	351.0	351.2	351.6	351.9	352.1	352.2	352.0	351.7
155°	359.9	359.5	359.1	358.7	359.1	359.5	359.9	360.2	360.3	360.0	359.6
157.5°	366.7	366.2	365.7	365.2	365.7	366.2	366.7	367.2	367.3	366.9	366.5
160°	370.7	370.2	369.8	369.3	369.8	370.2	370.7	371.1	371.2	370.8	370.4
162.5°	374.5	374.1	373.7	373.2	373.7	374.1	374.5	374.9	374.8	374.4	374.0
165°	379.4	378.9	378.5	378.0	378.5	378.9	379.4	379.8	379.8	379.3	378.7
167.5°	382.9	382.4	381.9	381.4	381.9	382.4	382.9	383.4	383.4	382.9	382.4
170°	385.0	384.5	384.0	383.4	384.0	384.5	385.0	385.5	385.5	385.0	384.5
172.5°	386.3	385.7	385.1	384.6	385.1	385.7	386.3	386.9	386.9	386.4	385.9
175°	387.9	387.3	386.9	386.4	386.9	387.3	387.9	388.4	388.4	388.0	387.5
177.5°	388.4	387.9	387.3	386.9	387.3	387.9	388.4	388.9	389.0	388.6	388.2
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1237.1	1243.2	1249.5	1255.2	1264.1	1268.1	1273.9	1276.1	1282.8	1292.6	1300.6
5°	1161.8	1170.7	1182.3	1191.8	1206.8	1218.4	1231.2	1243.4	1257.8	1278.3	1296.7
7.5°	1098.0	1106.8	1120.8	1138.3	1154.9	1171.3	1188.8	1205.4	1226.0	1255.5	1284.7
10°	1055.9	1066.4	1083.0	1101.9	1122.4	1138.6	1159.0	1180.1	1205.7	1239.5	1274.5
12.5°	1019.5	1027.4	1046.7	1064.6	1087.9	1108.3	1128.5	1153.1	1182.1	1218.2	1260.3
15°	961.6	972.7	991.5	1011.5	1035.9	1057.5	1083.6	1113.5	1141.8	1186.3	1237.3
17.5°	903.4	920.2	939.9	962.5	980.5	1010.3	1038.7	1069.4	1104.2	1151.3	1207.3
20°	866.1	879.4	897.7	930.5	954.3	977.1	1003.1	1041.5	1073.6	1126.9	1185.1
22.5°	834.6	844.3	864.9	891.9	919.7	946.0	972.5	1009.0	1048.7	1099.3	1162.5
25°	787.9	803.4	819.0	838.4	868.3	899.9	928.8	959.9	1002.0	1055.9	1124.1
27.5°	742.2	756.4	771.7	795.5	818.2	847.8	878.0	913.6	958.9	1015.8	1085.0
30°	713.0	723.5	737.9	768.4	789.0	814.5	850.0	881.7	923.8	984.3	1057.5
32.5°	682.8	696.4	712.2	735.6	761.0	785.2	817.6	851.9	895.0	954.6	1029.6
35°	639.8	655.8	671.9	689.1	714.6	739.6	766.8	804.5	848.3	906.0	979.8
37.5°	600.1	613.1	626.1	647.5	671.7	695.5	720.8	758.0	799.3	861.5	929.3
40°	574.8	586.4	596.5	618.6	642.0	667.5	692.4	725.2	769.6	827.9	893.3
42.5°	547.3	558.1	571.6	589.8	614.9	636.4	661.4	692.4	734.0	793.2	850.7
45°	506.0	518.2	529.9	547.1	572.0	593.1	615.3	644.7	687.5	736.3	787.3
47.5°	463.1	475.2	488.6	505.2	527.0	548.4	570.6	596.6	635.6	683.5	718.0
50°	435.5	445.6	458.9	475.5	495.5	518.2	538.2	566.5	603.6	641.4	671.3
52.5°	407.2	416.2	431.3	448.9	467.5	487.1	508.4	532.7	566.4	601.9	625.7
55°	362.9	374.0	386.7	403.9	422.2	438.9	459.4	484.4	511.0	537.6	553.8
57.5°	321.5	330.7	341.4	359.2	375.0	394.9	413.4	432.8	457.4	477.5	488.0
60°	291.3	299.6	313.5	329.1	344.0	361.2	382.3	401.7	420.5	436.7	445.0
62.5°	262.9	272.6	284.6	298.8	315.1	331.5	349.8	366.2	382.9	396.7	402.4
65°	225.8	233.6	242.5	255.8	269.1	285.8	300.2	316.8	329.1	336.8	341.8
67.5°	192.1	197.2	204.0	212.9	225.9	240.4	254.5	267.4	277.6	283.0	287.4
70°	170.3	173.7	178.6	187.5	197.5	210.3	224.7	234.2	243.0	247.4	251.9
72.5°	148.5	152.8	157.4	164.4	172.7	181.9	192.3	204.0	208.9	214.2	216.9
75°	112.6	118.7	124.8	129.3	134.9	142.0	151.5	158.7	161.4	165.9	166.5
77.5°	85.0	86.3	90.7	96.3	101.0	106.2	112.2	118.6	119.9	122.3	123.8
80°	69.9	69.9	69.9	73.2	78.8	82.7	88.2	91.6	93.8	94.3	94.9
82.5°	56.2	56.2	55.7	56.3	58.4	60.5	65.6	69.4	71.1	70.8	69.5
85°	36.6	35.5	35.5	35.0	35.5	34.4	33.8	36.0	39.4	39.4	38.3
87.5°	16.6	16.1	16.3	15.7	15.1	14.5	13.0	13.3	13.2	14.8	14.3
90°	7.2	6.9	6.1	5.2	4.4	3.6	2.9	2.2	1.5	0.9	0.3
92.5°	7.7	7.3	6.8	6.1	5.5	4.9	4.6	4.8	5.0	5.2	5.4
95°	9.4	9.0	8.2	7.5	6.8	6.1	7.1	9.7	12.3	14.9	17.6
97.5°	9.8	9.3	13.9	18.5	23.1	27.7	30.6	31.8	32.9	34.2	35.3
100°	10.0	9.5	19.5	29.5	39.5	49.5	53.8	52.5	51.3	50.0	48.7
102.5°	17.4	19.0	29.8	40.8	51.7	62.6	67.6	66.7	65.7	64.8	63.9
105°	51.8	63.1	68.9	74.6	80.4	86.2	88.7	88.0	87.2	86.6	85.9
107.5°	107.3	115.6	114.7	113.8	112.9	112.0	111.3	110.7	110.1	109.6	109.0
110°	127.8	130.0	129.2	128.5	127.8	127.1	126.5	126.0	125.5	125.0	124.5



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	144.5	144.5	143.7	143.1	142.4	141.6	141.0	140.6	140.1	139.7	139.2
115°	166.0	165.3	164.8	164.2	163.6	163.1	162.6	162.2	161.8	161.4	161.0
117.5°	186.1	185.6	185.4	185.1	184.7	184.5	184.1	183.6	183.1	182.7	182.2
120°	199.3	198.8	198.6	198.4	198.2	198.0	197.6	197.1	196.5	195.9	195.3
122.5°	212.3	211.9	211.7	211.4	211.2	210.9	210.6	210.1	209.6	209.2	208.7
125°	230.6	230.5	230.2	230.0	229.8	229.4	229.1	228.5	228.0	227.6	227.1
127.5°	248.7	248.4	248.2	247.9	247.5	247.2	246.8	246.3	245.8	245.3	244.8
130°	259.5	259.3	259.0	258.8	258.5	258.3	257.9	257.4	256.8	256.3	255.8
132.5°	269.9	269.7	269.5	269.3	269.0	268.8	268.5	268.0	267.5	266.9	266.4
135°	285.7	285.5	285.3	285.0	284.7	284.5	284.1	283.8	283.4	283.0	282.7
137.5°	299.6	299.3	299.1	299.0	298.9	298.7	298.4	297.9	297.4	296.9	296.4
140°	308.5	308.3	308.1	307.9	307.7	307.5	307.2	306.8	306.5	306.1	305.7
142.5°	317.0	316.8	316.6	316.4	316.3	316.0	315.8	315.4	315.0	314.6	314.2
145°	328.9	328.7	328.6	328.5	328.3	328.2	327.9	327.5	327.0	326.6	326.1
147.5°	339.4	339.2	339.2	339.0	338.9	338.8	338.5	338.3	337.9	337.7	337.4
150°	345.8	345.7	345.6	345.4	345.4	345.2	345.0	344.9	344.6	344.5	344.3
152.5°	351.5	351.2	351.1	351.1	351.0	351.0	350.8	350.7	350.7	350.6	350.5
155°	359.3	359.0	358.9	358.8	358.8	358.7	358.7	358.9	359.0	359.1	359.3
157.5°	366.1	365.7	365.7	365.8	365.9	366.0	366.0	366.0	366.1	366.1	366.1
160°	370.0	369.7	369.7	369.7	369.8	369.9	370.0	370.0	370.1	370.1	370.2
162.5°	373.5	373.1	373.2	373.2	373.2	373.3	373.5	373.7	373.8	374.0	374.1
165°	378.2	377.7	377.7	377.8	377.9	378.0	378.1	378.3	378.5	378.6	378.9
167.5°	381.9	381.4	381.4	381.4	381.4	381.4	381.5	381.8	382.0	382.3	382.5
170°	384.0	383.4	383.4	383.4	383.4	383.4	383.6	383.8	384.1	384.3	384.6
172.5°	385.4	384.8	384.8	384.7	384.7	384.7	384.7	385.1	385.4	385.7	386.0
175°	387.1	386.6	386.5	386.5	386.5	386.4	386.5	386.9	387.1	387.4	387.8
177.5°	387.8	387.3	387.3	387.2	387.2	387.1	387.2	387.5	387.8	388.0	388.2
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1303.2	1308.1	1314.3	1323.6	1330.7	1336.9	1338.2	1340.0	1344.5	1352.0	1357.8
5°	1311.7	1324.4	1344.9	1364.9	1386.6	1404.3	1420.9	1432.6	1443.7	1467.0	1485.9
7.5°	1309.0	1337.4	1369.5	1405.4	1441.7	1476.8	1509.5	1538.7	1567.7	1601.7	1640.5
10°	1307.2	1340.5	1383.7	1429.8	1480.3	1529.7	1577.4	1614.6	1657.8	1696.7	1746.0
12.5°	1298.8	1346.7	1398.4	1457.3	1519.4	1576.3	1639.1	1690.4	1740.0	1796.1	1853.5
15°	1287.8	1346.1	1411.5	1489.7	1584.0	1652.9	1717.2	1806.5	1867.6	1928.6	2010.8
17.5°	1267.7	1338.8	1420.6	1522.2	1600.9	1693.4	1790.2	1860.8	1943.0	2029.0	2103.4
20°	1251.7	1334.4	1426.0	1525.8	1626.2	1726.6	1820.4	1904.8	1989.7	2089.0	2150.0
22.5°	1235.7	1317.5	1412.6	1518.7	1626.7	1732.4	1838.6	1937.6	2033.1	2133.3	2211.3
25°	1201.8	1298.9	1402.1	1510.3	1616.8	1733.3	1859.8	1970.3	2088.4	2191.6	2265.4
27.5°	1167.3	1256.4	1359.1	1468.8	1587.3	1725.0	1873.8	1999.3	2117.7	2191.6	2214.8
30°	1136.3	1230.6	1324.9	1436.5	1564.6	1718.3	1876.5	2020.1	2117.3	2149.5	2125.6
32.5°	1104.8	1190.3	1283.7	1397.8	1534.0	1701.9	1880.0	2007.8	2066.2	2041.6	1944.5
35°	1049.2	1126.3	1216.8	1331.1	1487.5	1692.8	1865.4	1951.9	1937.5	1798.8	1615.7
37.5°	989.7	1052.6	1136.3	1255.8	1439.3	1656.8	1802.3	1815.1	1690.3	1477.3	1265.8
40°	942.6	999.2	1085.2	1210.1	1402.1	1621.2	1738.9	1687.3	1493.6	1256.7	1080.3
42.5°	896.9	944.7	1027.5	1162.1	1366.6	1572.9	1644.3	1531.9	1308.6	1084.5	924.1
45°	819.5	864.5	947.6	1085.8	1293.9	1480.3	1470.9	1275.5	1052.0	871.6	738.5
47.5°	746.0	785.3	863.4	1004.4	1208.5	1341.6	1253.4	1045.5	855.9	711.2	616.2
50°	694.1	733.0	810.7	949.9	1140.2	1237.3	1111.3	911.0	737.4	617.5	542.1
52.5°	644.4	682.3	753.3	889.1	1057.6	1115.7	980.4	794.8	650.0	546.5	481.7
55°	574.8	603.6	667.5	797.3	923.2	936.5	799.5	644.2	524.9	452.7	408.4
57.5°	503.9	528.7	591.8	695.2	783.5	776.7	646.7	512.3	432.0	378.4	346.3
60°	457.7	482.2	537.6	626.4	693.0	669.7	550.4	442.2	373.4	334.0	308.5
62.5°	414.7	433.7	485.7	550.5	598.4	572.0	470.5	381.0	326.4	293.2	273.0
65°	352.3	367.9	409.4	443.3	469.9	444.4	360.1	297.9	258.5	235.2	221.4
67.5°	293.1	303.0	329.2	341.4	360.2	332.2	270.8	229.2	206.8	187.1	177.4
70°	255.8	263.0	276.9	286.8	291.9	263.0	217.5	186.9	168.1	154.3	148.1
72.5°	218.5	224.9	227.6	235.8	233.3	206.2	174.9	150.6	137.1	127.6	119.8
75°	167.0	169.7	167.0	163.7	156.5	137.6	115.9	103.8	93.8	89.4	86.6
77.5°	121.7	120.8	117.1	111.9	99.5	87.6	76.0	71.9	67.6	65.2	64.2
80°	93.8	91.6	88.2	79.9	69.4	61.1	58.3	55.5	53.8	51.0	50.5
82.5°	69.8	68.5	62.9	55.9	48.5	44.6	42.3	41.3	39.6	38.2	38.1
85°	37.2	35.5	29.4	25.5	24.4	23.3	22.7	22.7	20.5	20.0	20.0
87.5°	12.1	9.6	9.3	8.2	8.2	7.6	8.2	7.4	7.2	7.7	6.8
90°	0.9	1.5	2.2	2.9	3.6	4.4	5.2	6.1	6.9	7.2	7.4
92.5°	5.2	5.0	4.8	4.6	4.9	5.5	6.1	6.8	7.3	7.7	8.2
95°	14.9	12.3	9.7	7.1	6.1	6.8	7.5	8.2	9.0	9.4	9.9
97.5°	34.2	32.9	31.8	30.6	27.7	23.1	18.5	13.9	9.3	9.8	10.3
100°	50.0	51.3	52.5	53.8	49.5	39.5	29.5	19.5	9.5	10.0	10.5
102.5°	64.8	65.7	66.7	67.6	62.6	51.7	40.8	29.8	19.0	17.4	15.8
105°	86.6	87.2	88.0	88.7	86.2	80.4	74.6	68.9	63.1	51.8	40.4
107.5°	109.6	110.1	110.7	111.3	112.0	112.9	113.8	114.7	115.6	107.3	99.1
110°	125.0	125.5	126.0	126.5	127.1	127.8	128.5	129.2	130.0	127.8	125.7



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	139.7	140.1	140.6	141.0	141.6	142.4	143.1	143.7	144.5	144.5	144.6
115°	161.4	161.8	162.2	162.6	163.1	163.6	164.2	164.8	165.3	166.0	166.6
117.5°	182.7	183.1	183.6	184.1	184.5	184.7	185.1	185.4	185.6	186.1	186.7
120°	195.9	196.5	197.1	197.6	198.0	198.2	198.4	198.6	198.8	199.3	199.8
122.5°	209.2	209.6	210.1	210.6	210.9	211.2	211.4	211.7	211.9	212.3	212.6
125°	227.6	228.0	228.5	229.1	229.4	229.8	230.0	230.2	230.5	230.6	230.7
127.5°	245.3	245.8	246.3	246.8	247.2	247.5	247.9	248.2	248.4	248.7	248.8
130°	256.3	256.8	257.4	257.9	258.3	258.5	258.8	259.0	259.3	259.5	259.8
132.5°	266.9	267.5	268.0	268.5	268.8	269.0	269.3	269.5	269.7	269.9	270.2
135°	283.0	283.4	283.8	284.1	284.5	284.7	285.0	285.3	285.5	285.7	285.9
137.5°	296.9	297.4	297.9	298.4	298.7	298.9	299.0	299.1	299.3	299.6	299.9
140°	306.1	306.5	306.8	307.2	307.5	307.7	307.9	308.1	308.3	308.5	308.8
142.5°	314.6	315.0	315.4	315.8	316.0	316.3	316.4	316.6	316.8	317.0	317.2
145°	326.6	327.0	327.5	327.9	328.2	328.3	328.5	328.6	328.7	328.9	329.0
147.5°	337.7	337.9	338.3	338.5	338.8	338.9	339.0	339.2	339.2	339.4	339.5
150°	344.5	344.6	344.9	345.0	345.2	345.4	345.4	345.6	345.7	345.8	346.0
152.5°	350.6	350.7	350.7	350.8	351.0	351.0	351.1	351.1	351.2	351.5	351.7
155°	359.1	359.0	358.9	358.7	358.7	358.8	358.8	358.9	359.0	359.3	359.6
157.5°	366.1	366.1	366.0	366.0	366.0	365.9	365.8	365.7	365.7	366.1	366.5
160°	370.1	370.1	370.0	370.0	369.9	369.8	369.7	369.7	369.7	370.0	370.4
162.5°	374.0	373.8	373.7	373.5	373.3	373.2	373.2	373.2	373.1	373.5	374.0
165°	378.6	378.5	378.3	378.1	378.0	377.9	377.8	377.7	377.7	378.2	378.7
167.5°	382.3	382.0	381.8	381.5	381.4	381.4	381.4	381.4	381.4	381.9	382.4
170°	384.3	384.1	383.8	383.6	383.4	383.4	383.4	383.4	383.4	384.0	384.5
172.5°	385.7	385.4	385.1	384.7	384.7	384.7	384.7	384.8	384.8	385.4	385.9
175°	387.4	387.1	386.9	386.5	386.4	386.5	386.5	386.5	386.6	387.1	387.5
177.5°	388.0	387.8	387.5	387.2	387.1	387.2	387.2	387.3	387.3	387.8	388.2
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8	387.8



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
0°	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1	1296.1
2.5°	1367.1	1367.1	1368.9	1375.6	1376.5	1382.2	1380.5
5°	1502.5	1513.0	1516.9	1533.6	1543.5	1548.0	1539.1
7.5°	1668.1	1697.8	1711.9	1729.3	1744.7	1749.4	1737.3
10°	1788.8	1819.8	1845.9	1862.1	1877.0	1887.0	1899.7
12.5°	1905.5	1943.7	1968.5	1991.2	2006.6	2019.3	2021.4
15°	2032.4	2090.1	2133.9	2166.1	2182.1	2190.5	2187.2
17.5°	2160.3	2213.8	2245.0	2277.9	2300.1	2301.3	2301.9
20°	2232.7	2284.8	2320.9	2345.3	2370.2	2369.2	2374.7
22.5°	2281.0	2322.1	2349.8	2367.5	2376.0	2371.8	2372.9
25°	2303.7	2315.9	2310.9	2282.6	2275.4	2249.3	2253.7
27.5°	2187.0	2129.2	2069.6	1992.8	1932.2	1883.7	1886.2
30°	2028.5	1926.4	1809.9	1712.2	1624.6	1600.2	1548.0
32.5°	1807.0	1653.8	1517.4	1426.4	1351.1	1330.7	1285.2
35°	1431.5	1282.8	1142.4	1058.1	1024.7	978.2	977.6
37.5°	1112.6	981.7	907.5	844.2	811.1	782.9	780.1
40°	936.0	833.9	777.9	732.4	699.7	678.6	673.6
42.5°	812.6	730.0	677.6	649.4	624.2	613.3	605.2
45°	663.6	608.1	571.4	545.9	534.3	525.9	521.5
47.5°	555.1	517.9	492.9	476.0	466.5	457.7	460.1
50°	496.0	465.5	447.2	431.1	423.9	417.8	418.3
52.5°	448.5	421.1	406.3	394.7	385.7	381.4	379.3
55°	380.6	363.4	348.5	340.1	335.1	329.1	327.3
57.5°	324.7	311.4	299.1	289.8	288.5	282.7	283.4
60°	287.4	276.3	266.4	261.3	257.5	252.4	254.1
62.5°	256.8	247.4	238.4	234.2	230.4	226.7	227.5
65°	210.3	201.4	195.8	193.6	192.0	190.3	188.7
67.5°	167.5	162.2	158.7	153.9	150.5	149.9	148.2
70°	141.0	133.7	127.6	121.5	119.8	119.3	119.8
72.5°	113.0	108.4	106.7	103.8	103.5	102.0	103.0
75°	84.9	83.2	82.1	79.9	79.9	79.9	79.9
77.5°	62.6	61.6	60.9	60.5	59.9	59.1	59.0
80°	48.8	48.3	47.1	47.1	46.6	47.1	46.6
82.5°	36.9	36.8	35.6	35.6	35.1	34.7	35.1
85°	18.8	18.3	19.4	18.3	18.8	17.8	18.8
87.5°	6.8	6.9	6.5	6.5	6.1	7.0	6.2
90°	7.7	7.9	8.2	8.2	8.4	8.5	8.6
92.5°	8.6	9.0	9.3	9.3	9.4	9.5	9.5
95°	10.3	10.8	10.9	10.9	10.9	10.9	10.9
97.5°	10.8	11.3	11.6	11.7	11.7	11.8	11.9
100°	11.0	11.6	11.8	11.9	12.0	12.1	12.1
102.5°	14.2	12.6	11.9	12.0	12.1	12.2	12.3
105°	29.1	17.8	12.1	12.3	12.4	12.6	12.6
107.5°	90.7	82.4	73.9	65.5	56.9	48.3	39.8
110°	123.6	121.5	115.9	106.7	97.5	88.4	79.2



TEST NUMBER: P332330-930

CATALOG NUMBER: S123RDIP-S1000D365U930-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
112.5°	144.6	144.6	143.7	141.7	139.8	137.9	135.9
115°	167.3	168.0	168.4	168.6	168.9	169.2	169.4
117.5°	187.2	187.7	188.0	188.0	188.1	188.2	188.2
120°	200.3	200.8	201.1	201.1	201.1	201.1	201.1
122.5°	213.0	213.4	213.5	213.6	213.7	213.7	213.8
125°	230.9	231.0	231.1	231.2	231.4	231.5	231.6
127.5°	249.1	249.3	249.3	249.2	249.1	248.9	248.8
130°	260.1	260.3	260.4	260.2	260.2	260.0	259.8
132.5°	270.4	270.7	270.8	270.5	270.4	270.2	270.0
135°	286.1	286.3	286.3	286.1	285.9	285.7	285.5
137.5°	300.2	300.5	300.6	300.4	300.4	300.2	300.1
140°	309.0	309.3	309.3	309.2	309.1	309.0	308.8
142.5°	317.4	317.6	317.6	317.5	317.2	317.1	316.9
145°	329.1	329.2	329.3	329.3	329.3	329.3	329.3
147.5°	339.7	339.8	339.7	339.4	339.1	338.8	338.5
150°	346.1	346.3	346.2	346.0	345.8	345.6	345.4
152.5°	352.0	352.2	352.1	351.9	351.6	351.2	351.0
155°	360.0	360.3	360.2	359.9	359.5	359.1	358.7
157.5°	366.9	367.3	367.2	366.7	366.2	365.7	365.2
160°	370.8	371.2	371.1	370.7	370.2	369.8	369.3
162.5°	374.4	374.8	374.9	374.5	374.1	373.7	373.2
165°	379.3	379.8	379.8	379.4	378.9	378.5	378.0
167.5°	382.9	383.4	383.4	382.9	382.4	381.9	381.4
170°	385.0	385.5	385.5	385.0	384.5	384.0	383.4
172.5°	386.4	386.9	386.9	386.3	385.7	385.1	384.6
175°	388.0	388.4	388.4	387.9	387.3	386.9	386.4
177.5°	388.6	389.0	388.9	388.4	387.9	387.3	386.9
180°	387.8	387.8	387.8	387.8	387.8	387.8	387.8

(END OF REPORT)