

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P332312-840

Luminaire Tested: **S123RDIP-S775D805U840-4F0-1E-UDD-A**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P332312-840
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-5,
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: NEO-RAY
Catalog Number: S123RDIP-S775D805U840-4F0-1E-UDD-A
Description: DEFINE 3 DIRECT-INDIRECT PENDANT LED LUMINAIRE
DOWNLIGHT 775 LUMENS PER FOOT, ASYMMETRIC DIFFUSER, REGRESSED HOUSING
UPLIGHT 805 LUMENS PER FOOT, NO LENS
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6318.8 lumens
Efficiency: N/A
Efficacy: 137.7 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.22 / 1.36
Luminous Opening: Rectangular (W 4' x L: 0.25' x H: 0')
CIE Type: General Diffuse


Input Watts (W): 45.9
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

Luminous Intensity Polar Plot





TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	107	107	107	107	98	98	98	98	83	83	83	68	68	68	55	55	55	49
1	98	94	90	87	90	87	84	81	73	71	69	61	59	58	49	48	47	42
2	90	83	77	72	83	77	71	67	65	61	58	54	52	49	44	42	41	36
3	82	73	66	61	76	68	62	57	58	53	49	48	45	42	40	37	35	31
4	75	65	58	52	69	60	54	49	52	47	43	43	40	37	36	33	31	27
5	69	58	50	45	64	54	47	42	46	41	37	39	35	32	32	30	27	24
6	64	52	45	39	59	49	42	37	42	37	33	36	32	28	30	27	24	21
7	59	47	40	34	55	44	37	33	38	33	29	33	28	25	27	24	22	19
8	55	43	36	31	51	40	34	29	35	30	26	30	26	23	25	22	20	17
9	51	40	32	27	47	37	30	26	32	27	23	28	23	20	23	20	18	16
10	48	36	29	25	44	34	28	23	30	25	21	25	21	19	22	18	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	13295	13295	13295	13295
5°	15847	13351	11757	13351
10°	19787	13274	10622	13274
15°	23226	13138	9686	13138
20°	25921	12936	8891	12936
25°	25508	12722	8402	12722
30°	18334	12525	7899	12525
35°	12242	12269	7573	12269
40°	9020	11960	7235	11960
45°	7566	11420	6905	11420
50°	6677	10712	6445	10712
55°	5853	9903	5814	9903
60°	5214	9128	5326	9128
65°	4579	8295	4956	8295
70°	3594	7553	4526	7553
75°	3165	6596	4134	6596
80°	2752	5604	4060	5604
85°	2223	4508	4310	4508



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	121.5	1.9
10°-20°	379.5	6.0
20°-30°	596.1	9.4
30°-40°	621.9	9.8
40°-50°	532.3	8.4
50°-60°	405.7	6.4
60°-70°	260.0	4.1
70°-80°	125.1	2.0
80°-90°	36.1	0.6
90°-100°	38.6	0.6
100°-110°	184.1	2.9
110°-120°	442.3	7.0
120°-130°	563.2	8.9
130°-140°	601.8	9.5
140°-150°	562.7	8.9
150°-160°	453.9	7.2
160°-170°	293.0	4.6
170°-180°	101.0	1.6
0°-30°	1097.0	17.4
0°-40°	1719.0	27.2
0°-60°	2656.9	42.0
0°-90°	3078.1	48.7
90°-120°	665.1	10.5
90°-150°	2392.8	37.9
90°-180°	3241.0	51.3
0°-180°	6318.8	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1235	1235	1235	1235	1235	
5°	1467	1236	1088	1236	1467	151
15°	2084	1179	869	1179	2084	591
25°	2148	1071	707	1071	2148	923
35°	932	934	576	934	932	611
45°	497	750	454	750	497	391
55°	312	528	310	528	312	282
65°	180	326	195	326	180	177
75°	76	159	99	159	76	82
85°	18	36	35	36	18	21
90°	24	1	24	1	24	11
95°	30	48	30	48	30	25
105°	35	235	35	235	35	79
115°	464	441	464	441	464	429
125°	635	622	635	622	635	567
135°	782	774	782	774	782	603
145°	902	894	902	894	902	563
155°	983	984	983	984	983	453
165°	1036	1038	1036	1038	1036	292
175°	1059	1063	1059	1063	1059	101
180°	1063	1063	1063	1063	1063	



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1315.5	1317.2	1311.6	1310.8	1304.4	1302.7	1302.7	1293.8	1288.4	1281.2	1277.0
5°	1466.6	1475.1	1470.9	1461.4	1445.5	1441.8	1431.8	1415.9	1398.0	1375.7	1365.1
7.5°	1655.5	1667.1	1662.6	1647.9	1631.3	1617.9	1589.5	1563.2	1526.3	1493.9	1466.2
10°	1810.3	1798.2	1788.7	1774.3	1759.1	1734.1	1704.6	1663.9	1616.8	1579.8	1538.5
12.5°	1926.2	1924.2	1912.2	1897.4	1875.8	1852.2	1815.8	1766.3	1711.5	1658.1	1610.9
15°	2084.2	2087.4	2079.4	2064.1	2033.5	1991.7	1936.7	1916.0	1837.9	1779.7	1721.5
17.5°	2193.5	2192.9	2191.8	2170.6	2139.3	2109.6	2058.6	2004.4	1933.5	1851.6	1773.2
20°	2262.9	2257.7	2258.7	2234.8	2211.6	2177.3	2127.6	2048.8	1990.6	1896.0	1815.0
22.5°	2261.2	2260.2	2264.2	2256.0	2239.1	2212.8	2173.6	2107.2	2033.0	1937.4	1846.3
25°	2147.7	2143.4	2168.3	2175.1	2202.1	2206.9	2195.2	2158.8	2088.4	1990.0	1877.4
27.5°	1797.5	1795.1	1841.2	1899.0	1972.1	2029.0	2084.0	2110.5	2088.4	2018.0	1905.2
30°	1475.1	1524.8	1548.1	1631.6	1724.6	1835.7	1933.0	2025.5	2048.2	2017.6	1925.0
32.5°	1224.8	1268.1	1287.5	1359.2	1445.9	1576.0	1721.9	1852.9	1945.5	1968.9	1913.2
35°	931.6	932.1	976.5	1008.2	1088.6	1222.3	1364.1	1539.6	1714.0	1846.2	1860.0
37.5°	743.4	746.0	772.8	804.5	864.7	935.5	1060.3	1206.2	1407.8	1610.6	1729.6
40°	641.9	646.6	666.7	697.9	741.2	794.7	891.9	1029.5	1197.5	1423.3	1607.8
42.5°	576.7	584.4	594.8	618.8	645.7	695.7	774.4	880.5	1033.4	1246.9	1459.8
45°	497.0	501.2	509.2	520.3	544.6	579.5	632.4	703.7	830.6	1002.5	1215.5
47.5°	438.4	436.2	444.5	453.5	469.7	493.5	529.0	587.2	677.7	815.6	996.3
50°	398.7	398.1	403.9	410.8	426.2	443.6	472.7	516.5	588.4	702.7	868.2
52.5°	361.4	363.5	367.6	376.2	387.2	401.3	427.4	459.0	520.8	619.4	757.3
55°	311.9	313.6	319.3	324.1	332.0	346.3	362.7	389.1	431.4	500.2	613.8
57.5°	270.0	269.3	274.9	276.1	285.1	296.7	309.4	329.9	360.6	411.6	488.2
60°	242.2	240.5	245.3	249.0	253.8	263.3	273.9	294.0	318.3	355.8	421.4
62.5°	216.8	216.0	219.5	223.2	227.1	235.8	244.7	260.1	279.3	311.0	363.0
65°	179.8	181.4	182.9	184.5	186.6	191.9	200.4	211.0	224.2	246.4	283.9
67.5°	141.3	142.9	143.4	146.6	151.2	154.5	159.7	169.1	178.2	197.0	218.3
70°	114.2	113.7	114.2	115.8	121.6	127.4	134.3	141.2	146.9	160.2	178.1
72.5°	98.2	97.1	98.6	98.9	101.7	103.3	107.7	114.1	121.6	130.6	143.5
75°	76.1	76.1	76.1	76.1	78.3	79.3	80.9	82.5	85.1	89.4	98.9
77.5°	56.2	56.4	57.1	57.7	58.1	58.7	59.7	61.2	62.2	64.4	68.6
80°	44.4	44.9	44.4	44.9	44.9	45.9	46.6	48.1	48.7	51.3	52.9
82.5°	33.4	33.1	33.4	33.9	33.9	35.0	35.1	36.3	36.4	37.8	39.4
85°	18.0	17.0	18.0	17.5	18.5	17.5	18.0	19.0	19.0	19.6	21.7
87.5°	9.0	9.7	8.8	9.2	9.1	9.4	9.3	9.2	9.9	9.3	9.3
90°	23.7	23.3	23.0	22.6	22.3	21.7	21.0	20.4	19.7	19.0	16.7
92.5°	26.3	26.0	25.8	25.5	25.3	24.7	23.5	22.4	21.3	20.2	18.5
95°	30.0	30.0	30.0	30.0	30.0	29.4	28.2	27.0	25.8	24.4	22.5
97.5°	32.5	32.3	32.2	32.0	31.8	31.0	29.6	28.3	26.9	25.4	38.1
100°	33.1	33.0	32.8	32.6	32.4	31.7	30.3	28.9	27.5	26.1	53.4
102.5°	33.8	33.4	33.1	32.8	32.5	34.5	38.9	43.2	47.6	51.9	81.8
105°	34.7	34.4	34.0	33.7	33.3	48.7	79.8	110.8	141.9	172.9	188.6
107.5°	109.1	132.5	155.9	179.4	202.7	225.8	248.6	271.4	294.2	316.9	314.4
110°	217.1	242.2	267.3	292.4	317.5	333.0	338.7	344.5	350.3	356.1	354.2



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	372.5	377.8	383.0	388.4	393.6	396.3	396.2	396.1	396.0	395.9	393.9
115°	464.2	463.5	462.8	462.1	461.4	460.2	458.5	456.7	454.9	453.2	451.6
117.5°	515.7	515.5	515.4	515.3	515.1	514.3	513.0	511.6	510.2	508.8	508.0
120°	551.1	551.1	551.1	551.1	551.1	550.4	549.0	547.5	546.1	544.7	544.2
122.5°	585.8	585.7	585.5	585.4	585.2	584.7	583.7	582.7	581.8	580.8	580.1
125°	634.8	634.4	634.1	633.7	633.4	633.0	632.7	632.3	632.0	631.6	630.9
127.5°	681.9	682.2	682.6	682.9	683.2	683.1	682.6	682.0	681.5	680.9	680.0
130°	712.2	712.5	712.9	713.2	713.6	713.4	712.7	712.0	711.2	710.5	709.8
132.5°	739.9	740.4	740.9	741.4	741.8	741.7	741.0	740.3	739.7	739.0	738.4
135°	782.4	782.9	783.5	784.0	784.5	784.5	784.0	783.5	782.9	782.4	781.7
137.5°	822.3	822.7	823.0	823.4	823.7	823.5	822.6	821.8	821.0	820.1	819.7
140°	846.4	846.7	847.1	847.4	847.8	847.6	846.9	846.2	845.5	844.8	844.2
142.5°	868.5	869.0	869.4	869.9	870.4	870.4	869.8	869.3	868.7	868.2	867.6
145°	902.4	902.4	902.4	902.4	902.4	902.2	901.9	901.5	901.2	900.8	900.5
147.5°	927.7	928.5	929.3	930.1	930.9	931.1	930.8	930.4	930.1	929.7	929.4
150°	946.6	947.2	947.7	948.2	948.8	948.8	948.5	948.1	947.8	947.5	947.1
152.5°	961.8	962.6	963.4	964.2	965.0	965.1	964.4	963.8	963.2	962.6	962.4
155°	982.9	984.0	985.0	986.1	987.1	987.2	986.3	985.5	984.6	983.7	983.5
157.5°	1000.8	1002.2	1003.5	1004.9	1006.2	1006.4	1005.3	1004.3	1003.3	1002.2	1002.4
160°	1012.2	1013.4	1014.6	1015.8	1017.0	1017.1	1016.1	1015.0	1014.0	1012.9	1013.1
162.5°	1022.9	1024.0	1025.0	1026.1	1027.2	1027.1	1026.0	1024.8	1023.6	1022.4	1022.6
165°	1035.8	1037.0	1038.2	1039.6	1040.8	1040.7	1039.3	1037.8	1036.4	1035.0	1035.2
167.5°	1045.1	1046.5	1047.9	1049.4	1050.8	1050.8	1049.4	1047.9	1046.5	1045.1	1045.1
170°	1050.9	1052.3	1053.6	1055.0	1056.4	1056.4	1055.0	1053.6	1052.3	1050.9	1050.9
172.5°	1054.0	1055.5	1057.1	1058.6	1060.2	1060.3	1058.8	1057.4	1056.0	1054.6	1054.5
175°	1058.7	1060.2	1061.6	1063.0	1064.3	1064.4	1063.2	1062.0	1060.8	1059.6	1059.3
177.5°	1060.2	1061.6	1063.0	1064.4	1065.8	1065.9	1064.8	1063.7	1062.6	1061.4	1061.3
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1275.3	1273.9	1268.1	1261.3	1252.4	1246.5	1241.8	1239.3	1231.7	1222.3	1216.1
5°	1354.0	1338.2	1321.3	1300.6	1281.6	1262.0	1249.9	1235.6	1218.2	1198.6	1184.9
7.5°	1438.5	1407.3	1373.8	1339.3	1305.0	1274.4	1247.4	1224.2	1196.4	1168.3	1148.7
10°	1503.2	1457.6	1410.6	1362.5	1318.6	1277.4	1245.7	1214.5	1181.1	1148.9	1124.6
12.5°	1562.0	1502.1	1447.8	1388.8	1332.6	1283.3	1237.6	1200.9	1160.8	1126.5	1098.7
15°	1636.4	1575.1	1509.4	1419.6	1345.0	1282.6	1227.2	1179.0	1130.4	1088.1	1061.2
17.5°	1706.0	1613.7	1525.6	1450.6	1353.7	1275.8	1208.0	1150.4	1097.1	1052.3	1019.1
20°	1734.7	1645.4	1549.6	1454.0	1358.8	1271.5	1192.8	1129.3	1073.8	1023.1	992.4
22.5°	1752.0	1650.8	1550.0	1447.2	1346.2	1255.5	1177.6	1107.7	1047.6	999.4	961.5
25°	1772.2	1651.7	1540.7	1439.2	1336.1	1237.7	1145.2	1071.2	1006.1	954.8	914.6
27.5°	1785.5	1643.8	1512.6	1399.7	1295.2	1197.2	1112.4	1034.0	968.0	913.7	870.6
30°	1788.1	1637.4	1491.0	1368.9	1262.5	1172.7	1082.8	1007.7	938.0	880.3	840.1
32.5°	1791.5	1621.7	1461.8	1332.0	1223.2	1134.2	1052.8	981.1	909.6	852.8	811.8
35°	1777.6	1613.2	1417.4	1268.4	1159.4	1073.3	999.8	933.7	863.4	808.4	766.6
37.5°	1717.5	1578.7	1371.6	1196.7	1082.8	1003.0	943.1	885.4	821.0	761.6	722.4
40°	1657.0	1544.9	1336.1	1153.2	1034.2	952.2	898.3	851.2	788.8	733.4	691.1
42.5°	1566.9	1498.8	1302.2	1107.4	979.2	900.2	854.7	810.6	755.9	699.5	659.7
45°	1401.6	1410.6	1232.9	1034.7	903.0	823.7	780.9	750.2	701.7	655.1	614.4
47.5°	1194.4	1278.4	1151.7	957.2	822.7	748.3	710.9	684.2	651.4	605.7	568.6
50°	1059.0	1179.0	1086.5	905.1	772.4	698.4	661.5	639.7	611.2	575.2	539.8
52.5°	934.2	1063.2	1007.8	847.2	717.9	650.3	614.1	596.2	573.5	539.7	507.7
55°	761.8	892.5	879.8	759.7	636.0	575.2	547.8	527.7	512.3	487.0	461.6
57.5°	616.3	740.1	746.7	662.5	563.9	503.8	480.2	465.0	455.0	435.9	412.4
60°	524.5	638.1	660.4	596.9	512.3	459.5	436.2	424.0	416.1	400.8	382.8
62.5°	448.4	545.1	570.3	524.6	462.8	413.3	395.2	383.4	378.0	364.8	348.9
65°	343.2	423.5	447.8	422.4	390.2	350.5	335.8	325.7	320.9	313.6	301.8
67.5°	258.0	316.6	343.3	325.4	313.8	288.7	279.2	273.9	269.6	264.6	254.9
70°	207.2	250.6	278.1	273.4	263.9	250.6	243.8	240.0	235.8	231.6	223.1
72.5°	166.6	196.5	222.3	224.7	216.9	214.2	208.2	206.6	204.1	199.0	194.4
75°	110.5	131.1	149.1	155.9	159.2	161.8	159.2	158.6	158.0	153.9	151.2
77.5°	72.4	83.5	94.8	106.5	111.6	115.1	116.0	118.0	116.5	114.3	113.0
80°	55.5	58.2	66.0	76.1	84.0	87.3	89.4	90.4	89.9	89.4	87.3
82.5°	40.3	42.5	46.3	53.3	60.0	65.2	66.6	66.3	67.5	67.8	66.0
85°	21.7	22.2	23.2	24.3	28.0	33.8	35.4	36.5	37.6	37.6	34.3
87.5°	9.7	8.8	9.2	8.8	9.7	9.7	11.9	13.7	14.4	13.1	13.4
90°	14.3	12.1	9.8	7.8	6.1	4.3	2.5	0.8	2.5	4.3	6.1
92.5°	16.8	15.0	13.3	12.7	13.2	13.7	14.2	14.6	14.2	13.7	13.2
95°	20.6	18.7	16.8	19.4	26.6	33.7	41.0	48.2	41.0	33.7	26.6
97.5°	50.7	63.3	75.9	83.9	87.2	90.4	93.6	96.7	93.6	90.4	87.2
100°	80.8	108.2	135.5	147.4	143.9	140.5	136.9	133.4	136.9	140.5	143.9
102.5°	111.7	141.7	171.6	185.2	182.7	180.2	177.6	175.1	177.6	180.2	182.7
105°	204.5	220.3	236.1	243.0	241.1	239.1	237.2	235.3	237.2	239.1	241.1
107.5°	311.9	309.4	306.9	304.9	303.4	301.8	300.3	298.7	300.3	301.8	303.4
110°	352.2	350.3	348.3	346.7	345.3	343.9	342.4	341.0	342.4	343.9	345.3



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	392.0	390.1	388.1	386.6	385.3	384.1	382.7	381.5	382.7	384.1	385.3
115°	450.0	448.5	446.9	445.6	444.5	443.4	442.4	441.3	442.4	443.4	444.5
117.5°	507.2	506.3	505.5	504.4	503.2	501.9	500.6	499.3	500.6	501.9	503.2
120°	543.7	543.2	542.7	541.6	540.0	538.5	536.8	535.3	536.8	538.5	540.0
122.5°	579.5	578.8	578.0	577.1	575.8	574.5	573.2	571.9	573.2	574.5	575.8
125°	630.2	629.5	628.8	627.7	626.3	624.9	623.5	622.2	623.5	624.9	626.3
127.5°	679.2	678.3	677.5	676.4	675.0	673.6	672.2	670.8	672.2	673.6	675.0
130°	709.1	708.4	707.7	706.7	705.3	703.9	702.5	701.0	702.5	703.9	705.3
132.5°	737.8	737.3	736.7	735.8	734.4	733.0	731.5	730.1	731.5	733.0	734.4
135°	781.0	780.3	779.6	778.7	777.7	776.6	775.6	774.5	775.6	776.6	777.7
137.5°	819.4	819.0	818.6	817.7	816.4	815.1	813.7	812.4	813.7	815.1	816.4
140°	843.7	843.2	842.6	841.9	840.8	839.8	838.7	837.7	838.7	839.8	840.8
142.5°	867.1	866.6	866.1	865.3	864.2	863.1	862.1	861.0	862.1	863.1	864.2
145°	900.1	899.8	899.4	898.7	897.4	896.2	894.9	893.7	894.9	896.2	897.4
147.5°	929.0	928.7	928.4	927.8	927.0	926.1	925.3	924.5	925.3	926.1	927.0
150°	946.7	946.3	946.0	945.5	945.0	944.5	944.0	943.4	944.0	944.5	945.0
152.5°	962.1	961.9	961.7	961.5	961.3	961.0	960.8	960.5	960.8	961.0	961.3
155°	983.4	983.2	983.0	983.1	983.5	983.8	984.2	984.5	984.2	983.8	983.5
157.5°	1002.6	1002.7	1002.9	1003.0	1003.0	1003.1	1003.1	1003.1	1003.1	1003.1	1003.0
160°	1013.3	1013.5	1013.6	1013.8	1014.0	1014.2	1014.3	1014.5	1014.3	1014.2	1014.0
162.5°	1022.8	1022.9	1023.1	1023.4	1023.9	1024.3	1024.8	1025.2	1024.8	1024.3	1023.9
165°	1035.4	1035.6	1035.7	1036.1	1036.6	1037.1	1037.6	1038.2	1037.6	1037.1	1036.6
167.5°	1045.1	1045.1	1045.1	1045.5	1046.2	1046.9	1047.6	1048.3	1047.6	1046.9	1046.2
170°	1050.9	1050.9	1050.9	1051.2	1051.9	1052.6	1053.3	1054.0	1053.3	1052.6	1051.9
172.5°	1054.3	1054.2	1054.1	1054.4	1055.2	1056.1	1056.9	1057.7	1056.9	1056.1	1055.2
175°	1059.1	1058.9	1058.8	1059.1	1060.1	1061.0	1061.8	1062.7	1061.8	1061.0	1060.1
177.5°	1061.2	1061.0	1060.9	1061.2	1061.9	1062.6	1063.3	1063.9	1063.3	1062.6	1061.9
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1214.0	1208.4	1204.7	1196.2	1190.6	1184.8	1178.8	1182.7	1182.2	1181.7	1181.7
5°	1173.3	1161.0	1149.9	1135.7	1126.7	1115.6	1107.1	1106.1	1108.2	1100.8	1096.5
7.5°	1132.9	1116.2	1100.4	1084.7	1068.0	1054.7	1046.3	1042.4	1037.0	1032.5	1027.7
10°	1104.5	1084.9	1069.5	1050.1	1032.1	1016.2	1006.1	999.3	995.5	991.9	985.0
12.5°	1075.3	1056.1	1036.6	1014.5	997.3	979.0	971.5	963.7	956.6	952.5	943.1
15°	1032.6	1007.7	987.1	963.8	944.8	926.9	916.3	900.9	898.8	893.5	884.0
17.5°	989.8	962.8	934.3	917.2	895.6	877.0	860.8	855.7	840.5	834.9	826.6
20°	955.9	931.1	909.4	886.7	855.5	838.0	825.4	818.5	806.3	798.9	793.6
22.5°	926.8	901.5	876.4	849.9	824.2	804.6	795.3	784.6	778.0	767.6	761.8
25°	885.0	857.6	827.5	798.9	780.4	765.6	750.7	741.2	731.7	727.0	716.4
27.5°	836.7	807.9	779.7	758.1	735.4	720.7	707.3	698.8	687.4	679.4	673.6
30°	810.0	776.2	751.8	732.3	703.2	689.4	679.4	668.8	660.4	651.9	646.1
32.5°	779.1	748.2	725.2	700.9	678.6	663.7	650.7	641.4	634.1	626.1	620.3
35°	730.6	704.8	681.0	656.6	640.3	624.9	609.7	601.7	594.8	587.4	582.1
37.5°	686.9	662.7	640.1	617.0	596.7	584.2	571.9	565.8	556.5	551.6	546.1
40°	659.8	636.0	611.7	589.6	568.4	558.9	547.8	538.8	530.3	526.6	520.8
42.5°	630.3	606.4	585.9	562.0	544.7	531.8	521.5	511.7	505.3	500.0	496.7
45°	586.3	565.2	545.1	521.3	504.9	493.8	482.2	473.2	467.4	463.7	457.9
47.5°	543.7	522.6	502.2	481.4	465.5	452.9	441.3	435.0	427.3	422.7	418.9
50°	512.8	493.8	472.1	453.1	437.3	424.5	415.1	407.1	400.2	394.5	391.8
52.5°	484.5	464.2	445.5	427.8	411.0	396.7	388.0	379.6	374.5	367.8	364.7
55°	437.8	418.2	402.3	384.9	368.5	356.4	345.8	338.4	333.1	325.7	321.4
57.5°	393.8	376.4	357.4	342.2	325.4	315.1	306.3	296.3	289.8	284.1	279.9
60°	364.3	344.2	327.8	313.6	298.7	285.5	277.6	269.6	262.8	256.9	253.3
62.5°	333.5	315.9	300.3	284.8	271.2	259.7	250.5	243.9	237.8	234.1	230.5
65°	286.0	272.3	256.4	243.8	231.1	222.6	215.2	209.3	205.1	202.5	199.3
67.5°	242.5	229.1	215.3	202.8	194.4	187.9	183.1	178.0	175.9	172.6	170.5
70°	214.1	200.4	188.2	178.7	170.3	165.5	162.3	158.6	156.5	152.3	150.2
72.5°	183.3	173.3	164.5	156.7	150.0	145.6	141.6	137.0	133.7	129.0	126.9
75°	144.3	135.3	128.5	123.2	119.0	113.1	107.3	102.6	101.0	99.4	98.9
77.5°	106.9	101.2	96.2	91.8	86.5	82.3	81.0	80.0	79.6	78.8	78.8
80°	84.0	78.8	75.0	69.8	66.7	66.7	66.7	65.5	66.0	66.0	66.0
82.5°	62.5	57.7	55.6	53.7	53.1	53.5	53.5	53.7	53.4	54.2	53.8
85°	32.2	32.8	33.8	33.3	33.8	33.8	34.9	34.3	34.9	33.8	34.9
87.5°	13.4	15.0	16.0	16.9	17.7	17.8	18.3	18.5	19.0	19.2	19.3
90°	7.8	9.8	12.1	14.3	16.7	19.0	19.7	20.4	21.0	21.7	22.3
92.5°	12.7	13.3	15.0	16.8	18.5	20.2	21.3	22.4	23.5	24.7	25.3
95°	19.4	16.8	18.7	20.6	22.5	24.4	25.8	27.0	28.2	29.4	30.0
97.5°	83.9	75.9	63.3	50.7	38.1	25.4	26.9	28.3	29.6	31.0	31.8
100°	147.4	135.5	108.2	80.8	53.4	26.1	27.5	28.9	30.3	31.7	32.4
102.5°	185.2	171.6	141.7	111.7	81.8	51.9	47.6	43.2	38.9	34.5	32.5
105°	243.0	236.1	220.3	204.5	188.6	172.9	141.9	110.8	79.8	48.7	33.3
107.5°	304.9	306.9	309.4	311.9	314.4	316.9	294.2	271.4	248.6	225.8	202.7
110°	346.7	348.3	350.3	352.2	354.2	356.1	350.3	344.5	338.7	333.0	317.5



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	386.6	388.1	390.1	392.0	393.9	395.9	396.0	396.1	396.2	396.3	393.6
115°	445.6	446.9	448.5	450.0	451.6	453.2	454.9	456.7	458.5	460.2	461.4
117.5°	504.4	505.5	506.3	507.2	508.0	508.8	510.2	511.6	513.0	514.3	515.1
120°	541.6	542.7	543.2	543.7	544.2	544.7	546.1	547.5	549.0	550.4	551.1
122.5°	577.1	578.0	578.8	579.5	580.1	580.8	581.8	582.7	583.7	584.7	585.2
125°	627.7	628.8	629.5	630.2	630.9	631.6	632.0	632.3	632.7	633.0	633.4
127.5°	676.4	677.5	678.3	679.2	680.0	680.9	681.5	682.0	682.6	683.1	683.2
130°	706.7	707.7	708.4	709.1	709.8	710.5	711.2	712.0	712.7	713.4	713.6
132.5°	735.8	736.7	737.3	737.8	738.4	739.0	739.7	740.3	741.0	741.7	741.8
135°	778.7	779.6	780.3	781.0	781.7	782.4	782.9	783.5	784.0	784.5	784.5
137.5°	817.7	818.6	819.0	819.4	819.7	820.1	821.0	821.8	822.6	823.5	823.7
140°	841.9	842.6	843.2	843.7	844.2	844.8	845.5	846.2	846.9	847.6	847.8
142.5°	865.3	866.1	866.6	867.1	867.6	868.2	868.7	869.3	869.8	870.4	870.4
145°	898.7	899.4	899.8	900.1	900.5	900.8	901.2	901.5	901.9	902.2	902.4
147.5°	927.8	928.4	928.7	929.0	929.4	929.7	930.1	930.4	930.8	931.1	930.9
150°	945.5	946.0	946.3	946.7	947.1	947.5	947.8	948.1	948.5	948.8	948.8
152.5°	961.5	961.7	961.9	962.1	962.4	962.6	963.2	963.8	964.4	965.1	965.0
155°	983.1	983.0	983.2	983.4	983.5	983.7	984.6	985.5	986.3	987.2	987.1
157.5°	1003.0	1002.9	1002.7	1002.6	1002.4	1002.2	1003.3	1004.3	1005.3	1006.4	1006.2
160°	1013.8	1013.6	1013.5	1013.3	1013.1	1012.9	1014.0	1015.0	1016.1	1017.1	1017.0
162.5°	1023.4	1023.1	1022.9	1022.8	1022.6	1022.4	1023.6	1024.8	1026.0	1027.1	1027.2
165°	1036.1	1035.7	1035.6	1035.4	1035.2	1035.0	1036.4	1037.8	1039.3	1040.7	1040.8
167.5°	1045.5	1045.1	1045.1	1045.1	1045.1	1045.1	1046.5	1047.9	1049.4	1050.8	1050.8
170°	1051.2	1050.9	1050.9	1050.9	1050.9	1050.9	1052.3	1053.6	1055.0	1056.4	1056.4
172.5°	1054.4	1054.1	1054.2	1054.3	1054.5	1054.6	1056.0	1057.4	1058.8	1060.3	1060.2
175°	1059.1	1058.8	1058.9	1059.1	1059.3	1059.6	1060.8	1062.0	1063.2	1064.4	1064.3
177.5°	1061.2	1060.9	1061.0	1061.2	1061.3	1061.4	1062.6	1063.7	1064.8	1065.9	1065.8
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1176.7	1176.3	1176.7	1175.0	1176.7	1176.3	1176.7	1181.7	1181.7	1182.2	1182.7
5°	1095.0	1094.4	1092.9	1088.1	1092.9	1094.4	1095.0	1096.5	1100.8	1108.2	1106.1
7.5°	1023.6	1022.9	1018.2	1018.3	1018.2	1022.9	1023.6	1027.7	1032.5	1037.0	1042.4
10°	981.3	981.8	975.5	971.8	975.5	981.8	981.3	985.0	991.9	995.5	999.3
12.5°	940.3	937.9	932.7	928.7	932.7	937.9	940.3	943.1	952.5	956.6	963.7
15°	886.2	880.8	868.2	869.2	868.2	880.8	886.2	884.0	893.5	898.8	900.9
17.5°	822.3	818.5	818.2	810.8	818.2	818.5	822.3	826.6	834.9	840.5	855.7
20°	785.2	782.5	783.6	776.2	783.6	782.5	785.2	793.6	798.9	806.3	818.5
22.5°	756.0	753.4	748.9	746.6	748.9	753.4	756.0	761.8	767.6	778.0	784.6
25°	713.3	709.0	704.8	707.4	704.8	709.0	713.3	716.4	727.0	731.7	741.2
27.5°	670.6	667.3	663.1	662.6	663.1	667.3	670.6	673.6	679.4	687.4	698.8
30°	643.5	640.3	638.1	635.5	638.1	640.3	643.5	646.1	651.9	660.4	668.8
32.5°	615.9	615.3	611.5	611.0	611.5	615.3	615.9	620.3	626.1	634.1	641.4
35°	580.0	576.8	575.7	576.3	575.7	576.8	580.0	582.1	587.4	594.8	601.7
37.5°	545.8	541.6	539.7	537.9	539.7	541.6	545.8	546.1	551.6	556.5	565.8
40°	521.3	517.1	516.0	514.9	516.0	517.1	521.3	520.8	526.6	530.3	538.8
42.5°	493.8	492.1	491.5	489.6	491.5	492.1	493.8	496.7	500.0	505.3	511.7
45°	456.3	455.8	452.6	453.6	452.6	455.8	456.3	457.9	463.7	467.4	473.2
47.5°	416.8	414.4	412.2	413.6	412.2	414.4	416.8	418.9	422.7	427.3	435.0
50°	389.7	388.6	383.8	384.9	383.8	388.6	389.7	391.8	394.5	400.2	407.1
52.5°	362.6	358.6	356.8	356.2	356.8	358.6	362.6	364.7	367.8	374.5	379.6
55°	317.8	313.0	310.8	309.8	310.8	313.0	317.8	321.4	325.7	333.1	338.4
57.5°	273.8	272.5	270.8	272.0	270.8	272.5	273.8	279.9	284.1	289.8	296.3
60°	247.9	247.9	247.9	247.4	247.9	247.9	247.9	253.3	256.9	262.8	269.6
62.5°	228.1	226.8	226.4	227.1	226.4	226.8	228.1	230.5	234.1	237.8	243.9
65°	197.7	197.2	195.1	194.6	195.1	197.2	197.7	199.3	202.5	205.1	209.3
67.5°	169.1	167.1	166.5	165.8	166.5	167.1	169.1	170.5	172.6	175.9	178.0
70°	147.5	146.4	143.3	143.8	143.3	146.4	147.5	150.2	152.3	156.5	158.6
72.5°	124.2	123.2	122.6	121.8	122.6	123.2	124.2	126.9	129.0	133.7	137.0
75°	98.4	97.9	97.3	99.4	97.3	97.9	98.4	98.9	99.4	101.0	102.6
77.5°	78.8	78.8	79.1	78.3	79.1	78.8	78.8	78.8	78.8	79.6	80.0
80°	66.0	66.0	65.5	65.5	65.5	66.0	66.0	66.0	66.0	66.0	65.5
82.5°	53.0	53.4	53.7	52.9	53.7	53.4	53.0	53.8	54.2	53.4	53.7
85°	34.9	34.3	35.4	34.9	35.4	34.3	34.9	34.9	33.8	34.9	34.3
87.5°	20.2	19.4	19.5	20.0	19.5	19.4	20.2	19.3	19.2	19.0	18.5
90°	22.6	23.0	23.3	23.7	23.3	23.0	22.6	22.3	21.7	21.0	20.4
92.5°	25.5	25.8	26.0	26.3	26.0	25.8	25.5	25.3	24.7	23.5	22.4
95°	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	29.4	28.2	27.0
97.5°	32.0	32.2	32.3	32.5	32.3	32.2	32.0	31.8	31.0	29.6	28.3
100°	32.6	32.8	33.0	33.1	33.0	32.8	32.6	32.4	31.7	30.3	28.9
102.5°	32.8	33.1	33.4	33.8	33.4	33.1	32.8	32.5	34.5	38.9	43.2
105°	33.7	34.0	34.4	34.7	34.4	34.0	33.7	33.3	48.7	79.8	110.8
107.5°	179.4	155.9	132.5	109.1	132.5	155.9	179.4	202.7	225.8	248.6	271.4
110°	292.4	267.3	242.2	217.1	242.2	267.3	292.4	317.5	333.0	338.7	344.5



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	388.4	383.0	377.8	372.5	377.8	383.0	388.4	393.6	396.3	396.2	396.1
115°	462.1	462.8	463.5	464.2	463.5	462.8	462.1	461.4	460.2	458.5	456.7
117.5°	515.3	515.4	515.5	515.7	515.5	515.4	515.3	515.1	514.3	513.0	511.6
120°	551.1	551.1	551.1	551.1	551.1	551.1	551.1	551.1	550.4	549.0	547.5
122.5°	585.4	585.5	585.7	585.8	585.7	585.5	585.4	585.2	584.7	583.7	582.7
125°	633.7	634.1	634.4	634.8	634.4	634.1	633.7	633.4	633.0	632.7	632.3
127.5°	682.9	682.6	682.2	681.9	682.2	682.6	682.9	683.2	683.1	682.6	682.0
130°	713.2	712.9	712.5	712.2	712.5	712.9	713.2	713.6	713.4	712.7	712.0
132.5°	741.4	740.9	740.4	739.9	740.4	740.9	741.4	741.8	741.7	741.0	740.3
135°	784.0	783.5	782.9	782.4	782.9	783.5	784.0	784.5	784.5	784.0	783.5
137.5°	823.4	823.0	822.7	822.3	822.7	823.0	823.4	823.7	823.5	822.6	821.8
140°	847.4	847.1	846.7	846.4	846.7	847.1	847.4	847.8	847.6	846.9	846.2
142.5°	869.9	869.4	869.0	868.5	869.0	869.4	869.9	870.4	870.4	869.8	869.3
145°	902.4	902.4	902.4	902.4	902.4	902.4	902.4	902.4	902.2	901.9	901.5
147.5°	930.1	929.3	928.5	927.7	928.5	929.3	930.1	930.9	931.1	930.8	930.4
150°	948.2	947.7	947.2	946.6	947.2	947.7	948.2	948.8	948.8	948.5	948.1
152.5°	964.2	963.4	962.6	961.8	962.6	963.4	964.2	965.0	965.1	964.4	963.8
155°	986.1	985.0	984.0	982.9	984.0	985.0	986.1	987.1	987.2	986.3	985.5
157.5°	1004.9	1003.5	1002.2	1000.8	1002.2	1003.5	1004.9	1006.2	1006.4	1005.3	1004.3
160°	1015.8	1014.6	1013.4	1012.2	1013.4	1014.6	1015.8	1017.0	1017.1	1016.1	1015.0
162.5°	1026.1	1025.0	1024.0	1022.9	1024.0	1025.0	1026.1	1027.2	1027.1	1026.0	1024.8
165°	1039.6	1038.2	1037.0	1035.8	1037.0	1038.2	1039.6	1040.8	1040.7	1039.3	1037.8
167.5°	1049.4	1047.9	1046.5	1045.1	1046.5	1047.9	1049.4	1050.8	1050.8	1049.4	1047.9
170°	1055.0	1053.6	1052.3	1050.9	1052.3	1053.6	1055.0	1056.4	1056.4	1055.0	1053.6
172.5°	1058.6	1057.1	1055.5	1054.0	1055.5	1057.1	1058.6	1060.2	1060.3	1058.8	1057.4
175°	1063.0	1061.6	1060.2	1058.7	1060.2	1061.6	1063.0	1064.3	1064.4	1063.2	1062.0
177.5°	1064.4	1063.0	1061.6	1060.2	1061.6	1063.0	1064.4	1065.8	1065.9	1064.8	1063.7
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1178.8	1184.8	1190.6	1196.2	1204.7	1208.4	1214.0	1216.1	1222.3	1231.7	1239.3
5°	1107.1	1115.6	1126.7	1135.7	1149.9	1161.0	1173.3	1184.9	1198.6	1218.2	1235.6
7.5°	1046.3	1054.7	1068.0	1084.7	1100.4	1116.2	1132.9	1148.7	1168.3	1196.4	1224.2
10°	1006.1	1016.2	1032.1	1050.1	1069.5	1084.9	1104.5	1124.6	1148.9	1181.1	1214.5
12.5°	971.5	979.0	997.3	1014.5	1036.6	1056.1	1075.3	1098.7	1126.5	1160.8	1200.9
15°	916.3	926.9	944.8	963.8	987.1	1007.7	1032.6	1061.2	1088.1	1130.4	1179.0
17.5°	860.8	877.0	895.6	917.2	934.3	962.8	989.8	1019.1	1052.3	1097.1	1150.4
20°	825.4	838.0	855.5	886.7	909.4	931.1	955.9	992.4	1023.1	1073.8	1129.3
22.5°	795.3	804.6	824.2	849.9	876.4	901.5	926.8	961.5	999.4	1047.6	1107.7
25°	750.7	765.6	780.4	798.9	827.5	857.6	885.0	914.6	954.8	1006.1	1071.2
27.5°	707.3	720.7	735.4	758.1	779.7	807.9	836.7	870.6	913.7	968.0	1034.0
30°	679.4	689.4	703.2	732.3	751.8	776.2	810.0	840.1	880.3	938.0	1007.7
32.5°	650.7	663.7	678.6	700.9	725.2	748.2	779.1	811.8	852.8	909.6	981.1
35°	609.7	624.9	640.3	656.6	681.0	704.8	730.6	766.6	808.4	863.4	933.7
37.5°	571.9	584.2	596.7	617.0	640.1	662.7	686.9	722.4	761.6	821.0	885.4
40°	547.8	558.9	568.4	589.6	611.7	636.0	659.8	691.1	733.4	788.8	851.2
42.5°	521.5	531.8	544.7	562.0	585.9	606.4	630.3	659.7	699.5	755.9	810.6
45°	482.2	493.8	504.9	521.3	545.1	565.2	586.3	614.4	655.1	701.7	750.2
47.5°	441.3	452.9	465.5	481.4	502.2	522.6	543.7	568.6	605.7	651.4	684.2
50°	415.1	424.5	437.3	453.1	472.1	493.8	512.8	539.8	575.2	611.2	639.7
52.5°	388.0	396.7	411.0	427.8	445.5	464.2	484.5	507.7	539.7	573.5	596.2
55°	345.8	356.4	368.5	384.9	402.3	418.2	437.8	461.6	487.0	512.3	527.7
57.5°	306.3	315.1	325.4	342.2	357.4	376.4	393.8	412.4	435.9	455.0	465.0
60°	277.6	285.5	298.7	313.6	327.8	344.2	364.3	382.8	400.8	416.1	424.0
62.5°	250.5	259.7	271.2	284.8	300.3	315.9	333.5	348.9	364.8	378.0	383.4
65°	215.2	222.6	231.1	243.8	256.4	272.3	286.0	301.8	313.6	320.9	325.7
67.5°	183.1	187.9	194.4	202.8	215.3	229.1	242.5	254.9	264.6	269.6	273.9
70°	162.3	165.5	170.3	178.7	188.2	200.4	214.1	223.1	231.6	235.8	240.0
72.5°	141.6	145.6	150.0	156.7	164.5	173.3	183.3	194.4	199.0	204.1	206.6
75°	107.3	113.1	119.0	123.2	128.5	135.3	144.3	151.2	153.9	158.0	158.6
77.5°	81.0	82.3	86.5	91.8	96.2	101.2	106.9	113.0	114.3	116.5	118.0
80°	66.7	66.7	66.7	69.8	75.0	78.8	84.0	87.3	89.4	89.9	90.4
82.5°	53.5	53.5	53.1	53.7	55.6	57.7	62.5	66.0	67.8	67.5	66.3
85°	34.9	33.8	33.8	33.3	33.8	32.8	32.2	34.3	37.6	37.6	36.5
87.5°	18.3	17.8	17.7	16.9	16.0	15.0	13.4	13.4	13.1	14.4	13.7
90°	19.7	19.0	16.7	14.3	12.1	9.8	7.8	6.1	4.3	2.5	0.8
92.5°	21.3	20.2	18.5	16.8	15.0	13.3	12.7	13.2	13.7	14.2	14.6
95°	25.8	24.4	22.5	20.6	18.7	16.8	19.4	26.6	33.7	41.0	48.2
97.5°	26.9	25.4	38.1	50.7	63.3	75.9	83.9	87.2	90.4	93.6	96.7
100°	27.5	26.1	53.4	80.8	108.2	135.5	147.4	143.9	140.5	136.9	133.4
102.5°	47.6	51.9	81.8	111.7	141.7	171.6	185.2	182.7	180.2	177.6	175.1
105°	141.9	172.9	188.6	204.5	220.3	236.1	243.0	241.1	239.1	237.2	235.3
107.5°	294.2	316.9	314.4	311.9	309.4	306.9	304.9	303.4	301.8	300.3	298.7
110°	350.3	356.1	354.2	352.2	350.3	348.3	346.7	345.3	343.9	342.4	341.0



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	396.0	395.9	393.9	392.0	390.1	388.1	386.6	385.3	384.1	382.7	381.5
115°	454.9	453.2	451.6	450.0	448.5	446.9	445.6	444.5	443.4	442.4	441.3
117.5°	510.2	508.8	508.0	507.2	506.3	505.5	504.4	503.2	501.9	500.6	499.3
120°	546.1	544.7	544.2	543.7	543.2	542.7	541.6	540.0	538.5	536.8	535.3
122.5°	581.8	580.8	580.1	579.5	578.8	578.0	577.1	575.8	574.5	573.2	571.9
125°	632.0	631.6	630.9	630.2	629.5	628.8	627.7	626.3	624.9	623.5	622.2
127.5°	681.5	680.9	680.0	679.2	678.3	677.5	676.4	675.0	673.6	672.2	670.8
130°	711.2	710.5	709.8	709.1	708.4	707.7	706.7	705.3	703.9	702.5	701.0
132.5°	739.7	739.0	738.4	737.8	737.3	736.7	735.8	734.4	733.0	731.5	730.1
135°	782.9	782.4	781.7	781.0	780.3	779.6	778.7	777.7	776.6	775.6	774.5
137.5°	821.0	820.1	819.7	819.4	819.0	818.6	817.7	816.4	815.1	813.7	812.4
140°	845.5	844.8	844.2	843.7	843.2	842.6	841.9	840.8	839.8	838.7	837.7
142.5°	868.7	868.2	867.6	867.1	866.6	866.1	865.3	864.2	863.1	862.1	861.0
145°	901.2	900.8	900.5	900.1	899.8	899.4	898.7	897.4	896.2	894.9	893.7
147.5°	930.1	929.7	929.4	929.0	928.7	928.4	927.8	927.0	926.1	925.3	924.5
150°	947.8	947.5	947.1	946.7	946.3	946.0	945.5	945.0	944.5	944.0	943.4
152.5°	963.2	962.6	962.4	962.1	961.9	961.7	961.5	961.3	961.0	960.8	960.5
155°	984.6	983.7	983.5	983.4	983.2	983.0	983.1	983.5	983.8	984.2	984.5
157.5°	1003.3	1002.2	1002.4	1002.6	1002.7	1002.9	1003.0	1003.0	1003.1	1003.1	1003.1
160°	1014.0	1012.9	1013.1	1013.3	1013.5	1013.6	1013.8	1014.0	1014.2	1014.3	1014.5
162.5°	1023.6	1022.4	1022.6	1022.8	1022.9	1023.1	1023.4	1023.9	1024.3	1024.8	1025.2
165°	1036.4	1035.0	1035.2	1035.4	1035.6	1035.7	1036.1	1036.6	1037.1	1037.6	1038.2
167.5°	1046.5	1045.1	1045.1	1045.1	1045.1	1045.1	1045.5	1046.2	1046.9	1047.6	1048.3
170°	1052.3	1050.9	1050.9	1050.9	1050.9	1050.9	1051.2	1051.9	1052.6	1053.3	1054.0
172.5°	1056.0	1054.6	1054.5	1054.3	1054.2	1054.1	1054.4	1055.2	1056.1	1056.9	1057.7
175°	1060.8	1059.6	1059.3	1059.1	1058.9	1058.8	1059.1	1060.1	1061.0	1061.8	1062.7
177.5°	1062.6	1061.4	1061.3	1061.2	1061.0	1060.9	1061.2	1061.9	1062.6	1063.3	1063.9
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1241.8	1246.5	1252.4	1261.3	1268.1	1273.9	1275.3	1277.0	1281.2	1288.4	1293.8
5°	1249.9	1262.0	1281.6	1300.6	1321.3	1338.2	1354.0	1365.1	1375.7	1398.0	1415.9
7.5°	1247.4	1274.4	1305.0	1339.3	1373.8	1407.3	1438.5	1466.2	1493.9	1526.3	1563.2
10°	1245.7	1277.4	1318.6	1362.5	1410.6	1457.6	1503.2	1538.5	1579.8	1616.8	1663.9
12.5°	1237.6	1283.3	1332.6	1388.8	1447.8	1502.1	1562.0	1610.9	1658.1	1711.5	1766.3
15°	1227.2	1282.6	1345.0	1419.6	1509.4	1575.1	1636.4	1721.5	1779.7	1837.9	1916.0
17.5°	1208.0	1275.8	1353.7	1450.6	1525.6	1613.7	1706.0	1773.2	1851.6	1933.5	2004.4
20°	1192.8	1271.5	1358.8	1454.0	1549.6	1645.4	1734.7	1815.0	1896.0	1990.6	2048.8
22.5°	1177.6	1255.5	1346.2	1447.2	1550.0	1650.8	1752.0	1846.3	1937.4	2033.0	2107.2
25°	1145.2	1237.7	1336.1	1439.2	1540.7	1651.7	1772.2	1877.4	1990.0	2088.4	2158.8
27.5°	1112.4	1197.2	1295.2	1399.7	1512.6	1643.8	1785.5	1905.2	2018.0	2088.4	2110.5
30°	1082.8	1172.7	1262.5	1368.9	1491.0	1637.4	1788.1	1925.0	2017.6	2048.2	2025.5
32.5°	1052.8	1134.2	1223.2	1332.0	1461.8	1621.7	1791.5	1913.2	1968.9	1945.5	1852.9
35°	999.8	1073.3	1159.4	1268.4	1417.4	1613.2	1777.6	1860.0	1846.2	1714.0	1539.6
37.5°	943.1	1003.0	1082.8	1196.7	1371.6	1578.7	1717.5	1729.6	1610.6	1407.8	1206.2
40°	898.3	952.2	1034.2	1153.2	1336.1	1544.9	1657.0	1607.8	1423.3	1197.5	1029.5
42.5°	854.7	900.2	979.2	1107.4	1302.2	1498.8	1566.9	1459.8	1246.9	1033.4	880.5
45°	780.9	823.7	903.0	1034.7	1232.9	1410.6	1401.6	1215.5	1002.5	830.6	703.7
47.5°	710.9	748.3	822.7	957.2	1151.7	1278.4	1194.4	996.3	815.6	677.7	587.2
50°	661.5	698.4	772.4	905.1	1086.5	1179.0	1059.0	868.2	702.7	588.4	516.5
52.5°	614.1	650.3	717.9	847.2	1007.8	1063.2	934.2	757.3	619.4	520.8	459.0
55°	547.8	575.2	636.0	759.7	879.8	892.5	761.8	613.8	500.2	431.4	389.1
57.5°	480.2	503.8	563.9	662.5	746.7	740.1	616.3	488.2	411.6	360.6	329.9
60°	436.2	459.5	512.3	596.9	660.4	638.1	524.5	421.4	355.8	318.3	294.0
62.5°	395.2	413.3	462.8	524.6	570.3	545.1	448.4	363.0	311.0	279.3	260.1
65°	335.8	350.5	390.2	422.4	447.8	423.5	343.2	283.9	246.4	224.2	211.0
67.5°	279.2	288.7	313.8	325.4	343.3	316.6	258.0	218.3	197.0	178.2	169.1
70°	243.8	250.6	263.9	273.4	278.1	250.6	207.2	178.1	160.2	146.9	141.2
72.5°	208.2	214.2	216.9	224.7	222.3	196.5	166.6	143.5	130.6	121.6	114.1
75°	159.2	161.8	159.2	155.9	149.1	131.1	110.5	98.9	89.4	85.1	82.5
77.5°	116.0	115.1	111.6	106.5	94.8	83.5	72.4	68.6	64.4	62.2	61.2
80°	89.4	87.3	84.0	76.1	66.0	58.2	55.5	52.9	51.3	48.7	48.1
82.5°	66.6	65.2	60.0	53.3	46.3	42.5	40.3	39.4	37.8	36.4	36.3
85°	35.4	33.8	28.0	24.3	23.2	22.2	21.7	21.7	19.6	19.0	19.0
87.5°	11.9	9.7	9.7	8.8	9.2	8.8	9.7	9.3	9.3	9.9	9.2
90°	2.5	4.3	6.1	7.8	9.8	12.1	14.3	16.7	19.0	19.7	20.4
92.5°	14.2	13.7	13.2	12.7	13.3	15.0	16.8	18.5	20.2	21.3	22.4
95°	41.0	33.7	26.6	19.4	16.8	18.7	20.6	22.5	24.4	25.8	27.0
97.5°	93.6	90.4	87.2	83.9	75.9	63.3	50.7	38.1	25.4	26.9	28.3
100°	136.9	140.5	143.9	147.4	135.5	108.2	80.8	53.4	26.1	27.5	28.9
102.5°	177.6	180.2	182.7	185.2	171.6	141.7	111.7	81.8	51.9	47.6	43.2
105°	237.2	239.1	241.1	243.0	236.1	220.3	204.5	188.6	172.9	141.9	110.8
107.5°	300.3	301.8	303.4	304.9	306.9	309.4	311.9	314.4	316.9	294.2	271.4
110°	342.4	343.9	345.3	346.7	348.3	350.3	352.2	354.2	356.1	350.3	344.5



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	382.7	384.1	385.3	386.6	388.1	390.1	392.0	393.9	395.9	396.0	396.1
115°	442.4	443.4	444.5	445.6	446.9	448.5	450.0	451.6	453.2	454.9	456.7
117.5°	500.6	501.9	503.2	504.4	505.5	506.3	507.2	508.0	508.8	510.2	511.6
120°	536.8	538.5	540.0	541.6	542.7	543.2	543.7	544.2	544.7	546.1	547.5
122.5°	573.2	574.5	575.8	577.1	578.0	578.8	579.5	580.1	580.8	581.8	582.7
125°	623.5	624.9	626.3	627.7	628.8	629.5	630.2	630.9	631.6	632.0	632.3
127.5°	672.2	673.6	675.0	676.4	677.5	678.3	679.2	680.0	680.9	681.5	682.0
130°	702.5	703.9	705.3	706.7	707.7	708.4	709.1	709.8	710.5	711.2	712.0
132.5°	731.5	733.0	734.4	735.8	736.7	737.3	737.8	738.4	739.0	739.7	740.3
135°	775.6	776.6	777.7	778.7	779.6	780.3	781.0	781.7	782.4	782.9	783.5
137.5°	813.7	815.1	816.4	817.7	818.6	819.0	819.4	819.7	820.1	821.0	821.8
140°	838.7	839.8	840.8	841.9	842.6	843.2	843.7	844.2	844.8	845.5	846.2
142.5°	862.1	863.1	864.2	865.3	866.1	866.6	867.1	867.6	868.2	868.7	869.3
145°	894.9	896.2	897.4	898.7	899.4	899.8	900.1	900.5	900.8	901.2	901.5
147.5°	925.3	926.1	927.0	927.8	928.4	928.7	929.0	929.4	929.7	930.1	930.4
150°	944.0	944.5	945.0	945.5	946.0	946.3	946.7	947.1	947.5	947.8	948.1
152.5°	960.8	961.0	961.3	961.5	961.7	961.9	962.1	962.4	962.6	963.2	963.8
155°	984.2	983.8	983.5	983.1	983.0	983.2	983.4	983.5	983.7	984.6	985.5
157.5°	1003.1	1003.1	1003.0	1003.0	1002.9	1002.7	1002.6	1002.4	1002.2	1003.3	1004.3
160°	1014.3	1014.2	1014.0	1013.8	1013.6	1013.5	1013.3	1013.1	1012.9	1014.0	1015.0
162.5°	1024.8	1024.3	1023.9	1023.4	1023.1	1022.9	1022.8	1022.6	1022.4	1023.6	1024.8
165°	1037.6	1037.1	1036.6	1036.1	1035.7	1035.6	1035.4	1035.2	1035.0	1036.4	1037.8
167.5°	1047.6	1046.9	1046.2	1045.5	1045.1	1045.1	1045.1	1045.1	1045.1	1046.5	1047.9
170°	1053.3	1052.6	1051.9	1051.2	1050.9	1050.9	1050.9	1050.9	1050.9	1052.3	1053.6
172.5°	1056.9	1056.1	1055.2	1054.4	1054.1	1054.2	1054.3	1054.5	1054.6	1056.0	1057.4
175°	1061.8	1061.0	1060.1	1059.1	1058.8	1058.9	1059.1	1059.3	1059.6	1060.8	1062.0
177.5°	1063.3	1062.6	1061.9	1061.2	1060.9	1061.0	1061.2	1061.3	1061.4	1062.6	1063.7
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
0°	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1	1235.1
2.5°	1302.7	1302.7	1304.4	1310.8	1311.6	1317.2	1315.5
5°	1431.8	1441.8	1445.5	1461.4	1470.9	1475.1	1466.6
7.5°	1589.5	1617.9	1631.3	1647.9	1662.6	1667.1	1655.5
10°	1704.6	1734.1	1759.1	1774.3	1788.7	1798.2	1810.3
12.5°	1815.8	1852.2	1875.8	1897.4	1912.2	1924.2	1926.2
15°	1936.7	1991.7	2033.5	2064.1	2079.4	2087.4	2084.2
17.5°	2058.6	2109.6	2139.3	2170.6	2191.8	2192.9	2193.5
20°	2127.6	2177.3	2211.6	2234.8	2258.7	2257.7	2262.9
22.5°	2173.6	2212.8	2239.1	2256.0	2264.2	2260.2	2261.2
25°	2195.2	2206.9	2202.1	2175.1	2168.3	2143.4	2147.7
27.5°	2084.0	2029.0	1972.1	1899.0	1841.2	1795.1	1797.5
30°	1933.0	1835.7	1724.6	1631.6	1548.1	1524.8	1475.1
32.5°	1721.9	1576.0	1445.9	1359.2	1287.5	1268.1	1224.8
35°	1364.1	1222.3	1088.6	1008.2	976.5	932.1	931.6
37.5°	1060.3	935.5	864.7	804.5	772.8	746.0	743.4
40°	891.9	794.7	741.2	697.9	666.7	646.6	641.9
42.5°	774.4	695.7	645.7	618.8	594.8	584.4	576.7
45°	632.4	579.5	544.6	520.3	509.2	501.2	497.0
47.5°	529.0	493.5	469.7	453.5	444.5	436.2	438.4
50°	472.7	443.6	426.2	410.8	403.9	398.1	398.7
52.5°	427.4	401.3	387.2	376.2	367.6	363.5	361.4
55°	362.7	346.3	332.0	324.1	319.3	313.6	311.9
57.5°	309.4	296.7	285.1	276.1	274.9	269.3	270.0
60°	273.9	263.3	253.8	249.0	245.3	240.5	242.2
62.5°	244.7	235.8	227.1	223.2	219.5	216.0	216.8
65°	200.4	191.9	186.6	184.5	182.9	181.4	179.8
67.5°	159.7	154.5	151.2	146.6	143.4	142.9	141.3
70°	134.3	127.4	121.6	115.8	114.2	113.7	114.2
72.5°	107.7	103.3	101.7	98.9	98.6	97.1	98.2
75°	80.9	79.3	78.3	76.1	76.1	76.1	76.1
77.5°	59.7	58.7	58.1	57.7	57.1	56.4	56.2
80°	46.6	45.9	44.9	44.9	44.4	44.9	44.4
82.5°	35.1	35.0	33.9	33.9	33.4	33.1	33.4
85°	18.0	17.5	18.5	17.5	18.0	17.0	18.0
87.5°	9.3	9.4	9.1	9.2	8.8	9.7	9.0
90°	21.0	21.7	22.3	22.6	23.0	23.3	23.7
92.5°	23.5	24.7	25.3	25.5	25.8	26.0	26.3
95°	28.2	29.4	30.0	30.0	30.0	30.0	30.0
97.5°	29.6	31.0	31.8	32.0	32.2	32.3	32.5
100°	30.3	31.7	32.4	32.6	32.8	33.0	33.1
102.5°	38.9	34.5	32.5	32.8	33.1	33.4	33.8
105°	79.8	48.7	33.3	33.7	34.0	34.4	34.7
107.5°	248.6	225.8	202.7	179.4	155.9	132.5	109.1
110°	338.7	333.0	317.5	292.4	267.3	242.2	217.1



TEST NUMBER: P332312-840

CATALOG NUMBER: S123RDIP-S775D805U840-4F0-1E-UDD-A

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
112.5°	396.2	396.3	393.6	388.4	383.0	377.8	372.5
115°	458.5	460.2	461.4	462.1	462.8	463.5	464.2
117.5°	513.0	514.3	515.1	515.3	515.4	515.5	515.7
120°	549.0	550.4	551.1	551.1	551.1	551.1	551.1
122.5°	583.7	584.7	585.2	585.4	585.5	585.7	585.8
125°	632.7	633.0	633.4	633.7	634.1	634.4	634.8
127.5°	682.6	683.1	683.2	682.9	682.6	682.2	681.9
130°	712.7	713.4	713.6	713.2	712.9	712.5	712.2
132.5°	741.0	741.7	741.8	741.4	740.9	740.4	739.9
135°	784.0	784.5	784.5	784.0	783.5	782.9	782.4
137.5°	822.6	823.5	823.7	823.4	823.0	822.7	822.3
140°	846.9	847.6	847.8	847.4	847.1	846.7	846.4
142.5°	869.8	870.4	870.4	869.9	869.4	869.0	868.5
145°	901.9	902.2	902.4	902.4	902.4	902.4	902.4
147.5°	930.8	931.1	930.9	930.1	929.3	928.5	927.7
150°	948.5	948.8	948.8	948.2	947.7	947.2	946.6
152.5°	964.4	965.1	965.0	964.2	963.4	962.6	961.8
155°	986.3	987.2	987.1	986.1	985.0	984.0	982.9
157.5°	1005.3	1006.4	1006.2	1004.9	1003.5	1002.2	1000.8
160°	1016.1	1017.1	1017.0	1015.8	1014.6	1013.4	1012.2
162.5°	1026.0	1027.1	1027.2	1026.1	1025.0	1024.0	1022.9
165°	1039.3	1040.7	1040.8	1039.6	1038.2	1037.0	1035.8
167.5°	1049.4	1050.8	1050.8	1049.4	1047.9	1046.5	1045.1
170°	1055.0	1056.4	1056.4	1055.0	1053.6	1052.3	1050.9
172.5°	1058.8	1060.3	1060.2	1058.6	1057.1	1055.5	1054.0
175°	1063.2	1064.4	1064.3	1063.0	1061.6	1060.2	1058.7
177.5°	1064.8	1065.9	1065.8	1064.4	1063.0	1061.6	1060.2
180°	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7	1062.7

(END OF REPORT)