

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P831606

Luminaire Tested: S123DIP-S775D1025U940-4F0-1E-UDD-G

Issue Date: 05/03/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P831606  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2301-905-1, G3-1807-864-5)  
Test Lab: INNOVATION CENTER  
Issue Date: 05/03/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: NEO-RAY  
Catalog Number: S123DIP-S775D1025U940-4F0-1E-UDD-G  
Description: DEFINE 3 DIRECT-INDIRECT PENDANT LED LUMINAIRE  
DOWNLIGHT 775 LUMENS PER FOOT, GRAZE OPTIC  
UPLIGHT 1025 LUMENS PER FOOT, NO LENS  
Light Source: -  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 6817.2 lumens  
Efficiency: N/A  
Efficacy: 131.6 lumens/watt  
Spacing Criteria (0/90/45): 0.65 / 1.19 / 0.89  
Luminous Opening: Rectangular (W 4' x L: 0.25' x H: 0')  
CIE Type: General Diffuse  
  
Input Watts (W): 51.8  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

### Luminous Intensity Polar Plot





TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	106	106	106	106	98	98	98	98	81	81	81	66	66	66	53	53	53	46				
1	97	93	90	86	89	86	83	80	72	70	68	59	58	56	47	46	46	40				
2	89	82	76	71	82	76	71	66	64	60	57	53	50	48	42	41	39	34				
3	82	73	66	60	75	67	61	56	57	52	49	47	44	41	38	36	34	30				
4	75	65	57	51	69	60	53	48	51	46	42	42	39	36	34	32	30	26				
5	69	58	50	44	63	54	47	42	46	41	37	38	34	31	31	29	26	23				
6	64	52	45	39	59	49	42	37	42	36	32	35	31	28	29	26	24	21				
7	59	47	40	34	54	44	37	33	38	33	29	32	28	25	27	24	21	19				
8	55	43	36	31	51	40	34	29	35	30	26	30	26	23	25	22	19	17				
9	52	40	33	28	47	37	31	26	32	27	23	27	23	21	23	20	18	16				
10	48	37	30	25	45	34	28	24	30	25	21	25	22	19	21	18	16	14				

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°	135°	180°
0°	21177	21177	21177	21177	21177
5°	26782	25278	21367	17219	15823
10°	27042	27860	21225	13726	11995
15°	20367	25867	21080	11624	10143
20°	14191	20931	20811	10165	9213
25°	10821	16096	20352	9352	8641
30°	9362	12788	19619	8777	8181
35°	8686	10797	18775	8361	7858
40°	8223	9686	17588	7966	7748
45°	7949	8965	16079	7657	7700
50°	7812	8393	14294	7376	7659
55°	7522	7976	12542	7111	7692
60°	7253	7528	10809	6859	7567
65°	6813	7103	9324	6592	7417
70°	6291	6565	7931	6150	6980
75°	5693	5885	6796	5714	6380
80°	4699	5151	5374	4978	5374
85°	3717	4174	3952	4224	4286

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 80°  
 Vertical Angle: 45°  
 Luminance: 18358 cd/sqm



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	186.0	2.7
10°-20°	462.7	6.8
20°-30°	547.9	8.0
30°-40°	550.9	8.1
40°-50°	505.4	7.4
50°-60°	417.2	6.1
60°-70°	295.1	4.3
70°-80°	157.5	2.3
80°-90°	42.4	0.6
90°-100°	42.2	0.6
100°-110°	204.2	3.0
110°-120°	500.5	7.3
120°-130°	635.4	9.3
130°-140°	678.8	10.0
140°-150°	634.7	9.3
150°-160°	512.0	7.5
160°-170°	330.4	4.8
170°-180°	113.9	1.7
0°-30°	1196.6	17.6
0°-40°	1747.5	25.6
0°-60°	2670.1	39.2
0°-90°	3165.1	46.4
90°-120°	746.9	11.0
90°-150°	2695.8	39.5
90°-180°	3652.0	53.6
0°-180°	6817.2	100.0

**CANDELA DISTRIBUTION:**

	0°	45°	90°	135°	180°	Flux
0°	1967	1967	1967	1967	1967	
5°	2479	2340	1978	1594	1464	236
15°	1828	2321	1892	1043	910	505
25°	911	1355	1714	787	728	430
35°	661	822	1429	636	598	415
45°	522	589	1056	503	506	404
55°	401	425	668	379	410	359
65°	268	279	366	259	291	266
75°	137	142	163	137	153	144
85°	30	34	32	34	35	34
90°	27	21	1	21	27	13
95°	34	28	54	28	34	28
105°	39	195	265	195	39	82
115°	523	511	498	511	523	492
125°	716	712	701	712	716	639
135°	882	882	873	882	882	680
145°	1017	1016	1008	1016	1017	635
155°	1108	1109	1110	1109	1108	511
165°	1168	1167	1170	1167	1168	330
175°	1194	1194	1198	1194	1194	114
180°	1198	1198	1198	1198	1198	



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (FULL):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4
2.5°	2217.6	2215.3	2213.0	2201.6	2190.2	2184.7	2179.2	2162.8	2146.4	2128.1	2109.8
5°	2478.7	2485.1	2491.5	2484.2	2476.9	2454.5	2432.1	2402.5	2372.8	2339.5	2306.1
7.5°	2599.2	2602.8	2606.5	2601.9	2597.4	2591.4	2585.5	2559.0	2532.5	2498.3	2464.1
10°	2474.1	2482.3	2490.6	2508.4	2526.2	2546.2	2566.3	2562.7	2559.0	2549.0	2538.9
12.5°	2199.3	2209.4	2219.4	2255.0	2290.6	2336.3	2381.9	2421.2	2460.4	2487.8	2515.2
15°	1827.7	1855.6	1883.4	1915.8	1948.3	2015.4	2082.5	2165.1	2247.7	2321.2	2394.7
17.5°	1505.5	1516.0	1526.5	1561.2	1595.9	1680.3	1764.8	1860.2	1955.6	2077.4	2199.3
20°	1238.9	1248.5	1258.1	1303.7	1349.4	1415.5	1481.7	1589.0	1696.3	1827.3	1958.3
22.5°	1040.8	1055.8	1070.9	1096.5	1122.0	1185.5	1248.9	1344.3	1439.7	1584.4	1729.1
25°	911.1	922.1	933.0	948.6	964.1	1014.8	1065.4	1143.9	1222.5	1355.3	1488.1
27.5°	822.6	827.1	831.7	847.2	862.7	895.6	928.5	996.0	1063.6	1176.3	1289.1
30°	753.2	756.4	759.6	773.3	787.0	809.3	831.7	880.5	929.4	1028.9	1128.4
32.5°	704.8	707.1	709.4	719.9	730.4	746.3	762.3	797.9	833.5	915.7	997.9
35°	661.0	662.4	663.7	671.5	679.2	691.1	703.0	729.9	756.8	821.7	886.5
37.5°	622.6	624.5	626.3	630.9	635.4	645.9	656.4	677.9	699.3	749.1	798.8
40°	585.2	588.4	591.6	594.8	598.0	606.7	615.3	631.8	648.2	689.3	730.4
42.5°	553.3	556.4	559.6	561.0	562.4	567.4	572.4	587.5	602.6	633.1	663.7
45°	522.2	523.6	525.0	526.3	527.7	531.8	535.9	549.1	562.4	588.9	615.3
47.5°	493.9	493.9	493.9	494.8	495.7	499.4	503.0	512.6	522.2	542.8	563.3
50°	466.5	466.5	466.5	465.2	463.8	466.1	468.3	475.7	483.0	501.2	519.5
52.5°	433.7	433.7	433.7	434.1	434.6	434.6	434.6	441.0	447.4	463.8	480.2
55°	400.8	402.6	404.4	403.1	401.7	402.6	403.5	407.6	411.7	425.0	438.2
57.5°	367.9	368.8	369.7	369.3	368.8	369.3	369.7	373.4	377.1	387.1	397.1
60°	336.9	336.9	336.9	336.0	335.1	336.0	336.9	338.7	340.5	349.7	358.8
62.5°	302.2	302.6	303.1	303.6	304.0	303.1	302.2	304.5	306.8	313.6	320.4
65°	267.5	268.0	268.4	269.8	271.1	270.2	269.3	271.6	273.9	278.9	283.9
67.5°	236.5	235.5	234.6	235.1	235.5	236.9	238.3	238.7	239.2	244.7	250.2
70°	199.9	200.9	201.8	201.3	200.9	201.3	201.8	203.1	204.5	208.6	212.7
72.5°	167.1	167.5	168.0	168.0	168.0	168.9	169.8	171.2	172.5	174.8	177.1
75°	136.9	136.9	136.9	137.9	138.8	139.2	139.7	139.7	139.7	141.5	143.3
77.5°	104.1	106.4	108.6	108.2	107.7	108.6	109.6	110.9	112.3	113.2	114.1
80°	75.8	75.8	75.8	76.2	76.7	78.1	79.4	80.3	81.3	83.1	84.9
82.5°	48.4	48.8	49.3	50.7	52.0	53.0	53.9	55.2	56.6	56.6	56.6
85°	30.1	29.2	28.3	29.2	30.1	31.0	32.0	32.4	32.9	33.8	34.7
87.5°	14.6	14.6	14.6	14.6	14.6	15.1	15.5	15.5	15.5	15.5	15.5
90°	26.7	26.3	25.9	25.5	25.1	24.5	23.7	22.9	22.2	21.4	18.8
92.5°	30.3	30.1	29.9	29.7	29.5	28.7	27.3	25.9	24.5	23.1	21.4
95°	33.8	33.8	33.8	33.8	33.8	33.1	31.7	30.4	29.0	27.6	25.4
97.5°	36.5	36.3	36.1	35.9	35.7	34.8	33.2	31.6	30.1	28.5	38.6
100°	37.4	37.2	37.0	36.8	36.6	35.7	34.1	32.5	31.0	29.4	60.2
102.5°	38.3	37.9	37.5	37.1	36.7	39.8	46.3	52.8	59.3	65.9	100.3
105°	39.2	38.8	38.4	38.0	37.6	54.9	89.9	124.9	159.9	194.9	212.7
107.5°	92.6	118.5	144.4	170.3	196.2	224.4	254.9	285.3	315.8	346.2	343.3
110°	244.8	273.0	301.3	329.6	357.9	375.3	381.8	388.4	394.9	401.4	399.2



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	463.7	464.1	464.5	464.9	465.3	464.6	462.8	461.0	459.3	457.5	455.3
115°	523.4	522.6	521.8	521.0	520.2	518.8	516.8	514.8	512.9	510.9	509.1
117.5°	571.4	571.2	571.0	570.8	570.6	569.7	568.2	566.6	565.0	563.4	562.4
120°	621.3	621.3	621.3	621.3	621.3	620.5	618.9	617.3	615.7	614.1	613.5
122.5°	670.2	670.0	669.8	669.6	669.4	668.8	667.8	666.9	665.9	664.9	664.1
125°	715.6	715.2	714.8	714.4	714.0	713.6	713.2	712.8	712.4	712.0	711.3
127.5°	760.1	760.5	760.9	761.3	761.7	761.6	761.0	760.4	759.8	759.2	758.2
130°	802.8	803.2	803.6	804.0	804.4	804.2	803.4	802.6	801.8	801.1	800.3
132.5°	842.0	842.6	843.2	843.8	844.4	844.3	843.5	842.7	841.9	841.1	840.5
135°	882.0	882.6	883.2	883.8	884.4	884.4	883.8	883.2	882.6	882.0	881.3
137.5°	920.3	920.7	921.1	921.5	921.9	921.6	920.6	919.6	918.6	917.6	917.3
140°	954.1	954.5	954.9	955.3	955.7	955.5	954.7	953.9	953.2	952.4	951.8
142.5°	985.3	985.9	986.5	987.1	987.7	987.7	987.1	986.5	985.9	985.3	984.7
145°	1017.3	1017.3	1017.3	1017.3	1017.3	1017.1	1016.7	1016.3	1016.0	1015.6	1015.2
147.5°	1040.5	1041.5	1042.5	1043.4	1044.4	1044.7	1044.3	1043.9	1043.5	1043.1	1042.8
150°	1067.2	1067.8	1068.4	1069.0	1069.6	1069.7	1069.3	1068.9	1068.5	1068.1	1067.7
152.5°	1088.5	1089.5	1090.5	1091.5	1092.5	1092.6	1091.8	1091.0	1090.2	1089.4	1089.2
155°	1108.1	1109.3	1110.5	1111.7	1112.9	1113.0	1112.0	1111.0	1110.0	1109.0	1108.8
157.5°	1125.0	1126.6	1128.2	1129.8	1131.4	1131.6	1130.4	1129.2	1128.0	1126.8	1127.0
160°	1141.1	1142.4	1143.8	1145.2	1146.6	1146.7	1145.5	1144.3	1143.1	1141.9	1142.1
162.5°	1156.2	1157.4	1158.6	1159.7	1160.9	1160.8	1159.4	1158.1	1156.7	1155.3	1155.5
165°	1167.8	1169.1	1170.5	1171.9	1173.3	1173.2	1171.6	1170.0	1168.4	1166.9	1167.1
167.5°	1176.7	1178.2	1179.8	1181.4	1183.0	1183.0	1181.4	1179.8	1178.2	1176.7	1176.7
170°	1184.7	1186.2	1187.8	1189.4	1191.0	1191.0	1189.4	1187.8	1186.2	1184.7	1184.7
172.5°	1189.1	1190.9	1192.7	1194.5	1196.2	1196.3	1194.8	1193.2	1191.6	1190.0	1189.8
175°	1193.6	1195.1	1196.7	1198.3	1199.9	1200.0	1198.6	1197.2	1195.8	1194.5	1194.3
177.5°	1194.5	1196.4	1198.4	1200.4	1202.4	1202.6	1201.0	1199.4	1197.8	1196.2	1196.0
180°	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4
2.5°	2104.4	2098.9	2078.8	2058.7	2035.9	2013.1	1996.2	1979.3	1954.2	1929.1	1908.5
5°	2280.6	2255.0	2212.6	2170.1	2112.6	2055.1	2016.3	1977.5	1925.4	1873.4	1831.9
7.5°	2420.3	2376.4	2317.1	2257.7	2182.4	2107.1	2035.9	1964.7	1885.3	1805.8	1741.0
10°	2509.3	2479.6	2411.1	2342.7	2241.8	2140.9	2041.4	1941.9	1839.6	1737.4	1651.5
12.5°	2517.9	2520.7	2457.7	2394.7	2280.6	2166.5	2045.5	1924.5	1795.8	1667.1	1567.1
15°	2441.7	2488.7	2454.0	2419.3	2304.3	2189.3	2040.5	1891.7	1743.3	1594.9	1479.5
17.5°	2300.2	2401.1	2406.1	2411.1	2296.1	2181.1	2016.3	1851.5	1683.5	1515.5	1394.1
20°	2107.1	2255.9	2307.0	2358.2	2264.6	2171.0	1993.9	1816.8	1628.7	1440.7	1313.3
22.5°	1909.9	2090.7	2184.3	2277.8	2208.4	2139.1	1950.5	1762.0	1563.4	1364.9	1235.7
25°	1685.3	1882.5	2026.3	2170.1	2127.7	2085.2	1899.4	1713.6	1502.3	1290.9	1159.0
27.5°	1489.5	1689.9	1863.4	2036.8	2027.7	2018.6	1834.1	1649.7	1433.3	1217.0	1089.6
30°	1315.1	1501.8	1695.8	1889.8	1912.2	1934.6	1756.5	1578.5	1361.7	1144.9	1022.1
32.5°	1160.8	1323.8	1531.9	1740.1	1783.9	1827.7	1667.1	1506.4	1291.8	1077.3	959.1
35°	1034.4	1182.3	1390.4	1598.6	1653.4	1708.1	1568.5	1428.8	1219.7	1010.6	897.9
37.5°	922.5	1046.3	1249.4	1452.5	1519.6	1586.7	1461.6	1336.6	1140.7	944.9	841.3
40°	829.9	929.4	1116.1	1302.8	1380.4	1458.0	1354.8	1251.7	1065.9	880.1	784.7
42.5°	752.3	840.8	1010.2	1179.5	1253.9	1328.4	1241.2	1154.0	988.7	823.5	736.3
45°	686.1	756.8	910.7	1064.5	1135.3	1206.0	1131.2	1056.3	910.7	765.1	683.8
47.5°	624.0	684.7	816.2	947.7	1010.6	1073.6	1015.2	956.8	833.5	710.3	636.8
50°	568.3	617.2	732.2	847.2	902.0	956.8	905.2	853.6	752.3	650.9	587.0
52.5°	519.9	559.6	656.0	752.3	799.3	846.3	802.0	757.8	677.4	597.1	541.4
55°	472.0	505.8	589.3	672.9	704.8	736.8	702.5	668.3	603.5	538.6	491.6
57.5°	427.3	457.4	525.9	594.3	619.0	643.6	612.6	581.6	532.7	483.9	444.6
60°	383.4	408.1	465.2	522.2	537.3	552.3	527.2	502.1	467.9	433.7	398.5
62.5°	342.8	365.2	407.6	450.1	460.1	470.2	451.0	431.8	405.8	379.8	352.4
65°	300.8	317.7	352.4	387.1	393.5	399.9	383.0	366.1	346.5	326.8	306.8
67.5°	262.0	273.9	302.2	330.5	330.9	331.4	317.7	304.0	293.1	282.1	266.1
70°	224.1	235.5	254.3	273.0	273.4	273.9	262.9	252.0	243.8	235.5	223.7
72.5°	185.3	193.5	207.7	221.8	220.9	220.0	213.2	206.3	199.9	193.5	184.9
75°	150.2	157.0	166.6	176.2	173.5	170.7	167.1	163.4	157.9	152.5	147.0
77.5°	118.2	122.3	127.8	133.3	131.5	129.6	126.4	123.2	119.1	115.0	112.8
80°	86.7	88.6	92.2	95.9	94.9	94.0	90.4	86.7	85.8	84.9	81.7
82.5°	58.9	61.2	62.1	63.0	62.5	62.1	59.3	56.6	55.7	54.8	54.3
85°	35.1	35.6	36.1	36.5	35.1	33.8	32.9	32.0	32.0	32.0	31.5
87.5°	16.0	16.4	16.4	16.4	16.0	15.5	14.6	13.7	14.2	14.6	14.6
90°	16.2	13.6	11.1	8.8	6.8	4.8	2.9	0.9	2.9	4.8	6.8
92.5°	19.6	17.8	16.0	15.7	16.9	18.1	19.3	20.5	19.3	18.1	16.9
95°	23.2	21.1	18.9	21.9	30.0	38.1	46.2	54.3	46.2	38.1	30.0
97.5°	48.7	58.7	68.8	76.6	82.2	87.7	93.3	98.8	93.3	87.7	82.2
100°	91.1	121.9	152.8	166.2	162.3	158.3	154.4	150.4	154.4	158.3	162.3
102.5°	134.7	169.1	203.5	219.4	216.9	214.3	211.7	209.2	211.7	214.3	216.9
105°	230.5	248.3	266.1	273.9	271.8	269.6	267.4	265.2	267.4	269.6	271.8
107.5°	340.3	337.3	334.4	332.0	330.2	328.4	326.7	324.9	326.7	328.4	330.2
110°	397.1	394.9	392.7	390.8	389.3	387.7	386.1	384.5	386.1	387.7	389.3





TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	453.1	451.0	448.8	447.0	445.6	444.2	442.9	441.5	442.9	444.2	445.6
115°	507.3	505.6	503.8	502.3	501.1	499.9	498.7	497.5	498.7	499.9	501.1
117.5°	561.4	560.4	559.5	558.3	556.9	555.5	554.1	552.7	554.1	555.5	556.9
120°	613.0	612.4	611.8	610.6	608.8	607.0	605.2	603.5	605.2	607.0	608.8
122.5°	663.3	662.5	661.7	660.6	659.2	657.9	656.5	655.1	656.5	657.9	659.2
125°	710.5	709.7	708.9	707.7	706.1	704.5	702.9	701.4	702.9	704.5	706.1
127.5°	757.2	756.3	755.3	754.0	752.4	750.8	749.2	747.6	749.2	750.8	752.4
130°	799.5	798.7	797.9	796.7	795.1	793.5	792.0	790.4	792.0	793.5	795.1
132.5°	839.9	839.3	838.7	837.6	836.1	834.5	832.9	831.3	832.9	834.5	836.1
135°	880.5	879.7	878.9	877.9	876.7	875.5	874.3	873.1	874.3	875.5	876.7
137.5°	916.9	916.5	916.1	915.1	913.5	911.9	910.3	908.7	910.3	911.9	913.5
140°	951.2	950.6	950.0	949.1	947.9	946.7	945.5	944.4	945.5	946.7	947.9
142.5°	984.1	983.5	982.9	982.0	980.8	979.7	978.5	977.3	978.5	979.7	980.8
145°	1014.8	1014.4	1014.0	1013.1	1011.7	1010.3	1008.9	1007.5	1008.9	1010.3	1011.7
147.5°	1042.4	1042.0	1041.6	1040.9	1039.9	1038.9	1037.9	1036.9	1037.9	1038.9	1039.9
150°	1067.3	1066.9	1066.5	1066.0	1065.4	1064.8	1064.2	1063.6	1064.2	1064.8	1065.4
152.5°	1089.0	1088.8	1088.6	1088.4	1088.2	1088.0	1087.8	1087.7	1087.8	1088.0	1088.2
155°	1108.6	1108.4	1108.2	1108.3	1108.7	1109.1	1109.5	1109.9	1109.5	1109.1	1108.7
157.5°	1127.2	1127.4	1127.6	1127.7	1127.7	1127.7	1127.7	1127.7	1127.7	1127.7	1127.7
160°	1142.3	1142.5	1142.7	1142.9	1143.1	1143.3	1143.5	1143.7	1143.5	1143.3	1143.1
162.5°	1155.7	1155.9	1156.1	1156.5	1157.1	1157.7	1158.3	1158.9	1158.3	1157.7	1157.1
165°	1167.3	1167.5	1167.7	1168.1	1168.6	1169.2	1169.8	1170.4	1169.8	1169.2	1168.6
167.5°	1176.7	1176.7	1176.7	1177.1	1177.8	1178.6	1179.4	1180.2	1179.4	1178.6	1177.8
170°	1184.7	1184.7	1184.7	1185.1	1185.9	1186.6	1187.4	1188.2	1187.4	1186.6	1185.9
172.5°	1189.6	1189.4	1189.2	1189.6	1190.6	1191.6	1192.6	1193.6	1192.6	1191.6	1190.6
175°	1194.1	1193.9	1193.7	1194.1	1195.1	1196.0	1197.0	1198.0	1197.0	1196.0	1195.1
177.5°	1195.8	1195.6	1195.4	1195.8	1196.8	1197.8	1198.8	1199.8	1198.8	1197.8	1196.8
180°	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4	1967.4
2.5°	1888.0	1870.2	1852.4	1838.7	1825.0	1801.7	1778.4	1773.0	1767.5	1759.7	1752.0
5°	1790.3	1746.5	1702.7	1663.4	1624.2	1593.6	1563.0	1542.9	1522.8	1508.2	1493.6
7.5°	1676.2	1610.5	1544.7	1498.2	1451.6	1407.3	1363.0	1348.9	1334.7	1315.6	1296.4
10°	1565.7	1493.1	1420.6	1359.9	1299.1	1255.8	1212.4	1195.1	1177.7	1153.5	1129.3
12.5°	1467.1	1387.7	1308.3	1247.1	1185.9	1143.9	1101.9	1076.8	1051.7	1038.0	1024.3
15°	1364.0	1279.1	1194.2	1137.5	1080.9	1043.1	1005.2	983.3	961.3	948.1	934.9
17.5°	1272.7	1188.7	1104.7	1050.4	996.0	961.3	926.7	907.5	888.3	878.3	868.2
20°	1185.9	1103.8	1021.6	968.7	915.7	887.4	859.1	846.8	834.4	826.2	818.0
22.5°	1106.5	1025.7	944.9	899.7	854.5	831.7	808.9	800.2	791.5	784.7	777.8
25°	1027.1	955.0	882.8	844.5	806.1	787.4	768.7	760.0	751.4	744.5	737.7
27.5°	962.3	893.3	824.4	791.5	758.7	744.1	729.5	722.6	715.8	709.4	703.0
30°	899.3	837.6	776.0	747.7	719.4	706.2	692.9	686.1	679.2	673.3	667.4
32.5°	840.8	787.9	734.9	708.9	682.9	671.9	661.0	652.8	644.5	640.0	635.4
35°	785.1	737.7	690.2	668.7	647.3	636.3	625.4	618.5	611.7	608.0	604.4
37.5°	737.7	695.2	652.8	632.2	611.7	601.2	590.7	584.8	578.8	577.4	576.1
40°	689.3	652.8	616.2	596.2	576.1	566.9	557.8	554.2	550.5	549.6	548.7
42.5°	649.1	613.5	577.9	559.6	541.4	533.6	525.9	524.0	522.2	523.6	525.0
45°	602.6	572.9	543.2	526.3	509.4	503.0	496.7	495.3	493.9	496.7	499.4
47.5°	563.3	535.9	508.5	492.5	476.6	472.0	467.4	467.0	466.5	470.2	473.8
50°	523.1	496.7	470.2	457.4	444.6	440.5	436.4	437.8	439.1	445.1	451.0
52.5°	485.7	461.0	436.4	424.5	412.7	409.9	407.2	410.4	413.6	420.0	426.4
55°	444.6	422.2	399.9	390.7	381.6	378.9	376.1	382.5	388.9	394.9	400.8
57.5°	405.4	385.7	366.1	357.9	349.7	349.2	348.8	354.7	360.6	367.0	373.4
60°	363.4	346.9	330.5	324.1	317.7	318.6	319.5	326.4	333.2	338.3	343.3
62.5°	325.0	311.3	297.6	291.7	285.8	288.0	290.3	297.2	304.0	309.9	315.9
65°	286.7	275.3	263.8	259.7	255.6	258.8	262.0	268.0	273.9	278.0	282.1
67.5°	250.2	240.6	231.0	227.8	224.6	227.8	231.0	236.9	242.8	247.0	251.1
70°	211.8	204.0	196.3	194.0	191.7	195.4	199.0	204.0	209.1	213.2	217.3
72.5°	176.2	170.3	164.3	163.9	163.4	166.6	169.8	174.8	179.9	182.6	185.3
75°	141.5	138.3	135.1	134.7	134.2	137.4	140.6	143.3	146.1	148.4	150.6
77.5°	110.5	107.7	105.0	105.4	105.9	108.2	110.5	113.2	115.9	117.3	118.7
80°	78.5	77.6	76.7	77.6	78.5	80.3	82.2	84.0	85.8	86.7	87.6
82.5°	53.9	53.0	52.0	53.4	54.8	56.1	57.5	58.9	60.3	60.7	61.2
85°	31.0	32.4	33.8	33.8	33.8	34.2	34.7	35.1	35.6	35.1	34.7
87.5°	14.6	15.1	15.5	15.5	15.5	16.0	16.4	16.4	16.4	16.0	15.5
90°	8.8	11.1	13.6	16.2	18.8	21.4	22.2	22.9	23.7	24.5	25.1
92.5°	15.7	16.0	17.8	19.6	21.4	23.1	24.5	25.9	27.3	28.7	29.5
95°	21.9	18.9	21.1	23.2	25.4	27.6	29.0	30.4	31.7	33.1	33.8
97.5°	76.6	68.8	58.7	48.7	38.6	28.5	30.1	31.6	33.2	34.8	35.7
100°	166.2	152.8	121.9	91.1	60.2	29.4	31.0	32.5	34.1	35.7	36.6
102.5°	219.4	203.5	169.1	134.7	100.3	65.9	59.3	52.8	46.3	39.8	36.7
105°	273.9	266.1	248.3	230.5	212.7	194.9	159.9	124.9	89.9	54.9	37.6
107.5°	332.0	334.4	337.3	340.3	343.3	346.2	315.8	285.3	254.9	224.4	196.2
110°	390.8	392.7	394.9	397.1	399.2	401.4	394.9	388.4	381.8	375.3	357.9



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	447.0	448.8	451.0	453.1	455.3	457.5	459.3	461.0	462.8	464.6	465.3
115°	502.3	503.8	505.6	507.3	509.1	510.9	512.9	514.8	516.8	518.8	520.2
117.5°	558.3	559.5	560.4	561.4	562.4	563.4	565.0	566.6	568.2	569.7	570.6
120°	610.6	611.8	612.4	613.0	613.5	614.1	615.7	617.3	618.9	620.5	621.3
122.5°	660.6	661.7	662.5	663.3	664.1	664.9	665.9	666.9	667.8	668.8	669.4
125°	707.7	708.9	709.7	710.5	711.3	712.0	712.4	712.8	713.2	713.6	714.0
127.5°	754.0	755.3	756.3	757.2	758.2	759.2	759.8	760.4	761.0	761.6	761.7
130°	796.7	797.9	798.7	799.5	800.3	801.1	801.8	802.6	803.4	804.2	804.4
132.5°	837.6	838.7	839.3	839.9	840.5	841.1	841.9	842.7	843.5	844.3	844.4
135°	877.9	878.9	879.7	880.5	881.3	882.0	882.6	883.2	883.8	884.4	884.4
137.5°	915.1	916.1	916.5	916.9	917.3	917.6	918.6	919.6	920.6	921.6	921.9
140°	949.1	950.0	950.6	951.2	951.8	952.4	953.2	953.9	954.7	955.5	955.7
142.5°	982.0	982.9	983.5	984.1	984.7	985.3	985.9	986.5	987.1	987.7	987.7
145°	1013.1	1014.0	1014.4	1014.8	1015.2	1015.6	1016.0	1016.3	1016.7	1017.1	1017.3
147.5°	1040.9	1041.6	1042.0	1042.4	1042.8	1043.1	1043.5	1043.9	1044.3	1044.7	1044.4
150°	1066.0	1066.5	1066.9	1067.3	1067.7	1068.1	1068.5	1068.9	1069.3	1069.7	1069.6
152.5°	1088.4	1088.6	1088.8	1089.0	1089.2	1089.4	1090.2	1091.0	1091.8	1092.6	1092.5
155°	1108.3	1108.2	1108.4	1108.6	1108.8	1109.0	1110.0	1111.0	1112.0	1113.0	1112.9
157.5°	1127.7	1127.6	1127.4	1127.2	1127.0	1126.8	1128.0	1129.2	1130.4	1131.6	1131.4
160°	1142.9	1142.7	1142.5	1142.3	1142.1	1141.9	1143.1	1144.3	1145.5	1146.7	1146.6
162.5°	1156.5	1156.1	1155.9	1155.7	1155.5	1155.3	1156.7	1158.1	1159.4	1160.8	1160.9
165°	1168.1	1167.7	1167.5	1167.3	1167.1	1166.9	1168.4	1170.0	1171.6	1173.2	1173.3
167.5°	1177.1	1176.7	1176.7	1176.7	1176.7	1176.7	1178.2	1179.8	1181.4	1183.0	1183.0
170°	1185.1	1184.7	1184.7	1184.7	1184.7	1184.7	1186.2	1187.8	1189.4	1191.0	1191.0
172.5°	1189.6	1189.2	1189.4	1189.6	1189.8	1190.0	1191.6	1193.2	1194.8	1196.3	1196.2
175°	1194.1	1193.7	1193.9	1194.1	1194.3	1194.5	1195.8	1197.2	1198.6	1200.0	1199.9
177.5°	1195.8	1195.4	1195.6	1195.8	1196.0	1196.2	1197.8	1199.4	1201.0	1202.6	1202.4
180°	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0	1198.0



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°
0°	1967.4	1967.4	1967.4	1967.4
2.5°	1748.8	1745.6	1732.8	1720.0
5°	1482.6	1471.7	1468.0	1464.4
7.5°	1295.5	1294.6	1275.4	1256.2
10°	1130.7	1132.1	1114.7	1097.4
12.5°	1012.9	1001.5	1000.1	998.8
15°	924.4	913.9	912.0	910.2
17.5°	861.8	855.4	853.6	851.8
20°	814.4	810.7	807.5	804.3
22.5°	773.3	768.7	766.0	763.2
25°	733.6	729.5	728.5	727.6
27.5°	698.0	692.9	692.9	692.9
30°	664.2	661.0	659.6	658.2
32.5°	632.7	629.9	629.9	629.9
35°	603.0	601.6	599.8	598.0
37.5°	576.1	576.1	575.2	574.3
40°	550.1	551.4	551.4	551.4
42.5°	526.3	527.7	527.7	527.7
45°	501.7	504.0	504.9	505.8
47.5°	477.5	481.1	482.0	483.0
50°	453.7	456.5	456.9	457.4
52.5°	429.5	432.7	435.0	437.3
55°	404.0	407.2	408.5	409.9
57.5°	376.6	379.8	380.2	380.7
60°	346.5	349.7	350.6	351.5
62.5°	317.7	319.5	320.4	321.4
65°	284.8	287.6	289.4	291.2
67.5°	253.3	255.6	255.6	255.6
70°	218.2	219.1	220.5	221.8
72.5°	185.8	186.2	186.2	186.2
75°	151.6	152.5	152.9	153.4
77.5°	119.1	119.6	119.6	119.6
80°	87.2	86.7	86.7	86.7
82.5°	59.8	58.4	58.4	58.4
85°	34.2	33.8	34.2	34.7
87.5°	15.5	15.5	15.5	15.5
90°	25.5	25.9	26.3	26.7
92.5°	29.7	29.9	30.1	30.3
95°	33.8	33.8	33.8	33.8
97.5°	35.9	36.1	36.3	36.5
100°	36.8	37.0	37.2	37.4
102.5°	37.1	37.5	37.9	38.3
105°	38.0	38.4	38.8	39.2
107.5°	170.3	144.4	118.5	92.6
110°	329.6	301.3	273.0	244.8



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°
112.5°	464.9	464.5	464.1	463.7
115°	521.0	521.8	522.6	523.4
117.5°	570.8	571.0	571.2	571.4
120°	621.3	621.3	621.3	621.3
122.5°	669.6	669.8	670.0	670.2
125°	714.4	714.8	715.2	715.6
127.5°	761.3	760.9	760.5	760.1
130°	804.0	803.6	803.2	802.8
132.5°	843.8	843.2	842.6	842.0
135°	883.8	883.2	882.6	882.0
137.5°	921.5	921.1	920.7	920.3
140°	955.3	954.9	954.5	954.1
142.5°	987.1	986.5	985.9	985.3
145°	1017.3	1017.3	1017.3	1017.3
147.5°	1043.4	1042.5	1041.5	1040.5
150°	1069.0	1068.4	1067.8	1067.2
152.5°	1091.5	1090.5	1089.5	1088.5
155°	1111.7	1110.5	1109.3	1108.1
157.5°	1129.8	1128.2	1126.6	1125.0
160°	1145.2	1143.8	1142.4	1141.1
162.5°	1159.7	1158.6	1157.4	1156.2
165°	1171.9	1170.5	1169.1	1167.8
167.5°	1181.4	1179.8	1178.2	1176.7
170°	1189.4	1187.8	1186.2	1184.7
172.5°	1194.5	1192.7	1190.9	1189.1
175°	1198.3	1196.7	1195.1	1193.6
177.5°	1200.4	1198.4	1196.4	1194.5
180°	1198.0	1198.0	1198.0	1198.0



TEST NUMBER: P831606

CATALOG NUMBER: S123DIP-S775D1025U940-4F0-1E-UDD-G

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.83	14.63	14.83	15.63	16.95	16.07	16.86	17.06	17.87	19.19
	3H	15.47	16.19	16.48	17.20	18.54	17.49	18.20	18.49	19.21	20.56
	4H	16.05	16.72	17.07	17.74	19.09	17.93	18.61	18.95	19.62	20.98
	6H	16.42	17.04	17.44	18.05	19.42	18.21	18.83	19.24	19.85	21.21
	8H	16.51	17.10	17.54	18.14	19.50	18.27	18.86	19.30	19.89	21.25
	12H	16.55	17.12	17.59	18.14	19.53	18.29	18.85	19.32	19.87	21.26
4H	2H	14.40	15.07	15.42	16.09	17.44	16.22	16.90	17.25	17.91	19.27
	3H	16.22	16.78	17.25	17.83	19.19	17.84	18.40	18.87	19.44	20.81
	4H	16.92	17.43	17.96	18.47	19.86	18.42	18.93	19.46	19.97	21.36
	6H	17.39	17.83	18.44	18.89	20.27	18.82	19.26	19.87	20.32	21.70
	8H	17.52	17.94	18.57	18.99	20.39	18.93	19.34	19.98	20.39	21.79
	12H	17.59	17.96	18.66	19.03	20.43	18.97	19.34	20.04	20.41	21.81
8H	4H	17.18	17.59	18.23	18.64	20.04	18.52	18.93	19.57	19.98	21.38
	6H	17.77	18.11	18.84	19.20	20.59	19.02	19.36	20.09	20.45	21.85
	8H	17.97	18.27	19.05	19.35	20.76	19.20	19.50	20.28	20.57	21.99
	12H	18.09	18.36	19.18	19.43	20.88	19.30	19.56	20.38	20.63	22.09
12H	4H	17.18	17.55	18.24	18.61	20.02	18.49	18.86	19.56	19.93	21.33
	6H	17.82	18.11	18.90	19.19	20.61	19.03	19.33	20.11	20.41	21.82
	8H	18.05	18.31	19.13	19.38	20.84	19.23	19.49	20.31	20.56	22.02