

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P831218

Luminaire Tested: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

Issue Date: 05/03/2024

**Test Information**


Test Method: LM-79-2019  
Report Number: P831218  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2301-905-1, G3-1807-864-17)  
Test Lab: INNOVATION CENTER  
Issue Date: 05/03/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: NEO-RAY  
Catalog Number: S123DIP-S1165D1195U850-4F0-1E-UDD-G4  
Description: DEFINE 3 DIRECT-INDIRECT PENDANT LED LUMINAIRE  
DOWNLIGHT 1165 LUMENS PER FOOT, GRAZE OPTIC  
UPLIGHT 1195 LUMENS PER FOOT, BATWING OPTIC  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 10696.3 lumens  
Efficiency: N/A  
Efficacy: 146.1 lumens/watt  
Spacing Criteria (0/90/45): 0.65 / 1.19 / 0.89  
Luminous Opening: Rectangular (W 4' x L: 0.25' x H: 0')  
CIE Type: General Diffuse  
  
Input Watts (W): 73.2  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P831218  
CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

### Luminous Intensity Polar Plot





TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	108	108	108	108	101	101	101	101	86	86	86	73	73	73	61	61	61	55				
1	100	95	92	88	92	89	86	83	76	74	72	65	64	62	55	54	53	48				
2	91	84	78	73	84	78	73	69	68	64	61	58	55	53	49	47	45	41				
3	84	74	67	62	77	70	63	58	60	56	52	52	48	45	44	41	39	35				
4	77	66	59	53	71	62	55	50	54	49	45	47	43	40	40	37	35	31				
5	71	60	52	46	66	56	49	44	49	43	39	42	38	35	36	33	31	28				
6	66	54	46	40	61	51	44	39	44	39	35	39	34	31	33	30	27	25				
7	61	49	41	36	57	46	39	34	41	35	31	36	31	28	31	27	25	22				
8	57	45	37	32	53	42	35	31	37	32	28	33	28	25	28	25	23	20				
9	53	41	34	29	50	39	32	28	35	29	25	30	26	23	27	23	21	19				
10	50	38	31	26	46	36	30	25	32	27	23	28	24	21	25	21	19	17				

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°	135°	180°
0°	39539	39539	39539	39539	39539
5°	50004	47195	39892	32148	29542
10°	50489	52017	39628	25626	22394
15°	38028	48294	39357	21701	18937
20°	26496	39079	38854	18978	17202
25°	20203	30053	37998	17461	16134
30°	17478	23876	36630	16388	15275
35°	16216	20159	35053	15612	14671
40°	15352	18083	32836	14873	14466
45°	14842	16736	30020	14297	14375
50°	14585	15671	26688	13772	14301
55°	14043	14891	23415	13275	14362
60°	13541	14053	20182	12807	14127
65°	12720	13262	17408	12307	13848
70°	11748	12258	14807	11481	13036
75°	10634	10988	12689	10667	11911
80°	8771	9614	10036	9298	10036
85°	6941	7793	7373	7892	8003

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 80°  
 Vertical Angle: 45°  
 Luminance: 34276 cd/sqm



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	347.3	3.2
10°-20°	863.9	8.1
20°-30°	1022.9	9.6
30°-40°	1028.5	9.6
40°-50°	943.7	8.8
50°-60°	778.9	7.3
60°-70°	551.0	5.2
70°-80°	294.1	2.7
80°-90°	78.1	0.7
90°-100°	345.4	3.2
100°-110°	1011.2	9.5
110°-120°	987.5	9.2
120°-130°	786.4	7.4
130°-140°	620.5	5.8
140°-150°	462.9	4.3
150°-160°	322.7	3.0
160°-170°	189.6	1.8
170°-180°	61.7	0.6
0°-30°	2234.1	20.9
0°-40°	3262.7	30.5
0°-60°	4985.2	46.6
0°-90°	5908.4	55.2
90°-120°	2344.1	21.9
90°-150°	4213.9	39.4
90°-180°	4788.0	44.8
0°-180°	10696.3	100.0

**CANDELA DISTRIBUTION:**

	0°	45°	90°	135°	180°	Flux
0°	3673	3673	3673	3673	3673	
5°	4628	4368	3692	2975	2734	441
15°	3412	4334	3532	1947	1699	943
25°	1701	2530	3199	1470	1358	803
35°	1234	1534	2668	1188	1116	775
45°	975	1099	1972	939	944	755
55°	748	794	1248	707	765	670
65°	499	521	684	483	544	496
75°	256	264	305	256	286	269
85°	56	63	60	64	65	63
90°	37	32	3	32	37	23
95°	150	764	44	764	150	243
105°	1639	1036	150	1036	1639	1635
115°	1993	792	264	792	1993	1944
125°	1572	740	367	740	1572	1423
135°	1274	729	430	729	1274	988
145°	996	720	491	720	996	632
155°	826	697	558	697	826	385
165°	720	667	610	667	720	206
175°	648	640	635	640	648	63
180°	636	636	636	636	636	



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (FULL):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3
2.5°	4140.3	4136.1	4131.8	4110.5	4089.2	4079.0	4068.7	4038.0	4007.4	3973.3	3939.2
5°	4627.8	4639.7	4651.7	4638.0	4624.4	4582.6	4540.9	4485.5	4430.1	4367.9	4305.7
7.5°	4852.8	4859.6	4866.5	4857.9	4849.4	4838.3	4827.2	4777.8	4728.4	4664.5	4600.5
10°	4619.3	4634.6	4650.0	4683.2	4716.5	4754.0	4791.5	4784.6	4777.8	4759.1	4740.3
12.5°	4106.2	4125.0	4143.7	4210.2	4276.7	4361.9	4447.1	4520.4	4593.7	4644.9	4696.0
15°	3412.5	3464.5	3516.5	3577.0	3637.5	3762.8	3888.0	4042.3	4196.6	4333.8	4471.0
17.5°	2810.8	2830.4	2850.0	2914.8	2979.5	3137.2	3294.9	3473.0	3651.1	3878.7	4106.2
20°	2313.1	2331.0	2348.9	2434.1	2519.3	2642.9	2766.5	2966.7	3167.0	3411.6	3656.2
22.5°	1943.2	1971.3	1999.4	2047.1	2094.9	2213.3	2331.8	2509.9	2688.1	2958.2	3228.4
25°	1701.1	1721.6	1742.0	1771.0	1800.0	1894.6	1989.2	2135.8	2282.4	2530.4	2778.4
27.5°	1535.8	1544.3	1552.8	1581.8	1610.8	1672.2	1733.5	1859.6	1985.8	2196.3	2406.8
30°	1406.2	1412.2	1418.2	1443.7	1469.3	1511.1	1552.8	1644.0	1735.2	1921.0	2106.8
32.5°	1315.9	1320.2	1324.4	1344.0	1363.6	1393.5	1423.3	1489.8	1556.2	1709.7	1863.1
35°	1234.1	1236.6	1239.2	1253.7	1268.2	1290.3	1312.5	1362.8	1413.1	1534.1	1655.1
37.5°	1162.5	1165.9	1169.3	1177.8	1186.4	1206.0	1225.6	1265.6	1305.7	1398.6	1491.5
40°	1092.6	1098.6	1104.5	1110.5	1116.5	1132.7	1148.9	1179.5	1210.2	1286.9	1363.6
42.5°	1032.9	1038.9	1044.9	1047.4	1050.0	1059.4	1068.7	1096.9	1125.0	1182.1	1239.2
45°	975.0	977.6	980.1	982.7	985.2	992.9	1000.6	1025.3	1050.0	1099.4	1148.9
47.5°	922.2	922.2	922.2	923.9	925.6	932.4	939.2	957.1	975.0	1013.3	1051.7
50°	871.0	871.0	871.0	868.5	865.9	870.2	874.4	888.1	901.7	935.8	969.9
52.5°	809.7	809.7	809.7	810.5	811.4	811.4	811.4	823.3	835.2	865.9	896.6
55°	748.3	751.7	755.1	752.6	750.0	751.7	753.4	761.1	768.7	793.5	818.2
57.5°	686.9	688.6	690.3	689.5	688.6	689.5	690.3	697.2	704.0	722.7	741.5
60°	629.0	629.0	629.0	627.3	625.6	627.3	629.0	632.4	635.8	652.8	669.9
62.5°	564.2	565.1	565.9	566.8	567.6	565.9	564.2	568.5	572.7	585.5	598.3
65°	499.4	500.3	501.1	503.7	506.2	504.5	502.8	507.1	511.4	520.7	530.1
67.5°	441.5	439.8	438.1	438.9	439.8	442.3	444.9	445.7	446.6	456.8	467.0
70°	373.3	375.0	376.7	375.9	375.0	375.9	376.7	379.3	381.8	389.5	397.2
72.5°	311.9	312.8	313.6	313.6	313.6	315.3	317.0	319.6	322.2	326.4	330.7
75°	255.7	255.7	255.7	257.4	259.1	259.9	260.8	260.8	260.8	264.2	267.6
77.5°	194.3	198.6	202.8	202.0	201.1	202.8	204.5	207.1	209.7	211.4	213.1
80°	141.5	141.5	141.5	142.3	143.2	145.7	148.3	150.0	151.7	155.1	158.5
82.5°	90.3	91.2	92.0	94.6	97.2	98.9	100.6	103.1	105.7	105.7	105.7
85°	56.2	54.5	52.8	54.5	56.2	58.0	59.7	60.5	61.4	63.1	64.8
87.5°	27.3	27.3	27.3	27.3	27.3	28.1	29.0	29.0	29.0	29.0	29.0
90°	37.4	38.7	37.4	36.1	37.4	34.8	33.5	32.2	30.9	32.2	28.3
92.5°	68.3	70.9	69.6	74.7	77.3	86.3	99.2	127.6	179.1	239.7	265.4
95°	149.5	154.6	163.6	175.2	199.7	246.1	314.4	463.9	619.8	764.1	680.3
97.5°	306.7	320.8	351.8	400.7	487.0	633.9	804.0	1065.6	1215.0	1175.1	877.5
100°	807.9	806.6	856.8	950.9	1081.0	1264.0	1414.8	1519.1	1474.0	1220.2	824.6
102.5°	1279.5	1316.8	1356.8	1426.4	1520.4	1619.6	1691.8	1669.9	1486.9	1136.4	747.3
105°	1639.0	1645.4	1686.6	1735.6	1794.9	1828.4	1803.9	1675.0	1405.7	1035.9	686.8
107.5°	1873.5	1887.6	1904.4	1927.6	1935.3	1900.5	1800.0	1597.7	1289.8	947.0	643.0
110°	2007.5	2010.0	2012.6	2002.3	1966.2	1876.0	1713.7	1476.6	1181.5	873.6	619.8



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	2034.5	2033.2	2020.4	1983.0	1909.5	1787.1	1600.3	1356.8	1087.5	824.6	606.9
115°	1993.3	1986.9	1961.1	1904.4	1807.8	1667.3	1477.9	1253.7	1015.3	792.4	605.6
117.5°	1903.1	1894.1	1855.4	1792.3	1691.8	1546.2	1372.2	1173.8	967.7	770.5	606.9
120°	1784.6	1776.8	1745.9	1673.7	1572.0	1441.8	1287.2	1113.3	931.6	756.3	612.0
122.5°	1673.7	1663.4	1628.7	1565.5	1477.9	1359.4	1218.9	1065.6	901.9	747.3	621.1
125°	1572.0	1562.9	1530.7	1474.0	1391.6	1288.5	1164.8	1024.3	877.5	739.6	630.1
127.5°	1484.3	1476.6	1447.0	1398.0	1323.3	1227.9	1114.5	987.0	854.3	735.7	640.4
130°	1412.2	1401.9	1374.8	1328.4	1260.1	1172.5	1068.2	952.2	836.2	731.9	650.7
132.5°	1341.3	1334.9	1311.7	1265.3	1202.2	1119.7	1024.3	920.0	819.5	730.6	658.4
135°	1274.3	1265.3	1242.1	1203.4	1140.3	1066.9	983.1	891.6	805.3	729.3	666.1
137.5°	1203.4	1195.7	1176.4	1136.4	1082.3	1016.6	941.9	864.6	792.4	726.7	671.3
140°	1128.7	1130.0	1109.4	1073.3	1024.3	968.9	907.1	841.4	780.8	725.4	676.5
142.5°	1059.1	1060.4	1042.4	1011.5	971.5	925.1	873.6	819.5	770.5	722.8	680.3
145°	996.0	993.4	983.1	956.1	923.8	886.5	845.2	802.7	761.5	720.3	681.6
147.5°	941.9	940.6	930.3	911.0	885.2	858.1	823.3	788.6	752.5	716.4	681.6
150°	895.5	895.5	887.8	873.6	854.3	829.8	802.7	773.1	743.5	711.2	681.6
152.5°	856.8	856.8	853.0	840.1	825.9	806.6	783.4	758.9	733.2	704.8	677.7
155°	825.9	824.6	822.1	811.7	800.2	784.7	765.4	744.7	722.8	697.1	675.2
157.5°	796.3	796.3	793.7	786.0	775.7	762.8	747.3	729.3	711.2	690.6	671.3
160°	767.9	769.2	769.2	761.5	752.5	743.5	730.6	716.4	699.6	682.9	668.7
162.5°	742.2	743.5	743.5	737.0	731.9	724.1	712.5	700.9	688.1	675.2	663.6
165°	720.3	720.3	721.6	716.4	711.2	704.8	695.8	688.1	677.7	667.4	658.4
167.5°	698.4	698.4	699.6	695.8	693.2	688.1	682.9	676.5	667.4	659.7	653.3
170°	679.0	679.0	680.3	677.7	676.5	673.9	668.7	664.9	658.4	652.0	648.1
172.5°	661.0	662.3	664.9	662.3	662.3	661.0	657.1	654.6	649.4	645.5	644.2
175°	648.1	649.4	650.7	649.4	649.4	649.4	646.8	645.5	643.0	640.4	640.4
177.5°	639.1	639.1	641.7	640.4	641.7	641.7	640.4	639.1	637.8	636.5	637.8
180°	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3
2.5°	3929.0	3918.7	3881.2	3843.7	3801.1	3758.5	3727.0	3695.4	3648.6	3601.7	3563.3
5°	4257.9	4210.2	4130.9	4051.7	3944.3	3836.9	3764.5	3692.0	3594.9	3497.7	3420.2
7.5°	4518.7	4436.9	4326.1	4215.3	4074.7	3934.1	3801.1	3668.2	3519.9	3371.6	3250.6
10°	4684.9	4629.5	4501.7	4373.8	4185.5	3997.1	3811.3	3625.6	3434.6	3243.7	3083.5
12.5°	4701.1	4706.2	4588.6	4471.0	4257.9	4044.9	3819.0	3593.2	3352.8	3112.5	2925.8
15°	4558.8	4646.6	4581.8	4517.0	4302.3	4087.5	3809.6	3531.8	3254.8	2977.8	2762.2
17.5°	4294.6	4482.9	4492.3	4501.7	4286.9	4072.1	3764.5	3456.8	3143.2	2829.5	2602.8
20°	3934.1	4211.9	4307.4	4402.8	4228.1	4053.4	3722.7	3392.0	3040.9	2689.8	2452.0
22.5°	3565.9	3903.4	4078.1	4252.8	4123.3	3993.7	3641.7	3289.8	2919.0	2548.3	2307.1
25°	3146.6	3514.8	3783.2	4051.7	3972.4	3893.2	3546.3	3199.4	2804.8	2410.2	2163.9
27.5°	2781.0	3155.1	3479.0	3802.8	3785.8	3768.7	3424.4	3080.1	2676.1	2272.1	2034.4
30°	2455.4	2804.0	3166.2	3528.4	3570.2	3611.9	3279.5	2947.1	2542.3	2137.5	1908.2
32.5°	2167.3	2471.6	2860.2	3248.8	3330.7	3412.5	3112.5	2812.5	2411.9	2011.4	1790.6
35°	1931.2	2207.4	2596.0	2984.6	3086.9	3189.2	2928.4	2667.6	2277.3	1886.9	1676.4
37.5°	1722.4	1953.4	2332.7	2711.9	2837.2	2962.5	2729.0	2495.4	2129.8	1764.2	1570.7
40°	1549.4	1735.2	2083.8	2432.4	2577.3	2722.1	2529.5	2336.9	1990.0	1643.2	1465.0
42.5°	1404.5	1569.9	1886.1	2202.3	2341.2	2480.1	2317.3	2154.5	1846.0	1537.5	1374.7
45°	1281.0	1413.1	1700.3	1987.5	2119.6	2251.7	2111.9	1972.1	1700.3	1428.4	1276.7
47.5°	1165.1	1278.4	1523.9	1769.3	1886.9	2004.5	1895.4	1786.4	1556.2	1326.1	1188.9
50°	1061.1	1152.3	1367.0	1581.8	1684.1	1786.4	1690.0	1593.7	1404.5	1215.3	1096.0
52.5°	970.7	1044.9	1224.7	1404.5	1492.3	1580.1	1497.4	1414.8	1264.8	1114.8	1010.8
55°	881.2	944.3	1100.3	1256.2	1315.9	1375.6	1311.6	1247.7	1126.7	1005.7	917.9
57.5°	797.7	854.0	981.8	1109.7	1155.7	1201.7	1143.7	1085.8	994.6	903.4	830.1
60°	715.9	761.9	868.5	975.0	1003.1	1031.2	984.4	937.5	873.6	809.7	744.0
62.5°	640.1	681.8	761.1	840.3	859.1	877.8	842.0	806.2	757.7	709.1	658.0
65°	561.6	593.2	658.0	722.7	734.7	746.6	715.1	683.5	646.9	610.2	572.7
67.5°	489.2	511.4	564.2	617.0	617.9	618.7	593.2	567.6	547.2	526.7	496.9
70°	418.5	439.8	474.7	509.7	510.5	511.4	490.9	470.5	455.1	439.8	417.6
72.5°	346.0	361.4	387.8	414.2	412.5	410.8	398.0	385.2	373.3	361.4	345.2
75°	280.4	293.2	311.1	329.0	323.9	318.7	311.9	305.1	294.9	284.7	274.4
77.5°	220.7	228.4	238.6	248.9	245.5	242.0	236.1	230.1	222.4	214.8	210.5
80°	161.9	165.3	172.2	179.0	177.3	175.6	168.7	161.9	160.2	158.5	152.6
82.5°	109.9	114.2	115.9	117.6	116.8	115.9	110.8	105.7	104.0	102.3	101.4
85°	65.6	66.5	67.3	68.2	65.6	63.1	61.4	59.7	59.7	59.7	58.8
87.5°	29.8	30.7	30.7	30.7	29.8	29.0	27.3	25.6	26.4	27.3	27.3
90°	24.5	20.6	16.8	14.2	11.6	7.7	5.2	2.6	5.2	7.7	11.6
92.5°	198.4	130.1	88.9	65.7	52.8	41.2	28.3	19.3	28.3	41.2	52.8
95°	469.0	277.0	167.5	117.3	83.8	61.8	47.7	43.8	47.7	61.8	83.8
97.5°	521.8	298.9	190.7	135.3	101.8	82.5	70.9	69.6	70.9	82.5	101.8
100°	485.8	295.1	204.9	154.6	123.7	105.7	96.6	95.3	96.6	105.7	123.7
102.5°	454.8	300.2	221.6	176.5	149.5	132.7	125.0	122.4	125.0	132.7	149.5
105°	443.2	310.5	240.9	201.0	176.5	161.1	153.3	149.5	153.3	161.1	176.5
107.5°	440.7	327.3	265.4	228.1	204.9	189.4	181.7	177.8	181.7	189.4	204.9
110°	447.1	349.2	291.2	255.1	233.2	219.0	212.6	208.7	212.6	219.0	233.2





TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	460.0	371.1	318.3	283.5	261.6	247.4	240.9	237.1	240.9	247.4	261.6
115°	474.2	395.6	346.6	311.8	289.9	277.0	269.3	264.1	269.3	277.0	289.9
117.5°	492.2	421.3	372.4	340.2	315.7	304.1	297.6	291.2	297.6	304.1	315.7
120°	512.8	445.8	399.4	367.2	342.7	329.9	323.4	319.5	323.4	329.9	342.7
122.5°	532.1	471.6	426.5	391.7	368.5	354.3	347.9	344.0	347.9	354.3	368.5
125°	552.8	496.1	451.0	416.2	391.7	377.5	369.8	367.2	369.8	377.5	391.7
127.5°	569.5	518.0	474.2	439.4	412.3	398.1	389.1	385.3	389.1	398.1	412.3
130°	586.3	537.3	494.8	460.0	432.9	417.5	405.9	402.0	405.9	417.5	432.9
132.5°	601.7	554.1	512.8	479.3	452.3	432.9	420.0	414.9	420.0	432.9	452.3
135°	614.6	570.8	530.9	496.1	469.0	449.7	435.5	430.4	435.5	449.7	469.0
137.5°	624.9	582.4	543.7	511.5	484.5	463.9	449.7	444.5	449.7	463.9	484.5
140°	632.6	594.0	556.6	524.4	498.6	478.0	465.1	458.7	465.1	478.0	498.6
142.5°	640.4	603.0	566.9	537.3	511.5	493.5	479.3	474.2	479.3	493.5	511.5
145°	645.5	610.7	577.2	547.6	525.7	506.4	494.8	490.9	494.8	506.4	525.7
147.5°	649.4	617.2	586.3	560.5	538.6	521.8	510.2	507.7	510.2	521.8	538.6
150°	650.7	623.6	594.0	570.8	552.8	536.0	525.7	524.4	525.7	536.0	552.8
152.5°	653.3	627.5	603.0	581.1	565.6	551.5	541.2	541.2	541.2	551.5	565.6
155°	653.3	632.6	610.7	592.7	578.5	565.6	557.9	557.9	557.9	565.6	578.5
157.5°	654.6	635.2	617.2	603.0	590.1	578.5	572.1	570.8	572.1	578.5	590.1
160°	654.6	639.1	623.6	610.7	601.7	591.4	586.3	586.3	586.3	591.4	601.7
162.5°	653.3	640.4	627.5	617.2	609.5	601.7	597.9	597.9	597.9	601.7	609.5
165°	650.7	641.7	631.4	622.3	617.2	610.7	608.2	609.5	608.2	610.7	617.2
167.5°	649.4	641.7	633.9	627.5	623.6	618.5	617.2	618.5	617.2	618.5	623.6
170°	645.5	640.4	633.9	631.4	628.8	624.9	623.6	626.2	623.6	624.9	628.8
172.5°	644.2	640.4	635.2	633.9	632.6	630.1	630.1	631.4	630.1	630.1	632.6
175°	641.7	639.1	636.5	635.2	635.2	632.6	633.9	635.2	633.9	632.6	635.2
177.5°	640.4	637.8	636.5	636.5	636.5	635.2	636.5	637.8	636.5	635.2	636.5
180°	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3	3673.3
2.5°	3525.0	3491.7	3458.5	3432.9	3407.4	3363.9	3320.4	3310.2	3300.0	3285.5	3271.0
5°	3342.6	3260.8	3179.0	3105.7	3032.4	2975.3	2918.2	2880.7	2843.2	2815.9	2788.6
7.5°	3129.5	3006.8	2884.1	2797.1	2710.2	2627.5	2544.9	2518.5	2492.0	2456.2	2420.4
10°	2923.3	2787.8	2652.3	2538.9	2425.6	2344.6	2263.6	2231.2	2198.9	2153.7	2108.5
12.5°	2739.2	2590.9	2442.6	2328.4	2214.2	2135.8	2057.4	2010.5	1963.6	1938.1	1912.5
15°	2546.6	2388.1	2229.5	2123.9	2018.2	1947.4	1876.7	1835.8	1794.9	1770.2	1745.4
17.5°	2376.1	2219.3	2062.5	1961.1	1859.6	1794.9	1730.1	1694.3	1658.5	1639.8	1621.0
20°	2214.2	2060.8	1907.4	1808.5	1709.7	1656.8	1604.0	1581.0	1557.9	1542.6	1527.3
22.5°	2065.9	1915.0	1764.2	1679.8	1595.4	1552.8	1510.2	1494.0	1477.8	1465.0	1452.3
25°	1917.6	1782.9	1648.3	1576.7	1505.1	1470.2	1435.2	1419.0	1402.8	1390.0	1377.3
27.5°	1796.6	1667.9	1539.2	1477.8	1416.5	1389.2	1361.9	1349.1	1336.4	1324.4	1312.5
30°	1679.0	1563.9	1448.9	1396.0	1343.2	1318.5	1293.7	1281.0	1268.2	1257.1	1246.0
32.5°	1569.9	1471.0	1372.2	1323.6	1275.0	1254.5	1234.1	1218.7	1203.4	1194.9	1186.4
35°	1465.9	1377.3	1288.6	1248.6	1208.5	1188.1	1167.6	1154.8	1142.0	1135.2	1128.4
37.5°	1377.3	1298.0	1218.7	1180.4	1142.0	1122.4	1102.8	1091.8	1080.7	1078.1	1075.6
40°	1286.9	1218.7	1150.6	1113.1	1075.6	1058.5	1041.5	1034.7	1027.8	1026.1	1024.4
42.5°	1211.9	1145.4	1079.0	1044.9	1010.8	996.3	981.8	978.4	975.0	977.6	980.1
45°	1125.0	1069.6	1014.2	982.7	951.1	939.2	927.3	924.7	922.2	927.3	932.4
47.5°	1051.7	1000.6	949.4	919.6	889.8	881.2	872.7	871.9	871.0	877.8	884.7
50°	976.7	927.3	877.8	854.0	830.1	822.4	814.8	817.3	819.9	831.0	842.0
52.5°	906.8	860.8	814.8	792.6	770.5	765.3	760.2	766.2	772.2	784.1	796.0
55°	830.1	788.3	746.6	729.5	712.5	707.4	702.3	714.2	726.1	737.2	748.3
57.5°	756.8	720.2	683.5	668.2	652.8	652.0	651.1	662.2	673.3	685.2	697.2
60°	678.4	647.7	617.0	605.1	593.2	594.9	596.6	609.4	622.2	631.5	640.9
62.5°	606.8	581.2	555.7	544.6	533.5	537.8	542.0	554.8	567.6	578.7	589.8
65°	535.2	513.9	492.6	484.9	477.3	483.2	489.2	500.3	511.4	519.0	526.7
67.5°	467.0	449.1	431.2	425.3	419.3	425.3	431.2	442.3	453.4	461.1	468.7
70°	395.5	381.0	366.5	362.2	358.0	364.8	371.6	381.0	390.3	398.0	405.7
72.5°	329.0	317.9	306.8	306.0	305.1	311.1	317.0	326.4	335.8	340.9	346.0
75°	264.2	258.2	252.3	251.4	250.6	256.5	262.5	267.6	272.7	277.0	281.2
77.5°	206.2	201.1	196.0	196.9	197.7	202.0	206.2	211.4	216.5	219.0	221.6
80°	146.6	144.9	143.2	144.9	146.6	150.0	153.4	156.8	160.2	161.9	163.6
82.5°	100.6	98.9	97.2	99.7	102.3	104.8	107.4	109.9	112.5	113.4	114.2
85°	58.0	60.5	63.1	63.1	63.1	63.9	64.8	65.6	66.5	65.6	64.8
87.5°	27.3	28.1	29.0	29.0	29.0	29.8	30.7	30.7	30.7	29.8	29.0
90°	14.2	16.8	20.6	24.5	28.3	32.2	30.9	32.2	33.5	34.8	37.4
92.5°	65.7	88.9	130.1	198.4	265.4	239.7	179.1	127.6	99.2	86.3	77.3
95°	117.3	167.5	277.0	469.0	680.3	764.1	619.8	463.9	314.4	246.1	199.7
97.5°	135.3	190.7	298.9	521.8	877.5	1175.1	1215.0	1065.6	804.0	633.9	487.0
100°	154.6	204.9	295.1	485.8	824.6	1220.2	1474.0	1519.1	1414.8	1264.0	1081.0
102.5°	176.5	221.6	300.2	454.8	747.3	1136.4	1486.9	1669.9	1691.8	1619.6	1520.4
105°	201.0	240.9	310.5	443.2	686.8	1035.9	1405.7	1675.0	1803.9	1828.4	1794.9
107.5°	228.1	265.4	327.3	440.7	643.0	947.0	1289.8	1597.7	1800.0	1900.5	1935.3
110°	255.1	291.2	349.2	447.1	619.8	873.6	1181.5	1476.6	1713.7	1876.0	1966.2



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	283.5	318.3	371.1	460.0	606.9	824.6	1087.5	1356.8	1600.3	1787.1	1909.5
115°	311.8	346.6	395.6	474.2	605.6	792.4	1015.3	1253.7	1477.9	1667.3	1807.8
117.5°	340.2	372.4	421.3	492.2	606.9	770.5	967.7	1173.8	1372.2	1546.2	1691.8
120°	367.2	399.4	445.8	512.8	612.0	756.3	931.6	1113.3	1287.2	1441.8	1572.0
122.5°	391.7	426.5	471.6	532.1	621.1	747.3	901.9	1065.6	1218.9	1359.4	1477.9
125°	416.2	451.0	496.1	552.8	630.1	739.6	877.5	1024.3	1164.8	1288.5	1391.6
127.5°	439.4	474.2	518.0	569.5	640.4	735.7	854.3	987.0	1114.5	1227.9	1323.3
130°	460.0	494.8	537.3	586.3	650.7	731.9	836.2	952.2	1068.2	1172.5	1260.1
132.5°	479.3	512.8	554.1	601.7	658.4	730.6	819.5	920.0	1024.3	1119.7	1202.2
135°	496.1	530.9	570.8	614.6	666.1	729.3	805.3	891.6	983.1	1066.9	1140.3
137.5°	511.5	543.7	582.4	624.9	671.3	726.7	792.4	864.6	941.9	1016.6	1082.3
140°	524.4	556.6	594.0	632.6	676.5	725.4	780.8	841.4	907.1	968.9	1024.3
142.5°	537.3	566.9	603.0	640.4	680.3	722.8	770.5	819.5	873.6	925.1	971.5
145°	547.6	577.2	610.7	645.5	681.6	720.3	761.5	802.7	845.2	886.5	923.8
147.5°	560.5	586.3	617.2	649.4	681.6	716.4	752.5	788.6	823.3	858.1	885.2
150°	570.8	594.0	623.6	650.7	681.6	711.2	743.5	773.1	802.7	829.8	854.3
152.5°	581.1	603.0	627.5	653.3	677.7	704.8	733.2	758.9	783.4	806.6	825.9
155°	592.7	610.7	632.6	653.3	675.2	697.1	722.8	744.7	765.4	784.7	800.2
157.5°	603.0	617.2	635.2	654.6	671.3	690.6	711.2	729.3	747.3	762.8	775.7
160°	610.7	623.6	639.1	654.6	668.7	682.9	699.6	716.4	730.6	743.5	752.5
162.5°	617.2	627.5	640.4	653.3	663.6	675.2	688.1	700.9	712.5	724.1	731.9
165°	622.3	631.4	641.7	650.7	658.4	667.4	677.7	688.1	695.8	704.8	711.2
167.5°	627.5	633.9	641.7	649.4	653.3	659.7	667.4	676.5	682.9	688.1	693.2
170°	631.4	633.9	640.4	645.5	648.1	652.0	658.4	664.9	668.7	673.9	676.5
172.5°	633.9	635.2	640.4	644.2	644.2	645.5	649.4	654.6	657.1	661.0	662.3
175°	635.2	636.5	639.1	641.7	640.4	640.4	643.0	645.5	646.8	649.4	649.4
177.5°	636.5	636.5	637.8	640.4	637.8	636.5	637.8	639.1	640.4	641.7	641.7
180°	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5	636.5



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°
0°	3673.3	3673.3	3673.3	3673.3
2.5°	3265.0	3259.1	3235.2	3211.3
5°	2768.2	2747.7	2740.9	2734.1
7.5°	2418.7	2417.0	2381.2	2345.4
10°	2111.1	2113.6	2081.2	2048.9
12.5°	1891.2	1869.9	1867.3	1864.8
15°	1725.8	1706.2	1702.8	1699.4
17.5°	1609.1	1597.2	1593.7	1590.3
20°	1520.4	1513.6	1507.7	1501.7
22.5°	1443.7	1435.2	1430.1	1425.0
25°	1369.6	1361.9	1360.2	1358.5
27.5°	1303.1	1293.7	1293.7	1293.7
30°	1240.1	1234.1	1231.5	1229.0
32.5°	1181.2	1176.1	1176.1	1176.1
35°	1125.8	1123.3	1119.9	1116.5
37.5°	1075.6	1075.6	1073.9	1072.2
40°	1027.0	1029.5	1029.5	1029.5
42.5°	982.7	985.2	985.2	985.2
45°	936.6	940.9	942.6	944.3
47.5°	891.5	898.3	900.0	901.7
50°	847.2	852.3	853.1	854.0
52.5°	802.0	808.0	812.2	816.5
55°	754.3	760.2	762.8	765.3
57.5°	703.1	709.1	709.9	710.8
60°	646.9	652.8	654.5	656.2
62.5°	593.2	596.6	598.3	600.0
65°	531.8	536.9	540.3	543.7
67.5°	473.0	477.3	477.3	477.3
70°	407.4	409.1	411.6	414.2
72.5°	346.9	347.7	347.7	347.7
75°	283.0	284.7	285.5	286.4
77.5°	222.4	223.3	223.3	223.3
80°	162.8	161.9	161.9	161.9
82.5°	111.6	109.1	109.1	109.1
85°	63.9	63.1	63.9	64.8
87.5°	29.0	29.0	29.0	29.0
90°	36.1	37.4	38.7	37.4
92.5°	74.7	69.6	70.9	68.3
95°	175.2	163.6	154.6	149.5
97.5°	400.7	351.8	320.8	306.7
100°	950.9	856.8	806.6	807.9
102.5°	1426.4	1356.8	1316.8	1279.5
105°	1735.6	1686.6	1645.4	1639.0
107.5°	1927.6	1904.4	1887.6	1873.5
110°	2002.3	2012.6	2010.0	2007.5



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°
112.5°	1983.0	2020.4	2033.2	2034.5
115°	1904.4	1961.1	1986.9	1993.3
117.5°	1792.3	1855.4	1894.1	1903.1
120°	1673.7	1745.9	1776.8	1784.6
122.5°	1565.5	1628.7	1663.4	1673.7
125°	1474.0	1530.7	1562.9	1572.0
127.5°	1398.0	1447.0	1476.6	1484.3
130°	1328.4	1374.8	1401.9	1412.2
132.5°	1265.3	1311.7	1334.9	1341.3
135°	1203.4	1242.1	1265.3	1274.3
137.5°	1136.4	1176.4	1195.7	1203.4
140°	1073.3	1109.4	1130.0	1128.7
142.5°	1011.5	1042.4	1060.4	1059.1
145°	956.1	983.1	993.4	996.0
147.5°	911.0	930.3	940.6	941.9
150°	873.6	887.8	895.5	895.5
152.5°	840.1	853.0	856.8	856.8
155°	811.7	822.1	824.6	825.9
157.5°	786.0	793.7	796.3	796.3
160°	761.5	769.2	769.2	767.9
162.5°	737.0	743.5	743.5	742.2
165°	716.4	721.6	720.3	720.3
167.5°	695.8	699.6	698.4	698.4
170°	677.7	680.3	679.0	679.0
172.5°	662.3	664.9	662.3	661.0
175°	649.4	650.7	649.4	648.1
177.5°	640.4	641.7	639.1	639.1
180°	636.5	636.5	636.5	636.5



TEST NUMBER: P831218

CATALOG NUMBER: S123DIP-S1165D1195U850-4F0-1E-UDD-G4

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	16.82	17.69	17.74	18.62	19.82	19.06	19.93	19.98	20.86	22.06
	3H	18.47	19.25	19.40	20.19	21.41	20.48	21.26	21.41	22.20	23.42
	4H	19.05	19.78	19.99	20.73	21.96	20.93	21.67	21.88	22.61	23.85
	6H	19.42	20.09	20.37	21.05	22.29	21.21	21.89	22.17	22.84	24.08
	8H	19.51	20.16	20.48	21.13	22.37	21.27	21.92	22.24	22.88	24.13
	12H	19.56	20.17	20.53	21.13	22.40	21.29	21.90	22.26	22.87	24.13
4H	2H	17.40	18.13	18.35	19.08	20.31	19.22	19.96	20.17	20.90	22.13
	3H	19.23	19.84	20.19	20.81	22.06	20.84	21.45	21.80	22.43	23.67
	4H	19.92	20.48	20.89	21.45	22.72	21.43	21.98	22.39	22.95	24.22
	6H	20.40	20.88	21.38	21.87	23.14	21.83	22.31	22.81	23.31	24.57
	8H	20.54	20.99	21.52	21.97	23.26	21.94	22.39	22.93	23.38	24.66
	12H	20.60	21.01	21.61	22.01	23.30	21.99	22.39	22.99	23.40	24.68
8H	4H	20.19	20.64	21.17	21.63	22.91	21.53	21.98	22.52	22.97	24.25
	6H	20.78	21.15	21.79	22.18	23.46	22.03	22.40	23.04	23.43	24.71
	8H	20.99	21.31	22.01	22.33	23.63	22.21	22.54	23.23	23.56	24.86
	12H	21.11	21.40	22.13	22.41	23.75	22.32	22.60	23.34	23.61	24.96
12H	4H	20.19	20.60	21.19	21.60	22.89	21.51	21.91	22.51	22.92	24.20
	6H	20.83	21.16	21.85	22.17	23.47	22.05	22.38	23.07	23.39	24.69
	8H	21.07	21.35	22.09	22.36	23.71	22.25	22.54	23.27	23.55	24.89