

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P332890

Luminaire Tested: **S124RDIP-S350D1205U835-4F0-1E-UDD-A1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P332890
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-10,
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: NEO-RAY
Catalog Number: S124RDIP-S350D1205U835-4F0-1E-UDD-A1
Description: DEFINE 4 DIRECT-INDIRECT PENDANT LED LUMINAIRE
DOWNLIGHT 350 LUMENS PER FOOT, ASYMMETRIC DIFFUSER, REGRESSED HOUSING
UPLIGHT 1205 LUMENS PER FOOT, FLUSH SATIN WHITE DIFFUSER
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5657.1 lumens
Efficiency: N/A
Efficacy: 134.1 lumens/watt
Spacing Criteria (0/90/45): 1.28 / 1.23 / 1.39
Luminous Opening: Rectangular (W 4' x L: 0.33' x H: 0')
CIE Type: Semi-Indirect


Input Watts (W): 42.2
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

Luminous Intensity Polar Plot



— 0°-180° - - 45°-225° - - - 90°-270° - · - · 135°-315°



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	102	102	102	102	91	91	91	91	70	70	70	52	52	52	34	34	34	26
1	93	89	85	82	83	79	76	73	62	60	58	46	44	43	31	30	29	23
2	85	78	72	67	75	70	65	61	54	51	48	40	38	36	27	26	25	19
3	77	68	61	56	69	61	55	51	48	44	41	36	33	31	24	23	22	17
4	71	60	53	47	63	54	48	43	43	38	35	32	29	27	22	20	19	14
5	65	54	46	41	58	48	42	37	38	34	30	29	26	23	20	18	16	13
6	60	48	41	35	53	43	37	32	34	30	26	26	23	20	18	16	15	11
7	55	43	36	31	49	39	33	28	31	26	23	24	20	18	16	14	13	10
8	51	39	32	27	45	35	29	25	28	24	20	21	18	16	15	13	12	9
9	47	36	29	24	42	32	26	22	26	21	18	20	17	14	14	12	10	8
10	44	33	26	21	39	30	24	20	24	19	16	18	15	13	13	11	9	7

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	4742	4742	4742	4742
5°	5501	4756	4204	4756
10°	6507	4736	3752	4736
15°	7516	4692	3224	4692
20°	8369	4631	2916	4631
25°	8639	4572	2707	4572
30°	7563	4501	2581	4501
35°	5887	4394	2505	4394
40°	4415	4272	2464	4272
45°	3486	4077	2442	4077
50°	2943	3852	2372	3852
55°	2564	3605	2245	3605
60°	2307	3347	1988	3347
65°	2034	3070	1710	3070
70°	1832	2783	1541	2783
75°	1535	2464	1313	2464
80°	1297	2101	1232	2101
85°	1093	1649	1093	1649



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	56.9	1.0
10°-20°	171.7	3.0
20°-30°	268.5	4.7
30°-40°	298.5	5.3
40°-50°	264.9	4.7
50°-60°	206.4	3.6
60°-70°	135.1	2.4
70°-80°	66.4	1.2
80°-90°	20.9	0.4
90°-100°	99.1	1.8
100°-110°	293.5	5.2
110°-120°	498.2	8.8
120°-130°	656.9	11.6
130°-140°	737.7	13.0
140°-150°	724.9	12.8
150°-160°	609.7	10.8
160°-170°	405.7	7.2
170°-180°	142.1	2.5
0°-30°	497.1	8.8
0°-40°	795.6	14.1
0°-60°	1266.9	22.4
0°-90°	1489.3	26.3
90°-120°	890.8	15.7
90°-150°	3010.3	53.2
90°-180°	4168.0	73.7
0°-180°	5657.1	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	587	587	587	587	587	
5°	679	587	519	587	679	69
15°	899	561	386	561	899	256
25°	970	513	304	513	970	430
35°	597	446	254	446	597	374
45°	305	357	214	357	305	242
55°	182	256	160	256	182	166
65°	106	161	90	161	106	107
75°	49	79	42	79	49	54
85°	12	18	12	18	12	14
90°	35	4	35	4	35	18
95°	92	70	92	70	92	96
105°	284	271	284	271	284	299
115°	502	506	502	506	502	496
125°	732	738	732	738	732	653
135°	953	952	953	952	953	736
145°	1157	1156	1157	1156	1157	724
155°	1323	1324	1323	1324	1323	609
165°	1438	1442	1438	1442	1438	405
175°	1493	1500	1493	1500	1493	142
180°	1502	1502	1502	1502	1502	



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	619.6	621.3	619.6	619.4	617.5	616.9	616.2	613.7	609.2	606.5	607.1
5°	678.8	684.7	681.4	680.9	675.7	670.5	667.2	659.6	651.5	646.1	641.6
7.5°	747.2	750.6	748.5	745.2	736.8	732.0	724.3	714.4	699.9	688.9	678.8
10°	793.8	796.6	795.7	789.5	783.4	770.8	763.7	749.8	731.5	717.1	703.6
12.5°	839.6	842.6	834.3	834.6	822.9	813.0	801.8	784.2	763.2	744.6	727.7
15°	899.3	895.5	895.5	890.8	877.8	864.1	852.5	834.0	807.5	785.3	761.8
17.5°	946.1	947.4	945.5	934.3	924.1	909.9	888.6	867.1	842.5	812.6	788.7
20°	974.1	974.1	972.0	964.4	951.2	936.0	913.1	889.6	858.4	828.3	801.4
22.5°	985.5	986.2	983.7	977.5	965.6	950.8	931.2	907.4	875.2	841.4	808.0
25°	969.9	974.4	974.8	973.2	969.6	960.6	943.8	919.5	890.6	853.9	817.9
27.5°	890.4	896.1	901.1	909.3	920.2	925.8	926.6	914.2	889.0	853.7	817.5
30°	811.3	816.0	831.4	851.5	867.1	881.3	893.7	897.0	882.8	851.1	813.0
32.5°	723.4	729.9	745.3	766.9	792.9	817.0	844.6	858.7	858.3	839.3	804.1
35°	597.3	602.1	616.3	639.0	670.2	706.0	749.8	783.8	807.0	805.4	783.8
37.5°	481.8	487.1	501.4	520.3	550.6	594.8	637.2	684.2	727.0	751.1	743.9
40°	418.9	419.1	433.1	452.5	480.9	519.5	565.6	617.7	665.5	704.6	712.1
42.5°	369.3	369.3	378.6	399.5	419.9	456.2	500.3	552.0	608.0	653.1	673.1
45°	305.3	307.4	315.0	327.5	343.6	374.4	409.7	457.7	520.4	573.9	607.3
47.5°	258.5	261.7	266.5	276.7	289.5	310.0	339.2	382.4	433.4	492.2	539.7
50°	234.3	234.8	240.9	246.6	257.7	274.1	299.6	335.6	382.5	439.0	491.8
52.5°	213.5	213.4	217.1	224.3	233.3	246.0	266.7	299.4	341.0	391.7	446.2
55°	182.2	183.4	186.3	191.9	198.8	207.8	224.1	248.7	281.4	324.7	374.2
57.5°	158.5	159.1	161.3	163.7	170.0	176.6	188.8	205.9	233.4	268.9	315.0
60°	142.9	143.2	143.9	147.4	152.4	158.6	166.9	181.3	204.5	236.9	273.4
62.5°	127.8	128.2	129.3	131.9	135.8	140.0	148.7	160.3	179.5	207.2	240.0
65°	106.5	106.7	108.4	109.3	112.4	116.2	122.6	130.4	143.7	166.9	191.7
67.5°	89.0	89.0	89.1	90.4	92.5	95.0	98.8	105.1	115.1	129.3	151.2
70°	77.6	77.6	78.1	78.8	80.0	82.1	84.3	89.0	96.3	107.9	124.7
72.5°	67.0	67.2	67.7	67.8	68.4	70.2	71.8	74.8	80.2	89.0	102.6
75°	49.2	49.9	51.1	52.1	53.3	53.0	54.7	56.6	58.2	63.4	71.2
77.5°	36.6	36.3	36.4	37.2	37.3	37.6	38.8	40.2	41.5	43.9	46.7
80°	27.9	27.9	28.6	28.9	28.6	28.9	30.1	30.8	31.2	32.2	34.8
82.5°	21.1	21.5	21.3	21.5	21.6	21.9	22.9	23.0	23.5	23.9	24.9
85°	11.8	12.1	12.3	11.8	11.8	11.8	12.3	12.5	13.0	12.8	13.3
87.5°	11.1	10.8	10.9	10.8	10.9	10.5	10.4	10.5	9.8	9.7	9.2
90°	34.9	34.3	33.8	33.3	32.8	31.8	30.2	28.7	27.1	25.6	23.5
92.5°	51.6	51.3	51.0	50.7	50.3	49.7	48.8	47.9	46.9	46.0	44.6
95°	91.8	91.8	91.8	91.8	91.8	91.4	90.6	89.8	89.1	88.3	86.5
97.5°	143.8	143.8	143.8	143.8	143.8	143.4	142.4	141.5	140.6	139.6	137.5
100°	180.1	180.1	180.1	180.1	180.1	179.8	179.3	178.8	178.3	177.8	175.4
102.5°	221.0	220.8	220.6	220.4	220.1	219.7	219.0	218.2	217.5	216.8	214.7
105°	283.5	282.7	281.9	281.2	280.4	279.6	278.8	278.1	277.3	276.5	275.5
107.5°	344.4	344.4	344.5	344.5	344.6	344.2	343.5	342.8	342.1	341.3	341.2
110°	388.0	387.3	386.5	385.7	384.9	384.8	385.3	385.8	386.4	386.9	387.1



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	432.7	432.5	432.3	432.2	432.0	432.0	432.1	432.2	432.3	432.4	432.9
115°	501.9	502.2	502.4	502.7	502.9	503.2	503.4	503.7	504.0	504.2	504.7
117.5°	567.9	568.4	568.9	569.4	570.0	570.6	571.5	572.4	573.3	574.2	574.5
120°	618.1	617.6	617.0	616.5	616.0	616.4	617.7	619.0	620.3	621.6	622.3
122.5°	659.9	660.8	661.8	662.7	663.6	664.5	665.4	666.3	667.2	668.0	668.4
125°	731.9	732.4	733.0	733.5	734.0	734.5	735.0	735.5	736.1	736.6	736.8
127.5°	798.6	799.0	799.4	799.9	800.3	800.7	801.3	801.8	802.3	802.8	803.2
130°	842.3	843.3	844.4	845.4	846.4	847.2	847.7	848.2	848.8	849.3	849.3
132.5°	888.8	889.2	889.6	890.0	890.4	890.9	891.4	891.9	892.4	893.0	893.2
135°	952.7	953.4	954.2	955.0	955.8	956.4	956.9	957.5	958.0	958.5	958.5
137.5°	1019.8	1019.7	1019.5	1019.4	1019.2	1019.5	1020.1	1020.8	1021.5	1022.1	1021.7
140°	1060.7	1061.0	1061.2	1061.5	1061.8	1062.0	1062.3	1062.5	1062.8	1063.0	1063.0
142.5°	1101.6	1101.7	1101.7	1101.8	1101.8	1101.9	1101.9	1102.0	1102.0	1102.1	1102.3
145°	1157.2	1157.9	1158.7	1159.5	1160.2	1160.8	1161.0	1161.3	1161.5	1161.8	1161.5
147.5°	1213.4	1213.6	1213.9	1214.2	1214.4	1214.6	1214.9	1215.1	1215.3	1215.5	1215.7
150°	1247.8	1248.0	1248.3	1248.5	1248.8	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9
152.5°	1279.4	1280.0	1280.7	1281.4	1282.1	1282.1	1281.5	1280.8	1280.2	1279.6	1279.4
155°	1323.3	1324.3	1325.4	1326.4	1327.4	1327.4	1326.4	1325.4	1324.3	1323.3	1323.5
157.5°	1362.6	1363.4	1364.3	1365.2	1366.1	1366.1	1365.3	1364.6	1363.8	1363.0	1363.1
160°	1384.9	1386.2	1387.4	1388.7	1390.0	1390.3	1389.5	1388.7	1388.0	1387.2	1387.4
162.5°	1408.1	1409.4	1410.7	1412.0	1413.3	1413.2	1411.8	1410.4	1409.0	1407.6	1407.9
165°	1438.3	1439.3	1440.4	1441.4	1442.4	1442.2	1440.6	1439.1	1437.5	1436.0	1436.5
167.5°	1459.9	1461.5	1463.1	1464.7	1466.3	1466.3	1464.8	1463.2	1461.7	1460.1	1460.1
170°	1472.0	1473.8	1475.6	1477.4	1479.2	1479.4	1477.8	1476.3	1474.7	1473.2	1472.9
172.5°	1482.2	1484.0	1485.8	1487.6	1489.5	1489.5	1487.7	1486.0	1484.2	1482.5	1482.4
175°	1492.9	1494.7	1496.5	1498.3	1500.1	1500.1	1498.3	1496.5	1494.7	1492.9	1493.2
177.5°	1498.5	1500.1	1501.8	1503.4	1505.1	1505.2	1503.8	1502.3	1500.9	1499.4	1499.4
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	605.2	602.6	601.2	598.2	594.6	592.7	591.0	588.5	585.3	581.9	579.5
5°	635.9	630.2	623.1	614.6	607.1	599.7	593.3	586.9	579.6	572.0	564.5
7.5°	667.4	656.3	644.2	630.2	616.7	604.3	592.9	582.1	569.8	558.7	548.7
10°	689.4	674.3	657.5	639.7	622.0	606.6	591.4	577.7	562.6	549.1	537.7
12.5°	707.2	689.4	669.2	647.1	625.7	607.1	589.7	571.8	554.6	540.0	524.8
15°	736.7	712.4	685.2	658.6	631.0	605.6	582.2	561.4	541.7	521.1	506.7
17.5°	757.1	728.1	695.0	663.2	630.5	600.6	573.6	548.8	526.1	505.1	487.9
20°	769.2	737.2	700.5	664.3	627.6	595.7	566.6	539.1	515.7	493.0	475.2
22.5°	776.0	740.6	700.5	662.6	624.6	590.0	558.1	529.5	504.0	481.2	461.6
25°	778.2	740.3	699.4	655.8	614.2	577.5	544.3	513.3	484.9	462.2	441.4
27.5°	775.1	730.5	688.6	643.9	600.9	562.3	527.5	494.9	466.5	442.1	420.7
30°	770.6	722.8	677.8	631.4	587.9	550.7	514.0	482.8	453.2	427.9	406.4
32.5°	760.7	713.3	664.9	617.4	573.3	535.0	500.2	468.8	439.8	413.9	391.0
35°	741.2	693.2	640.7	591.9	548.6	508.8	476.2	445.9	418.2	390.5	366.4
37.5°	715.5	666.5	614.2	560.8	517.4	479.9	450.0	421.5	394.5	369.2	342.5
40°	691.3	646.6	592.6	539.6	495.1	458.9	431.2	405.4	378.2	353.1	326.4
42.5°	662.0	623.9	569.3	516.1	472.2	437.3	411.5	386.3	361.5	337.2	309.3
45°	613.0	584.1	533.0	481.9	437.6	403.0	379.4	357.1	335.4	312.2	285.9
47.5°	556.8	537.3	493.2	440.8	399.9	368.8	345.9	327.7	309.3	286.1	263.1
50°	517.8	505.3	462.7	414.9	375.8	347.2	323.8	306.7	291.3	269.1	248.5
52.5°	476.2	469.5	433.5	387.8	350.1	322.0	302.0	286.7	271.1	252.6	233.4
55°	412.7	416.3	385.8	346.2	310.7	287.1	268.9	256.1	242.8	227.2	212.3
57.5°	347.9	360.9	340.4	305.7	272.4	250.5	236.8	226.1	214.9	202.0	189.2
60°	309.1	320.0	308.4	277.8	248.7	228.4	215.6	207.3	196.2	184.4	174.7
62.5°	271.2	282.9	276.0	251.3	224.3	206.8	195.5	187.8	179.5	169.2	159.1
65°	223.7	231.2	227.9	210.9	191.7	176.8	166.4	160.7	153.1	145.6	136.6
67.5°	171.3	185.9	184.0	174.9	158.4	146.7	139.9	134.9	128.0	122.4	116.3
70°	140.8	154.3	154.1	146.7	137.7	126.9	122.1	117.9	111.7	106.3	101.3
72.5°	115.3	127.6	129.5	123.8	117.7	109.4	104.9	102.0	96.0	92.3	88.2
75°	80.7	89.7	92.1	92.1	89.2	85.0	80.9	79.0	74.8	71.5	69.1
77.5°	52.9	58.6	62.3	63.1	63.6	62.1	58.8	57.5	54.2	53.1	50.8
80°	37.4	41.2	45.4	46.9	48.0	47.6	46.2	45.2	42.1	40.9	40.0
82.5°	25.8	27.9	31.4	34.6	34.2	35.5	34.2	33.5	31.1	30.7	29.8
85°	13.5	13.7	14.2	16.3	17.5	18.0	18.2	17.8	17.0	17.0	15.4
87.5°	8.8	8.2	8.2	7.7	7.3	7.5	7.5	7.1	7.1	7.1	7.1
90°	21.4	19.4	17.3	14.8	12.0	9.2	6.3	3.5	6.3	9.2	12.0
92.5°	43.1	41.7	40.2	37.9	34.6	31.4	28.1	24.9	28.1	31.4	34.6
95°	84.7	82.9	81.1	79.0	76.7	74.4	72.0	69.7	72.0	74.4	76.7
97.5°	135.4	133.3	131.2	129.2	127.3	125.5	123.6	121.8	123.6	125.5	127.3
100°	173.1	170.8	168.5	166.8	165.7	164.7	163.7	162.7	163.7	164.7	165.7
102.5°	212.6	210.4	208.3	207.1	206.6	206.2	205.8	205.4	205.8	206.2	206.6
105°	274.4	273.4	272.4	271.7	271.5	271.2	271.0	270.7	271.0	271.2	271.5
107.5°	341.0	340.9	340.7	340.5	340.2	339.9	339.6	339.2	339.6	339.9	340.2
110°	387.4	387.7	387.9	387.8	387.3	386.7	386.2	385.7	386.2	386.7	387.3



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	433.4	433.8	434.3	434.5	434.4	434.3	434.2	434.0	434.2	434.3	434.4
115°	505.3	505.8	506.3	506.5	506.5	506.5	506.5	506.5	506.5	506.5	506.5
117.5°	574.9	575.2	575.6	575.7	575.5	575.3	575.1	574.9	575.1	575.3	575.5
120°	623.1	623.9	624.7	624.5	623.5	622.5	621.4	620.4	621.4	622.5	623.5
122.5°	668.8	669.1	669.5	669.5	669.0	668.6	668.2	667.8	668.2	668.6	669.0
125°	737.1	737.4	737.6	737.7	737.7	737.7	737.7	737.7	737.7	737.7	737.7
127.5°	803.6	804.0	804.5	804.3	803.5	802.7	802.0	801.2	802.0	802.7	803.5
130°	849.3	849.3	849.3	848.9	848.1	847.3	846.6	845.8	846.6	847.3	848.1
132.5°	893.4	893.6	893.8	893.6	893.0	892.5	891.9	891.3	891.9	892.5	893.0
135°	958.5	958.5	958.5	957.7	956.2	954.6	953.1	951.5	953.1	954.6	956.2
137.5°	1021.3	1020.9	1020.5	1019.9	1019.2	1018.5	1017.8	1017.0	1017.8	1018.5	1019.2
140°	1063.0	1063.0	1063.0	1062.8	1062.3	1061.8	1061.2	1060.7	1061.2	1061.8	1062.3
142.5°	1102.5	1102.7	1102.9	1102.8	1102.2	1101.7	1101.2	1100.7	1101.2	1101.7	1102.2
145°	1161.3	1161.0	1160.8	1160.1	1159.1	1158.1	1157.0	1156.0	1157.0	1158.1	1159.1
147.5°	1215.9	1216.1	1216.3	1215.8	1214.5	1213.3	1212.1	1210.8	1212.1	1213.3	1214.5
150°	1248.9	1248.9	1248.9	1248.4	1247.4	1246.4	1245.3	1244.3	1245.3	1246.4	1247.4
152.5°	1279.2	1279.0	1278.8	1278.4	1277.7	1277.1	1276.5	1275.9	1276.5	1277.1	1277.7
155°	1323.8	1324.1	1324.3	1324.4	1324.4	1324.4	1324.4	1324.4	1324.4	1324.4	1324.4
157.5°	1363.1	1363.2	1363.2	1363.5	1364.0	1364.4	1364.9	1365.3	1364.9	1364.4	1364.0
160°	1387.7	1388.0	1388.2	1388.5	1388.7	1389.0	1389.3	1389.5	1389.3	1389.0	1388.7
162.5°	1408.2	1408.4	1408.7	1409.1	1409.8	1410.5	1411.1	1411.8	1411.1	1410.5	1409.8
165°	1437.0	1437.5	1438.0	1438.7	1439.5	1440.2	1441.0	1441.8	1441.0	1440.2	1439.5
167.5°	1460.0	1460.0	1459.9	1460.5	1461.5	1462.6	1463.7	1464.8	1463.7	1462.6	1461.5
170°	1472.6	1472.4	1472.1	1472.6	1473.9	1475.2	1476.5	1477.8	1476.5	1475.2	1473.9
172.5°	1482.4	1482.3	1482.2	1482.8	1483.8	1484.9	1486.0	1487.1	1486.0	1484.9	1483.8
175°	1493.4	1493.7	1493.9	1494.7	1496.0	1497.3	1498.6	1499.9	1498.6	1497.3	1496.0
177.5°	1499.4	1499.4	1499.4	1499.9	1501.0	1502.0	1503.0	1504.1	1503.0	1502.0	1501.0
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	576.8	574.9	572.5	569.6	566.2	563.2	561.8	563.0	563.6	562.0	561.8
5°	559.2	553.3	548.6	541.5	535.8	531.1	527.8	526.3	526.8	523.0	522.1
7.5°	539.5	532.5	524.7	516.3	508.5	501.5	497.9	495.9	491.8	490.1	487.2
10°	526.8	517.4	509.8	499.8	490.8	482.6	478.5	475.2	471.2	469.3	465.3
12.5°	513.8	502.8	494.4	484.1	474.9	465.0	461.1	455.0	448.7	444.7	439.5
15°	495.3	482.1	471.9	459.6	448.7	437.4	427.2	415.8	411.6	402.6	397.4
17.5°	473.8	460.4	447.8	431.3	414.5	400.3	389.5	378.6	372.1	366.4	363.7
20°	459.6	447.3	429.8	410.6	391.9	376.3	367.5	360.4	353.3	349.3	346.5
22.5°	446.2	430.4	410.1	389.4	370.7	358.5	351.1	343.8	338.0	334.2	330.4
25°	423.6	403.0	381.5	357.8	345.1	334.4	326.4	320.4	316.9	311.9	310.0
27.5°	400.5	375.5	351.8	335.9	322.6	312.8	305.8	301.4	296.9	293.7	291.2
30°	382.7	357.4	336.1	320.9	307.4	299.4	293.7	288.5	284.9	282.3	280.5
32.5°	365.1	339.8	321.9	305.6	294.9	287.1	281.0	277.1	274.3	271.0	269.8
35°	339.6	317.1	301.5	286.8	276.0	268.9	264.1	260.1	257.7	256.8	256.1
37.5°	315.1	296.7	279.9	267.9	258.2	252.6	247.0	245.0	243.4	241.7	242.5
40°	299.6	282.3	267.4	254.7	246.8	240.7	237.4	235.0	233.6	233.6	233.6
42.5°	286.2	269.3	254.7	243.3	235.5	230.3	226.6	224.6	224.1	223.9	225.1
45°	265.3	249.7	235.0	225.5	218.9	213.7	211.6	209.9	209.9	210.9	211.1
47.5°	244.6	230.0	218.2	207.6	201.5	198.3	196.4	195.6	195.7	196.6	197.7
50°	231.9	217.5	205.9	196.4	190.8	187.7	186.0	185.5	186.0	186.0	187.7
52.5°	218.1	205.2	193.8	185.8	179.4	176.5	175.6	174.9	175.2	176.0	176.7
55°	197.9	186.3	175.4	167.8	163.1	161.2	159.0	159.3	158.8	159.3	159.3
57.5°	177.5	167.1	157.0	151.0	146.8	144.1	141.8	142.4	141.7	141.6	141.2
60°	164.5	153.1	145.1	139.6	134.9	132.5	130.4	130.9	130.2	129.7	128.7
62.5°	150.3	140.8	133.1	127.9	124.1	121.4	119.2	118.8	117.1	115.5	113.4
65°	129.7	121.9	115.0	110.1	106.5	104.4	102.7	101.3	97.7	94.0	92.1
67.5°	109.7	104.0	97.6	93.4	90.5	87.8	84.6	82.2	78.9	76.8	75.6
70°	96.8	91.4	85.9	81.9	78.8	76.2	72.7	71.0	68.6	67.7	66.5
72.5°	84.5	79.4	74.4	70.7	67.5	65.4	62.6	61.0	59.9	59.5	58.4
75°	65.8	61.8	58.0	54.7	52.1	50.6	49.5	48.3	47.8	45.7	44.5
77.5°	48.0	45.3	43.0	40.6	38.8	37.8	35.5	34.2	33.4	32.4	32.1
80°	37.4	35.5	33.1	31.7	29.1	28.2	27.2	27.0	26.7	26.5	26.3
82.5°	28.1	26.2	23.9	23.0	22.3	21.7	21.2	20.9	20.7	20.8	20.8
85°	14.2	13.3	13.3	13.0	12.8	12.5	12.3	12.3	12.1	12.3	12.1
87.5°	7.7	8.0	8.4	8.5	9.1	9.5	9.6	9.9	10.4	10.3	10.5
90°	14.8	17.3	19.4	21.4	23.5	25.6	27.1	28.7	30.2	31.8	32.8
92.5°	37.9	40.2	41.7	43.1	44.6	46.0	46.9	47.9	48.8	49.7	50.3
95°	79.0	81.1	82.9	84.7	86.5	88.3	89.1	89.8	90.6	91.4	91.8
97.5°	129.2	131.2	133.3	135.4	137.5	139.6	140.6	141.5	142.4	143.4	143.8
100°	166.8	168.5	170.8	173.1	175.4	177.8	178.3	178.8	179.3	179.8	180.1
102.5°	207.1	208.3	210.4	212.6	214.7	216.8	217.5	218.2	219.0	219.7	220.1
105°	271.7	272.4	273.4	274.4	275.5	276.5	277.3	278.1	278.8	279.6	280.4
107.5°	340.5	340.7	340.9	341.0	341.2	341.3	342.1	342.8	343.5	344.2	344.6
110°	387.8	387.9	387.7	387.4	387.1	386.9	386.4	385.8	385.3	384.8	384.9



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	434.5	434.3	433.8	433.4	432.9	432.4	432.3	432.2	432.1	432.0	432.0
115°	506.5	506.3	505.8	505.3	504.7	504.2	504.0	503.7	503.4	503.2	502.9
117.5°	575.7	575.6	575.2	574.9	574.5	574.2	573.3	572.4	571.5	570.6	570.0
120°	624.5	624.7	623.9	623.1	622.3	621.6	620.3	619.0	617.7	616.4	616.0
122.5°	669.5	669.5	669.1	668.8	668.4	668.0	667.2	666.3	665.4	664.5	663.6
125°	737.7	737.6	737.4	737.1	736.8	736.6	736.1	735.5	735.0	734.5	734.0
127.5°	804.3	804.5	804.0	803.6	803.2	802.8	802.3	801.8	801.3	800.7	800.3
130°	848.9	849.3	849.3	849.3	849.3	849.3	848.8	848.2	847.7	847.2	846.4
132.5°	893.6	893.8	893.6	893.4	893.2	893.0	892.4	891.9	891.4	890.9	890.4
135°	957.7	958.5	958.5	958.5	958.5	958.5	958.0	957.5	956.9	956.4	955.8
137.5°	1019.9	1020.5	1020.9	1021.3	1021.7	1022.1	1021.5	1020.8	1020.1	1019.5	1019.2
140°	1062.8	1063.0	1063.0	1063.0	1063.0	1063.0	1062.8	1062.5	1062.3	1062.0	1061.8
142.5°	1102.8	1102.9	1102.7	1102.5	1102.3	1102.1	1102.0	1102.0	1101.9	1101.9	1101.8
145°	1160.1	1160.8	1161.0	1161.3	1161.5	1161.8	1161.5	1161.3	1161.0	1160.8	1160.2
147.5°	1215.8	1216.3	1216.1	1215.9	1215.7	1215.5	1215.3	1215.1	1214.9	1214.6	1214.4
150°	1248.4	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.8
152.5°	1278.4	1278.8	1279.0	1279.2	1279.4	1279.6	1280.2	1280.8	1281.5	1282.1	1282.1
155°	1324.4	1324.3	1324.1	1323.8	1323.5	1323.3	1324.3	1325.4	1326.4	1327.4	1327.4
157.5°	1363.5	1363.2	1363.2	1363.1	1363.1	1363.0	1363.8	1364.6	1365.3	1366.1	1366.1
160°	1388.5	1388.2	1388.0	1387.7	1387.4	1387.2	1388.0	1388.7	1389.5	1390.3	1390.0
162.5°	1409.1	1408.7	1408.4	1408.2	1407.9	1407.6	1409.0	1410.4	1411.8	1413.2	1413.3
165°	1438.7	1438.0	1437.5	1437.0	1436.5	1436.0	1437.5	1439.1	1440.6	1442.2	1442.4
167.5°	1460.5	1459.9	1460.0	1460.0	1460.1	1460.1	1461.7	1463.2	1464.8	1466.3	1466.3
170°	1472.6	1472.1	1472.4	1472.6	1472.9	1473.2	1474.7	1476.3	1477.8	1479.4	1479.2
172.5°	1482.8	1482.2	1482.3	1482.4	1482.4	1482.5	1484.2	1486.0	1487.7	1489.5	1489.5
175°	1494.7	1493.9	1493.7	1493.4	1493.2	1492.9	1494.7	1496.5	1498.3	1500.1	1500.1
177.5°	1499.9	1499.4	1499.4	1499.4	1499.4	1499.4	1500.9	1502.3	1503.8	1505.2	1505.1
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	560.7	561.1	559.8	559.4	559.8	561.1	560.7	561.8	562.0	563.6	563.0
5°	520.2	519.7	518.5	518.8	518.5	519.7	520.2	522.1	523.0	526.8	526.3
7.5°	485.5	483.7	484.2	482.3	484.2	483.7	485.5	487.2	490.1	491.8	495.9
10°	464.3	461.7	459.6	457.7	459.6	461.7	464.3	465.3	469.3	471.2	475.2
12.5°	435.4	433.1	430.3	430.8	430.3	433.1	435.4	439.5	444.7	448.7	455.0
15°	394.3	390.7	385.1	385.8	385.1	390.7	394.3	397.4	402.6	411.6	415.8
17.5°	359.5	359.5	356.9	357.6	356.9	359.5	359.5	363.7	366.4	372.1	378.6
20°	341.5	339.9	340.1	339.4	340.1	339.9	341.5	346.5	349.3	353.3	360.4
22.5°	329.0	327.0	325.3	323.9	325.3	327.0	329.0	330.4	334.2	338.0	343.8
25°	307.9	306.5	304.4	303.9	304.4	306.5	307.9	310.0	311.9	316.9	320.4
27.5°	289.3	289.1	288.2	287.1	288.2	289.1	289.3	291.2	293.7	296.9	301.4
30°	278.6	278.1	277.6	276.9	277.6	278.1	278.6	280.5	282.3	284.9	288.5
32.5°	268.9	268.6	268.1	268.2	268.1	268.6	268.9	269.8	271.0	274.3	277.1
35°	255.1	254.9	254.4	254.2	254.4	254.9	255.1	256.1	256.8	257.7	260.1
37.5°	242.3	242.9	242.6	242.5	242.6	242.9	242.3	242.5	241.7	243.4	245.0
40°	233.4	233.6	234.1	233.8	234.1	233.6	233.4	233.6	233.6	233.6	235.0
42.5°	226.0	226.0	226.7	225.9	226.7	226.0	226.0	225.1	223.9	224.1	224.6
45°	212.8	214.2	213.9	213.9	213.9	214.2	212.8	211.1	210.9	209.9	209.9
47.5°	198.3	199.6	199.9	199.8	199.9	199.6	198.3	197.7	196.6	195.7	195.6
50°	188.9	188.4	189.1	188.9	189.1	188.4	188.9	187.7	186.0	186.0	185.5
52.5°	177.3	177.4	177.4	177.1	177.4	177.4	177.3	176.7	176.0	175.2	174.9
55°	159.5	159.8	159.3	159.5	159.3	159.8	159.5	159.3	159.3	158.8	159.3
57.5°	140.2	139.1	139.5	139.0	139.5	139.1	140.2	141.2	141.6	141.7	142.4
60°	126.4	124.5	124.0	123.1	124.0	124.5	126.4	128.7	129.7	130.2	130.9
62.5°	110.9	109.5	107.9	108.7	107.9	109.5	110.9	113.4	115.5	117.1	118.8
65°	90.2	89.2	88.5	89.5	88.5	89.2	90.2	92.1	94.0	97.7	101.3
67.5°	74.6	74.1	74.1	73.7	74.1	74.1	74.6	75.6	76.8	78.9	82.2
70°	66.5	65.8	65.8	65.3	65.8	65.8	66.5	66.5	67.7	68.6	71.0
72.5°	58.2	57.5	57.7	57.4	57.7	57.5	58.2	58.4	59.5	59.9	61.0
75°	43.1	41.9	41.9	42.1	41.9	41.9	43.1	44.5	45.7	47.8	48.3
77.5°	32.1	31.9	32.2	31.8	32.2	31.9	32.1	32.1	32.4	33.4	34.2
80°	26.3	26.0	25.8	26.5	25.8	26.0	26.3	26.3	26.5	26.7	27.0
82.5°	20.4	20.4	20.3	21.2	20.3	20.4	20.4	20.8	20.8	20.7	20.9
85°	12.3	11.8	12.3	11.8	12.3	11.8	12.3	12.1	12.3	12.1	12.3
87.5°	11.0	10.9	10.8	11.1	10.8	10.9	11.0	10.5	10.3	10.4	9.9
90°	33.3	33.8	34.3	34.9	34.3	33.8	33.3	32.8	31.8	30.2	28.7
92.5°	50.7	51.0	51.3	51.6	51.3	51.0	50.7	50.3	49.7	48.8	47.9
95°	91.8	91.8	91.8	91.8	91.8	91.8	91.8	91.8	91.4	90.6	89.8
97.5°	143.8	143.8	143.8	143.8	143.8	143.8	143.8	143.8	143.4	142.4	141.5
100°	180.1	180.1	180.1	180.1	180.1	180.1	180.1	180.1	179.8	179.3	178.8
102.5°	220.4	220.6	220.8	221.0	220.8	220.6	220.4	220.1	219.7	219.0	218.2
105°	281.2	281.9	282.7	283.5	282.7	281.9	281.2	280.4	279.6	278.8	278.1
107.5°	344.5	344.5	344.4	344.4	344.4	344.5	344.5	344.6	344.2	343.5	342.8
110°	385.7	386.5	387.3	388.0	387.3	386.5	385.7	384.9	384.8	385.3	385.8



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	432.2	432.3	432.5	432.7	432.5	432.3	432.2	432.0	432.0	432.1	432.2
115°	502.7	502.4	502.2	501.9	502.2	502.4	502.7	502.9	503.2	503.4	503.7
117.5°	569.4	568.9	568.4	567.9	568.4	568.9	569.4	570.0	570.6	571.5	572.4
120°	616.5	617.0	617.6	618.1	617.6	617.0	616.5	616.0	616.4	617.7	619.0
122.5°	662.7	661.8	660.8	659.9	660.8	661.8	662.7	663.6	664.5	665.4	666.3
125°	733.5	733.0	732.4	731.9	732.4	733.0	733.5	734.0	734.5	735.0	735.5
127.5°	799.9	799.4	799.0	798.6	799.0	799.4	799.9	800.3	800.7	801.3	801.8
130°	845.4	844.4	843.3	842.3	843.3	844.4	845.4	846.4	847.2	847.7	848.2
132.5°	890.0	889.6	889.2	888.8	889.2	889.6	890.0	890.4	890.9	891.4	891.9
135°	955.0	954.2	953.4	952.7	953.4	954.2	955.0	955.8	956.4	956.9	957.5
137.5°	1019.4	1019.5	1019.7	1019.8	1019.7	1019.5	1019.4	1019.2	1019.5	1020.1	1020.8
140°	1061.5	1061.2	1061.0	1060.7	1061.0	1061.2	1061.5	1061.8	1062.0	1062.3	1062.5
142.5°	1101.8	1101.7	1101.7	1101.6	1101.7	1101.7	1101.8	1101.8	1101.9	1101.9	1102.0
145°	1159.5	1158.7	1157.9	1157.2	1157.9	1158.7	1159.5	1160.2	1160.8	1161.0	1161.3
147.5°	1214.2	1213.9	1213.6	1213.4	1213.6	1213.9	1214.2	1214.4	1214.6	1214.9	1215.1
150°	1248.5	1248.3	1248.0	1247.8	1248.0	1248.3	1248.5	1248.8	1248.9	1248.9	1248.9
152.5°	1281.4	1280.7	1280.0	1279.4	1280.0	1280.7	1281.4	1282.1	1282.1	1281.5	1280.8
155°	1326.4	1325.4	1324.3	1323.3	1324.3	1325.4	1326.4	1327.4	1327.4	1326.4	1325.4
157.5°	1365.2	1364.3	1363.4	1362.6	1363.4	1364.3	1365.2	1366.1	1366.1	1365.3	1364.6
160°	1388.7	1387.4	1386.2	1384.9	1386.2	1387.4	1388.7	1390.0	1390.3	1389.5	1388.7
162.5°	1412.0	1410.7	1409.4	1408.1	1409.4	1410.7	1412.0	1413.3	1413.2	1411.8	1410.4
165°	1441.4	1440.4	1439.3	1438.3	1439.3	1440.4	1441.4	1442.4	1442.2	1440.6	1439.1
167.5°	1464.7	1463.1	1461.5	1459.9	1461.5	1463.1	1464.7	1466.3	1466.3	1464.8	1463.2
170°	1477.4	1475.6	1473.8	1472.0	1473.8	1475.6	1477.4	1479.2	1479.4	1477.8	1476.3
172.5°	1487.6	1485.8	1484.0	1482.2	1484.0	1485.8	1487.6	1489.5	1489.5	1487.7	1486.0
175°	1498.3	1496.5	1494.7	1492.9	1494.7	1496.5	1498.3	1500.1	1500.1	1498.3	1496.5
177.5°	1503.4	1501.8	1500.1	1498.5	1500.1	1501.8	1503.4	1505.1	1505.2	1503.8	1502.3
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	561.8	563.2	566.2	569.6	572.5	574.9	576.8	579.5	581.9	585.3	588.5
5°	527.8	531.1	535.8	541.5	548.6	553.3	559.2	564.5	572.0	579.6	586.9
7.5°	497.9	501.5	508.5	516.3	524.7	532.5	539.5	548.7	558.7	569.8	582.1
10°	478.5	482.6	490.8	499.8	509.8	517.4	526.8	537.7	549.1	562.6	577.7
12.5°	461.1	465.0	474.9	484.1	494.4	502.8	513.8	524.8	540.0	554.6	571.8
15°	427.2	437.4	448.7	459.6	471.9	482.1	495.3	506.7	521.1	541.7	561.4
17.5°	389.5	400.3	414.5	431.3	447.8	460.4	473.8	487.9	505.1	526.1	548.8
20°	367.5	376.3	391.9	410.6	429.8	447.3	459.6	475.2	493.0	515.7	539.1
22.5°	351.1	358.5	370.7	389.4	410.1	430.4	446.2	461.6	481.2	504.0	529.5
25°	326.4	334.4	345.1	357.8	381.5	403.0	423.6	441.4	462.2	484.9	513.3
27.5°	305.8	312.8	322.6	335.9	351.8	375.5	400.5	420.7	442.1	466.5	494.9
30°	293.7	299.4	307.4	320.9	336.1	357.4	382.7	406.4	427.9	453.2	482.8
32.5°	281.0	287.1	294.9	305.6	321.9	339.8	365.1	391.0	413.9	439.8	468.8
35°	264.1	268.9	276.0	286.8	301.5	317.1	339.6	366.4	390.5	418.2	445.9
37.5°	247.0	252.6	258.2	267.9	279.9	296.7	315.1	342.5	369.2	394.5	421.5
40°	237.4	240.7	246.8	254.7	267.4	282.3	299.6	326.4	353.1	378.2	405.4
42.5°	226.6	230.3	235.5	243.3	254.7	269.3	286.2	309.3	337.2	361.5	386.3
45°	211.6	213.7	218.9	225.5	235.0	249.7	265.3	285.9	312.2	335.4	357.1
47.5°	196.4	198.3	201.5	207.6	218.2	230.0	244.6	263.1	286.1	309.3	327.7
50°	186.0	187.7	190.8	196.4	205.9	217.5	231.9	248.5	269.1	291.3	306.7
52.5°	175.6	176.5	179.4	185.8	193.8	205.2	218.1	233.4	252.6	271.1	286.7
55°	159.0	161.2	163.1	167.8	175.4	186.3	197.9	212.3	227.2	242.8	256.1
57.5°	141.8	144.1	146.8	151.0	157.0	167.1	177.5	189.2	202.0	214.9	226.1
60°	130.4	132.5	134.9	139.6	145.1	153.1	164.5	174.7	184.4	196.2	207.3
62.5°	119.2	121.4	124.1	127.9	133.1	140.8	150.3	159.1	169.2	179.5	187.8
65°	102.7	104.4	106.5	110.1	115.0	121.9	129.7	136.6	145.6	153.1	160.7
67.5°	84.6	87.8	90.5	93.4	97.6	104.0	109.7	116.3	122.4	128.0	134.9
70°	72.7	76.2	78.8	81.9	85.9	91.4	96.8	101.3	106.3	111.7	117.9
72.5°	62.6	65.4	67.5	70.7	74.4	79.4	84.5	88.2	92.3	96.0	102.0
75°	49.5	50.6	52.1	54.7	58.0	61.8	65.8	69.1	71.5	74.8	79.0
77.5°	35.5	37.8	38.8	40.6	43.0	45.3	48.0	50.8	53.1	54.2	57.5
80°	27.2	28.2	29.1	31.7	33.1	35.5	37.4	40.0	40.9	42.1	45.2
82.5°	21.2	21.7	22.3	23.0	23.9	26.2	28.1	29.8	30.7	31.1	33.5
85°	12.3	12.5	12.8	13.0	13.3	13.3	14.2	15.4	17.0	17.0	17.8
87.5°	9.6	9.5	9.1	8.5	8.4	8.0	7.7	7.1	7.1	7.1	7.1
90°	27.1	25.6	23.5	21.4	19.4	17.3	14.8	12.0	9.2	6.3	3.5
92.5°	46.9	46.0	44.6	43.1	41.7	40.2	37.9	34.6	31.4	28.1	24.9
95°	89.1	88.3	86.5	84.7	82.9	81.1	79.0	76.7	74.4	72.0	69.7
97.5°	140.6	139.6	137.5	135.4	133.3	131.2	129.2	127.3	125.5	123.6	121.8
100°	178.3	177.8	175.4	173.1	170.8	168.5	166.8	165.7	164.7	163.7	162.7
102.5°	217.5	216.8	214.7	212.6	210.4	208.3	207.1	206.6	206.2	205.8	205.4
105°	277.3	276.5	275.5	274.4	273.4	272.4	271.7	271.5	271.2	271.0	270.7
107.5°	342.1	341.3	341.2	341.0	340.9	340.7	340.5	340.2	339.9	339.6	339.2
110°	386.4	386.9	387.1	387.4	387.7	387.9	387.8	387.3	386.7	386.2	385.7



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	432.3	432.4	432.9	433.4	433.8	434.3	434.5	434.4	434.3	434.2	434.0
115°	504.0	504.2	504.7	505.3	505.8	506.3	506.5	506.5	506.5	506.5	506.5
117.5°	573.3	574.2	574.5	574.9	575.2	575.6	575.7	575.5	575.3	575.1	574.9
120°	620.3	621.6	622.3	623.1	623.9	624.7	624.5	623.5	622.5	621.4	620.4
122.5°	667.2	668.0	668.4	668.8	669.1	669.5	669.5	669.0	668.6	668.2	667.8
125°	736.1	736.6	736.8	737.1	737.4	737.6	737.7	737.7	737.7	737.7	737.7
127.5°	802.3	802.8	803.2	803.6	804.0	804.5	804.3	803.5	802.7	802.0	801.2
130°	848.8	849.3	849.3	849.3	849.3	849.3	848.9	848.1	847.3	846.6	845.8
132.5°	892.4	893.0	893.2	893.4	893.6	893.8	893.6	893.0	892.5	891.9	891.3
135°	958.0	958.5	958.5	958.5	958.5	958.5	957.7	956.2	954.6	953.1	951.5
137.5°	1021.5	1022.1	1021.7	1021.3	1020.9	1020.5	1019.9	1019.2	1018.5	1017.8	1017.0
140°	1062.8	1063.0	1063.0	1063.0	1063.0	1063.0	1062.8	1062.3	1061.8	1061.2	1060.7
142.5°	1102.0	1102.1	1102.3	1102.5	1102.7	1102.9	1102.8	1102.2	1101.7	1101.2	1100.7
145°	1161.5	1161.8	1161.5	1161.3	1161.0	1160.8	1160.1	1159.1	1158.1	1157.0	1156.0
147.5°	1215.3	1215.5	1215.7	1215.9	1216.1	1216.3	1215.8	1214.5	1213.3	1212.1	1210.8
150°	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.4	1247.4	1246.4	1245.3	1244.3
152.5°	1280.2	1279.6	1279.4	1279.2	1279.0	1278.8	1278.4	1277.7	1277.1	1276.5	1275.9
155°	1324.3	1323.3	1323.5	1323.8	1324.1	1324.3	1324.4	1324.4	1324.4	1324.4	1324.4
157.5°	1363.8	1363.0	1363.1	1363.1	1363.2	1363.2	1363.5	1364.0	1364.4	1364.9	1365.3
160°	1388.0	1387.2	1387.4	1387.7	1388.0	1388.2	1388.5	1388.7	1389.0	1389.3	1389.5
162.5°	1409.0	1407.6	1407.9	1408.2	1408.4	1408.7	1409.1	1409.8	1410.5	1411.1	1411.8
165°	1437.5	1436.0	1436.5	1437.0	1437.5	1438.0	1438.7	1439.5	1440.2	1441.0	1441.8
167.5°	1461.7	1460.1	1460.1	1460.0	1460.0	1459.9	1460.5	1461.5	1462.6	1463.7	1464.8
170°	1474.7	1473.2	1472.9	1472.6	1472.4	1472.1	1472.6	1473.9	1475.2	1476.5	1477.8
172.5°	1484.2	1482.5	1482.4	1482.4	1482.3	1482.2	1482.8	1483.8	1484.9	1486.0	1487.1
175°	1494.7	1492.9	1493.2	1493.4	1493.7	1493.9	1494.7	1496.0	1497.3	1498.6	1499.9
177.5°	1500.9	1499.4	1499.4	1499.4	1499.4	1499.4	1499.9	1501.0	1502.0	1503.0	1504.1
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	591.0	592.7	594.6	598.2	601.2	602.6	605.2	607.1	606.5	609.2	613.7
5°	593.3	599.7	607.1	614.6	623.1	630.2	635.9	641.6	646.1	651.5	659.6
7.5°	592.9	604.3	616.7	630.2	644.2	656.3	667.4	678.8	688.9	699.9	714.4
10°	591.4	606.6	622.0	639.7	657.5	674.3	689.4	703.6	717.1	731.5	749.8
12.5°	589.7	607.1	625.7	647.1	669.2	689.4	707.2	727.7	744.6	763.2	784.2
15°	582.2	605.6	631.0	658.6	685.2	712.4	736.7	761.8	785.3	807.5	834.0
17.5°	573.6	600.6	630.5	663.2	695.0	728.1	757.1	788.7	812.6	842.5	867.1
20°	566.6	595.7	627.6	664.3	700.5	737.2	769.2	801.4	828.3	858.4	889.6
22.5°	558.1	590.0	624.6	662.6	700.5	740.6	776.0	808.0	841.4	875.2	907.4
25°	544.3	577.5	614.2	655.8	699.4	740.3	778.2	817.9	853.9	890.6	919.5
27.5°	527.5	562.3	600.9	643.9	688.6	730.5	775.1	817.5	853.7	889.0	914.2
30°	514.0	550.7	587.9	631.4	677.8	722.8	770.6	813.0	851.1	882.8	897.0
32.5°	500.2	535.0	573.3	617.4	664.9	713.3	760.7	804.1	839.3	858.3	858.7
35°	476.2	508.8	548.6	591.9	640.7	693.2	741.2	783.8	805.4	807.0	783.8
37.5°	450.0	479.9	517.4	560.8	614.2	666.5	715.5	743.9	751.1	727.0	684.2
40°	431.2	458.9	495.1	539.6	592.6	646.6	691.3	712.1	704.6	665.5	617.7
42.5°	411.5	437.3	472.2	516.1	569.3	623.9	662.0	673.1	653.1	608.0	552.0
45°	379.4	403.0	437.6	481.9	533.0	584.1	613.0	607.3	573.9	520.4	457.7
47.5°	345.9	368.8	399.9	440.8	493.2	537.3	556.8	539.7	492.2	433.4	382.4
50°	323.8	347.2	375.8	414.9	462.7	505.3	517.8	491.8	439.0	382.5	335.6
52.5°	302.0	322.0	350.1	387.8	433.5	469.5	476.2	446.2	391.7	341.0	299.4
55°	268.9	287.1	310.7	346.2	385.8	416.3	412.7	374.2	324.7	281.4	248.7
57.5°	236.8	250.5	272.4	305.7	340.4	360.9	347.9	315.0	268.9	233.4	205.9
60°	215.6	228.4	248.7	277.8	308.4	320.0	309.1	273.4	236.9	204.5	181.3
62.5°	195.5	206.8	224.3	251.3	276.0	282.9	271.2	240.0	207.2	179.5	160.3
65°	166.4	176.8	191.7	210.9	227.9	231.2	223.7	191.7	166.9	143.7	130.4
67.5°	139.9	146.7	158.4	174.9	184.0	185.9	171.3	151.2	129.3	115.1	105.1
70°	122.1	126.9	137.7	146.7	154.1	154.3	140.8	124.7	107.9	96.3	89.0
72.5°	104.9	109.4	117.7	123.8	129.5	127.6	115.3	102.6	89.0	80.2	74.8
75°	80.9	85.0	89.2	92.1	92.1	89.7	80.7	71.2	63.4	58.2	56.6
77.5°	58.8	62.1	63.6	63.1	62.3	58.6	52.9	46.7	43.9	41.5	40.2
80°	46.2	47.6	48.0	46.9	45.4	41.2	37.4	34.8	32.2	31.2	30.8
82.5°	34.2	35.5	34.2	34.6	31.4	27.9	25.8	24.9	23.9	23.5	23.0
85°	18.2	18.0	17.5	16.3	14.2	13.7	13.5	13.3	12.8	13.0	12.5
87.5°	7.5	7.5	7.3	7.7	8.2	8.2	8.8	9.2	9.7	9.8	10.5
90°	6.3	9.2	12.0	14.8	17.3	19.4	21.4	23.5	25.6	27.1	28.7
92.5°	28.1	31.4	34.6	37.9	40.2	41.7	43.1	44.6	46.0	46.9	47.9
95°	72.0	74.4	76.7	79.0	81.1	82.9	84.7	86.5	88.3	89.1	89.8
97.5°	123.6	125.5	127.3	129.2	131.2	133.3	135.4	137.5	139.6	140.6	141.5
100°	163.7	164.7	165.7	166.8	168.5	170.8	173.1	175.4	177.8	178.3	178.8
102.5°	205.8	206.2	206.6	207.1	208.3	210.4	212.6	214.7	216.8	217.5	218.2
105°	271.0	271.2	271.5	271.7	272.4	273.4	274.4	275.5	276.5	277.3	278.1
107.5°	339.6	339.9	340.2	340.5	340.7	340.9	341.0	341.2	341.3	342.1	342.8
110°	386.2	386.7	387.3	387.8	387.9	387.7	387.4	387.1	386.9	386.4	385.8



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	434.2	434.3	434.4	434.5	434.3	433.8	433.4	432.9	432.4	432.3	432.2
115°	506.5	506.5	506.5	506.5	506.3	505.8	505.3	504.7	504.2	504.0	503.7
117.5°	575.1	575.3	575.5	575.7	575.6	575.2	574.9	574.5	574.2	573.3	572.4
120°	621.4	622.5	623.5	624.5	624.7	623.9	623.1	622.3	621.6	620.3	619.0
122.5°	668.2	668.6	669.0	669.5	669.5	669.1	668.8	668.4	668.0	667.2	666.3
125°	737.7	737.7	737.7	737.7	737.6	737.4	737.1	736.8	736.6	736.1	735.5
127.5°	802.0	802.7	803.5	804.3	804.5	804.0	803.6	803.2	802.8	802.3	801.8
130°	846.6	847.3	848.1	848.9	849.3	849.3	849.3	849.3	849.3	848.8	848.2
132.5°	891.9	892.5	893.0	893.6	893.8	893.6	893.4	893.2	893.0	892.4	891.9
135°	953.1	954.6	956.2	957.7	958.5	958.5	958.5	958.5	958.5	958.0	957.5
137.5°	1017.8	1018.5	1019.2	1019.9	1020.5	1020.9	1021.3	1021.7	1022.1	1021.5	1020.8
140°	1061.2	1061.8	1062.3	1062.8	1063.0	1063.0	1063.0	1063.0	1063.0	1062.8	1062.5
142.5°	1101.2	1101.7	1102.2	1102.8	1102.9	1102.7	1102.5	1102.3	1102.1	1102.0	1102.0
145°	1157.0	1158.1	1159.1	1160.1	1160.8	1161.0	1161.3	1161.5	1161.8	1161.5	1161.3
147.5°	1212.1	1213.3	1214.5	1215.8	1216.3	1216.1	1215.9	1215.7	1215.5	1215.3	1215.1
150°	1245.3	1246.4	1247.4	1248.4	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9	1248.9
152.5°	1276.5	1277.1	1277.7	1278.4	1278.8	1279.0	1279.2	1279.4	1279.6	1280.2	1280.8
155°	1324.4	1324.4	1324.4	1324.4	1324.3	1324.1	1323.8	1323.5	1323.3	1324.3	1325.4
157.5°	1364.9	1364.4	1364.0	1363.5	1363.2	1363.2	1363.1	1363.1	1363.0	1363.8	1364.6
160°	1389.3	1389.0	1388.7	1388.5	1388.2	1388.0	1387.7	1387.4	1387.2	1388.0	1388.7
162.5°	1411.1	1410.5	1409.8	1409.1	1408.7	1408.4	1408.2	1407.9	1407.6	1409.0	1410.4
165°	1441.0	1440.2	1439.5	1438.7	1438.0	1437.5	1437.0	1436.5	1436.0	1437.5	1439.1
167.5°	1463.7	1462.6	1461.5	1460.5	1459.9	1460.0	1460.0	1460.1	1460.1	1461.7	1463.2
170°	1476.5	1475.2	1473.9	1472.6	1472.1	1472.4	1472.6	1472.9	1473.2	1474.7	1476.3
172.5°	1486.0	1484.9	1483.8	1482.8	1482.2	1482.3	1482.4	1482.4	1482.5	1484.2	1486.0
175°	1498.6	1497.3	1496.0	1494.7	1493.9	1493.7	1493.4	1493.2	1492.9	1494.7	1496.5
177.5°	1503.0	1502.0	1501.0	1499.9	1499.4	1499.4	1499.4	1499.4	1499.4	1500.9	1502.3
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
0°	587.4	587.4	587.4	587.4	587.4	587.4	587.4
2.5°	616.2	616.9	617.5	619.4	619.6	621.3	619.6
5°	667.2	670.5	675.7	680.9	681.4	684.7	678.8
7.5°	724.3	732.0	736.8	745.2	748.5	750.6	747.2
10°	763.7	770.8	783.4	789.5	795.7	796.6	793.8
12.5°	801.8	813.0	822.9	834.6	834.3	842.6	839.6
15°	852.5	864.1	877.8	890.8	895.5	895.5	899.3
17.5°	888.6	909.9	924.1	934.3	945.5	947.4	946.1
20°	913.1	936.0	951.2	964.4	972.0	974.1	974.1
22.5°	931.2	950.8	965.6	977.5	983.7	986.2	985.5
25°	943.8	960.6	969.6	973.2	974.8	974.4	969.9
27.5°	926.6	925.8	920.2	909.3	901.1	896.1	890.4
30°	893.7	881.3	867.1	851.5	831.4	816.0	811.3
32.5°	844.6	817.0	792.9	766.9	745.3	729.9	723.4
35°	749.8	706.0	670.2	639.0	616.3	602.1	597.3
37.5°	637.2	594.8	550.6	520.3	501.4	487.1	481.8
40°	565.6	519.5	480.9	452.5	433.1	419.1	418.9
42.5°	500.3	456.2	419.9	399.5	378.6	369.3	369.3
45°	409.7	374.4	343.6	327.5	315.0	307.4	305.3
47.5°	339.2	310.0	289.5	276.7	266.5	261.7	258.5
50°	299.6	274.1	257.7	246.6	240.9	234.8	234.3
52.5°	266.7	246.0	233.3	224.3	217.1	213.4	213.5
55°	224.1	207.8	198.8	191.9	186.3	183.4	182.2
57.5°	188.8	176.6	170.0	163.7	161.3	159.1	158.5
60°	166.9	158.6	152.4	147.4	143.9	143.2	142.9
62.5°	148.7	140.0	135.8	131.9	129.3	128.2	127.8
65°	122.6	116.2	112.4	109.3	108.4	106.7	106.5
67.5°	98.8	95.0	92.5	90.4	89.1	89.0	89.0
70°	84.3	82.1	80.0	78.8	78.1	77.6	77.6
72.5°	71.8	70.2	68.4	67.8	67.7	67.2	67.0
75°	54.7	53.0	53.3	52.1	51.1	49.9	49.2
77.5°	38.8	37.6	37.3	37.2	36.4	36.3	36.6
80°	30.1	28.9	28.6	28.9	28.6	27.9	27.9
82.5°	22.9	21.9	21.6	21.5	21.3	21.5	21.1
85°	12.3	11.8	11.8	11.8	12.3	12.1	11.8
87.5°	10.4	10.5	10.9	10.8	10.9	10.8	11.1
90°	30.2	31.8	32.8	33.3	33.8	34.3	34.9
92.5°	48.8	49.7	50.3	50.7	51.0	51.3	51.6
95°	90.6	91.4	91.8	91.8	91.8	91.8	91.8
97.5°	142.4	143.4	143.8	143.8	143.8	143.8	143.8
100°	179.3	179.8	180.1	180.1	180.1	180.1	180.1
102.5°	219.0	219.7	220.1	220.4	220.6	220.8	221.0
105°	278.8	279.6	280.4	281.2	281.9	282.7	283.5
107.5°	343.5	344.2	344.6	344.5	344.5	344.4	344.4
110°	385.3	384.8	384.9	385.7	386.5	387.3	388.0



TEST NUMBER: P332890

CATALOG NUMBER: S124RDIP-S350D1205U835-4F0-1E-UDD-A1

CANDELA DISTRIBUTION (continued):

	330°	335°	340°	345°	350°	355°	360°
112.5°	432.1	432.0	432.0	432.2	432.3	432.5	432.7
115°	503.4	503.2	502.9	502.7	502.4	502.2	501.9
117.5°	571.5	570.6	570.0	569.4	568.9	568.4	567.9
120°	617.7	616.4	616.0	616.5	617.0	617.6	618.1
122.5°	665.4	664.5	663.6	662.7	661.8	660.8	659.9
125°	735.0	734.5	734.0	733.5	733.0	732.4	731.9
127.5°	801.3	800.7	800.3	799.9	799.4	799.0	798.6
130°	847.7	847.2	846.4	845.4	844.4	843.3	842.3
132.5°	891.4	890.9	890.4	890.0	889.6	889.2	888.8
135°	956.9	956.4	955.8	955.0	954.2	953.4	952.7
137.5°	1020.1	1019.5	1019.2	1019.4	1019.5	1019.7	1019.8
140°	1062.3	1062.0	1061.8	1061.5	1061.2	1061.0	1060.7
142.5°	1101.9	1101.9	1101.8	1101.8	1101.7	1101.7	1101.6
145°	1161.0	1160.8	1160.2	1159.5	1158.7	1157.9	1157.2
147.5°	1214.9	1214.6	1214.4	1214.2	1213.9	1213.6	1213.4
150°	1248.9	1248.9	1248.8	1248.5	1248.3	1248.0	1247.8
152.5°	1281.5	1282.1	1282.1	1281.4	1280.7	1280.0	1279.4
155°	1326.4	1327.4	1327.4	1326.4	1325.4	1324.3	1323.3
157.5°	1365.3	1366.1	1366.1	1365.2	1364.3	1363.4	1362.6
160°	1389.5	1390.3	1390.0	1388.7	1387.4	1386.2	1384.9
162.5°	1411.8	1413.2	1413.3	1412.0	1410.7	1409.4	1408.1
165°	1440.6	1442.2	1442.4	1441.4	1440.4	1439.3	1438.3
167.5°	1464.8	1466.3	1466.3	1464.7	1463.1	1461.5	1459.9
170°	1477.8	1479.4	1479.2	1477.4	1475.6	1473.8	1472.0
172.5°	1487.7	1489.5	1489.5	1487.6	1485.8	1484.0	1482.2
175°	1498.3	1500.1	1500.1	1498.3	1496.5	1494.7	1492.9
177.5°	1503.8	1505.2	1505.1	1503.4	1501.8	1500.1	1498.5
180°	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2	1502.2

(END OF REPORT)