

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: NEO-RAY

Report Number: P332688-935

Luminaire Tested: **S124DIP-S1195D810U935-4F0-1E-UDD-A**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P332688-935  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1807-864-6,  
Test Lab: INNOVATION CENTER  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: NEO-RAY  
Catalog Number: S124DIP-S1195D810U935-4F0-1E-UDD-A  
Description: DEFINE 4 DIRECT-INDIRECT PENDANT LED LUMINAIRE  
DOWNLIGHT 1195 LUMENS PER FOOT, ASYMMETRIC DIFFUSER  
UPLIGHT 810 LUMENS PER FOOT, NO LENS  
Light Source: -  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 7365.3 lumens  
Efficiency: N/A  
Efficacy: 121.3 lumens/watt  
Spacing Criteria (0/90/45): 1.31 / 1.23 / 1.41  
Luminous Opening: Rectangular (W 4' x L: 0.33' x H: 0')  
CIE Type: Semi-Direct


Input Watts (W): 60.7  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

### Luminous Intensity Polar Plot





TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67	62
1	101	96	93	89	94	91	87	84	79	77	75	69	67	66	60	59	57	53
2	92	85	78	73	86	80	74	70	70	66	62	61	58	55	53	51	49	45
3	84	75	67	61	79	70	64	58	62	57	53	54	50	47	47	44	42	38
4	77	66	58	52	72	62	55	50	55	50	45	49	44	41	42	39	36	33
5	71	59	51	45	66	56	49	43	50	44	39	44	39	35	38	35	32	29
6	66	53	45	39	61	50	43	38	45	39	34	40	35	31	35	31	28	25
7	61	48	40	35	57	46	38	33	41	35	30	36	31	28	32	28	25	23
8	56	44	36	31	53	42	35	30	37	31	27	33	28	25	29	25	23	20
9	53	40	33	28	49	38	31	27	34	29	24	31	26	22	27	23	20	18
10	49	37	30	25	46	35	28	24	32	26	22	28	24	20	25	21	19	17

**AVERAGE LUMINANCE (cd/sqm):**

	0°	90°	180°	270°
0°	13397	13397	13397	13397
5°	15776	13431	11854	13431
10°	18889	13373	10673	13373
15°	22349	13237	9802	13237
20°	24887	13099	9024	13099
25°	25289	12896	8487	12896
30°	21519	12701	8318	12701
35°	16544	12384	8319	12384
40°	12896	12012	8476	12012
45°	10752	11451	8617	11451
50°	9463	10766	8911	10766
55°	8670	9947	9270	9947
60°	8125	9213	9700	9213
65°	7564	8392	10059	8392
70°	6911	7579	10286	7579
75°	6173	6669	10162	6669
80°	5174	5463	9842	5463
85°	3816	3946	9429	3946



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	161.7	2.2
10°-20°	498.3	6.8
20°-30°	790.2	10.7
30°-40°	879.4	11.9
40°-50°	800.5	10.9
50°-60°	654.1	8.9
60°-70°	467.0	6.3
70°-80°	257.1	3.5
80°-90°	72.8	1.0
90°-100°	30.8	0.4
100°-110°	196.3	2.7
110°-120°	375.5	5.1
120°-130°	476.7	6.5
130°-140°	510.0	6.9
140°-150°	476.9	6.5
150°-160°	384.6	5.2
160°-170°	248.0	3.4
170°-180°	85.5	1.2
0°-30°	1450.2	19.7
0°-40°	2329.6	31.6
0°-60°	3784.2	51.4
0°-90°	4581.1	62.2
90°-120°	602.6	8.2
90°-150°	2066.1	28.1
90°-180°	2784.0	37.8
0°-180°	7365.3	100.0

**CANDELA DISTRIBUTION:**

	0°	90°	180°	270°	360°	Flux
0°	1660	1660	1660	1660	1660	
5°	1947	1657	1463	1657	1947	198
15°	2674	1584	1173	1584	2674	756
25°	2839	1448	953	1448	2839	1252
35°	1679	1257	844	1257	1679	1066
45°	942	1003	755	1003	942	742
55°	616	707	659	707	616	556
65°	396	439	527	439	396	392
75°	198	214	326	214	198	210
85°	41	43	102	43	41	51
90°	20	2	20	2	20	10
95°	20	37	20	37	20	16
105°	192	203	192	203	192	167
115°	381	378	381	378	381	377
125°	536	532	536	532	536	477
135°	664	660	664	660	664	511
145°	765	761	765	761	765	478
155°	833	834	833	834	833	384
165°	876	880	876	880	876	247
175°	895	900	895	900	895	85
180°	900	900	900	900	900	



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (FULL):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1766.2	1765.6	1760.1	1759.0	1755.1	1750.2	1749.1	1740.3	1722.7	1714.4	1712.3
5°	1946.8	1960.6	1942.7	1939.2	1937.2	1914.5	1902.8	1889.0	1857.4	1838.9	1824.5
7.5°	2162.4	2164.0	2156.2	2149.9	2132.4	2112.6	2082.9	2051.3	2013.6	1974.4	1944.9
10°	2304.3	2309.8	2300.9	2299.5	2264.4	2242.4	2198.4	2161.3	2118.7	2071.2	2027.9
12.5°	2453.8	2446.2	2441.6	2412.2	2405.7	2365.6	2314.5	2276.2	2210.5	2155.9	2098.3
15°	2674.1	2659.0	2649.4	2608.8	2588.9	2533.1	2478.9	2437.0	2351.0	2269.3	2207.3
17.5°	2803.3	2818.5	2796.2	2779.6	2728.0	2689.0	2633.5	2545.5	2478.2	2376.6	2298.5
20°	2896.8	2898.2	2885.8	2868.7	2828.1	2778.6	2718.1	2621.8	2541.4	2440.4	2333.1
22.5°	2922.1	2922.4	2917.2	2901.1	2870.4	2830.3	2769.2	2689.0	2591.5	2481.7	2374.4
25°	2839.1	2836.3	2842.5	2860.4	2848.7	2836.3	2801.3	2741.5	2650.8	2534.5	2419.1
27.5°	2530.6	2549.5	2584.5	2628.5	2670.8	2703.1	2712.2	2699.9	2643.7	2548.2	2427.2
30°	2308.4	2331.8	2357.9	2401.8	2487.2	2535.9	2589.5	2630.1	2607.5	2531.2	2418.4
32.5°	2064.2	2070.0	2108.8	2158.8	2236.9	2330.8	2415.8	2498.1	2525.5	2485.4	2391.4
35°	1678.7	1688.3	1730.3	1779.8	1875.3	1990.1	2118.0	2232.1	2326.2	2364.0	2315.9
37.5°	1369.9	1397.6	1427.1	1480.3	1564.4	1667.8	1800.7	1948.4	2088.7	2182.7	2198.6
40°	1223.7	1240.8	1262.1	1302.7	1374.2	1475.9	1590.0	1759.1	1908.3	2043.1	2087.1
42.5°	1108.1	1118.2	1131.3	1167.9	1222.4	1323.6	1427.8	1576.6	1726.3	1887.4	1961.1
45°	941.8	952.1	974.0	995.4	1036.6	1106.7	1203.7	1326.0	1476.6	1631.9	1768.1
47.5°	821.7	828.2	841.3	864.1	899.1	945.4	1024.2	1126.4	1266.0	1416.8	1561.9
50°	753.5	758.9	769.2	789.9	816.7	857.9	922.6	1018.0	1127.4	1279.3	1421.6
52.5°	699.6	701.7	709.3	723.3	744.6	779.3	832.3	911.4	1013.0	1148.4	1290.2
55°	616.0	618.7	625.6	635.8	654.4	676.4	717.0	776.1	864.8	982.3	1105.4
57.5°	547.2	549.1	554.9	558.9	574.1	592.0	623.2	665.5	732.6	832.3	942.2
60°	503.2	501.8	508.7	512.1	522.5	537.6	561.6	602.2	660.6	741.1	842.1
62.5°	460.3	458.4	464.2	468.7	474.6	487.5	507.2	539.0	586.3	659.1	746.4
65°	396.0	393.2	396.7	402.2	407.7	414.5	429.0	457.1	495.0	547.2	613.9
67.5°	331.3	334.2	334.8	337.5	340.7	350.1	359.9	379.9	406.6	448.3	504.9
70°	292.8	293.5	296.3	296.3	298.3	306.6	314.9	326.5	352.7	391.2	437.2
72.5°	254.3	257.3	256.1	258.3	259.8	265.4	271.4	282.5	304.8	333.4	372.3
75°	197.9	200.0	200.0	200.7	202.8	204.8	209.7	217.9	233.8	255.0	281.8
77.5°	144.4	144.6	145.6	148.1	148.1	151.4	155.0	161.5	169.4	184.0	200.4
80°	111.3	112.7	112.0	113.4	113.4	116.1	117.5	125.8	129.2	138.9	151.9
82.5°	81.7	83.0	82.9	84.8	85.9	86.4	88.4	91.7	95.1	103.7	109.0
85°	41.2	42.6	41.2	42.6	44.7	45.4	47.4	48.1	50.9	53.0	57.8
87.5°	16.1	17.7	17.7	18.2	19.2	19.6	20.0	19.3	21.3	21.7	23.6
90°	20.2	19.9	19.6	19.3	19.0	18.4	17.5	16.6	15.7	14.8	13.6
92.5°	18.6	18.5	18.4	18.4	18.3	17.8	17.0	16.1	15.2	14.3	13.1
95°	19.5	19.4	19.2	19.1	18.9	18.4	17.5	16.6	15.7	14.8	14.6
97.5°	18.9	18.7	18.5	18.4	18.3	18.2	18.1	18.0	17.8	17.7	34.4
100°	18.9	18.7	18.5	18.4	18.3	19.5	22.0	24.5	27.0	29.6	50.3
102.5°	19.4	19.4	19.3	19.3	19.3	33.0	60.4	87.8	115.3	142.8	145.4
105°	191.8	197.3	202.6	208.0	213.4	215.4	214.0	212.8	211.4	210.0	209.3
107.5°	267.4	266.8	266.2	265.7	265.1	264.5	263.8	263.2	262.5	261.9	260.9
110°	300.2	299.8	299.4	298.9	298.4	298.1	297.8	297.5	297.2	296.9	296.0



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
112.5°	333.1	332.5	332.0	331.4	330.8	330.5	330.6	330.7	330.8	330.8	330.4
115°	381.1	381.1	381.1	381.1	381.1	380.9	380.6	380.3	380.0	379.7	379.9
117.5°	429.8	429.8	429.9	430.0	430.0	430.1	430.2	430.2	430.2	430.3	430.0
120°	460.5	460.8	461.1	461.4	461.7	461.7	461.4	461.1	460.8	460.5	460.6
122.5°	490.6	490.9	491.2	491.5	491.8	491.9	491.7	491.5	491.4	491.2	490.9
125°	535.9	535.7	535.5	535.5	535.3	534.9	534.5	534.1	533.6	533.2	533.5
127.5°	575.6	575.8	575.8	575.9	576.1	576.2	576.3	576.4	576.4	576.5	575.8
130°	602.5	602.5	602.5	602.5	602.5	602.4	602.3	602.2	602.0	601.8	601.4
132.5°	627.3	627.4	627.5	627.7	627.8	627.8	627.6	627.5	627.3	627.2	626.5
135°	664.4	664.2	663.8	663.6	663.2	663.0	662.6	662.4	662.0	661.8	661.2
137.5°	696.2	696.3	696.4	696.5	696.5	696.5	696.1	695.8	695.5	695.2	694.5
140°	718.3	718.2	718.0	717.9	717.7	717.4	717.0	716.5	716.1	715.6	715.3
142.5°	736.6	736.6	736.6	736.5	736.5	736.3	736.0	735.6	735.4	735.0	734.9
145°	764.7	764.5	764.1	763.9	763.5	763.4	763.2	763.0	762.9	762.8	762.8
147.5°	788.1	787.9	787.7	787.6	787.5	787.3	787.2	787.1	787.0	786.9	787.0
150°	803.1	803.0	802.8	802.7	802.5	802.5	802.5	802.5	802.5	802.5	802.6
152.5°	816.1	816.1	816.2	816.3	816.4	816.3	816.1	815.9	815.6	815.4	815.6
155°	833.4	833.9	834.3	834.7	835.3	835.2	834.6	834.0	833.4	832.8	833.2
157.5°	848.0	848.8	849.5	850.3	851.1	851.1	850.3	849.5	848.8	848.0	848.5
160°	857.6	858.6	859.5	860.4	861.3	861.3	860.4	859.5	858.6	857.6	857.8
162.5°	865.2	866.3	867.2	868.2	869.3	869.4	868.4	867.5	866.7	865.7	865.9
165°	875.8	877.2	878.6	879.9	881.2	881.3	880.1	878.9	877.7	876.5	876.5
167.5°	883.8	885.3	886.7	888.3	889.8	889.8	888.6	887.3	885.9	884.6	884.7
170°	888.6	890.1	891.7	893.1	894.6	894.8	893.5	892.3	891.1	890.0	889.8
172.5°	891.3	892.9	894.6	896.2	897.8	898.0	896.8	895.6	894.4	893.2	893.0
175°	894.7	896.5	898.3	900.1	901.9	902.1	900.8	899.4	898.0	896.7	896.6
177.5°	896.8	898.3	899.7	901.1	902.6	902.8	901.9	901.0	899.9	899.0	898.8
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1712.8	1705.1	1699.6	1695.2	1683.1	1675.9	1670.4	1662.8	1654.0	1644.6	1633.1
5°	1810.0	1786.7	1769.4	1743.4	1718.6	1698.0	1676.6	1657.4	1634.0	1608.6	1590.0
7.5°	1912.2	1877.4	1832.8	1794.2	1750.8	1713.0	1679.1	1644.5	1608.4	1573.6	1541.5
10°	1977.0	1932.3	1882.8	1824.5	1769.4	1720.6	1675.2	1631.3	1588.6	1546.0	1509.6
12.5°	2046.9	1991.2	1918.0	1849.8	1788.1	1722.9	1668.1	1614.2	1562.8	1518.0	1475.5
15°	2140.7	2060.2	1975.7	1884.2	1803.1	1726.8	1651.9	1583.8	1526.1	1467.0	1425.7
17.5°	2198.3	2098.8	2002.1	1906.5	1808.4	1712.1	1631.3	1552.8	1480.5	1421.8	1369.8
20°	2236.2	2137.3	2016.9	1921.4	1804.5	1705.6	1612.1	1524.7	1449.1	1386.6	1332.9
22.5°	2269.3	2154.8	2034.5	1908.8	1792.4	1687.4	1585.1	1497.2	1420.0	1354.1	1302.7
25°	2287.1	2155.8	2025.2	1900.1	1768.1	1643.6	1550.8	1447.8	1365.2	1295.8	1240.8
27.5°	2289.1	2148.6	2000.9	1861.8	1725.6	1609.7	1492.5	1400.4	1314.7	1241.4	1188.6
30°	2282.9	2136.6	1977.7	1827.2	1690.4	1564.6	1462.8	1362.5	1275.2	1202.3	1147.3
32.5°	2263.7	2111.3	1948.0	1788.7	1646.9	1523.9	1418.8	1323.4	1238.4	1166.6	1108.8
35°	2208.0	2057.4	1883.5	1717.9	1572.9	1448.5	1353.6	1256.6	1171.4	1103.4	1047.7
37.5°	2121.0	1984.9	1808.1	1636.7	1494.2	1369.2	1275.2	1187.6	1110.8	1041.6	984.6
40°	2045.1	1925.5	1748.2	1581.1	1427.1	1308.2	1220.2	1139.8	1063.4	998.2	943.8
42.5°	1957.7	1853.5	1689.9	1512.9	1364.4	1244.9	1159.2	1086.9	1015.0	954.7	900.4
45°	1801.7	1733.0	1579.1	1415.4	1260.8	1148.0	1066.2	1003.0	942.5	883.4	838.0
47.5°	1622.5	1588.4	1458.7	1303.4	1156.5	1045.4	974.5	916.1	863.0	813.0	772.9
50°	1502.0	1485.6	1373.5	1223.7	1083.4	978.9	907.4	857.2	811.8	767.8	730.0
52.5°	1383.3	1382.7	1281.7	1144.4	1014.7	914.0	843.1	796.2	756.9	721.1	687.2
55°	1201.6	1220.9	1141.9	1019.4	903.3	812.5	748.6	706.7	679.2	649.6	624.2
57.5°	1034.8	1066.8	1001.6	893.8	796.9	713.3	657.6	626.1	596.8	578.9	560.4
60°	926.0	956.2	905.3	814.6	723.2	651.7	598.7	570.6	545.1	532.8	519.7
62.5°	829.1	856.1	818.5	734.3	655.0	586.3	541.6	514.4	497.3	483.8	475.2
65°	690.9	713.6	681.2	620.1	552.0	497.1	460.5	439.3	422.8	417.2	407.7
67.5°	558.4	579.1	561.6	509.6	455.0	413.5	385.0	364.5	354.7	349.9	343.0
70°	479.8	500.4	481.9	436.5	394.6	359.6	332.7	321.1	310.7	308.7	299.0
72.5°	413.3	427.3	408.7	373.2	337.4	307.8	287.1	274.8	269.5	265.8	260.5
75°	310.0	322.4	310.0	282.5	257.1	236.5	218.6	213.8	207.6	205.5	202.1
77.5°	219.5	230.1	220.7	203.5	184.5	168.6	158.9	152.7	151.4	147.8	149.5
80°	167.7	174.6	165.7	153.9	138.9	127.9	121.0	117.5	113.4	112.0	114.8
82.5°	120.5	123.5	118.9	111.1	99.8	92.6	88.0	84.0	83.2	83.4	83.4
85°	62.6	61.9	61.2	54.3	50.9	46.1	43.3	42.6	41.9	43.3	44.7
87.5°	23.4	23.7	22.9	20.4	18.4	16.4	15.6	14.7	15.6	16.4	17.3
90°	12.4	11.2	10.0	8.6	7.0	5.3	3.7	2.0	3.7	5.3	7.0
92.5°	11.9	10.7	9.5	8.9	8.8	8.7	8.6	8.5	8.6	8.7	8.8
95°	14.6	14.4	14.2	16.7	21.8	26.9	31.9	37.0	31.9	26.9	21.8
97.5°	51.1	67.8	84.6	91.4	88.2	85.0	81.8	78.6	81.8	85.0	88.2
100°	70.9	91.5	112.2	121.1	118.5	115.8	113.1	110.4	113.1	115.8	118.5
102.5°	148.1	150.8	153.5	153.9	151.9	149.9	147.9	145.9	147.9	149.9	151.9
105°	208.5	207.8	207.1	206.2	205.3	204.4	203.5	202.6	203.5	204.4	205.3
107.5°	259.8	258.8	257.8	257.1	256.7	256.1	255.7	255.3	255.7	256.1	256.7
110°	295.1	294.2	293.3	292.7	292.1	291.7	291.3	290.8	291.3	291.7	292.1





TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°	95°	100°	105°
112.5°	329.9	329.6	329.2	328.6	327.7	326.9	326.1	325.3	326.1	326.9	327.7
115°	380.0	380.1	380.3	380.1	379.7	379.3	378.8	378.3	378.8	379.3	379.7
117.5°	429.6	429.3	429.0	428.5	427.9	427.3	426.7	426.1	426.7	427.3	427.9
120°	460.8	460.9	461.1	460.8	460.3	459.7	459.1	458.5	459.1	459.7	460.3
122.5°	490.8	490.5	490.3	490.1	489.7	489.3	489.0	488.6	489.0	489.3	489.7
125°	533.8	534.1	534.3	534.3	533.6	533.0	532.4	531.8	532.4	533.0	533.6
127.5°	575.1	574.5	573.8	573.3	573.3	573.1	572.9	572.7	572.9	573.1	573.3
130°	601.0	600.5	600.0	599.8	599.6	599.4	599.3	599.2	599.3	599.4	599.6
132.5°	626.0	625.4	624.9	624.5	624.2	624.0	623.6	623.4	623.6	624.0	624.2
135°	660.6	660.0	659.4	659.2	659.3	659.4	659.6	659.8	659.6	659.4	659.3
137.5°	693.9	693.2	692.5	692.2	692.1	692.1	692.0	691.9	692.0	692.1	692.1
140°	715.1	714.7	714.5	714.1	713.9	713.5	713.3	712.9	713.3	713.5	713.9
142.5°	734.7	734.4	734.3	733.9	733.4	732.9	732.3	731.8	732.3	732.9	733.4
145°	762.8	762.8	762.8	762.5	762.1	761.6	761.2	760.7	761.2	761.6	762.1
147.5°	787.1	787.3	787.5	787.1	786.3	785.4	784.6	783.8	784.6	785.4	786.3
150°	802.8	802.9	803.1	802.8	802.3	801.7	801.1	800.5	801.1	801.7	802.3
152.5°	816.0	816.2	816.5	816.4	815.9	815.4	814.9	814.4	814.9	815.4	815.9
155°	833.6	834.1	834.6	834.7	834.6	834.4	834.2	834.1	834.2	834.4	834.6
157.5°	849.0	849.5	850.0	850.3	850.4	850.5	850.6	850.7	850.6	850.5	850.4
160°	858.0	858.2	858.2	858.6	859.0	859.5	859.9	860.4	859.9	859.5	859.0
162.5°	866.1	866.2	866.3	866.7	867.3	867.8	868.4	869.0	868.4	867.8	867.3
165°	876.5	876.5	876.5	876.9	877.6	878.4	879.2	879.9	879.2	878.4	877.6
167.5°	884.8	884.8	884.9	885.4	886.1	886.9	887.7	888.5	887.7	886.9	886.1
170°	889.7	889.5	889.4	889.8	890.6	891.6	892.4	893.4	892.4	891.6	890.6
172.5°	892.9	892.8	892.6	893.0	893.9	894.8	895.7	896.6	895.7	894.8	893.9
175°	896.4	896.3	896.1	896.5	897.4	898.3	899.1	900.1	899.1	898.3	897.4
177.5°	898.5	898.3	898.0	898.4	899.1	900.0	900.9	901.7	900.9	900.0	899.1
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1627.5	1622.6	1615.5	1605.6	1597.3	1588.5	1586.3	1583.0	1589.6	1584.2	1582.4
5°	1574.3	1559.8	1541.2	1519.9	1507.5	1489.7	1486.3	1479.4	1472.5	1471.8	1464.9
7.5°	1517.7	1496.5	1472.2	1450.4	1430.4	1410.9	1398.1	1395.3	1385.2	1379.2	1372.3
10°	1481.4	1455.3	1427.1	1406.5	1383.1	1362.5	1348.1	1339.8	1332.9	1325.3	1318.5
12.5°	1438.6	1410.7	1387.5	1365.2	1337.5	1321.8	1298.0	1283.8	1282.4	1282.5	1264.6
15°	1388.6	1361.2	1325.3	1293.7	1278.6	1248.4	1235.3	1218.8	1208.5	1198.2	1190.0
17.5°	1331.5	1297.4	1269.4	1233.1	1204.3	1180.2	1163.0	1153.1	1137.6	1123.0	1112.4
20°	1295.8	1259.4	1229.9	1191.3	1159.7	1130.1	1115.7	1102.0	1090.3	1077.9	1066.2
22.5°	1259.5	1221.4	1185.3	1147.9	1118.4	1087.3	1073.3	1054.6	1043.5	1036.6	1024.9
25°	1202.3	1161.1	1119.8	1084.1	1053.9	1026.3	1007.8	993.3	980.9	975.4	967.9
27.5°	1140.1	1099.2	1059.4	1018.7	984.4	964.5	949.6	938.7	931.6	924.3	920.9
30°	1100.6	1058.0	1015.4	977.5	945.9	926.0	912.2	904.7	899.1	895.7	892.3
32.5°	1060.4	1018.4	973.5	939.0	910.7	892.9	882.5	874.9	872.2	871.0	869.8
35°	996.1	953.5	912.2	881.3	854.5	847.6	838.7	834.6	833.2	838.0	840.1
37.5°	933.8	894.2	856.3	826.3	808.7	798.7	795.7	795.7	800.7	804.9	809.9
40°	893.6	855.1	819.4	793.3	776.8	770.6	769.2	772.7	778.2	783.0	788.5
42.5°	854.6	816.7	784.2	759.7	748.2	742.5	743.4	746.8	754.5	760.4	768.7
45°	794.0	762.3	730.7	710.8	701.2	702.6	702.6	708.8	716.3	725.2	734.2
47.5°	736.9	705.1	679.1	662.3	657.3	656.1	660.0	668.0	678.9	689.9	702.4
50°	698.4	668.2	645.5	630.3	624.9	627.0	632.4	640.0	653.1	666.8	679.8
52.5°	659.4	631.9	610.9	596.8	593.0	596.7	602.2	614.2	625.6	640.4	656.3
55°	598.7	575.4	558.9	548.5	547.2	549.2	555.4	568.5	585.0	603.6	618.7
57.5°	538.4	518.8	503.8	496.6	497.3	499.2	509.4	525.0	542.5	562.3	581.9
60°	497.7	479.8	467.4	461.9	462.6	466.7	479.1	493.6	515.6	534.9	555.4
62.5°	459.2	443.5	431.7	426.8	425.8	434.9	446.7	461.7	483.7	505.1	527.4
65°	397.4	385.0	375.3	372.6	374.6	381.5	396.7	416.6	435.1	457.8	481.2
67.5°	336.8	326.7	320.0	321.3	323.8	334.0	346.6	363.8	384.9	408.4	431.4
70°	298.3	288.7	283.2	283.9	288.0	300.4	311.4	328.6	351.3	375.3	394.6
72.5°	258.7	252.4	247.5	250.4	254.5	263.0	276.7	293.9	313.9	336.3	356.6
75°	198.6	198.6	195.9	197.9	204.1	212.4	222.7	240.6	260.5	278.4	294.9
77.5°	147.4	145.9	147.7	150.2	153.7	163.5	175.3	188.0	203.1	220.9	234.5
80°	112.7	113.4	116.8	121.0	122.3	129.9	142.3	153.9	165.7	180.8	193.9
82.5°	84.7	85.4	87.1	92.4	93.8	101.9	109.9	121.6	132.2	142.3	153.2
85°	46.1	46.1	49.5	51.6	55.0	60.5	65.3	72.2	81.8	88.7	99.0
87.5°	19.3	19.6	22.0	23.4	25.3	28.2	29.5	35.7	38.1	41.1	46.1
90°	8.6	10.0	11.2	12.4	13.6	14.8	15.7	16.6	17.5	18.4	19.0
92.5°	8.9	9.5	10.7	11.9	13.1	14.3	15.2	16.1	17.0	17.8	18.3
95°	16.7	14.2	14.4	14.6	14.6	14.8	15.7	16.6	17.5	18.4	18.9
97.5°	91.4	84.6	67.8	51.1	34.4	17.7	17.8	18.0	18.1	18.2	18.3
100°	121.1	112.2	91.5	70.9	50.3	29.6	27.0	24.5	22.0	19.5	18.3
102.5°	153.9	153.5	150.8	148.1	145.4	142.8	115.3	87.8	60.4	33.0	19.3
105°	206.2	207.1	207.8	208.5	209.3	210.0	211.4	212.8	214.0	215.4	213.4
107.5°	257.1	257.8	258.8	259.8	260.9	261.9	262.5	263.2	263.8	264.5	265.1
110°	292.7	293.3	294.2	295.1	296.0	296.9	297.2	297.5	297.8	298.1	298.4



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	110°	115°	120°	125°	130°	135°	140°	145°	150°	155°	160°
112.5°	328.6	329.2	329.6	329.9	330.4	330.8	330.8	330.7	330.6	330.5	330.8
115°	380.1	380.3	380.1	380.0	379.9	379.7	380.0	380.3	380.6	380.9	381.1
117.5°	428.5	429.0	429.3	429.6	430.0	430.3	430.2	430.2	430.2	430.1	430.0
120°	460.8	461.1	460.9	460.8	460.6	460.5	460.8	461.1	461.4	461.7	461.7
122.5°	490.1	490.3	490.5	490.8	490.9	491.2	491.4	491.5	491.7	491.9	491.8
125°	534.3	534.3	534.1	533.8	533.5	533.2	533.6	534.1	534.5	534.9	535.3
127.5°	573.3	573.8	574.5	575.1	575.8	576.5	576.4	576.4	576.3	576.2	576.1
130°	599.8	600.0	600.5	601.0	601.4	601.8	602.0	602.2	602.3	602.4	602.5
132.5°	624.5	624.9	625.4	626.0	626.5	627.2	627.3	627.5	627.6	627.8	627.8
135°	659.2	659.4	660.0	660.6	661.2	661.8	662.0	662.4	662.6	663.0	663.2
137.5°	692.2	692.5	693.2	693.9	694.5	695.2	695.5	695.8	696.1	696.5	696.5
140°	714.1	714.5	714.7	715.1	715.3	715.6	716.1	716.5	717.0	717.4	717.7
142.5°	733.9	734.3	734.4	734.7	734.9	735.0	735.4	735.6	736.0	736.3	736.5
145°	762.5	762.8	762.8	762.8	762.8	762.8	762.9	763.0	763.2	763.4	763.5
147.5°	787.1	787.5	787.3	787.1	787.0	786.9	787.0	787.1	787.2	787.3	787.5
150°	802.8	803.1	802.9	802.8	802.6	802.5	802.5	802.5	802.5	802.5	802.5
152.5°	816.4	816.5	816.2	816.0	815.6	815.4	815.6	815.9	816.1	816.3	816.4
155°	834.7	834.6	834.1	833.6	833.2	832.8	833.4	834.0	834.6	835.2	835.3
157.5°	850.3	850.0	849.5	849.0	848.5	848.0	848.8	849.5	850.3	851.1	851.1
160°	858.6	858.2	858.2	858.0	857.8	857.6	858.6	859.5	860.4	861.3	861.3
162.5°	866.7	866.3	866.2	866.1	865.9	865.7	866.7	867.5	868.4	869.4	869.3
165°	876.9	876.5	876.5	876.5	876.5	876.5	877.7	878.9	880.1	881.3	881.2
167.5°	885.4	884.9	884.8	884.8	884.7	884.6	885.9	887.3	888.6	889.8	889.8
170°	889.8	889.4	889.5	889.7	889.8	890.0	891.1	892.3	893.5	894.8	894.6
172.5°	893.0	892.6	892.8	892.9	893.0	893.2	894.4	895.6	896.8	898.0	897.8
175°	896.5	896.1	896.3	896.4	896.6	896.7	898.0	899.4	900.8	902.1	901.9
177.5°	898.4	898.0	898.3	898.5	898.8	899.0	899.9	901.0	901.9	902.8	902.6
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1581.4	1580.3	1576.4	1575.9	1576.4	1580.3	1581.4	1582.4	1584.2	1589.6	1583.0
5°	1460.8	1457.3	1455.3	1462.8	1455.3	1457.3	1460.8	1464.9	1471.8	1472.5	1479.4
7.5°	1369.9	1367.2	1361.2	1359.2	1361.2	1367.2	1369.9	1372.3	1379.2	1385.2	1395.3
10°	1311.6	1308.9	1303.4	1302.0	1303.4	1308.9	1311.6	1318.5	1325.3	1332.9	1339.8
12.5°	1255.5	1250.0	1249.0	1250.3	1249.0	1250.0	1255.5	1264.6	1282.5	1282.4	1283.8
15°	1181.0	1178.3	1170.7	1172.8	1170.7	1178.3	1181.0	1190.0	1198.2	1208.5	1218.8
17.5°	1107.6	1104.3	1095.1	1103.2	1095.1	1104.3	1107.6	1112.4	1123.0	1137.6	1153.1
20°	1061.4	1055.9	1051.1	1050.4	1051.1	1055.9	1061.4	1066.2	1077.9	1090.3	1102.0
22.5°	1017.4	1012.4	1012.0	1007.5	1012.0	1012.4	1017.4	1024.9	1036.6	1043.5	1054.6
25°	962.4	957.6	956.2	952.8	956.2	957.6	962.4	967.9	975.4	980.9	993.3
27.5°	920.2	917.8	915.4	916.4	915.4	917.8	920.2	920.9	924.3	931.6	938.7
30°	894.3	893.6	892.3	892.3	892.3	893.6	894.3	892.3	895.7	899.1	904.7
32.5°	872.9	872.8	873.6	873.6	873.6	872.8	872.9	869.8	871.0	872.2	874.9
35°	842.8	844.8	846.2	844.1	846.2	844.8	842.8	840.1	838.0	833.2	834.6
37.5°	815.5	817.6	819.6	821.9	819.6	817.6	815.5	809.9	804.9	800.7	795.7
40°	794.7	799.5	800.8	804.3	800.8	799.5	794.7	788.5	783.0	778.2	772.7
42.5°	774.9	780.2	783.8	784.5	783.8	780.2	774.9	768.7	760.4	754.5	746.8
45°	744.5	750.0	754.8	754.8	754.8	750.0	744.5	734.2	725.2	716.3	708.8
47.5°	713.0	721.0	725.8	727.0	725.8	721.0	713.0	702.4	689.9	678.9	668.0
50°	691.6	701.2	706.0	709.5	706.0	701.2	691.6	679.8	666.8	653.1	640.0
52.5°	670.6	680.3	686.7	688.5	686.7	680.3	670.6	656.3	640.4	625.6	614.2
55°	634.5	648.2	655.8	658.6	655.8	648.2	634.5	618.7	603.6	585.0	568.5
57.5°	600.4	613.0	621.8	623.9	621.8	613.0	600.4	581.9	562.3	542.5	525.0
60°	574.0	587.7	598.7	600.8	598.7	587.7	574.0	555.4	534.9	515.6	493.6
62.5°	547.1	561.4	571.3	576.6	571.3	561.4	547.1	527.4	505.1	483.7	461.7
65°	500.4	514.9	524.5	526.6	524.5	514.9	500.4	481.2	457.8	435.1	416.6
67.5°	449.6	464.0	470.4	474.3	470.4	464.0	449.6	431.4	408.4	384.9	363.8
70°	413.8	425.5	432.4	435.8	432.4	425.5	413.8	394.6	375.3	351.3	328.6
72.5°	373.2	385.4	393.4	394.0	393.4	385.4	373.2	356.6	336.3	313.9	293.9
75°	310.7	321.8	325.8	325.8	325.8	321.8	310.7	294.9	278.4	260.5	240.6
77.5°	246.0	251.6	256.8	258.0	256.8	251.6	246.0	234.5	220.9	203.1	188.0
80°	204.1	207.6	211.7	211.7	211.7	207.6	204.1	193.9	180.8	165.7	153.9
82.5°	161.3	164.2	168.3	167.7	168.3	164.2	161.3	153.2	142.3	132.2	121.6
85°	97.6	103.8	103.1	101.8	103.1	103.8	97.6	99.0	88.7	81.8	72.2
87.5°	47.9	48.5	50.2	51.3	50.2	48.5	47.9	46.1	41.1	38.1	35.7
90°	19.3	19.6	19.9	20.2	19.9	19.6	19.3	19.0	18.4	17.5	16.6
92.5°	18.4	18.4	18.5	18.6	18.5	18.4	18.4	18.3	17.8	17.0	16.1
95°	19.1	19.2	19.4	19.5	19.4	19.2	19.1	18.9	18.4	17.5	16.6
97.5°	18.4	18.5	18.7	18.9	18.7	18.5	18.4	18.3	18.2	18.1	18.0
100°	18.4	18.5	18.7	18.9	18.7	18.5	18.4	18.3	19.5	22.0	24.5
102.5°	19.3	19.3	19.4	19.4	19.4	19.3	19.3	19.3	33.0	60.4	87.8
105°	208.0	202.6	197.3	191.8	197.3	202.6	208.0	213.4	215.4	214.0	212.8
107.5°	265.7	266.2	266.8	267.4	266.8	266.2	265.7	265.1	264.5	263.8	263.2
110°	298.9	299.4	299.8	300.2	299.8	299.4	298.9	298.4	298.1	297.8	297.5



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	165°	170°	175°	180°	185°	190°	195°	200°	205°	210°	215°
112.5°	331.4	332.0	332.5	333.1	332.5	332.0	331.4	330.8	330.5	330.6	330.7
115°	381.1	381.1	381.1	381.1	381.1	381.1	381.1	381.1	380.9	380.6	380.3
117.5°	430.0	429.9	429.8	429.8	429.8	429.9	430.0	430.0	430.1	430.2	430.2
120°	461.4	461.1	460.8	460.5	460.8	461.1	461.4	461.7	461.7	461.4	461.1
122.5°	491.5	491.2	490.9	490.6	490.9	491.2	491.5	491.8	491.9	491.7	491.5
125°	535.5	535.5	535.7	535.9	535.7	535.5	535.5	535.3	534.9	534.5	534.1
127.5°	575.9	575.8	575.8	575.6	575.8	575.8	575.9	576.1	576.2	576.3	576.4
130°	602.5	602.5	602.5	602.5	602.5	602.5	602.5	602.5	602.4	602.3	602.2
132.5°	627.7	627.5	627.4	627.3	627.4	627.5	627.7	627.8	627.8	627.6	627.5
135°	663.6	663.8	664.2	664.4	664.2	663.8	663.6	663.2	663.0	662.6	662.4
137.5°	696.5	696.4	696.3	696.2	696.3	696.4	696.5	696.5	696.5	696.1	695.8
140°	717.9	718.0	718.2	718.3	718.2	718.0	717.9	717.7	717.4	717.0	716.5
142.5°	736.5	736.6	736.6	736.6	736.6	736.6	736.5	736.5	736.3	736.0	735.6
145°	763.9	764.1	764.5	764.7	764.5	764.1	763.9	763.5	763.4	763.2	763.0
147.5°	787.6	787.7	787.9	788.1	787.9	787.7	787.6	787.5	787.3	787.2	787.1
150°	802.7	802.8	803.0	803.1	803.0	802.8	802.7	802.5	802.5	802.5	802.5
152.5°	816.3	816.2	816.1	816.1	816.1	816.2	816.3	816.4	816.3	816.1	815.9
155°	834.7	834.3	833.9	833.4	833.9	834.3	834.7	835.3	835.2	834.6	834.0
157.5°	850.3	849.5	848.8	848.0	848.8	849.5	850.3	851.1	851.1	850.3	849.5
160°	860.4	859.5	858.6	857.6	858.6	859.5	860.4	861.3	861.3	860.4	859.5
162.5°	868.2	867.2	866.3	865.2	866.3	867.2	868.2	869.3	869.4	868.4	867.5
165°	879.9	878.6	877.2	875.8	877.2	878.6	879.9	881.2	881.3	880.1	878.9
167.5°	888.3	886.7	885.3	883.8	885.3	886.7	888.3	889.8	889.8	888.6	887.3
170°	893.1	891.7	890.1	888.6	890.1	891.7	893.1	894.6	894.8	893.5	892.3
172.5°	896.2	894.6	892.9	891.3	892.9	894.6	896.2	897.8	898.0	896.8	895.6
175°	900.1	898.3	896.5	894.7	896.5	898.3	900.1	901.9	902.1	900.8	899.4
177.5°	901.1	899.7	898.3	896.8	898.3	899.7	901.1	902.6	902.8	901.9	901.0
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1586.3	1588.5	1597.3	1605.6	1615.5	1622.6	1627.5	1633.1	1644.6	1654.0	1662.8
5°	1486.3	1489.7	1507.5	1519.9	1541.2	1559.8	1574.3	1590.0	1608.6	1634.0	1657.4
7.5°	1398.1	1410.9	1430.4	1450.4	1472.2	1496.5	1517.7	1541.5	1573.6	1608.4	1644.5
10°	1348.1	1362.5	1383.1	1406.5	1427.1	1455.3	1481.4	1509.6	1546.0	1588.6	1631.3
12.5°	1298.0	1321.8	1337.5	1365.2	1387.5	1410.7	1438.6	1475.5	1518.0	1562.8	1614.2
15°	1235.3	1248.4	1278.6	1293.7	1325.3	1361.2	1388.6	1425.7	1467.0	1526.1	1583.8
17.5°	1163.0	1180.2	1204.3	1233.1	1269.4	1297.4	1331.5	1369.8	1421.8	1480.5	1552.8
20°	1115.7	1130.1	1159.7	1191.3	1229.9	1259.4	1295.8	1332.9	1386.6	1449.1	1524.7
22.5°	1073.3	1087.3	1118.4	1147.9	1185.3	1221.4	1259.5	1302.7	1354.1	1420.0	1497.2
25°	1007.8	1026.3	1053.9	1084.1	1119.8	1161.1	1202.3	1240.8	1295.8	1365.2	1447.8
27.5°	949.6	964.5	984.4	1018.7	1059.4	1099.2	1140.1	1188.6	1241.4	1314.7	1400.4
30°	912.2	926.0	945.9	977.5	1015.4	1058.0	1100.6	1147.3	1202.3	1275.2	1362.5
32.5°	882.5	892.9	910.7	939.0	973.5	1018.4	1060.4	1108.8	1166.6	1238.4	1323.4
35°	838.7	847.6	854.5	881.3	912.2	953.5	996.1	1047.7	1103.4	1171.4	1256.6
37.5°	795.7	798.7	808.7	826.3	856.3	894.2	933.8	984.6	1041.6	1110.8	1187.6
40°	769.2	770.6	776.8	793.3	819.4	855.1	893.6	943.8	998.2	1063.4	1139.8
42.5°	743.4	742.5	748.2	759.7	784.2	816.7	854.6	900.4	954.7	1015.0	1086.9
45°	702.6	702.6	701.2	710.8	730.7	762.3	794.0	838.0	883.4	942.5	1003.0
47.5°	660.0	656.1	657.3	662.3	679.1	705.1	736.9	772.9	813.0	863.0	916.1
50°	632.4	627.0	624.9	630.3	645.5	668.2	698.4	730.0	767.8	811.8	857.2
52.5°	602.2	596.7	593.0	596.8	610.9	631.9	659.4	687.2	721.1	756.9	796.2
55°	555.4	549.2	547.2	548.5	558.9	575.4	598.7	624.2	649.6	679.2	706.7
57.5°	509.4	499.2	497.3	496.6	503.8	518.8	538.4	560.4	578.9	596.8	626.1
60°	479.1	466.7	462.6	461.9	467.4	479.8	497.7	519.7	532.8	545.1	570.6
62.5°	446.7	434.9	425.8	426.8	431.7	443.5	459.2	475.2	483.8	497.3	514.4
65°	396.7	381.5	374.6	372.6	375.3	385.0	397.4	407.7	417.2	422.8	439.3
67.5°	346.6	334.0	323.8	321.3	320.0	326.7	336.8	343.0	349.9	354.7	364.5
70°	311.4	300.4	288.0	283.9	283.2	288.7	298.3	299.0	308.7	310.7	321.1
72.5°	276.7	263.0	254.5	250.4	247.5	252.4	258.7	260.5	265.8	269.5	274.8
75°	222.7	212.4	204.1	197.9	195.9	198.6	198.6	202.1	205.5	207.6	213.8
77.5°	175.3	163.5	153.7	150.2	147.7	145.9	147.4	149.5	147.8	151.4	152.7
80°	142.3	129.9	122.3	121.0	116.8	113.4	112.7	114.8	112.0	113.4	117.5
82.5°	109.9	101.9	93.8	92.4	87.1	85.4	84.7	83.4	83.4	83.2	84.0
85°	65.3	60.5	55.0	51.6	49.5	46.1	46.1	44.7	43.3	41.9	42.6
87.5°	29.5	28.2	25.3	23.4	22.0	19.6	19.3	17.3	16.4	15.6	14.7
90°	15.7	14.8	13.6	12.4	11.2	10.0	8.6	7.0	5.3	3.7	2.0
92.5°	15.2	14.3	13.1	11.9	10.7	9.5	8.9	8.8	8.7	8.6	8.5
95°	15.7	14.8	14.6	14.6	14.4	14.2	16.7	21.8	26.9	31.9	37.0
97.5°	17.8	17.7	34.4	51.1	67.8	84.6	91.4	88.2	85.0	81.8	78.6
100°	27.0	29.6	50.3	70.9	91.5	112.2	121.1	118.5	115.8	113.1	110.4
102.5°	115.3	142.8	145.4	148.1	150.8	153.5	153.9	151.9	149.9	147.9	145.9
105°	211.4	210.0	209.3	208.5	207.8	207.1	206.2	205.3	204.4	203.5	202.6
107.5°	262.5	261.9	260.9	259.8	258.8	257.8	257.1	256.7	256.1	255.7	255.3
110°	297.2	296.9	296.0	295.1	294.2	293.3	292.7	292.1	291.7	291.3	290.8



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	220°	225°	230°	235°	240°	245°	250°	255°	260°	265°	270°
112.5°	330.8	330.8	330.4	329.9	329.6	329.2	328.6	327.7	326.9	326.1	325.3
115°	380.0	379.7	379.9	380.0	380.1	380.3	380.1	379.7	379.3	378.8	378.3
117.5°	430.2	430.3	430.0	429.6	429.3	429.0	428.5	427.9	427.3	426.7	426.1
120°	460.8	460.5	460.6	460.8	460.9	461.1	460.8	460.3	459.7	459.1	458.5
122.5°	491.4	491.2	490.9	490.8	490.5	490.3	490.1	489.7	489.3	489.0	488.6
125°	533.6	533.2	533.5	533.8	534.1	534.3	534.3	533.6	533.0	532.4	531.8
127.5°	576.4	576.5	575.8	575.1	574.5	573.8	573.3	573.3	573.1	572.9	572.7
130°	602.0	601.8	601.4	601.0	600.5	600.0	599.8	599.6	599.4	599.3	599.2
132.5°	627.3	627.2	626.5	626.0	625.4	624.9	624.5	624.2	624.0	623.6	623.4
135°	662.0	661.8	661.2	660.6	660.0	659.4	659.2	659.3	659.4	659.6	659.8
137.5°	695.5	695.2	694.5	693.9	693.2	692.5	692.2	692.1	692.1	692.0	691.9
140°	716.1	715.6	715.3	715.1	714.7	714.5	714.1	713.9	713.5	713.3	712.9
142.5°	735.4	735.0	734.9	734.7	734.4	734.3	733.9	733.4	732.9	732.3	731.8
145°	762.9	762.8	762.8	762.8	762.8	762.8	762.5	762.1	761.6	761.2	760.7
147.5°	787.0	786.9	787.0	787.1	787.3	787.5	787.1	786.3	785.4	784.6	783.8
150°	802.5	802.5	802.6	802.8	802.9	803.1	802.8	802.3	801.7	801.1	800.5
152.5°	815.6	815.4	815.6	816.0	816.2	816.5	816.4	815.9	815.4	814.9	814.4
155°	833.4	832.8	833.2	833.6	834.1	834.6	834.7	834.6	834.4	834.2	834.1
157.5°	848.8	848.0	848.5	849.0	849.5	850.0	850.3	850.4	850.5	850.6	850.7
160°	858.6	857.6	857.8	858.0	858.2	858.2	858.6	859.0	859.5	859.9	860.4
162.5°	866.7	865.7	865.9	866.1	866.2	866.3	866.7	867.3	867.8	868.4	869.0
165°	877.7	876.5	876.5	876.5	876.5	876.5	876.9	877.6	878.4	879.2	879.9
167.5°	885.9	884.6	884.7	884.8	884.8	884.9	885.4	886.1	886.9	887.7	888.5
170°	891.1	890.0	889.8	889.7	889.5	889.4	889.8	890.6	891.6	892.4	893.4
172.5°	894.4	893.2	893.0	892.9	892.8	892.6	893.0	893.9	894.8	895.7	896.6
175°	898.0	896.7	896.6	896.4	896.3	896.1	896.5	897.4	898.3	899.1	900.1
177.5°	899.9	899.0	898.8	898.5	898.3	898.0	898.4	899.1	900.0	900.9	901.7
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1670.4	1675.9	1683.1	1695.2	1699.6	1705.1	1712.8	1712.3	1714.4	1722.7	1740.3
5°	1676.6	1698.0	1718.6	1743.4	1769.4	1786.7	1810.0	1824.5	1838.9	1857.4	1889.0
7.5°	1679.1	1713.0	1750.8	1794.2	1832.8	1877.4	1912.2	1944.9	1974.4	2013.6	2051.3
10°	1675.2	1720.6	1769.4	1824.5	1882.8	1932.3	1977.0	2027.9	2071.2	2118.7	2161.3
12.5°	1668.1	1722.9	1788.1	1849.8	1918.0	1991.2	2046.9	2098.3	2155.9	2210.5	2276.2
15°	1651.9	1726.8	1803.1	1884.2	1975.7	2060.2	2140.7	2207.3	2269.3	2351.0	2437.0
17.5°	1631.3	1712.1	1808.4	1906.5	2002.1	2098.8	2198.3	2298.5	2376.6	2478.2	2545.5
20°	1612.1	1705.6	1804.5	1921.4	2016.9	2137.3	2236.2	2333.1	2440.4	2541.4	2621.8
22.5°	1585.1	1687.4	1792.4	1908.8	2034.5	2154.8	2269.3	2374.4	2481.7	2591.5	2689.0
25°	1550.8	1643.6	1768.1	1900.1	2025.2	2155.8	2287.1	2419.1	2534.5	2650.8	2741.5
27.5°	1492.5	1609.7	1725.6	1861.8	2000.9	2148.6	2289.1	2427.2	2548.2	2643.7	2699.9
30°	1462.8	1564.6	1690.4	1827.2	1977.7	2136.6	2282.9	2418.4	2531.2	2607.5	2630.1
32.5°	1418.8	1523.9	1646.9	1788.7	1948.0	2111.3	2263.7	2391.4	2485.4	2525.5	2498.1
35°	1353.6	1448.5	1572.9	1717.9	1883.5	2057.4	2208.0	2315.9	2364.0	2326.2	2232.1
37.5°	1275.2	1369.2	1494.2	1636.7	1808.1	1984.9	2121.0	2198.6	2182.7	2088.7	1948.4
40°	1220.2	1308.2	1427.1	1581.1	1748.2	1925.5	2045.1	2087.1	2043.1	1908.3	1759.1
42.5°	1159.2	1244.9	1364.4	1512.9	1689.9	1853.5	1957.7	1961.1	1887.4	1726.3	1576.6
45°	1066.2	1148.0	1260.8	1415.4	1579.1	1733.0	1801.7	1768.1	1631.9	1476.6	1326.0
47.5°	974.5	1045.4	1156.5	1303.4	1458.7	1588.4	1622.5	1561.9	1416.8	1266.0	1126.4
50°	907.4	978.9	1083.4	1223.7	1373.5	1485.6	1502.0	1421.6	1279.3	1127.4	1018.0
52.5°	843.1	914.0	1014.7	1144.4	1281.7	1382.7	1383.3	1290.2	1148.4	1013.0	911.4
55°	748.6	812.5	903.3	1019.4	1141.9	1220.9	1201.6	1105.4	982.3	864.8	776.1
57.5°	657.6	713.3	796.9	893.8	1001.6	1066.8	1034.8	942.2	832.3	732.6	665.5
60°	598.7	651.7	723.2	814.6	905.3	956.2	926.0	842.1	741.1	660.6	602.2
62.5°	541.6	586.3	655.0	734.3	818.5	856.1	829.1	746.4	659.1	586.3	539.0
65°	460.5	497.1	552.0	620.1	681.2	713.6	690.9	613.9	547.2	495.0	457.1
67.5°	385.0	413.5	455.0	509.6	561.6	579.1	558.4	504.9	448.3	406.6	379.9
70°	332.7	359.6	394.6	436.5	481.9	500.4	479.8	437.2	391.2	352.7	326.5
72.5°	287.1	307.8	337.4	373.2	408.7	427.3	413.3	372.3	333.4	304.8	282.5
75°	218.6	236.5	257.1	282.5	310.0	322.4	310.0	281.8	255.0	233.8	217.9
77.5°	158.9	168.6	184.5	203.5	220.7	230.1	219.5	200.4	184.0	169.4	161.5
80°	121.0	127.9	138.9	153.9	165.7	174.6	167.7	151.9	138.9	129.2	125.8
82.5°	88.0	92.6	99.8	111.1	118.9	123.5	120.5	109.0	103.7	95.1	91.7
85°	43.3	46.1	50.9	54.3	61.2	61.9	62.6	57.8	53.0	50.9	48.1
87.5°	15.6	16.4	18.4	20.4	22.9	23.7	23.4	23.6	21.7	21.3	19.3
90°	3.7	5.3	7.0	8.6	10.0	11.2	12.4	13.6	14.8	15.7	16.6
92.5°	8.6	8.7	8.8	8.9	9.5	10.7	11.9	13.1	14.3	15.2	16.1
95°	31.9	26.9	21.8	16.7	14.2	14.4	14.6	14.6	14.8	15.7	16.6
97.5°	81.8	85.0	88.2	91.4	84.6	67.8	51.1	34.4	17.7	17.8	18.0
100°	113.1	115.8	118.5	121.1	112.2	91.5	70.9	50.3	29.6	27.0	24.5
102.5°	147.9	149.9	151.9	153.9	153.5	150.8	148.1	145.4	142.8	115.3	87.8
105°	203.5	204.4	205.3	206.2	207.1	207.8	208.5	209.3	210.0	211.4	212.8
107.5°	255.7	256.1	256.7	257.1	257.8	258.8	259.8	260.9	261.9	262.5	263.2
110°	291.3	291.7	292.1	292.7	293.3	294.2	295.1	296.0	296.9	297.2	297.5





TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	275°	280°	285°	290°	295°	300°	305°	310°	315°	320°	325°
112.5°	326.1	326.9	327.7	328.6	329.2	329.6	329.9	330.4	330.8	330.8	330.7
115°	378.8	379.3	379.7	380.1	380.3	380.1	380.0	379.9	379.7	380.0	380.3
117.5°	426.7	427.3	427.9	428.5	429.0	429.3	429.6	430.0	430.3	430.2	430.2
120°	459.1	459.7	460.3	460.8	461.1	460.9	460.8	460.6	460.5	460.8	461.1
122.5°	489.0	489.3	489.7	490.1	490.3	490.5	490.8	490.9	491.2	491.4	491.5
125°	532.4	533.0	533.6	534.3	534.3	534.1	533.8	533.5	533.2	533.6	534.1
127.5°	572.9	573.1	573.3	573.3	573.8	574.5	575.1	575.8	576.5	576.4	576.4
130°	599.3	599.4	599.6	599.8	600.0	600.5	601.0	601.4	601.8	602.0	602.2
132.5°	623.6	624.0	624.2	624.5	624.9	625.4	626.0	626.5	627.2	627.3	627.5
135°	659.6	659.4	659.3	659.2	659.4	660.0	660.6	661.2	661.8	662.0	662.4
137.5°	692.0	692.1	692.1	692.2	692.5	693.2	693.9	694.5	695.2	695.5	695.8
140°	713.3	713.5	713.9	714.1	714.5	714.7	715.1	715.3	715.6	716.1	716.5
142.5°	732.3	732.9	733.4	733.9	734.3	734.4	734.7	734.9	735.0	735.4	735.6
145°	761.2	761.6	762.1	762.5	762.8	762.8	762.8	762.8	762.8	762.9	763.0
147.5°	784.6	785.4	786.3	787.1	787.5	787.3	787.1	787.0	786.9	787.0	787.1
150°	801.1	801.7	802.3	802.8	803.1	802.9	802.8	802.6	802.5	802.5	802.5
152.5°	814.9	815.4	815.9	816.4	816.5	816.2	816.0	815.6	815.4	815.6	815.9
155°	834.2	834.4	834.6	834.7	834.6	834.1	833.6	833.2	832.8	833.4	834.0
157.5°	850.6	850.5	850.4	850.3	850.0	849.5	849.0	848.5	848.0	848.8	849.5
160°	859.9	859.5	859.0	858.6	858.2	858.2	858.0	857.8	857.6	858.6	859.5
162.5°	868.4	867.8	867.3	866.7	866.3	866.2	866.1	865.9	865.7	866.7	867.5
165°	879.2	878.4	877.6	876.9	876.5	876.5	876.5	876.5	876.5	877.7	878.9
167.5°	887.7	886.9	886.1	885.4	884.9	884.8	884.8	884.7	884.6	885.9	887.3
170°	892.4	891.6	890.6	889.8	889.4	889.5	889.7	889.8	890.0	891.1	892.3
172.5°	895.7	894.8	893.9	893.0	892.6	892.8	892.9	893.0	893.2	894.4	895.6
175°	899.1	898.3	897.4	896.5	896.1	896.3	896.4	896.6	896.7	898.0	899.4
177.5°	900.9	900.0	899.1	898.4	898.0	898.3	898.5	898.8	899.0	899.9	901.0
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1	900.1



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	330°	335°	340°	345°	350°	355°	360°
0°	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5	1659.5
2.5°	1749.1	1750.2	1755.1	1759.0	1760.1	1765.6	1766.2
5°	1902.8	1914.5	1937.2	1939.2	1942.7	1960.6	1946.8
7.5°	2082.9	2112.6	2132.4	2149.9	2156.2	2164.0	2162.4
10°	2198.4	2242.4	2264.4	2299.5	2300.9	2309.8	2304.3
12.5°	2314.5	2365.6	2405.7	2412.2	2441.6	2446.2	2453.8
15°	2478.9	2533.1	2588.9	2608.8	2649.4	2659.0	2674.1
17.5°	2633.5	2689.0	2728.0	2779.6	2796.2	2818.5	2803.3
20°	2718.1	2778.6	2828.1	2868.7	2885.8	2898.2	2896.8
22.5°	2769.2	2830.3	2870.4	2901.1	2917.2	2922.4	2922.1
25°	2801.3	2836.3	2848.7	2860.4	2842.5	2836.3	2839.1
27.5°	2712.2	2703.1	2670.8	2628.5	2584.5	2549.5	2530.6
30°	2589.5	2535.9	2487.2	2401.8	2357.9	2331.8	2308.4
32.5°	2415.8	2330.8	2236.9	2158.8	2108.8	2070.0	2064.2
35°	2118.0	1990.1	1875.3	1779.8	1730.3	1688.3	1678.7
37.5°	1800.7	1667.8	1564.4	1480.3	1427.1	1397.6	1369.9
40°	1590.0	1475.9	1374.2	1302.7	1262.1	1240.8	1223.7
42.5°	1427.8	1323.6	1222.4	1167.9	1131.3	1118.2	1108.1
45°	1203.7	1106.7	1036.6	995.4	974.0	952.1	941.8
47.5°	1024.2	945.4	899.1	864.1	841.3	828.2	821.7
50°	922.6	857.9	816.7	789.9	769.2	758.9	753.5
52.5°	832.3	779.3	744.6	723.3	709.3	701.7	699.6
55°	717.0	676.4	654.4	635.8	625.6	618.7	616.0
57.5°	623.2	592.0	574.1	558.9	554.9	549.1	547.2
60°	561.6	537.6	522.5	512.1	508.7	501.8	503.2
62.5°	507.2	487.5	474.6	468.7	464.2	458.4	460.3
65°	429.0	414.5	407.7	402.2	396.7	393.2	396.0
67.5°	359.9	350.1	340.7	337.5	334.8	334.2	331.3
70°	314.9	306.6	298.3	296.3	296.3	293.5	292.8
72.5°	271.4	265.4	259.8	258.3	256.1	257.3	254.3
75°	209.7	204.8	202.8	200.7	200.0	200.0	197.9
77.5°	155.0	151.4	148.1	148.1	145.6	144.6	144.4
80°	117.5	116.1	113.4	113.4	112.0	112.7	111.3
82.5°	88.4	86.4	85.9	84.8	82.9	83.0	81.7
85°	47.4	45.4	44.7	42.6	41.2	42.6	41.2
87.5°	20.0	19.6	19.2	18.2	17.7	17.7	16.1
90°	17.5	18.4	19.0	19.3	19.6	19.9	20.2
92.5°	17.0	17.8	18.3	18.4	18.4	18.5	18.6
95°	17.5	18.4	18.9	19.1	19.2	19.4	19.5
97.5°	18.1	18.2	18.3	18.4	18.5	18.7	18.9
100°	22.0	19.5	18.3	18.4	18.5	18.7	18.9
102.5°	60.4	33.0	19.3	19.3	19.3	19.4	19.4
105°	214.0	215.4	213.4	208.0	202.6	197.3	191.8
107.5°	263.8	264.5	265.1	265.7	266.2	266.8	267.4
110°	297.8	298.1	298.4	298.9	299.4	299.8	300.2



TEST NUMBER: P332688-935

CATALOG NUMBER: S124DIP-S1195D810U935-4F0-1E-UDD-A

**CANDELA DISTRIBUTION (continued):**

	330°	335°	340°	345°	350°	355°	360°
112.5°	330.6	330.5	330.8	331.4	332.0	332.5	333.1
115°	380.6	380.9	381.1	381.1	381.1	381.1	381.1
117.5°	430.2	430.1	430.0	430.0	429.9	429.8	429.8
120°	461.4	461.7	461.7	461.4	461.1	460.8	460.5
122.5°	491.7	491.9	491.8	491.5	491.2	490.9	490.6
125°	534.5	534.9	535.3	535.5	535.5	535.7	535.9
127.5°	576.3	576.2	576.1	575.9	575.8	575.8	575.6
130°	602.3	602.4	602.5	602.5	602.5	602.5	602.5
132.5°	627.6	627.8	627.8	627.7	627.5	627.4	627.3
135°	662.6	663.0	663.2	663.6	663.8	664.2	664.4
137.5°	696.1	696.5	696.5	696.5	696.4	696.3	696.2
140°	717.0	717.4	717.7	717.9	718.0	718.2	718.3
142.5°	736.0	736.3	736.5	736.5	736.6	736.6	736.6
145°	763.2	763.4	763.5	763.9	764.1	764.5	764.7
147.5°	787.2	787.3	787.5	787.6	787.7	787.9	788.1
150°	802.5	802.5	802.5	802.7	802.8	803.0	803.1
152.5°	816.1	816.3	816.4	816.3	816.2	816.1	816.1
155°	834.6	835.2	835.3	834.7	834.3	833.9	833.4
157.5°	850.3	851.1	851.1	850.3	849.5	848.8	848.0
160°	860.4	861.3	861.3	860.4	859.5	858.6	857.6
162.5°	868.4	869.4	869.3	868.2	867.2	866.3	865.2
165°	880.1	881.3	881.2	879.9	878.6	877.2	875.8
167.5°	888.6	889.8	889.8	888.3	886.7	885.3	883.8
170°	893.5	894.8	894.6	893.1	891.7	890.1	888.6
172.5°	896.8	898.0	897.8	896.2	894.6	892.9	891.3
175°	900.8	902.1	901.9	900.1	898.3	896.5	894.7
177.5°	901.9	902.8	902.6	901.1	899.7	898.3	896.8
180°	900.1	900.1	900.1	900.1	900.1	900.1	900.1

(END OF REPORT)