

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P902167

Luminaire Tested: DFN2DIP-4P2F0-040D030US830-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P902167
REPORT IS A COMBINATION OF REPORTS P900541 AND P897455
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P2F0-040D030US830-FLLONL
Description: 2 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6531.8 lumens
Efficiency: N/A
Efficacy: 102.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.07' x L: 2.07' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 63.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.983
Total Harmonic Distortion (THDi): 0.073
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	109	109	109	109	101	101	101	101	87	87	87	74	74	74	63	63	63
1	99	95	91	88	92	89	85	82	77	74	72	66	64	62	55	54	53
2	91	83	77	72	84	77	72	67	67	63	59	58	55	52	49	47	45
3	83	73	66	60	77	68	62	56	59	54	50	51	47	44	43	40	38
4	76	65	57	50	70	61	53	48	53	47	43	45	41	38	39	35	33
5	69	58	49	43	64	54	47	41	47	41	37	41	36	33	35	31	29
6	64	52	44	38	59	49	41	36	43	37	32	37	32	29	32	28	25
7	59	47	39	33	55	44	37	31	39	33	28	34	29	25	29	25	22
8	55	43	35	29	51	40	33	28	35	29	25	31	26	23	27	23	20
9	51	39	31	26	48	37	30	25	32	27	23	28	24	20	25	21	18
10	48	36	28	24	45	34	27	22	30	24	20	26	22	18	23	19	17

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3673	3673	3673
5°	3672	3613	3640
10°	3635	3555	3585
15°	3574	3487	3502
20°	3494	3397	3417
25°	3415	3290	3320
30°	3317	3190	3198
35°	3224	3074	3070
40°	3111	2957	2947
45°	2998	2838	2821
50°	2873	2714	2676
55°	2743	2570	2541
60°	2595	2401	2386
65°	2432	2224	2205
70°	2225	2009	2007
75°	1943	1751	1816
80°	1598	1422	1470
85°	1070	888	915

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2998 cd/sqm

TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	138.1	2.1
10°-20°	388.5	5.9
20°-30°	570.9	8.7
30°-40°	663.1	10.2
40°-50°	662.3	10.1
50°-60°	577.5	8.8
60°-70°	426.9	6.5
70°-80°	241.5	3.7
80°-90°	65.4	1.0
90°-100°	31.5	0.5
100°-110°	117.3	1.8
110°-120°	311.1	4.8
120°-130°	516.0	7.9
130°-140°	548.1	8.4
140°-150°	509.4	7.8
150°-160°	409.6	6.3
160°-170°	263.9	4.0
170°-180°	90.8	1.4
0°-30°	1097.5	16.8
0°-40°	1760.6	27.0
0°-60°	3000.3	45.9
0°-90°	3734.1	57.2
90°-120°	459.9	7.0
90°-150°	2033.4	31.1
90°-180°	2798.0	42.8
0°-180°	6531.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1467	1467	1467	1467	1467	
5°	1467	1461	1446	1457	1454	139
15°	1396	1388	1370	1375	1368	393
25°	1264	1253	1229	1231	1229	582
35°	1090	1076	1054	1045	1038	681
45°	887	878	856	841	835	685
55°	672	663	646	629	622	600
65°	453	444	430	418	411	448
75°	237	234	227	219	222	253
85°	58	56	55	51	49	64
90°	1	8	14	17	19	6
95°	45	22	27	30	30	53
105°	210	231	42	50	52	224
115°	397	409	426	106	57	391
125°	561	570	584	588	590	501
135°	695	706	712	719	718	537
145°	806	805	817	822	818	504
155°	887	881	889	894	888	409
165°	935	931	933	938	933	264
175°	956	952	953	958	951	91
180°	954	954	954	954	954	

TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1467.0	1467.0	1467.0	1467.0	1467.0
2.5°	1475.5	1468.5	1452.9	1467.0	1464.3
5°	1467.0	1461.4	1445.9	1457.1	1454.4
7.5°	1457.1	1448.7	1433.1	1444.5	1441.7
10°	1441.7	1431.8	1414.9	1426.2	1421.9
12.5°	1420.4	1412.0	1395.2	1402.2	1399.3
15°	1396.5	1388.1	1369.7	1375.4	1368.4
17.5°	1366.9	1358.5	1340.1	1347.1	1340.1
20°	1334.4	1326.0	1306.3	1310.4	1304.9
22.5°	1302.0	1289.3	1270.9	1270.9	1268.1
25°	1263.9	1252.6	1228.7	1231.4	1228.7
27.5°	1221.5	1211.6	1193.4	1189.2	1182.2
30°	1179.3	1168.0	1146.9	1142.6	1137.0
32.5°	1134.2	1125.8	1103.2	1094.7	1088.9
35°	1090.4	1076.4	1053.8	1045.3	1038.2
37.5°	1041.0	1028.3	1005.7	995.9	988.8
40°	990.3	978.9	956.3	943.8	938.1
42.5°	940.9	929.5	907.1	892.9	884.5
45°	887.3	877.5	856.2	840.8	835.1
47.5°	835.1	825.2	802.7	787.1	778.7
50°	780.0	773.0	753.3	733.5	726.4
52.5°	726.4	716.6	698.3	682.8	672.9
55°	671.6	663.0	646.1	629.1	622.2
57.5°	616.4	609.4	591.0	574.1	568.4
60°	561.4	555.8	536.1	520.6	516.3
62.5°	507.8	497.9	483.9	469.8	464.1
65°	452.9	444.3	430.3	417.5	410.6
67.5°	396.4	389.3	376.7	366.8	361.2
70°	344.2	338.6	325.8	315.9	310.4
72.5°	290.7	284.9	278.0	268.1	263.8
75°	237.0	234.2	227.1	218.7	221.5
77.5°	189.0	183.3	180.5	176.3	172.1
80°	141.1	139.6	136.8	132.6	129.8
82.5°	96.0	96.0	94.6	88.9	88.9
85°	57.8	56.5	55.0	50.7	49.4
87.5°	25.4	22.6	19.8	15.6	14.0
90°	0.7	8.3	13.8	17.3	18.6
92.5°	17.3	14.5	16.6	18.0	18.6
95°	44.9	22.1	26.9	30.4	29.7
97.5°	80.8	24.2	35.2	37.3	38.0
100°	122.2	27.6	39.4	44.9	46.3
102.5°	167.8	166.5	40.7	48.3	50.4
105°	209.9	230.6	42.1	49.7	52.5
107.5°	258.9	276.2	43.5	51.1	53.9
110°	305.9	320.4	120.8	51.8	54.6

TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	350.2	362.5	350.8	53.2	55.2
115°	397.0	408.8	426.0	106.3	56.6
117.5°	437.8	451.6	463.4	364.6	183.7
120°	483.3	493.7	506.1	514.4	421.2
122.5°	522.0	533.1	547.0	551.0	551.8
125°	561.4	570.3	583.5	588.3	590.4
127.5°	597.3	606.9	617.4	624.2	624.9
130°	631.1	642.2	649.8	657.3	656.8
132.5°	665.6	674.7	682.2	688.4	687.8
135°	694.7	705.8	711.9	718.9	717.5
137.5°	725.0	733.3	740.3	747.2	745.1
140°	754.7	760.3	767.8	774.0	770.6
142.5°	779.7	784.5	793.4	798.9	795.5
145°	805.9	805.1	816.9	821.7	818.2
147.5°	828.6	826.5	838.3	841.7	839.0
150°	850.7	845.9	857.0	861.0	857.6
152.5°	869.3	863.8	874.2	878.4	873.5
155°	887.3	881.2	889.4	893.5	888.1
157.5°	901.8	896.4	902.6	907.4	901.8
160°	914.3	910.1	914.3	918.4	913.5
162.5°	925.3	921.1	924.6	929.4	923.2
165°	934.9	930.9	932.9	937.7	932.9
167.5°	942.5	938.4	940.5	945.4	939.1
170°	948.8	944.6	946.0	950.8	944.6
172.5°	952.9	948.8	950.2	955.0	948.8
175°	956.3	951.5	952.9	957.7	950.8
177.5°	957.7	952.9	953.7	958.5	952.3
180°	954.3	954.3	954.3	954.3	954.3

TEST NUMBER: P902167

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US830-FLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.29	13.22	13.19	14.14	15.30	11.85	12.78	12.74	13.69	14.86
	3H	13.94	14.77	14.84	15.69	16.88	13.45	14.28	14.35	15.20	16.39
	4H	14.51	15.30	15.43	16.23	17.43	14.02	14.81	14.94	15.74	16.94
	6H	14.90	15.63	15.83	16.56	17.77	14.40	15.13	15.33	16.06	17.27
	8H	15.00	15.69	15.94	16.64	17.85	14.50	15.19	15.44	16.14	17.35
	12H	15.04	15.70	15.98	16.64	17.88	14.53	15.19	15.48	16.14	17.37
4H	2H	12.75	13.54	13.68	14.47	15.67	12.40	13.18	13.32	14.11	15.31
	3H	14.60	15.26	15.53	16.21	17.43	14.19	14.85	15.12	15.81	17.02
	4H	15.30	15.90	16.24	16.85	18.09	14.87	15.47	15.82	16.43	17.67
	6H	15.79	16.31	16.75	17.29	18.53	15.36	15.88	16.32	16.86	18.10
	8H	15.93	16.42	16.89	17.39	18.64	15.50	15.98	16.46	16.95	18.20
	12H	16.00	16.44	16.98	17.42	18.68	15.55	15.99	16.53	16.98	18.23
8H	4H	15.48	15.97	16.45	16.94	18.19	15.11	15.59	16.07	16.56	17.81
	6H	16.09	16.49	17.08	17.50	18.76	15.71	16.11	16.69	17.12	18.37
	8H	16.30	16.65	17.29	17.65	18.92	15.90	16.26	16.90	17.26	18.53
	12H	16.42	16.73	17.42	17.72	19.04	16.01	16.32	17.01	17.31	18.63
12H	4H	15.47	15.91	16.45	16.90	18.15	15.10	15.54	16.08	16.53	17.78
	6H	16.12	16.47	17.11	17.47	18.74	15.74	16.10	16.74	17.10	18.37
	8H	16.34	16.66	17.34	17.65	18.97	15.96	16.27	16.96	17.27	18.58