

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P921259

Luminaire Tested: DFN2DIP-4P2F0-040D020US940-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P921259
REPORT IS A COMBINATION OF REPORTS P900535 AND P897455
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P2F0-040D020US940-FLLONL
Description: 2 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5296.8 lumens
Efficiency: N/A
Efficacy: 94.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.07' x L: 2.07' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 56.1
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.983
Total Harmonic Distortion (THDi): 0.073
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	111	111	111	111	105	105	105	105	93	93	93	82	82	82	71	71	71
1	102	97	93	90	95	92	88	85	81	79	76	72	70	68	63	62	60
2	92	85	79	73	87	80	75	70	71	67	63	63	60	57	56	53	51
3	84	75	67	61	79	71	64	58	63	58	53	56	52	48	49	46	43
4	77	66	58	52	72	63	55	50	56	50	45	50	45	41	44	40	37
5	71	59	51	44	67	56	48	43	50	44	39	45	40	36	40	36	33
6	66	53	45	39	62	50	43	37	45	39	34	41	35	32	36	32	29
7	61	48	40	34	57	46	38	33	41	35	30	37	32	28	33	29	26
8	56	44	36	30	53	42	34	29	38	31	27	34	29	25	30	26	23
9	53	40	32	27	50	38	31	26	35	29	24	31	26	23	28	24	21
10	49	37	29	24	46	35	28	24	32	26	22	29	24	20	26	22	19

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3475	3475	3475
5°	3474	3418	3444
10°	3439	3363	3391
15°	3381	3299	3313
20°	3306	3213	3233
25°	3231	3113	3141
30°	3138	3018	3026
35°	3050	2908	2904
40°	2943	2797	2788
45°	2836	2685	2669
50°	2719	2568	2531
55°	2595	2432	2404
60°	2455	2272	2258
65°	2301	2104	2086
70°	2105	1901	1898
75°	1838	1656	1718
80°	1512	1345	1390
85°	1013	841	865

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2836 cd/sqm

TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	130.6	2.5
10°-20°	367.5	6.9
20°-30°	540.1	10.2
30°-40°	627.3	11.8
40°-50°	626.6	11.8
50°-60°	546.3	10.3
60°-70°	403.9	7.6
70°-80°	228.5	4.3
80°-90°	61.4	1.2
90°-100°	19.8	0.4
100°-110°	74.0	1.4
110°-120°	196.2	3.7
120°-130°	325.4	6.1
130°-140°	345.7	6.5
140°-150°	321.3	6.1
150°-160°	258.3	4.9
160°-170°	166.4	3.1
170°-180°	57.3	1.1
0°-30°	1038.3	19.6
0°-40°	1665.6	31.4
0°-60°	2838.5	53.6
0°-90°	3532.3	66.7
90°-120°	290.0	5.5
90°-150°	1282.5	24.2
90°-180°	1765.0	33.3
0°-180°	5296.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1388	1388	1388	1388	1388	
5°	1388	1383	1368	1378	1376	132
15°	1321	1313	1296	1301	1295	372
25°	1196	1185	1162	1165	1162	550
35°	1032	1018	997	989	982	644
45°	840	830	810	796	790	648
55°	635	627	611	595	589	568
65°	428	420	407	395	388	424
75°	224	222	215	207	210	239
85°	55	53	52	48	47	61
90°	0	5	9	11	12	5
95°	28	14	17	19	19	33
105°	132	145	27	31	33	141
115°	250	258	269	67	36	247
125°	354	360	368	371	372	316
135°	438	445	449	453	452	338
145°	508	508	515	518	516	318
155°	560	556	561	564	560	258
165°	590	587	588	592	588	167
175°	603	600	601	604	600	57
180°	602	602	602	602	602	

TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1387.9	1387.9	1387.9	1387.9	1387.9
2.5°	1396.0	1389.3	1374.6	1387.9	1385.4
5°	1387.9	1382.6	1367.9	1378.5	1376.0
7.5°	1378.5	1370.6	1355.8	1366.6	1364.0
10°	1364.0	1354.6	1338.6	1349.2	1345.2
12.5°	1343.8	1335.9	1319.9	1326.6	1323.8
15°	1321.2	1313.2	1295.8	1301.2	1294.6
17.5°	1293.2	1285.2	1267.8	1274.4	1267.8
20°	1262.4	1254.5	1235.8	1239.7	1234.6
22.5°	1231.8	1219.8	1202.4	1202.4	1199.7
25°	1195.7	1185.1	1162.4	1165.0	1162.4
27.5°	1155.7	1146.3	1129.1	1125.1	1118.5
30°	1115.7	1105.0	1085.0	1081.0	1075.7
32.5°	1073.0	1065.1	1043.7	1035.6	1030.2
35°	1031.6	1018.3	996.9	988.9	982.2
37.5°	984.9	972.9	951.5	942.2	935.5
40°	936.9	926.1	904.7	892.9	887.5
42.5°	890.2	879.4	858.2	844.7	836.8
45°	839.5	830.2	810.0	795.5	790.1
47.5°	790.1	780.7	759.4	744.7	736.7
50°	738.0	731.3	712.7	693.9	687.2
52.5°	687.2	678.0	660.7	646.0	636.6
55°	635.3	627.2	611.3	595.2	588.6
57.5°	583.2	576.6	559.1	543.1	537.8
60°	531.1	525.8	507.2	492.5	488.5
62.5°	480.5	471.1	457.8	444.4	439.1
65°	428.5	420.4	407.1	395.0	388.4
67.5°	375.1	368.3	356.4	347.1	341.7
70°	325.7	320.3	308.3	298.9	293.6
72.5°	275.0	269.6	263.0	253.6	249.6
75°	224.2	221.6	214.8	206.9	209.6
77.5°	178.8	173.4	170.8	166.7	162.8
80°	133.5	132.1	129.4	125.5	122.8
82.5°	90.8	90.8	89.5	84.1	84.1
85°	54.7	53.4	52.1	48.0	46.7
87.5°	24.1	21.4	18.7	14.7	13.3
90°	0.4	5.3	8.6	10.9	11.8
92.5°	10.9	9.2	10.4	11.3	11.8
95°	28.3	13.9	16.9	19.2	18.7
97.5°	50.9	15.2	22.2	23.5	24.0
100°	77.1	17.4	24.8	28.3	29.2
102.5°	105.8	105.0	25.7	30.5	31.8
105°	132.4	145.4	26.6	31.3	33.1
107.5°	163.4	174.2	27.5	32.2	34.0
110°	193.0	202.1	76.2	32.7	34.4



TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	220.8	228.6	221.2	33.5	34.9
115°	250.4	257.8	268.8	67.1	35.8
117.5°	276.1	284.8	292.2	230.0	115.8
120°	304.9	311.4	319.2	324.5	265.6
122.5°	329.2	336.2	344.9	347.5	348.0
125°	354.1	359.7	368.0	371.0	372.4
127.5°	376.7	382.8	389.4	393.7	394.1
130°	398.1	405.0	409.8	414.6	414.2
132.5°	419.8	425.5	430.3	434.2	433.8
135°	438.2	445.1	449.0	453.4	452.5
137.5°	457.3	462.5	466.9	471.3	469.9
140°	476.0	479.6	484.3	488.2	486.1
142.5°	491.7	494.8	500.4	503.9	501.7
145°	508.3	507.8	515.2	518.3	516.1
147.5°	522.6	521.3	528.7	530.8	529.1
150°	536.5	533.5	540.5	543.1	540.9
152.5°	548.3	544.8	551.3	554.0	550.9
155°	559.6	555.7	561.0	563.6	560.1
157.5°	568.8	565.3	569.3	572.3	568.8
160°	576.7	574.0	576.7	579.3	576.2
162.5°	583.5	580.9	583.2	586.2	582.3
165°	589.7	587.1	588.4	591.5	588.4
167.5°	594.5	591.8	593.2	596.3	592.3
170°	598.4	595.8	596.6	599.7	595.8
172.5°	601.0	598.4	599.3	602.4	598.4
175°	603.2	600.1	601.0	604.0	599.7
177.5°	604.0	601.0	601.5	604.5	600.6
180°	601.9	601.9	601.9	601.9	601.9

TEST NUMBER: P921259

CATALOG NUMBER: DFN2DIP-4P2F0-040D020US940-FLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.88	13.91	13.68	14.74	15.75	12.43	13.47	13.23	14.29	15.30
	3H	14.53	15.46	15.34	16.29	17.33	14.04	14.97	14.85	15.80	16.84
	4H	15.11	15.99	15.94	16.83	17.88	14.62	15.49	15.44	16.33	17.38
	6H	15.50	16.31	16.34	17.16	18.22	15.00	15.81	15.84	16.66	17.72
	8H	15.60	16.37	16.45	17.24	18.30	15.10	15.87	15.95	16.74	17.80
	12H	15.65	16.38	16.50	17.24	18.33	15.14	15.87	16.00	16.73	17.82
4H	2H	13.35	14.23	14.18	15.06	16.12	12.99	13.87	13.83	14.71	15.76
	3H	15.20	15.94	16.05	16.81	17.87	14.79	15.53	15.64	16.40	17.47
	4H	15.91	16.57	16.76	17.44	18.54	15.48	16.15	16.34	17.02	18.11
	6H	16.41	16.99	17.28	17.88	18.98	15.98	16.55	16.85	17.45	18.54
	8H	16.55	17.09	17.43	17.98	19.09	16.11	16.65	16.99	17.54	18.65
	12H	16.62	17.11	17.52	18.02	19.13	16.17	16.66	17.07	17.57	18.68
8H	4H	16.10	16.64	16.98	17.53	18.64	15.72	16.26	16.60	17.15	18.26
	6H	16.71	17.16	17.62	18.09	19.20	16.33	16.77	17.23	17.71	18.82
	8H	16.92	17.32	17.84	18.24	19.37	16.53	16.92	17.44	17.85	18.97
	12H	17.04	17.39	17.96	18.31	19.49	16.63	16.98	17.55	17.90	19.08
12H	4H	16.09	16.58	16.99	17.49	18.60	15.72	16.21	16.62	17.12	18.23
	6H	16.74	17.14	17.65	18.06	19.19	16.36	16.76	17.28	17.69	18.81
	8H	16.97	17.32	17.89	18.24	19.42	16.59	16.94	17.51	17.85	19.03

END OF REPORT