

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P921262

Luminaire Tested: DFN2DIP-4P2F0-040D030US940-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P921262
REPORT IS A COMBINATION OF REPORTS P899021 AND P895899
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P2F0-040D030US940-FLLFLL
Description: 2 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5898.7 lumens
Efficiency: N/A
Efficacy: 92.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.07' x L: 2.07' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 63.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.983
Total Harmonic Distortion (THDi): 0.073
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	102	102	102	102	89	89	89	77	77	77	65	65	65
1	100	96	92	88	93	89	86	83	78	75	73	67	66	64	58	56	55
2	91	84	77	72	85	78	73	68	68	64	61	59	56	53	51	48	46
3	83	73	66	60	77	69	62	57	60	55	51	52	48	45	45	42	40
4	76	65	57	51	71	61	54	48	54	48	43	47	42	39	40	37	34
5	70	58	50	44	65	55	47	42	48	42	38	42	37	34	36	33	30
6	64	52	44	38	60	49	42	36	43	37	33	38	33	29	33	29	26
7	60	47	39	33	56	44	37	32	39	33	29	35	30	26	30	26	23
8	55	43	35	30	52	40	33	28	36	30	26	32	27	23	28	24	21
9	52	39	32	26	48	37	30	25	33	27	23	29	24	21	26	22	19
10	48	36	29	24	45	34	27	23	30	25	21	27	22	19	24	20	17

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3475	3475	3475
5°	3474	3418	3444
10°	3439	3363	3391
15°	3381	3299	3313
20°	3306	3213	3233
25°	3231	3113	3141
30°	3138	3018	3026
35°	3050	2908	2904
40°	2943	2797	2788
45°	2836	2685	2669
50°	2719	2568	2531
55°	2595	2432	2404
60°	2455	2272	2258
65°	2301	2104	2086
70°	2105	1901	1898
75°	1838	1656	1718
80°	1512	1345	1390
85°	1013	841	865

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2836 cd/sqm

TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	130.6	2.2
10°-20°	367.5	6.2
20°-30°	540.1	9.2
30°-40°	627.3	10.6
40°-50°	626.6	10.6
50°-60°	546.3	9.3
60°-70°	403.9	6.8
70°-80°	228.5	3.9
80°-90°	62.7	1.1
90°-100°	52.3	0.9
100°-110°	166.3	2.8
110°-120°	284.7	4.8
120°-130°	374.4	6.3
130°-140°	420.2	7.1
140°-150°	412.1	7.0
150°-160°	345.7	5.9
160°-170°	229.2	3.9
170°-180°	80.1	1.4
0°-30°	1038.3	17.6
0°-40°	1665.6	28.2
0°-60°	2838.5	48.1
0°-90°	3533.6	59.9
90°-120°	503.4	8.5
90°-150°	1710.0	29.0
90°-180°	2365.0	40.1
0°-180°	5898.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1388	1388	1388	1388	1388	
5°	1388	1383	1368	1378	1376	132
15°	1321	1313	1296	1301	1295	372
25°	1196	1185	1162	1165	1162	550
35°	1032	1018	997	989	982	644
45°	840	830	810	796	790	648
55°	635	627	611	595	589	568
65°	428	420	407	395	388	424
75°	224	222	215	207	210	239
85°	55	53	52	48	47	61
90°	1	9	25	24	24	6
95°	37	44	46	46	44	41
105°	154	156	157	158	158	162
115°	286	290	288	288	286	283
125°	416	422	420	418	417	371
135°	537	545	547	546	544	415
145°	652	658	662	662	660	408
155°	746	748	750	754	752	343
165°	812	811	811	816	812	229
175°	844	842	841	846	842	80
180°	846	846	846	846	846	

TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1387.9	1387.9	1387.9	1387.9	1387.9
2.5°	1396.0	1389.3	1374.6	1387.9	1385.4
5°	1387.9	1382.6	1367.9	1378.5	1376.0
7.5°	1378.5	1370.6	1355.8	1366.6	1364.0
10°	1364.0	1354.6	1338.6	1349.2	1345.2
12.5°	1343.8	1335.9	1319.9	1326.6	1323.8
15°	1321.2	1313.2	1295.8	1301.2	1294.6
17.5°	1293.2	1285.2	1267.8	1274.4	1267.8
20°	1262.4	1254.5	1235.8	1239.7	1234.6
22.5°	1231.8	1219.8	1202.4	1202.4	1199.7
25°	1195.7	1185.1	1162.4	1165.0	1162.4
27.5°	1155.7	1146.3	1129.1	1125.1	1118.5
30°	1115.7	1105.0	1085.0	1081.0	1075.7
32.5°	1073.0	1065.1	1043.7	1035.6	1030.2
35°	1031.6	1018.3	996.9	988.9	982.2
37.5°	984.9	972.9	951.5	942.2	935.5
40°	936.9	926.1	904.7	892.9	887.5
42.5°	890.2	879.4	858.2	844.7	836.8
45°	839.5	830.2	810.0	795.5	790.1
47.5°	790.1	780.7	759.4	744.7	736.7
50°	738.0	731.3	712.7	693.9	687.2
52.5°	687.2	678.0	660.7	646.0	636.6
55°	635.3	627.2	611.3	595.2	588.6
57.5°	583.2	576.6	559.1	543.1	537.8
60°	531.1	525.8	507.2	492.5	488.5
62.5°	480.5	471.1	457.8	444.4	439.1
65°	428.5	420.4	407.1	395.0	388.4
67.5°	375.1	368.3	356.4	347.1	341.7
70°	325.7	320.3	308.3	298.9	293.6
72.5°	275.0	269.6	263.0	253.6	249.6
75°	224.2	221.6	214.8	206.9	209.6
77.5°	178.8	173.4	170.8	166.7	162.8
80°	133.5	132.1	129.4	125.5	122.8
82.5°	90.8	90.8	89.5	84.1	84.1
85°	54.7	53.4	52.1	48.0	46.7
87.5°	24.1	21.4	18.7	14.7	13.3
90°	0.8	9.2	25.0	23.5	24.3
92.5°	15.8	21.4	22.2	22.9	22.9
95°	37.3	44.4	45.7	45.7	44.4
97.5°	62.0	68.6	71.4	71.4	71.4
100°	90.5	96.4	98.4	98.4	97.7
102.5°	120.6	125.0	127.8	128.6	127.8
105°	153.6	155.6	157.1	158.4	158.4
107.5°	186.2	189.2	189.2	189.8	186.2
110°	217.8	221.9	221.9	221.9	219.9

TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	252.0	256.4	255.6	253.5	252.0
115°	285.7	289.7	288.5	287.8	285.7
117.5°	319.1	324.7	321.1	319.1	317.0
120°	352.8	358.4	352.8	352.8	350.4
122.5°	383.3	390.5	386.9	384.9	383.3
125°	415.5	421.9	419.8	417.5	416.8
127.5°	446.8	454.8	452.0	448.9	446.8
130°	476.2	485.4	484.1	482.6	479.7
132.5°	509.1	516.2	516.7	513.2	511.1
135°	537.4	545.3	546.9	546.1	544.0
137.5°	569.0	575.4	576.7	576.2	573.1
140°	596.8	603.2	606.8	606.8	604.0
142.5°	625.4	631.8	633.8	634.6	631.8
145°	652.5	657.5	661.6	662.4	659.6
147.5°	676.7	683.1	686.1	687.4	684.6
150°	701.7	706.1	708.8	711.1	708.8
152.5°	723.9	728.2	731.7	734.6	731.7
155°	746.1	748.1	750.4	753.9	751.7
157.5°	765.2	766.7	768.0	773.1	769.5
160°	782.3	783.8	784.6	788.9	785.9
162.5°	798.1	798.1	798.9	803.7	800.1
165°	811.6	810.8	810.8	815.9	812.3
167.5°	823.9	821.5	821.5	826.6	823.0
170°	833.0	831.0	830.3	835.4	831.0
172.5°	839.4	837.4	836.6	841.7	837.4
175°	844.5	842.5	841.0	846.1	841.7
177.5°	847.3	845.3	843.7	848.1	843.7
180°	846.1	846.1	846.1	846.1	846.1

TEST NUMBER: P921262

CATALOG NUMBER: DFN2DIP-4P2F0-040D030US940-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.33	13.29	13.20	14.18	15.30	11.89	12.84	12.75	13.73	14.86
	3H	13.98	14.84	14.86	15.73	16.88	13.49	14.35	14.37	15.24	16.39
	4H	14.55	15.37	15.45	16.27	17.43	14.06	14.87	14.95	15.78	16.93
	6H	14.94	15.69	15.85	16.60	17.77	14.44	15.19	15.35	16.10	17.27
	8H	15.04	15.75	15.95	16.68	17.85	14.54	15.25	15.45	16.18	17.35
	12H	15.08	15.76	16.00	16.68	17.88	14.57	15.25	15.49	16.18	17.37
4H	2H	12.79	13.60	13.69	14.51	15.67	12.44	13.25	13.34	14.15	15.31
	3H	14.64	15.32	15.55	16.25	17.43	14.23	14.91	15.14	15.84	17.02
	4H	15.34	15.96	16.26	16.89	18.09	14.92	15.53	15.84	16.47	17.66
	6H	15.84	16.37	16.77	17.33	18.53	15.41	15.94	16.34	16.90	18.09
	8H	15.98	16.48	16.92	17.43	18.64	15.54	16.04	16.48	16.99	18.20
	12H	16.05	16.50	17.00	17.46	18.68	15.60	16.05	16.56	17.02	18.23
8H	4H	15.53	16.03	16.47	16.98	18.19	15.15	15.65	16.09	16.60	17.81
	6H	16.14	16.55	17.10	17.54	18.75	15.75	16.17	16.72	17.16	18.37
	8H	16.34	16.71	17.32	17.69	18.92	15.95	16.32	16.92	17.30	18.53
	12H	16.47	16.79	17.44	17.76	19.04	16.05	16.38	17.03	17.35	18.63
12H	4H	15.52	15.97	16.48	16.93	18.15	15.15	15.60	16.11	16.56	17.78
	6H	16.16	16.53	17.14	17.51	18.74	15.79	16.16	16.76	17.14	18.37
	8H	16.39	16.71	17.37	17.69	18.97	16.01	16.33	16.99	17.31	18.58