

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P902261

Luminaire Tested: DFN2DIP-4P3F0-060D030US830-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P902261
REPORT IS A COMBINATION OF REPORTS P900568 AND P897473
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P3F0-060D030US830-RLLONL
Description: 3 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7606.3 lumens
Efficiency: N/A
Efficacy: 90.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.07' x L: 3.07' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 84.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9963
Total Harmonic Distortion (THDi): 0.065
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	91	91	91	79	79	79	68	68	68
1	101	97	93	90	95	91	88	85	80	78	76	71	69	67	61	60	59
2	93	86	80	75	87	81	75	71	71	67	64	63	60	57	55	52	51
3	85	76	69	63	80	72	65	60	63	58	54	56	52	49	49	46	44
4	78	68	60	54	73	64	57	52	57	51	47	50	46	43	44	41	38
5	72	61	53	47	67	57	50	45	51	45	41	46	41	37	40	37	34
6	67	55	47	41	62	52	45	39	46	41	36	41	37	33	37	33	30
7	62	50	42	36	58	47	40	35	42	36	32	38	33	30	34	30	27
8	58	45	38	32	54	43	36	31	39	33	29	35	30	27	31	27	24
9	54	42	34	29	51	40	33	28	36	30	26	32	27	24	29	25	22
10	50	38	31	26	47	37	30	25	33	28	24	30	25	22	27	23	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2664	2664	2664
5°	2666	2620	2637
10°	2638	2567	2551
15°	2600	2480	2417
20°	2550	2361	2254
25°	2500	2229	2096
30°	2432	2093	1896
35°	2365	1947	1720
40°	2297	1796	1519
45°	2219	1630	1337
50°	2137	1461	1159
55°	2052	1282	988
60°	1953	1094	812
65°	1840	903	730
70°	1701	725	660
75°	1528	636	598
80°	1277	528	516
85°	866	344	383

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 2219 cd/sqm

TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	219.1	2.9
10°-20°	601.3	7.9
20°-30°	844.3	11.1
30°-40°	920.3	12.1
40°-50°	845.9	11.1
50°-60°	664.3	8.7
60°-70°	432.4	5.7
70°-80°	222.6	2.9
80°-90°	58.5	0.8
90°-100°	31.5	0.4
100°-110°	117.3	1.5
110°-120°	311.1	4.1
120°-130°	516.0	6.8
130°-140°	548.1	7.2
140°-150°	509.4	6.7
150°-160°	409.6	5.4
160°-170°	263.9	3.5
170°-180°	90.8	1.2
0°-30°	1664.7	21.9
0°-40°	2585.0	34.0
0°-60°	4095.1	53.8
0°-90°	4808.6	63.2
90°-120°	459.9	6.0
90°-150°	2033.4	26.7
90°-180°	2798.0	36.8
0°-180°	7606.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2337	2337	2337	2337	2337	
5°	2337	2327	2299	2318	2312	222
15°	2223	2200	2128	2088	2067	626
25°	2018	1950	1811	1724	1692	928
35°	1739	1631	1445	1312	1265	1088
45°	1421	1280	1058	907	857	1098
55°	1081	916	687	561	520	966
65°	730	558	368	296	290	724
75°	389	241	169	154	152	412
85°	91	46	40	40	40	104
90°	1	8	14	17	19	7
95°	45	22	27	30	30	53
105°	210	231	42	50	52	224
115°	397	409	426	106	57	391
125°	561	570	584	588	590	501
135°	695	706	712	719	718	537
145°	806	805	817	822	818	504
155°	887	881	889	894	888	409
165°	935	931	933	938	933	264
175°	956	952	953	958	951	91
180°	954	954	954	954	954	

TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2337.3	2337.3	2337.3	2337.3	2337.3
2.5°	2347.9	2337.3	2313.9	2335.2	2331.0
5°	2337.3	2326.8	2299.1	2318.3	2312.0
7.5°	2318.3	2305.6	2276.1	2284.3	2273.8
10°	2292.8	2278.0	2235.9	2229.4	2216.8
12.5°	2261.3	2242.1	2184.9	2172.4	2149.0
15°	2223.1	2199.7	2127.9	2087.7	2066.6
17.5°	2178.7	2144.8	2055.9	2009.4	1975.6
20°	2127.9	2085.5	1979.8	1927.0	1880.4
22.5°	2072.9	2024.2	1901.5	1829.7	1798.0
25°	2018.0	1950.2	1810.6	1724.0	1692.1
27.5°	1952.5	1880.4	1726.0	1626.5	1577.9
30°	1882.6	1802.0	1632.9	1525.1	1467.9
32.5°	1814.9	1717.5	1544.3	1417.2	1364.2
35°	1738.8	1630.9	1444.8	1311.5	1264.8
37.5°	1664.7	1548.2	1351.7	1205.6	1152.8
40°	1586.4	1459.6	1254.2	1104.1	1049.1
42.5°	1506.1	1370.7	1157.1	1000.4	947.7
45°	1421.4	1279.6	1057.7	907.3	856.6
47.5°	1341.1	1191.0	962.5	812.2	765.7
50°	1252.3	1102.1	869.4	723.3	679.1
52.5°	1165.4	1006.7	780.5	640.9	600.8
55°	1080.8	915.9	687.4	560.6	520.4
57.5°	994.2	824.9	605.0	486.5	452.6
60°	905.3	736.1	518.2	410.5	376.5
62.5°	818.7	649.5	444.1	342.7	325.8
65°	729.8	558.4	368.1	296.2	289.7
67.5°	645.2	473.7	296.2	260.1	253.8
70°	556.3	391.3	245.2	224.2	215.7
72.5°	471.7	315.1	205.1	188.3	184.0
75°	389.2	241.0	169.2	154.4	152.4
77.5°	306.8	171.3	133.3	124.8	120.6
80°	230.5	122.7	101.4	93.1	93.1
82.5°	160.7	82.6	69.7	65.5	65.5
85°	90.9	46.5	40.2	40.2	40.2
87.5°	33.9	16.9	16.9	14.8	14.8
90°	0.7	8.3	13.8	17.3	18.6
92.5°	17.3	14.5	16.6	18.0	18.6
95°	44.9	22.1	26.9	30.4	29.7
97.5°	80.8	24.2	35.2	37.3	38.0
100°	122.2	27.6	39.4	44.9	46.3
102.5°	167.8	166.5	40.7	48.3	50.4
105°	209.9	230.6	42.1	49.7	52.5
107.5°	258.9	276.2	43.5	51.1	53.9
110°	305.9	320.4	120.8	51.8	54.6

TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	350.2	362.5	350.8	53.2	55.2
115°	397.0	408.8	426.0	106.3	56.6
117.5°	437.8	451.6	463.4	364.6	183.7
120°	483.3	493.7	506.1	514.4	421.2
122.5°	522.0	533.1	547.0	551.0	551.8
125°	561.4	570.3	583.5	588.3	590.4
127.5°	597.3	606.9	617.4	624.2	624.9
130°	631.1	642.2	649.8	657.3	656.8
132.5°	665.6	674.7	682.2	688.4	687.8
135°	694.7	705.8	711.9	718.9	717.5
137.5°	725.0	733.3	740.3	747.2	745.1
140°	754.7	760.3	767.8	774.0	770.6
142.5°	779.7	784.5	793.4	798.9	795.5
145°	805.9	805.1	816.9	821.7	818.2
147.5°	828.6	826.5	838.3	841.7	839.0
150°	850.7	845.9	857.0	861.0	857.6
152.5°	869.3	863.8	874.2	878.4	873.5
155°	887.3	881.2	889.4	893.5	888.1
157.5°	901.8	896.4	902.6	907.4	901.8
160°	914.3	910.1	914.3	918.4	913.5
162.5°	925.3	921.1	924.6	929.4	923.2
165°	934.9	930.9	932.9	937.7	932.9
167.5°	942.5	938.4	940.5	945.4	939.1
170°	948.8	944.6	946.0	950.8	944.6
172.5°	952.9	948.8	950.2	955.0	948.8
175°	956.3	951.5	952.9	957.7	950.8
177.5°	957.7	952.9	953.7	958.5	952.3
180°	954.3	954.3	954.3	954.3	954.3

TEST NUMBER: P902261

CATALOG NUMBER: DFN2DIP-4P3F0-060D030US830-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.67	12.62	12.51	13.48	14.55	7.63	8.58	8.47	9.44	10.51
	3H	13.35	14.20	14.21	15.07	16.17	8.82	9.67	9.68	10.54	11.64
	4H	13.96	14.77	14.83	15.64	16.75	9.27	10.08	10.14	10.95	12.06
	6H	14.39	15.13	15.27	16.01	17.13	9.59	10.33	10.48	11.22	12.34
	8H	14.52	15.22	15.41	16.12	17.24	9.69	10.39	10.58	11.29	12.41
	12H	14.58	15.25	15.48	16.14	17.29	9.73	10.40	10.63	11.29	12.44
4H	2H	11.70	12.50	12.58	13.38	14.49	8.24	9.04	9.11	9.92	11.03
	3H	13.54	14.20	14.42	15.11	16.23	9.59	10.26	10.48	11.17	12.29
	4H	14.23	14.84	15.13	15.74	16.89	10.14	10.75	11.04	11.65	12.80
	6H	14.75	15.27	15.66	16.20	17.35	10.56	11.08	11.47	12.01	13.16
	8H	14.92	15.41	15.84	16.33	17.50	10.69	11.17	11.60	12.10	13.26
	12H	15.02	15.46	15.95	16.40	17.57	10.75	11.19	11.69	12.13	13.30
8H	4H	14.20	14.69	15.12	15.61	16.78	10.43	10.91	11.34	11.84	13.00
	6H	14.77	15.17	15.71	16.14	17.30	10.94	11.34	11.88	12.31	13.47
	8H	14.98	15.34	15.93	16.29	17.48	11.13	11.48	12.08	12.44	13.62
	12H	15.12	15.44	16.08	16.38	17.62	11.25	11.56	12.20	12.51	13.74
12H	4H	14.16	14.60	15.10	15.54	16.71	10.44	10.87	11.37	11.81	12.99
	6H	14.74	15.10	15.70	16.06	17.24	10.99	11.34	11.94	12.30	13.48
	8H	14.97	15.28	15.92	16.23	17.46	11.20	11.51	12.15	12.46	13.69

END OF REPORT