

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P913129

Luminaire Tested: DFN2DIP-4P3F0-040D020US927-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P913129
REPORT IS A COMBINATION OF REPORTS P900554 AND P897473
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P3F0-040D020US927-RLLONL
Description: 3 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4261.9 lumens
Efficiency: N/A
Efficacy: 80.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.07' x L: 3.07' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 53
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9789
Total Harmonic Distortion (THDi): 0.074
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	91	91	91	79	79	79	68	68	68
1	101	97	93	90	95	91	88	85	80	78	76	71	69	67	61	60	59
2	93	86	80	75	87	81	75	71	71	67	64	63	60	57	55	52	51
3	85	76	69	63	80	72	65	60	63	58	54	56	52	49	49	46	44
4	78	68	60	54	73	64	57	52	57	51	47	50	46	43	44	41	38
5	72	61	53	47	67	57	50	45	51	45	41	46	41	37	40	37	34
6	67	55	47	41	62	52	45	39	46	41	36	41	37	33	37	33	30
7	62	50	42	36	58	47	40	35	42	36	32	38	33	30	34	30	27
8	58	45	38	32	54	43	36	31	39	33	29	35	30	27	31	27	24
9	54	42	34	29	51	40	33	28	36	30	26	32	27	24	29	25	22
10	50	38	31	26	47	37	30	25	33	28	24	30	25	22	27	23	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1492	1492	1492
5°	1494	1468	1478
10°	1478	1438	1429
15°	1457	1390	1354
20°	1429	1323	1263
25°	1400	1249	1174
30°	1363	1173	1062
35°	1325	1091	964
40°	1287	1007	851
45°	1243	913	749
50°	1197	819	649
55°	1150	718	554
60°	1094	613	455
65°	1031	506	409
70°	953	406	369
75°	856	356	335
80°	715	296	289
85°	485	193	214

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1243 cd/sqm

TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	122.7	2.9
10°-20°	336.9	7.9
20°-30°	473.1	11.1
30°-40°	515.7	12.1
40°-50°	473.9	11.1
50°-60°	372.2	8.7
60°-70°	242.3	5.7
70°-80°	124.7	2.9
80°-90°	32.8	0.8
90°-100°	17.6	0.4
100°-110°	65.7	1.5
110°-120°	174.3	4.1
120°-130°	289.1	6.8
130°-140°	307.1	7.2
140°-150°	285.4	6.7
150°-160°	229.5	5.4
160°-170°	147.9	3.5
170°-180°	50.9	1.2
0°-30°	932.7	21.9
0°-40°	1448.4	34.0
0°-60°	2294.6	53.8
0°-90°	2694.3	63.2
90°-120°	257.7	6.0
90°-150°	1139.3	26.7
90°-180°	1568.0	36.8
0°-180°	4261.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1310	1310	1310	1310	1310	
5°	1310	1304	1288	1299	1296	124
15°	1246	1233	1192	1170	1158	351
25°	1131	1093	1014	966	948	520
35°	974	914	810	735	709	610
45°	796	717	593	508	480	615
55°	606	513	385	314	292	541
65°	409	313	206	166	162	405
75°	218	135	95	86	85	231
85°	51	26	22	22	22	58
90°	0	5	8	10	10	4
95°	25	12	15	17	17	30
105°	118	129	24	28	29	126
115°	222	229	239	60	32	219
125°	315	320	327	330	331	281
135°	389	396	399	403	402	301
145°	452	451	458	460	458	282
155°	497	494	498	501	498	229
165°	524	522	523	526	523	148
175°	536	533	534	537	533	51
180°	535	535	535	535	535	

TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1309.6	1309.6	1309.6	1309.6	1309.6
2.5°	1315.6	1309.6	1296.6	1308.5	1306.1
5°	1309.6	1303.7	1288.2	1298.9	1295.5
7.5°	1298.9	1291.9	1275.3	1279.9	1274.1
10°	1284.8	1276.4	1252.8	1249.1	1242.1
12.5°	1267.0	1256.3	1224.2	1217.2	1204.1
15°	1245.6	1232.6	1192.3	1169.8	1158.0
17.5°	1220.8	1201.7	1151.9	1125.9	1106.9
20°	1192.3	1168.5	1109.3	1079.7	1053.6
22.5°	1161.5	1134.2	1065.4	1025.2	1007.5
25°	1130.7	1092.7	1014.5	966.0	948.1
27.5°	1094.0	1053.6	967.1	911.4	884.1
30°	1054.9	1009.7	914.9	854.5	822.5
32.5°	1016.9	962.3	865.2	794.1	764.4
35°	974.3	913.8	809.5	734.8	708.7
37.5°	932.8	867.5	757.3	675.5	645.9
40°	888.9	817.8	702.8	618.7	587.9
42.5°	843.8	768.0	648.3	560.5	531.0
45°	796.5	717.0	592.6	508.4	480.0
47.5°	751.5	667.3	539.3	455.1	429.0
50°	701.6	617.5	487.1	405.3	380.5
52.5°	653.0	564.1	437.4	359.1	336.6
55°	605.6	513.2	385.2	314.1	291.6
57.5°	557.1	462.2	339.0	272.6	253.7
60°	507.2	412.4	290.3	230.0	211.0
62.5°	458.8	363.9	248.8	192.0	182.6
65°	408.9	312.8	206.2	166.0	162.3
67.5°	361.6	265.5	166.0	145.8	142.2
70°	311.7	219.3	137.4	125.6	120.8
72.5°	264.4	176.6	114.9	105.5	103.1
75°	218.0	135.1	94.8	86.5	85.4
77.5°	171.9	95.9	74.7	69.9	67.5
80°	129.1	68.8	56.8	52.2	52.2
82.5°	90.1	46.3	39.1	36.7	36.7
85°	50.9	26.1	22.5	22.5	22.5
87.5°	19.0	9.4	9.4	8.3	8.3
90°	0.4	4.7	7.7	9.7	10.5
92.5°	9.7	8.2	9.3	10.1	10.5
95°	25.1	12.4	15.1	17.0	16.6
97.5°	45.2	13.5	19.7	20.9	21.3
100°	68.5	15.4	22.0	25.1	25.9
102.5°	94.0	93.2	22.8	27.1	28.3
105°	117.6	129.2	23.6	27.8	29.4
107.5°	145.1	154.7	24.4	28.6	30.2
110°	171.4	179.5	67.7	29.1	30.6



TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	196.1	203.1	196.5	29.8	31.0
115°	222.4	229.0	238.8	59.6	31.8
117.5°	245.3	253.0	259.6	204.3	102.9
120°	270.8	276.6	283.6	288.3	236.0
122.5°	292.5	298.7	306.4	308.7	309.2
125°	314.6	319.6	326.9	329.6	330.8
127.5°	334.7	340.1	345.9	349.7	350.1
130°	353.6	359.8	364.1	368.4	368.0
132.5°	373.0	378.0	382.2	385.7	385.4
135°	389.3	395.5	398.9	402.8	402.0
137.5°	406.2	410.9	414.8	418.7	417.5
140°	422.9	426.0	430.2	433.7	431.8
142.5°	436.8	439.6	444.6	447.7	445.7
145°	451.5	451.1	457.7	460.4	458.5
147.5°	464.3	463.1	469.7	471.6	470.1
150°	476.7	474.0	480.1	482.4	480.5
152.5°	487.1	484.0	489.8	492.2	489.4
155°	497.2	493.7	498.4	500.7	497.6
157.5°	505.3	502.2	505.7	508.4	505.3
160°	512.3	509.9	512.3	514.6	511.9
162.5°	518.4	516.1	518.1	520.8	517.3
165°	523.9	521.6	522.7	525.5	522.7
167.5°	528.1	525.8	527.0	529.7	526.2
170°	531.6	529.3	530.0	532.7	529.3
172.5°	533.9	531.6	532.4	535.1	531.6
175°	535.8	533.1	533.9	536.6	532.7
177.5°	536.6	533.9	534.3	537.0	533.5
180°	534.7	534.7	534.7	534.7	534.7

TEST NUMBER: P913129

CATALOG NUMBER: DFN2DIP-4P3F0-040D020US927-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	9.66	10.61	10.50	11.47	12.54	5.62	6.57	6.46	7.43	8.50
	3H	11.34	12.19	12.19	13.06	14.16	6.81	7.66	7.66	8.53	9.63
	4H	11.95	12.75	12.82	13.63	14.74	7.26	8.06	8.13	8.94	10.05
	6H	12.38	13.11	13.26	14.00	15.12	7.58	8.32	8.47	9.20	10.33
	8H	12.50	13.21	13.39	14.11	15.23	7.67	8.38	8.56	9.28	10.40
	12H	12.57	13.24	13.46	14.13	15.28	7.72	8.39	8.61	9.28	10.43
4H	2H	9.69	10.49	10.56	11.37	12.48	6.23	7.03	7.10	7.90	9.01
	3H	11.52	12.19	12.41	13.10	14.22	7.58	8.25	8.47	9.15	10.28
	4H	12.22	12.82	13.12	13.73	14.88	8.13	8.73	9.03	9.64	10.79
	6H	12.73	13.26	13.65	14.18	15.34	8.55	9.07	9.46	10.00	11.15
	8H	12.91	13.40	13.82	14.32	15.49	8.67	9.16	9.59	10.08	11.25
	12H	13.01	13.45	13.94	14.39	15.56	8.74	9.18	9.67	10.12	11.29
8H	4H	12.19	12.68	13.11	13.60	14.77	8.41	8.90	9.33	9.82	10.99
	6H	12.76	13.16	13.70	14.12	15.29	8.93	9.33	9.87	10.29	11.46
	8H	12.97	13.33	13.92	14.28	15.47	9.11	9.47	10.07	10.43	11.61
	12H	13.11	13.43	14.07	14.37	15.61	9.23	9.55	10.19	10.49	11.73
12H	4H	12.15	12.59	13.08	13.53	14.70	8.42	8.86	9.36	9.80	10.97
	6H	12.73	13.09	13.68	14.04	15.23	8.98	9.33	9.93	10.29	11.47
	8H	12.95	13.27	13.91	14.22	15.45	9.19	9.50	10.14	10.45	11.68

END OF REPORT