

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P918622

Luminaire Tested: DFN2DIP-4P3F0-060D020US935-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P918622
REPORT IS A COMBINATION OF REPORTS P899037 AND P895917
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P3F0-060D020US935-FLLFLL
Description: 3 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6638.3 lumens
Efficiency: N/A
Efficacy: 85.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.07' x L: 3.07' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 77.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9963
Total Harmonic Distortion (THDi): 0.065
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	114	114	114	114	108	108	108	108	98	98	98	89	89	89	81	81	81
1	104	99	95	92	99	95	91	88	86	84	81	79	77	75	72	70	68
2	95	87	80	75	90	83	77	72	76	71	67	69	66	62	63	60	58
3	86	76	69	63	82	73	66	61	67	61	57	61	57	53	56	52	49
4	79	68	59	53	75	65	57	52	60	53	48	55	50	45	50	46	42
5	73	61	52	46	69	58	50	44	53	47	42	49	44	39	45	41	37
6	67	55	46	40	64	52	45	39	48	42	37	45	39	35	41	36	33
7	62	49	41	35	59	48	40	34	44	37	33	41	35	31	37	33	29
8	58	45	37	31	55	43	36	31	40	34	29	37	32	28	34	30	26
9	54	41	33	28	52	40	32	27	37	31	26	34	29	25	32	27	24
10	51	38	30	25	48	37	30	25	34	28	24	32	26	23	30	25	22

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2291	2291	2291
5°	2293	2257	2273
10°	2273	2225	2242
15°	2238	2187	2193
20°	2191	2135	2143
25°	2145	2072	2085
30°	2087	2014	2012
35°	2032	1946	1935
40°	1965	1877	1861
45°	1898	1808	1786
50°	1824	1735	1699
55°	1747	1650	1619
60°	1660	1551	1526
65°	1564	1447	1418
70°	1443	1320	1301
75°	1274	1169	1192
80°	1071	975	985
85°	754	646	645

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1898 cd/sqm

TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	189.2	2.9
10°-20°	532.3	8.0
20°-30°	782.3	11.8
30°-40°	908.6	13.7
40°-50°	907.5	13.7
50°-60°	791.3	11.9
60°-70°	584.9	8.8
70°-80°	330.9	5.0
80°-90°	88.9	1.3
90°-100°	33.7	0.5
100°-110°	107.1	1.6
110°-120°	183.2	2.8
120°-130°	241.0	3.6
130°-140°	270.5	4.1
140°-150°	265.3	4.0
150°-160°	222.5	3.4
160°-170°	147.6	2.2
170°-180°	51.6	0.8
0°-30°	1503.8	22.7
0°-40°	2412.4	36.3
0°-60°	4111.1	61.9
0°-90°	5115.9	77.1
90°-120°	324.0	4.9
90°-150°	1100.8	16.6
90°-180°	1522.0	22.9
0°-180°	6638.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2010	2010	2010	2010	2010	
5°	2010	2002	1981	1997	1993	191
15°	1914	1902	1877	1885	1875	539
25°	1732	1716	1684	1687	1684	797
35°	1494	1475	1444	1432	1422	933
45°	1216	1202	1173	1152	1144	938
55°	920	908	885	862	852	823
65°	620	609	590	572	562	614
75°	325	321	311	300	304	347
85°	79	77	75	70	68	88
90°	0	6	16	15	16	6
95°	24	29	29	29	29	27
105°	99	100	101	102	102	104
115°	184	186	186	185	184	182
125°	267	272	270	269	268	239
135°	346	351	352	352	350	267
145°	420	423	426	426	425	262
155°	480	482	483	485	484	221
165°	522	522	522	525	523	147
175°	544	542	541	545	542	52
180°	545	545	545	545	545	

TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2010.1	2010.1	2010.1	2010.1	2010.1
2.5°	2021.8	2012.2	1990.8	2010.1	2006.4
5°	2010.1	2002.5	1981.2	1996.6	1992.9
7.5°	1996.6	1985.1	1963.8	1979.3	1975.5
10°	1975.5	1962.0	1938.7	1954.1	1948.4
12.5°	1946.4	1934.8	1911.7	1921.3	1917.4
15°	1913.5	1902.0	1876.8	1884.6	1875.0
17.5°	1872.9	1861.5	1836.3	1845.8	1836.3
20°	1828.4	1817.0	1789.8	1795.6	1788.0
22.5°	1784.2	1766.7	1741.5	1741.5	1737.6
25°	1731.8	1716.5	1683.6	1687.3	1683.6
27.5°	1673.8	1660.3	1635.2	1629.5	1619.9
30°	1616.0	1600.3	1571.5	1565.7	1557.9
32.5°	1554.0	1542.6	1511.6	1499.9	1492.1
35°	1494.2	1474.9	1443.9	1432.2	1422.5
37.5°	1426.5	1409.0	1378.1	1364.5	1354.9
40°	1356.9	1341.3	1310.4	1293.2	1285.4
42.5°	1289.3	1273.7	1242.9	1223.5	1211.9
45°	1215.9	1202.3	1173.2	1152.1	1144.3
47.5°	1144.3	1130.7	1099.8	1078.5	1066.9
50°	1068.8	1059.2	1032.2	1005.0	995.4
52.5°	995.4	981.9	956.8	935.6	922.0
55°	920.1	908.4	885.3	862.1	852.5
57.5°	844.7	835.1	809.9	786.7	778.9
60°	769.2	761.6	734.6	713.3	707.5
62.5°	695.8	682.3	663.0	643.7	635.9
65°	620.5	608.9	589.6	572.1	562.5
67.5°	543.2	533.4	516.2	502.7	494.8
70°	471.7	463.9	446.4	432.9	425.3
72.5°	398.2	390.5	380.8	367.3	361.5
75°	324.6	321.0	311.1	299.6	303.5
77.5°	259.0	251.2	247.3	241.6	235.8
80°	193.4	191.3	187.4	181.7	177.8
82.5°	131.5	131.5	129.6	121.8	121.8
85°	79.1	77.3	75.4	69.5	67.7
87.5°	34.9	31.0	27.0	21.4	19.3
90°	0.5	5.9	16.1	15.1	15.6
92.5°	10.2	13.8	14.3	14.8	14.8
95°	23.9	28.6	29.4	29.4	28.6
97.5°	39.9	44.2	46.0	46.0	46.0
100°	58.3	62.1	63.4	63.4	62.9
102.5°	77.7	80.4	82.2	82.7	82.2
105°	98.8	100.1	101.2	101.9	101.9
107.5°	119.9	121.8	121.8	122.2	119.9
110°	140.3	142.8	142.8	142.8	141.5

TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	162.2	165.0	164.5	163.2	162.2
115°	183.9	186.5	185.7	185.2	183.9
117.5°	205.4	209.1	206.7	205.4	204.1
120°	227.0	230.7	227.0	227.0	225.6
122.5°	246.8	251.3	249.1	247.8	246.8
125°	267.4	271.6	270.3	268.8	268.3
127.5°	287.7	292.7	290.9	289.0	287.7
130°	306.5	312.5	311.6	310.6	308.8
132.5°	327.7	332.3	332.6	330.4	329.0
135°	345.9	351.0	352.0	351.5	350.2
137.5°	366.3	370.4	371.3	370.9	368.9
140°	384.2	388.3	390.6	390.6	388.8
142.5°	402.6	406.6	408.0	408.5	406.6
145°	420.0	423.3	425.9	426.4	424.6
147.5°	435.6	439.7	441.7	442.5	440.7
150°	451.7	454.4	456.2	457.7	456.2
152.5°	466.0	468.7	471.1	472.9	471.1
155°	480.3	481.6	483.0	485.3	483.9
157.5°	492.6	493.5	494.4	497.7	495.3
160°	503.6	504.5	505.1	507.8	505.8
162.5°	513.8	513.8	514.2	517.4	515.0
165°	522.5	521.9	521.9	525.2	523.0
167.5°	530.3	528.8	528.8	532.1	529.9
170°	536.2	534.9	534.4	537.7	534.9
172.5°	540.4	539.0	538.6	541.8	539.0
175°	543.6	542.3	541.3	544.6	541.8
177.5°	545.4	544.2	543.1	545.9	543.1
180°	544.6	544.6	544.6	544.6	544.6

TEST NUMBER: P918622

CATALOG NUMBER: DFN2DIP-4P3F0-060D020US935-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.32	13.49	13.00	14.19	15.01	11.87	13.04	12.56	13.75	14.57
	3H	13.99	15.05	14.69	15.76	16.62	13.50	14.56	14.20	15.27	16.13
	4H	14.59	15.59	15.31	16.31	17.18	14.10	15.09	14.82	15.82	16.69
	6H	15.01	15.92	15.74	16.66	17.54	14.51	15.42	15.23	16.16	17.04
	8H	15.12	15.99	15.86	16.75	17.63	14.62	15.49	15.36	16.24	17.13
	12H	15.17	16.01	15.92	16.76	17.67	14.66	15.50	15.41	16.25	17.16
4H	2H	12.81	13.80	13.53	14.53	15.40	12.46	13.45	13.17	14.17	15.04
	3H	14.70	15.53	15.43	16.29	17.18	14.29	15.12	15.02	15.88	16.77
	4H	15.42	16.18	16.17	16.94	17.85	15.00	15.75	15.75	16.51	17.43
	6H	15.95	16.60	16.72	17.39	18.31	15.52	16.17	16.28	16.96	17.88
	8H	16.10	16.72	16.88	17.50	18.43	15.67	16.28	16.44	17.06	18.00
	12H	16.19	16.74	16.98	17.55	18.49	15.74	16.29	16.53	17.10	18.04
8H	4H	15.64	16.25	16.41	17.03	17.97	15.26	15.87	16.03	16.65	17.59
	6H	16.28	16.78	17.08	17.61	18.55	15.89	16.40	16.69	17.22	18.16
	8H	16.50	16.95	17.31	17.77	18.73	16.10	16.56	16.92	17.38	18.33
	12H	16.64	17.04	17.45	17.85	18.86	16.23	16.63	17.04	17.44	18.45
12H	4H	15.64	16.19	16.43	16.99	17.94	15.27	15.82	16.06	16.62	17.57
	6H	16.31	16.76	17.12	17.58	18.54	15.93	16.39	16.75	17.21	18.16
	8H	16.56	16.96	17.37	17.77	18.78	16.18	16.58	16.99	17.39	18.40