

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P923999

Luminaire Tested: DFN2DIP-4P3F0-020D020US950-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P923999
REPORT IS A COMBINATION OF REPORTS P900549 AND P897473
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P3F0-020D020US950-FLLONL
Description: 3 foot, 90deg - 4way Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3777.8 lumens
Efficiency: N/A
Efficacy: 121.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.07' x L: 3.07' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 31
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	107	107	107	107	99	99	99	99	83	83	83	69	69	69	56	56	56
1	98	93	90	86	90	86	83	80	73	71	68	61	59	58	50	48	47
2	89	82	75	70	82	76	70	66	64	60	57	53	51	48	44	42	40
3	81	72	64	59	75	66	60	55	56	52	48	47	44	41	39	36	34
4	74	64	56	50	68	59	52	47	50	45	41	42	38	35	35	32	29
5	68	57	48	42	63	53	45	40	45	39	35	38	34	30	31	28	26
6	63	51	43	37	58	47	40	35	40	35	31	34	30	27	28	25	23
7	58	46	38	32	53	43	36	30	37	31	27	31	27	23	26	23	20
8	54	42	34	29	50	39	32	27	33	28	24	28	24	21	24	20	18
9	50	38	30	25	46	35	29	24	31	25	21	26	22	19	22	19	16
10	47	35	28	23	43	33	26	22	28	23	19	24	20	17	20	17	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	846	846	846
5°	847	834	840
10°	839	822	828
15°	827	808	810
20°	809	788	792
25°	792	765	770
30°	771	744	743
35°	751	719	715
40°	726	693	687
45°	701	668	660
50°	674	641	628
55°	645	609	598
60°	613	573	564
65°	578	535	524
70°	533	488	480
75°	471	432	440
80°	396	361	363
85°	278	239	238

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 701 cd/sqm

TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	69.9	1.8
10°-20°	196.6	5.2
20°-30°	288.9	7.6
30°-40°	335.6	8.9
40°-50°	335.2	8.9
50°-60°	292.2	7.7
60°-70°	216.0	5.7
70°-80°	122.2	3.2
80°-90°	33.4	0.9
90°-100°	21.2	0.6
100°-110°	79.1	2.1
110°-120°	209.9	5.6
120°-130°	348.2	9.2
130°-140°	369.8	9.8
140°-150°	343.7	9.1
150°-160°	276.4	7.3
160°-170°	178.1	4.7
170°-180°	61.3	1.6
0°-30°	555.4	14.7
0°-40°	891.0	23.6
0°-60°	1518.4	40.2
0°-90°	1890.1	50.0
90°-120°	310.3	8.2
90°-150°	1372.0	36.3
90°-180°	1888.0	50.0
0°-180°	3777.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	742	742	742	742	742	
5°	742	740	732	737	736	70
15°	707	702	693	696	692	199
25°	640	634	622	623	622	294
35°	552	545	533	529	525	345
45°	449	444	433	426	423	347
55°	340	336	327	318	315	304
65°	229	225	218	211	208	227
75°	120	119	115	111	112	128
85°	29	28	28	26	25	33
90°	0	6	9	12	13	3
95°	30	15	18	20	20	36
105°	142	156	28	34	35	151
115°	268	276	288	72	38	264
125°	379	385	394	397	398	338
135°	469	476	480	485	484	362
145°	544	543	551	554	552	340
155°	599	594	600	603	599	276
165°	631	628	629	633	629	178
175°	645	642	643	646	642	61
180°	644	644	644	644	644	

TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	742.4	742.4	742.4	742.4	742.4
2.5°	746.7	743.2	735.2	742.4	741.1
5°	742.4	739.6	731.7	737.4	736.0
7.5°	737.4	733.1	725.3	731.1	729.6
10°	729.6	724.7	716.1	721.7	719.6
12.5°	718.8	714.6	706.1	709.6	708.2
15°	706.7	702.5	693.2	696.0	692.5
17.5°	691.7	687.5	678.2	681.7	678.2
20°	675.3	671.0	661.0	663.2	660.4
22.5°	658.9	652.5	643.2	643.2	641.8
25°	639.7	633.9	621.8	623.2	621.8
27.5°	618.2	613.2	604.0	601.9	598.3
30°	596.8	591.1	580.4	578.3	575.4
32.5°	573.9	569.7	558.3	554.0	551.1
35°	551.9	544.7	533.3	529.0	525.4
37.5°	526.9	520.4	509.0	504.0	500.4
40°	501.1	495.4	484.0	477.7	474.7
42.5°	476.1	470.4	459.1	451.9	447.6
45°	449.0	444.1	433.3	425.5	422.6
47.5°	422.6	417.7	406.2	398.3	394.1
50°	394.8	391.2	381.2	371.2	367.7
52.5°	367.7	362.6	353.4	345.5	340.6
55°	339.8	335.5	326.9	318.4	314.8
57.5°	312.0	308.4	299.1	290.6	287.6
60°	284.1	281.3	271.3	263.4	261.3
62.5°	257.0	252.0	244.9	237.7	234.9
65°	229.2	224.9	217.8	211.3	207.8
67.5°	200.6	197.0	190.6	185.6	182.8
70°	174.2	171.3	164.9	159.9	157.1
72.5°	147.1	144.2	140.6	135.7	133.6
75°	119.9	118.6	114.9	110.7	112.1
77.5°	95.7	92.8	91.3	89.2	87.1
80°	71.5	70.7	69.3	67.1	65.6
82.5°	48.6	48.6	47.9	45.0	45.0
85°	29.2	28.5	27.9	25.7	25.0
87.5°	12.9	11.4	10.0	7.9	7.2
90°	0.5	5.6	9.3	11.6	12.6
92.5°	11.6	9.8	11.2	12.1	12.6
95°	30.2	14.9	18.1	20.5	20.0
97.5°	54.5	16.3	23.8	25.2	25.7
100°	82.5	18.6	26.5	30.2	31.2
102.5°	113.2	112.3	27.5	32.6	34.1
105°	141.7	155.6	28.4	33.5	35.4
107.5°	174.8	186.3	29.4	34.4	36.3
110°	206.4	216.2	81.6	35.0	36.8



TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	236.2	244.6	236.7	35.9	37.3
115°	267.9	275.8	287.5	71.7	38.3
117.5°	295.4	304.7	312.6	246.0	123.9
120°	326.2	333.1	341.5	347.2	284.2
122.5°	352.2	359.7	369.0	371.8	372.3
125°	378.8	384.8	393.7	397.0	398.4
127.5°	403.1	409.6	416.6	421.2	421.7
130°	425.9	433.3	438.5	443.6	443.1
132.5°	449.1	455.2	460.3	464.5	464.1
135°	468.8	476.2	480.3	485.1	484.2
137.5°	489.2	494.8	499.5	504.2	502.8
140°	509.2	513.1	518.1	522.3	520.0
142.5°	526.0	529.4	535.4	539.1	536.7
145°	543.8	543.3	551.2	554.5	552.2
147.5°	559.1	557.7	565.6	567.9	566.1
150°	574.0	570.8	578.2	581.0	578.7
152.5°	586.6	582.9	589.9	592.7	589.4
155°	598.7	594.5	600.2	602.9	599.2
157.5°	608.6	604.8	609.0	612.3	608.6
160°	617.0	614.1	617.0	619.7	616.5
162.5°	624.3	621.5	623.9	627.2	623.0
165°	630.9	628.1	629.4	632.8	629.4
167.5°	636.0	633.2	634.6	637.9	633.6
170°	640.2	637.4	638.3	641.6	637.4
172.5°	643.0	640.2	641.2	644.4	640.2
175°	645.3	642.0	643.0	646.2	641.6
177.5°	646.2	643.0	643.5	646.7	642.5
180°	643.9	643.9	643.9	643.9	643.9

TEST NUMBER: P923999

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US950-FLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	6.66	7.52	7.62	8.49	9.77	6.22	7.08	7.17	8.05	9.32
	3H	8.32	9.09	9.28	10.07	11.36	7.83	8.60	8.79	9.58	10.87
	4H	8.90	9.63	9.88	10.62	11.92	8.41	9.14	9.39	10.12	11.43
	6H	9.30	9.97	10.29	10.96	12.28	8.80	9.47	9.79	10.46	11.78
	8H	9.40	10.04	10.40	11.05	12.36	8.90	9.54	9.90	10.55	11.86
	12H	9.45	10.06	10.45	11.06	12.40	8.94	9.55	9.94	10.55	11.89
4H	2H	7.12	7.85	8.11	8.83	10.14	6.76	7.50	7.75	8.48	9.78
	3H	8.98	9.59	9.98	10.60	11.92	8.57	9.18	9.57	10.20	11.51
	4H	9.69	10.25	10.69	11.26	12.59	9.27	9.82	10.27	10.83	12.17
	6H	10.20	10.68	11.22	11.71	13.05	9.77	10.25	10.78	11.28	12.62
	8H	10.35	10.80	11.37	11.82	13.17	9.91	10.36	10.93	11.38	12.73
	12H	10.42	10.83	11.46	11.86	13.22	9.97	10.38	11.01	11.41	12.77
8H	4H	9.88	10.33	10.90	11.35	12.71	9.51	9.95	10.52	10.98	12.33
	6H	10.51	10.88	11.55	11.94	13.29	10.12	10.49	11.17	11.56	12.91
	8H	10.73	11.05	11.78	12.10	13.47	10.33	10.66	11.38	11.71	13.08
	12H	10.85	11.14	11.91	12.19	13.60	10.44	10.73	11.50	11.78	13.19
12H	4H	9.87	10.27	10.90	11.31	12.67	9.50	9.90	10.54	10.94	12.30
	6H	10.54	10.86	11.59	11.91	13.28	10.16	10.49	11.21	11.54	12.91
	8H	10.77	11.06	11.83	12.11	13.52	10.39	10.68	11.45	11.73	13.14