

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P910685

Luminaire Tested: DFN2DIP-HX2F0-060D020US850-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P910685
REPORT IS A COMBINATION OF REPORTS P900680 AND P897595
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX2F0-060D020US850-RLLONL
Description: 2 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7851.7 lumens
Efficiency: N/A
Efficacy: 105.1 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 1.99' x L: 2.3' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 74.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	112	112	112	112	107	107	107	107	96	96	96	86	86	86	76	76	76
1	103	99	95	92	98	94	91	88	85	82	80	76	75	73	69	67	66
2	95	87	81	76	90	83	78	73	75	71	68	68	65	62	61	59	57
3	87	78	70	65	82	74	67	62	67	62	58	61	57	53	55	52	49
4	80	69	61	55	76	66	59	54	60	54	50	55	50	46	50	46	43
5	74	62	54	48	70	59	52	47	54	48	44	50	45	41	45	41	38
6	68	56	48	42	65	54	46	41	49	43	39	45	40	36	41	37	34
7	63	51	43	38	60	49	42	36	45	39	34	41	36	32	38	34	30
8	59	47	39	34	56	45	38	33	41	35	31	38	33	29	35	31	27
9	55	43	35	30	52	41	34	30	38	32	28	35	30	26	32	28	25
10	52	40	32	28	49	38	31	27	35	29	25	33	28	24	30	26	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6480	6480	6480
5°	6480	6361	6406
10°	6405	6221	6185
15°	6307	6001	5852
20°	6180	5703	5448
25°	6050	5372	5057
30°	5879	5034	4567
35°	5711	4673	4135
40°	5539	4300	3643
45°	5340	3889	3198
50°	5134	3475	2763
55°	4918	3035	2347
60°	4668	2577	1920
65°	4378	2114	1716
70°	4027	1682	1536
75°	3586	1453	1374
80°	2951	1176	1157
85°	1930	726	810

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 5340 cd/sqm

TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	257.7	3.3
10°-20°	707.6	9.0
20°-30°	993.4	12.7
30°-40°	1082.8	13.8
40°-50°	995.2	12.7
50°-60°	781.6	10.0
60°-70°	508.8	6.5
70°-80°	261.9	3.3
80°-90°	68.2	0.9
90°-100°	24.7	0.3
100°-110°	92.0	1.2
110°-120°	244.0	3.1
120°-130°	404.8	5.2
130°-140°	429.9	5.5
140°-150°	399.6	5.1
150°-160°	321.3	4.1
160°-170°	207.0	2.6
170°-180°	71.2	0.9
0°-30°	1958.7	24.9
0°-40°	3041.5	38.7
0°-60°	4818.4	61.4
0°-90°	5657.2	72.1
90°-120°	360.7	4.6
90°-150°	1595.0	20.3
90°-180°	2194.0	27.9
0°-180°	7851.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2750	2750	2750	2750	2750	
5°	2750	2738	2705	2728	2720	261
15°	2616	2588	2504	2456	2432	737
25°	2374	2295	2130	2028	1991	1092
35°	2046	1919	1700	1543	1488	1281
45°	1672	1506	1244	1068	1008	1292
55°	1272	1078	809	660	612	1136
65°	859	657	433	349	341	851
75°	458	284	199	182	179	484
85°	107	55	47	47	47	123
90°	1	6	11	14	15	7
95°	35	17	21	24	23	42
105°	165	181	33	39	41	176
115°	311	321	334	83	44	307
125°	440	447	458	462	463	393
135°	545	554	558	564	563	421
145°	632	632	641	645	642	395
155°	696	691	698	701	697	321
165°	733	730	732	736	732	207
175°	750	746	748	751	746	71
180°	749	749	749	749	749	

TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2750.1	2750.1	2750.1	2750.1	2750.1
2.5°	2762.5	2750.1	2722.6	2747.7	2742.7
5°	2750.1	2737.7	2705.2	2727.7	2720.3
7.5°	2727.7	2712.8	2678.0	2687.8	2675.4
10°	2697.8	2680.3	2630.8	2623.1	2608.3
12.5°	2660.6	2638.1	2570.8	2556.0	2528.5
15°	2615.7	2588.2	2503.7	2456.4	2431.6
17.5°	2563.5	2523.5	2419.0	2364.3	2324.5
20°	2503.7	2453.8	2329.5	2267.4	2212.5
22.5°	2439.0	2381.7	2237.3	2152.8	2115.5
25°	2374.4	2294.6	2130.4	2028.5	1991.0
27.5°	2297.3	2212.5	2030.8	1913.8	1856.6
30°	2215.1	2120.3	1921.2	1794.5	1727.2
32.5°	2135.4	2020.8	1817.0	1667.5	1605.2
35°	2045.9	1918.9	1700.0	1543.1	1488.2
37.5°	1958.7	1821.6	1590.4	1418.5	1356.4
40°	1866.6	1717.4	1475.7	1299.1	1234.4
42.5°	1772.1	1612.8	1361.4	1177.1	1115.1
45°	1672.5	1505.6	1244.5	1067.5	1007.9
47.5°	1578.0	1401.3	1132.5	955.6	901.0
50°	1473.4	1296.8	1022.9	851.0	799.0
52.5°	1371.2	1184.5	918.4	754.1	706.9
55°	1271.7	1077.6	808.8	659.6	612.3
57.5°	1169.8	970.6	711.9	572.5	532.5
60°	1065.2	866.1	609.7	483.0	443.0
62.5°	963.3	764.2	522.6	403.2	383.4
65°	858.7	657.0	433.1	348.6	340.9
67.5°	759.1	557.4	348.6	306.1	298.7
70°	654.5	460.5	288.6	263.8	253.7
72.5°	555.1	370.7	241.3	221.6	216.5
75°	457.9	283.6	199.1	181.7	179.3
77.5°	361.0	201.5	156.8	146.8	141.8
80°	271.2	144.4	119.3	109.6	109.6
82.5°	189.1	97.1	82.1	77.1	77.1
85°	106.9	54.7	47.2	47.2	47.2
87.5°	39.9	19.9	19.9	17.4	17.4
90°	0.6	6.5	10.8	13.5	14.6
92.5°	13.5	11.4	13.0	14.1	14.6
95°	35.2	17.3	21.1	23.8	23.3
97.5°	63.3	19.0	27.6	29.3	29.8
100°	95.9	21.6	30.8	35.2	36.3
102.5°	131.6	130.5	31.9	37.9	39.6
105°	164.7	180.9	33.0	38.9	41.1
107.5°	203.2	216.6	34.2	40.0	42.3
110°	240.0	251.3	94.8	40.7	42.8



TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	274.6	284.3	275.1	41.7	43.4
115°	311.4	320.6	334.3	83.4	44.5
117.5°	343.3	354.2	363.4	286.0	144.1
120°	379.2	387.3	397.0	403.6	330.4
122.5°	409.4	418.1	429.0	432.2	432.8
125°	440.4	447.4	457.7	461.5	463.1
127.5°	468.6	476.1	484.3	489.6	490.2
130°	495.1	503.7	509.7	515.7	515.1
132.5°	522.1	529.2	535.1	540.0	539.5
135°	545.0	553.6	558.4	563.9	562.8
137.5°	568.7	575.2	580.7	586.1	584.4
140°	592.0	596.4	602.3	607.2	604.5
142.5°	611.5	615.4	622.4	626.7	623.9
145°	632.1	631.6	640.8	644.6	641.9
147.5°	650.0	648.3	657.5	660.2	658.1
150°	667.3	663.5	672.2	675.4	672.7
152.5°	681.9	677.6	685.7	689.0	685.1
155°	696.0	691.1	697.7	700.9	696.6
157.5°	707.4	703.1	708.0	711.8	707.4
160°	717.2	713.9	717.2	720.4	716.6
162.5°	725.7	722.5	725.3	729.1	724.2
165°	733.4	730.2	731.7	735.6	731.7
167.5°	739.4	736.0	737.7	741.6	736.6
170°	744.2	740.9	742.0	745.8	740.9
172.5°	747.5	744.2	745.4	749.1	744.2
175°	750.1	746.4	747.5	751.2	745.8
177.5°	751.2	747.5	748.0	751.8	746.9
180°	748.6	748.6	748.6	748.6	748.6

TEST NUMBER: P910685

CATALOG NUMBER: DFN2DIP-HX2F0-060D020US850-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.35	16.40	16.10	17.17	18.09	11.34	12.39	12.09	13.15	14.07
	3H	17.02	17.96	17.79	18.74	19.69	12.53	13.46	13.29	14.24	15.19
	4H	17.62	18.51	18.40	19.29	20.26	12.97	13.86	13.75	14.64	15.61
	6H	18.04	18.85	18.83	19.64	20.62	13.29	14.11	14.08	14.90	15.88
	8H	18.16	18.93	18.96	19.75	20.72	13.38	14.16	14.18	14.97	15.94
	12H	18.22	18.96	19.02	19.76	20.76	13.42	14.16	14.23	14.97	15.97
4H	2H	15.39	16.28	16.18	17.06	18.03	11.94	12.83	12.73	13.61	14.58
	3H	17.21	17.95	18.01	18.77	19.75	13.29	14.03	14.09	14.85	15.83
	4H	17.90	18.56	18.71	19.38	20.39	13.84	14.50	14.65	15.32	16.33
	6H	18.40	18.97	19.23	19.82	20.83	14.25	14.83	15.08	15.67	16.68
	8H	18.56	19.10	19.40	19.94	20.97	14.37	14.91	15.20	15.75	16.77
	12H	18.66	19.14	19.51	20.00	21.03	14.44	14.92	15.29	15.78	16.81
8H	4H	17.88	18.41	18.71	19.25	20.28	14.12	14.66	14.95	15.49	16.52
	6H	18.42	18.87	19.28	19.75	20.77	14.62	15.06	15.48	15.95	16.97
	8H	18.62	19.02	19.49	19.89	20.94	14.80	15.19	15.67	16.07	17.11
	12H	18.75	19.10	19.63	19.97	21.07	14.91	15.26	15.79	16.13	17.23
12H	4H	17.84	18.32	18.69	19.18	20.21	14.13	14.61	14.98	15.47	16.50
	6H	18.40	18.79	19.27	19.67	20.71	14.66	15.06	15.53	15.94	16.98
	8H	18.61	18.96	19.48	19.82	20.92	14.87	15.22	15.74	16.08	17.18