

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P916059

Luminaire Tested: DFN2DIP-HX2F0-020D020US930-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P916059
REPORT IS A COMBINATION OF REPORTS P900671 AND P897595
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX2F0-020D020US930-FLLONL
Description: 2 foot, Hexagon Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3228.6 lumens
Efficiency: N/A
Efficacy: 105.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 1.99' x L: 2.3' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 30.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9968
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	107	107	107	107	99	99	99	99	83	83	83	69	69	69	56	56	56
1	98	93	90	86	90	86	83	80	73	71	68	61	59	58	50	48	47
2	89	82	75	70	82	76	70	66	64	60	57	53	51	48	44	42	40
3	81	72	64	59	75	66	60	55	56	52	48	47	44	41	39	36	34
4	74	64	56	50	68	59	52	47	50	45	41	42	38	35	35	32	29
5	68	57	48	42	63	53	45	40	45	39	35	38	34	30	31	28	26
6	63	51	43	37	58	47	40	35	40	35	31	34	30	27	28	25	23
7	58	46	38	32	53	43	36	30	37	31	27	31	27	23	26	23	20
8	54	42	34	29	50	39	32	27	33	28	24	28	24	21	24	20	18
9	50	38	30	25	46	35	29	24	31	25	21	26	22	19	22	19	16
10	47	35	28	23	43	33	26	22	28	23	19	24	20	17	20	17	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1495	1495	1495
5°	1495	1470	1481
10°	1480	1447	1458
15°	1456	1420	1424
20°	1424	1383	1389
25°	1393	1340	1350
30°	1354	1300	1300
35°	1317	1253	1248
40°	1271	1205	1197
45°	1225	1157	1146
50°	1176	1107	1087
55°	1123	1048	1031
60°	1064	980	968
65°	998	908	894
70°	916	821	813
75°	803	717	734
80°	665	584	592
85°	449	366	367

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1225 cd/sqm

TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	59.7	1.8
10°-20°	168.0	5.2
20°-30°	246.9	7.6
30°-40°	286.8	8.9
40°-50°	286.4	8.9
50°-60°	249.7	7.7
60°-70°	184.6	5.7
70°-80°	104.5	3.2
80°-90°	28.5	0.9
90°-100°	18.1	0.6
100°-110°	67.6	2.1
110°-120°	179.4	5.6
120°-130°	297.6	9.2
130°-140°	316.1	9.8
140°-150°	293.8	9.1
150°-160°	236.2	7.3
160°-170°	152.2	4.7
170°-180°	52.4	1.6
0°-30°	474.7	14.7
0°-40°	761.5	23.6
0°-60°	1297.6	40.2
0°-90°	1615.3	50.0
90°-120°	265.2	8.2
90°-150°	1172.6	36.3
90°-180°	1613.0	50.0
0°-180°	3228.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	634	634	634	634	634	
5°	634	632	625	630	629	60
15°	604	600	592	595	592	170
25°	547	542	531	533	531	252
35°	472	466	456	452	449	295
45°	384	380	370	364	361	296
55°	290	287	279	272	269	260
65°	196	192	186	181	178	194
75°	102	101	98	95	96	109
85°	25	24	24	22	21	28
90°	0	5	8	10	11	3
95°	26	13	16	18	17	31
105°	121	133	24	29	30	129
115°	229	236	246	61	33	225
125°	324	329	336	339	340	289
135°	401	407	410	415	414	309
145°	465	464	471	474	472	291
155°	512	508	513	515	512	236
165°	539	537	538	541	538	152
175°	552	549	550	552	548	52
180°	550	550	550	550	550	

TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	634.5	634.5	634.5	634.5	634.5
2.5°	638.1	635.1	628.4	634.5	633.3
5°	634.5	632.1	625.3	630.2	629.0
7.5°	630.2	626.6	619.9	624.8	623.5
10°	623.5	619.3	612.0	616.8	615.0
12.5°	614.3	610.7	603.4	606.4	605.2
15°	604.0	600.4	592.4	594.8	591.8
17.5°	591.2	587.6	579.6	582.6	579.6
20°	577.1	573.5	564.9	566.8	564.3
22.5°	563.1	557.7	549.7	549.7	548.5
25°	546.7	541.8	531.4	532.6	531.4
27.5°	528.3	524.1	516.2	514.4	511.3
30°	510.1	505.2	496.0	494.2	491.7
32.5°	490.5	486.9	477.1	473.4	471.0
35°	471.7	465.5	455.8	452.1	449.0
37.5°	450.3	444.7	435.0	430.7	427.6
40°	428.3	423.4	413.6	408.2	405.7
42.5°	406.9	402.0	392.3	386.2	382.5
45°	383.8	379.5	370.3	363.6	361.2
47.5°	361.2	356.9	347.2	340.4	336.8
50°	337.4	334.4	325.8	317.2	314.2
52.5°	314.2	309.9	302.0	295.3	291.1
55°	290.4	286.7	279.4	272.1	269.0
57.5°	266.6	263.6	255.6	248.3	245.8
60°	242.8	240.4	231.9	225.1	223.3
62.5°	219.6	215.3	209.3	203.2	200.7
65°	195.8	192.2	186.1	180.6	177.6
67.5°	171.5	168.4	162.9	158.7	156.2
70°	148.9	146.4	140.9	136.6	134.3
72.5°	125.7	123.3	120.2	115.9	114.1
75°	102.5	101.3	98.2	94.6	95.8
77.5°	81.8	79.3	78.0	76.2	74.4
80°	61.1	60.4	59.2	57.3	56.1
82.5°	41.5	41.5	40.9	38.5	38.5
85°	24.9	24.4	23.8	21.9	21.4
87.5°	11.0	9.8	8.6	6.8	6.1
90°	0.4	4.8	7.9	9.9	10.8
92.5°	9.9	8.4	9.5	10.4	10.8
95°	25.8	12.7	15.5	17.5	17.1
97.5°	46.6	13.9	20.3	21.5	21.9
100°	70.5	15.9	22.7	25.8	26.7
102.5°	96.8	96.0	23.5	27.9	29.1
105°	121.1	133.0	24.3	28.6	30.2
107.5°	149.4	159.2	25.1	29.4	31.1
110°	176.4	184.7	69.7	29.9	31.5

TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	201.9	209.0	202.3	30.7	31.9
115°	228.9	235.7	245.7	61.3	32.7
117.5°	252.4	260.4	267.2	210.3	105.9
120°	278.8	284.7	291.9	296.7	242.9
122.5°	301.0	307.4	315.4	317.7	318.2
125°	323.8	328.9	336.5	339.2	340.5
127.5°	344.5	350.0	356.0	360.0	360.4
130°	363.9	370.3	374.7	379.1	378.7
132.5°	383.8	389.1	393.4	397.0	396.6
135°	400.6	407.0	410.5	414.6	413.8
137.5°	418.1	422.9	426.9	430.9	429.7
140°	435.2	438.5	442.8	446.4	444.4
142.5°	449.6	452.4	457.5	460.7	458.7
145°	464.7	464.3	471.1	473.9	471.9
147.5°	477.8	476.6	483.4	485.3	483.8
150°	490.6	487.8	494.2	496.5	494.6
152.5°	501.3	498.1	504.1	506.5	503.7
155°	511.7	508.1	512.9	515.3	512.1
157.5°	520.1	516.9	520.5	523.3	520.1
160°	527.3	524.8	527.3	529.6	526.8
162.5°	533.5	531.2	533.2	536.0	532.4
165°	539.2	536.8	537.9	540.8	537.9
167.5°	543.6	541.1	542.3	545.2	541.5
170°	547.1	544.7	545.5	548.3	544.7
172.5°	549.5	547.1	548.0	550.7	547.1
175°	551.5	548.7	549.5	552.3	548.3
177.5°	552.3	549.5	549.9	552.7	549.1
180°	550.3	550.3	550.3	550.3	550.3



TEST NUMBER: P916059

CATALOG NUMBER: DFN2DIP-HX2F0-020D020US930-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	8.54	9.40	9.49	10.37	11.64	8.11	8.97	9.07	9.95	11.22
	3H	10.17	10.94	11.14	11.92	13.22	9.71	10.48	10.68	11.46	12.76
	4H	10.74	11.47	11.72	12.46	13.76	10.28	11.01	11.26	12.00	13.30
	6H	11.12	11.80	12.12	12.79	14.10	10.66	11.34	11.65	12.33	13.64
	8H	11.22	11.86	12.22	12.87	14.18	10.76	11.40	11.76	12.41	13.72
	12H	11.26	11.87	12.26	12.87	14.20	10.79	11.40	11.80	12.41	13.74
4H	2H	8.99	9.72	9.97	10.70	12.01	8.65	9.38	9.64	10.36	11.67
	3H	10.82	11.43	11.82	12.45	13.76	10.44	11.05	11.44	12.07	13.38
	4H	11.52	12.08	12.52	13.08	14.42	11.12	11.68	12.13	12.69	14.03
	6H	12.01	12.49	13.03	13.52	14.86	11.61	12.09	12.63	13.13	14.46
	8H	12.15	12.60	13.17	13.62	14.97	11.75	12.20	12.77	13.22	14.57
	12H	12.21	12.62	13.25	13.65	15.01	11.80	12.21	12.84	13.25	14.61
8H	4H	11.70	12.15	12.72	13.18	14.53	11.35	11.80	12.37	12.83	14.18
	6H	12.31	12.68	13.35	13.74	15.09	11.95	12.33	13.00	13.39	14.74
	8H	12.51	12.84	13.56	13.89	15.26	12.15	12.48	13.20	13.53	14.90
	12H	12.63	12.91	13.68	13.96	15.37	12.26	12.54	13.31	13.59	15.00
12H	4H	11.69	12.09	12.72	13.13	14.49	11.34	11.75	12.38	12.79	14.14
	6H	12.33	12.66	13.38	13.71	15.08	11.99	12.32	13.04	13.37	14.73
	8H	12.55	12.84	13.61	13.89	15.30	12.21	12.50	13.26	13.54	14.95