

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P918937

Luminaire Tested: DFN2DIP-HX3F0-050D030US935-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P918937
REPORT IS A COMBINATION OF REPORTS P900726 AND P897645
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX3F0-050D030US935-RLLONL
Description: 3 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6216.5 lumens
Efficiency: N/A
Efficacy: 91.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.84' x L: 3.28' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 67.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	109	109	109	109	102	102	102	102	88	88	88		76	76	76		64
1	100	96	92	89	94	90	87	84	78	76	74		68	66	64		58
2	92	85	79	74	86	79	74	70	69	65	62		60	57	55		51
3	84	75	68	62	78	70	64	59	62	57	53		54	50	47		46
4	77	67	59	53	72	63	56	51	55	50	46		48	44	41		42
5	71	60	52	46	66	56	49	44	50	44	40		44	39	36		38
6	66	54	46	40	61	51	44	38	45	39	35		40	35	32		35
7	61	49	41	36	57	46	39	34	41	35	31		36	32	28		32
8	57	45	37	32	53	42	35	30	38	32	28		33	29	25		29
9	53	41	34	29	50	39	32	27	35	29	25		31	26	23		27
10	50	38	31	26	46	36	29	25	32	27	23		29	24	21		25

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2061	2061	2061
5°	2063	2027	2040
10°	2042	1986	1973
15°	2013	1919	1869
20°	1975	1827	1742
25°	1936	1724	1620
30°	1884	1619	1465
35°	1833	1506	1329
40°	1780	1390	1173
45°	1720	1260	1032
50°	1658	1130	894
55°	1592	991	762
60°	1516	846	626
65°	1429	698	562
70°	1323	561	507
75°	1190	491	459
80°	998	407	394
85°	682	266	290

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1720 cd/sqm

TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	166.8	2.7
10°-20°	457.8	7.4
20°-30°	642.7	10.3
30°-40°	700.6	11.3
40°-50°	643.9	10.4
50°-60°	505.7	8.1
60°-70°	329.2	5.3
70°-80°	169.5	2.7
80°-90°	44.8	0.7
90°-100°	28.7	0.5
100°-110°	107.2	1.7
110°-120°	284.2	4.6
120°-130°	471.3	7.6
130°-140°	500.7	8.1
140°-150°	465.3	7.5
150°-160°	374.1	6.0
160°-170°	241.1	3.9
170°-180°	83.0	1.3
0°-30°	1267.2	20.4
0°-40°	1967.8	31.7
0°-60°	3117.4	50.1
0°-90°	3660.8	58.9
90°-120°	420.1	6.8
90°-150°	1857.5	29.9
90°-180°	2556.0	41.1
0°-180°	6216.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1779	1779	1779	1779	1779	
5°	1779	1771	1750	1765	1760	169
15°	1692	1675	1620	1589	1573	477
25°	1536	1484	1378	1312	1288	706
35°	1324	1242	1100	998	963	828
45°	1082	974	805	691	652	836
55°	823	697	523	427	396	735
65°	556	425	280	226	221	551
75°	296	184	129	118	116	313
85°	69	35	31	31	31	79
90°	1	8	13	16	17	6
95°	41	20	24	28	27	49
105°	192	211	38	45	48	205
115°	363	373	389	97	52	357
125°	513	521	533	537	539	457
135°	635	645	650	657	655	490
145°	736	736	746	751	747	460
155°	810	805	812	816	811	373
165°	854	850	852	857	852	241
175°	874	869	870	875	869	83
180°	872	872	872	872	872	

TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1779.3	1779.3	1779.3	1779.3	1779.3
2.5°	1787.3	1779.3	1761.5	1777.7	1774.4
5°	1779.3	1771.2	1750.2	1764.7	1760.0
7.5°	1764.7	1755.1	1732.6	1739.0	1730.9
10°	1745.4	1734.1	1702.0	1697.1	1687.5
12.5°	1721.3	1706.8	1663.3	1653.7	1635.9
15°	1692.3	1674.6	1619.9	1589.3	1573.2
17.5°	1658.5	1632.7	1565.0	1529.6	1503.8
20°	1619.9	1587.6	1507.1	1467.0	1431.4
22.5°	1578.0	1540.9	1447.5	1392.8	1368.7
25°	1536.1	1484.5	1378.3	1312.3	1288.1
27.5°	1486.3	1431.4	1313.9	1238.2	1201.2
30°	1433.1	1371.8	1243.0	1161.0	1117.4
32.5°	1381.6	1307.4	1175.5	1078.8	1038.5
35°	1323.6	1241.5	1099.8	998.3	962.9
37.5°	1267.2	1178.6	1029.0	917.7	877.6
40°	1207.6	1111.1	954.8	840.5	798.7
42.5°	1146.5	1043.4	880.8	761.6	721.4
45°	1082.1	974.1	805.1	690.7	652.0
47.5°	1020.9	906.6	732.7	618.3	582.9
50°	953.3	839.0	661.8	550.6	516.9
52.5°	887.2	766.4	594.2	487.9	457.4
55°	822.8	697.1	523.2	426.7	396.1
57.5°	756.8	628.0	460.5	370.4	344.6
60°	689.1	560.3	394.4	312.5	286.6
62.5°	623.2	494.4	338.1	260.9	248.1
65°	555.5	425.1	280.2	225.5	220.6
67.5°	491.1	360.7	225.5	198.0	193.2
70°	423.5	297.9	186.8	170.6	164.2
72.5°	359.1	239.9	156.2	143.4	140.1
75°	296.3	183.5	128.8	117.5	116.0
77.5°	233.5	130.4	101.5	95.0	91.7
80°	175.5	93.4	77.2	70.9	70.9
82.5°	122.3	62.9	53.1	49.9	49.9
85°	69.2	35.4	30.6	30.6	30.6
87.5°	25.8	12.8	12.8	11.3	11.3
90°	0.6	7.6	12.6	15.8	17.0
92.5°	15.8	13.3	15.2	16.4	17.0
95°	41.0	20.1	24.5	27.8	27.1
97.5°	73.8	22.1	32.1	34.1	34.7
100°	111.7	25.2	36.0	41.0	42.3
102.5°	153.3	152.1	37.2	44.1	46.1
105°	191.7	210.7	38.5	45.4	48.0
107.5°	236.5	252.3	39.8	46.7	49.2
110°	279.5	292.7	110.4	47.4	49.9



TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	319.9	331.1	320.5	48.6	50.5
115°	362.7	373.4	389.2	97.1	51.7
117.5°	399.9	412.5	423.3	333.0	167.8
120°	441.5	451.0	462.4	469.9	384.8
122.5°	476.8	487.0	499.6	503.3	504.0
125°	512.8	521.0	533.0	537.4	539.3
127.5°	545.6	554.4	564.0	570.2	570.8
130°	576.5	586.7	593.6	600.5	599.9
132.5°	608.0	616.3	623.2	628.9	628.3
135°	634.6	644.7	650.3	656.7	655.4
137.5°	662.3	669.9	676.2	682.5	680.6
140°	689.4	694.5	701.4	707.1	704.0
142.5°	712.2	716.6	724.8	729.8	726.7
145°	736.2	735.5	746.2	750.6	747.4
147.5°	756.9	755.0	765.8	768.9	766.4
150°	777.1	772.7	782.8	786.5	783.4
152.5°	794.1	789.1	798.6	802.4	798.0
155°	810.5	804.9	812.4	816.2	811.2
157.5°	823.8	818.8	824.5	828.9	823.8
160°	835.2	831.4	835.2	839.0	834.5
162.5°	845.2	841.5	844.6	849.0	843.3
165°	854.0	850.3	852.2	856.6	852.2
167.5°	861.0	857.2	859.1	863.6	857.9
170°	866.7	862.9	864.2	868.6	862.9
172.5°	870.5	866.7	868.0	872.4	866.7
175°	873.6	869.2	870.5	874.9	868.6
177.5°	874.9	870.5	871.2	875.5	869.9
180°	871.8	871.8	871.8	871.8	871.8

TEST NUMBER: P918937

CATALOG NUMBER: DFN2DIP-HX3F0-050D030US935-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	10.41	11.32	11.29	12.22	13.36	6.38	7.29	7.27	8.19	9.33
	3H	12.08	12.90	12.98	13.81	14.97	7.57	8.39	8.47	9.30	10.46
	4H	12.69	13.46	13.60	14.37	15.55	8.03	8.79	8.94	9.71	10.88
	6H	13.11	13.82	14.03	14.74	15.93	8.35	9.05	9.27	9.97	11.16
	8H	13.24	13.91	14.17	14.84	16.03	8.44	9.11	9.37	10.05	11.24
	12H	13.30	13.94	14.23	14.87	16.08	8.48	9.12	9.42	10.05	11.26
4H	2H	10.43	11.20	11.35	12.12	13.29	6.99	7.75	7.90	8.67	9.84
	3H	12.26	12.90	13.19	13.85	15.04	8.34	8.97	9.26	9.92	11.11
	4H	12.95	13.53	13.89	14.47	15.69	8.88	9.46	9.82	10.41	11.62
	6H	13.46	13.96	14.42	14.93	16.15	9.30	9.80	10.25	10.77	11.98
	8H	13.64	14.10	14.59	15.06	16.29	9.43	9.90	10.38	10.86	12.09
	12H	13.73	14.15	14.70	15.13	16.36	9.50	9.92	10.47	10.89	12.13
8H	4H	12.92	13.39	13.88	14.35	15.58	9.17	9.63	10.12	10.59	11.82
	6H	13.48	13.87	14.46	14.87	16.10	9.68	10.07	10.66	11.07	12.29
	8H	13.70	14.04	14.68	15.03	16.27	9.87	10.21	10.86	11.20	12.45
	12H	13.83	14.13	14.82	15.11	16.41	9.99	10.29	10.98	11.27	12.56
12H	4H	12.88	13.30	13.85	14.28	15.51	9.17	9.59	10.14	10.57	11.80
	6H	13.46	13.80	14.45	14.79	16.04	9.73	10.07	10.72	11.06	12.30
	8H	13.68	13.98	14.67	14.96	16.26	9.94	10.24	10.93	11.22	12.51

END OF REPORT