

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P921760

Luminaire Tested: DFN2DIP-HX3F0-090D030US940-RLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P921760
REPORT IS A COMBINATION OF REPORTS P899214 AND P896089
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX3F0-090D030US940-RLLFLL
Description: 3 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 9189.1 lumens
Efficiency: N/A
Efficacy: 79.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.84' x L: 3.28' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 115.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9968
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	113	113	113	113	107	107	107	107	97	97	97	87	87	87	78	78	78
1	104	100	96	93	99	95	92	89	86	84	81	78	76	74	70	69	68
2	95	88	82	77	90	84	79	74	76	72	68	69	66	63	63	60	58
3	87	78	71	65	83	75	68	63	68	63	58	62	58	54	56	53	50
4	80	70	62	56	76	67	60	54	61	55	51	56	51	47	51	47	44
5	74	63	54	48	70	60	53	47	55	49	44	51	45	42	46	42	39
6	69	57	48	43	65	54	47	41	50	44	39	46	41	37	42	38	35
7	64	51	43	38	61	49	42	37	46	39	35	42	37	33	39	34	31
8	59	47	39	34	57	45	38	33	42	36	31	39	34	30	36	31	28
9	56	43	36	31	53	42	35	30	39	33	28	36	31	27	33	29	26
10	52	40	33	28	50	39	32	27	36	30	26	33	28	25	31	27	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3842	3842	3842
5°	3847	3779	3803
10°	3807	3702	3677
15°	3753	3577	3484
20°	3682	3406	3248
25°	3609	3214	3019
30°	3512	3018	2731
35°	3416	2808	2477
40°	3319	2590	2187
45°	3207	2349	1924
50°	3090	2107	1667
55°	2968	1847	1420
60°	2827	1577	1167
65°	2664	1302	1048
70°	2467	1045	945
75°	2219	916	855
80°	1860	760	735
85°	1270	495	540

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 3207 cd/sqm

TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLFL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	310.9	3.4
10°-20°	853.4	9.3
20°-30°	1198.1	13.0
30°-40°	1306.0	14.2
40°-50°	1200.4	13.1
50°-60°	942.7	10.3
60°-70°	613.6	6.7
70°-80°	315.9	3.4
80°-90°	83.0	0.9
90°-100°	52.3	0.6
100°-110°	166.3	1.8
110°-120°	284.7	3.1
120°-130°	374.4	4.1
130°-140°	420.2	4.6
140°-150°	412.1	4.5
150°-160°	345.7	3.8
160°-170°	229.2	2.5
170°-180°	80.1	0.9
0°-30°	2362.4	25.7
0°-40°	3668.4	39.9
0°-60°	5811.5	63.2
0°-90°	6824.0	74.3
90°-120°	503.4	5.5
90°-150°	1710.0	18.6
90°-180°	2365.0	25.7
0°-180°	9189.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3317	3317	3317	3317	3317	
5°	3317	3302	3263	3290	3281	315
15°	3155	3122	3020	2963	2933	889
25°	2864	2768	2570	2446	2401	1317
35°	2468	2314	2050	1861	1795	1544
45°	2017	1816	1501	1288	1216	1558
55°	1534	1300	975	796	738	1371
65°	1036	792	522	420	411	1027
75°	552	342	240	219	216	584
85°	129	66	57	57	57	148
90°	1	9	25	24	24	9
95°	37	44	46	46	44	41
105°	154	156	157	158	158	162
115°	286	290	288	288	286	283
125°	416	422	420	418	417	371
135°	537	545	547	546	544	415
145°	652	658	662	662	660	408
155°	746	748	750	754	752	343
165°	812	811	811	816	812	229
175°	844	842	841	846	842	80
180°	846	846	846	846	846	

TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLFL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3316.9	3316.9	3316.9	3316.9	3316.9
2.5°	3331.9	3316.9	3283.7	3314.0	3308.0
5°	3316.9	3301.9	3262.8	3289.8	3280.9
7.5°	3289.8	3272.0	3230.0	3241.7	3226.7
10°	3253.9	3232.8	3173.0	3163.7	3145.9
12.5°	3208.9	3181.9	3100.7	3082.8	3049.6
15°	3154.8	3121.7	3019.8	2962.7	2932.8
17.5°	3091.7	3043.7	2917.5	2851.6	2803.5
20°	3019.8	2959.6	2809.5	2734.7	2668.4
22.5°	2941.8	2872.6	2698.4	2596.5	2551.6
25°	2863.7	2767.5	2569.5	2446.5	2401.3
27.5°	2770.7	2668.4	2449.4	2308.3	2239.2
30°	2671.7	2557.3	2317.2	2164.4	2083.1
32.5°	2575.4	2437.2	2191.4	2011.2	1936.0
35°	2467.5	2314.3	2050.3	1861.2	1794.9
37.5°	2362.4	2197.2	1918.2	1710.8	1636.0
40°	2251.3	2071.4	1779.9	1566.9	1488.9
42.5°	2137.3	1945.3	1642.0	1419.8	1344.9
45°	2017.2	1816.0	1500.9	1287.5	1215.6
47.5°	1903.2	1690.1	1365.9	1152.5	1086.6
50°	1777.1	1564.0	1233.8	1026.4	963.7
52.5°	1653.9	1428.7	1107.7	909.5	852.6
55°	1533.7	1299.7	975.4	795.6	738.5
57.5°	1410.9	1170.7	858.6	690.5	642.4
60°	1284.7	1044.5	735.4	582.5	534.4
62.5°	1161.8	921.7	630.3	486.3	462.4
65°	1035.6	792.4	522.3	420.4	411.2
67.5°	915.6	672.3	420.4	369.1	360.2
70°	789.5	555.4	348.1	318.2	306.0
72.5°	669.4	447.1	291.1	267.2	261.2
75°	552.2	342.1	240.1	219.1	216.2
77.5°	435.3	243.0	189.1	177.1	171.0
80°	327.1	174.2	143.9	132.2	132.2
82.5°	228.0	117.2	99.1	93.0	93.0
85°	128.9	65.9	57.0	57.0	57.0
87.5°	48.1	23.9	23.9	21.0	21.0
90°	0.8	9.2	25.0	23.5	24.3
92.5°	15.8	21.4	22.2	22.9	22.9
95°	37.3	44.4	45.7	45.7	44.4
97.5°	62.0	68.6	71.4	71.4	71.4
100°	90.5	96.4	98.4	98.4	97.7
102.5°	120.6	125.0	127.8	128.6	127.8
105°	153.6	155.6	157.1	158.4	158.4
107.5°	186.2	189.2	189.2	189.8	186.2
110°	217.8	221.9	221.9	221.9	219.9



TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	252.0	256.4	255.6	253.5	252.0
115°	285.7	289.7	288.5	287.8	285.7
117.5°	319.1	324.7	321.1	319.1	317.0
120°	352.8	358.4	352.8	352.8	350.4
122.5°	383.3	390.5	386.9	384.9	383.3
125°	415.5	421.9	419.8	417.5	416.8
127.5°	446.8	454.8	452.0	448.9	446.8
130°	476.2	485.4	484.1	482.6	479.7
132.5°	509.1	516.2	516.7	513.2	511.1
135°	537.4	545.3	546.9	546.1	544.0
137.5°	569.0	575.4	576.7	576.2	573.1
140°	596.8	603.2	606.8	606.8	604.0
142.5°	625.4	631.8	633.8	634.6	631.8
145°	652.5	657.5	661.6	662.4	659.6
147.5°	676.7	683.1	686.1	687.4	684.6
150°	701.7	706.1	708.8	711.1	708.8
152.5°	723.9	728.2	731.7	734.6	731.7
155°	746.1	748.1	750.4	753.9	751.7
157.5°	765.2	766.7	768.0	773.1	769.5
160°	782.3	783.8	784.6	788.9	785.9
162.5°	798.1	798.1	798.9	803.7	800.1
165°	811.6	810.8	810.8	815.9	812.3
167.5°	823.9	821.5	821.5	826.6	823.0
170°	833.0	831.0	830.3	835.4	831.0
172.5°	839.4	837.4	836.6	841.7	837.4
175°	844.5	842.5	841.0	846.1	841.7
177.5°	847.3	845.3	843.7	848.1	843.7
180°	846.1	846.1	846.1	846.1	846.1

TEST NUMBER: P921760

CATALOG NUMBER: DFN2DIP-HX3F0-090D030US940-RLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.80	14.88	14.52	15.62	16.50	9.78	10.85	10.50	11.59	12.47
	3H	15.49	16.45	16.23	17.20	18.11	10.98	11.94	11.72	12.69	13.60
	4H	16.10	17.01	16.86	17.77	18.69	11.44	12.35	12.19	13.10	14.03
	6H	16.53	17.37	17.30	18.14	19.07	11.77	12.60	12.54	13.37	14.31
	8H	16.66	17.46	17.44	18.24	19.18	11.86	12.66	12.64	13.45	14.38
	12H	16.73	17.49	17.51	18.27	19.23	11.91	12.67	12.70	13.45	14.42
4H	2H	13.85	14.75	14.61	15.51	16.44	10.40	11.31	11.16	12.06	12.99
	3H	15.69	16.44	16.46	17.24	18.18	11.76	12.52	12.54	13.31	14.25
	4H	16.39	17.07	17.17	17.86	18.83	12.32	13.00	13.10	13.80	14.77
	6H	16.91	17.50	17.71	18.32	19.29	12.75	13.34	13.55	14.15	15.13
	8H	17.08	17.63	17.89	18.45	19.44	12.88	13.43	13.68	14.24	15.23
	12H	17.18	17.68	18.01	18.52	19.51	12.95	13.45	13.78	14.28	15.28
8H	4H	16.37	16.92	17.18	17.74	18.72	12.61	13.16	13.42	13.98	14.97
	6H	16.94	17.39	17.77	18.25	19.24	13.13	13.59	13.97	14.45	15.43
	8H	17.15	17.55	18.00	18.41	19.41	13.32	13.73	14.17	14.58	15.59
	12H	17.29	17.65	18.14	18.49	19.56	13.45	13.80	14.30	14.65	15.71
12H	4H	16.33	16.83	17.16	17.66	18.66	12.63	13.12	13.45	13.96	14.95
	6H	16.91	17.32	17.76	18.17	19.18	13.18	13.59	14.03	14.44	15.45
	8H	17.14	17.49	17.99	18.34	19.40	13.40	13.75	14.25	14.60	15.66