

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P927099

Luminaire Tested: DFN2DIP-HX4F0-100D070US830-FLLFLL

Issue Date: 12/12/2024

Test Information

Test Method: LM-79-2019
Report Number: P927099
REPORT IS A COMBINATION OF REPORTS P899365 AND P896187
Test Lab: INNOVATION CENTER
Issue Date: 12/12/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX4F0-100D070US830-FLLFLL
Description: 4 foot, Hexagon Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 15169.6 lumens
Efficiency: N/A
Efficacy: 99.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.54' x L: 4.09' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 152.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.946
Total Harmonic Distortion (THDi): 0.132
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67
1	100	96	92	88	94	90	87	83	79	76	74	68	67	65	59	58	56
2	91	84	78	72	85	79	73	68	69	65	61	60	57	54	52	50	48
3	83	74	66	60	78	69	63	57	61	56	51	53	49	46	46	43	40
4	76	65	57	51	71	61	54	49	54	48	44	47	43	39	41	38	35
5	70	58	50	44	65	55	47	42	49	43	38	43	38	34	37	33	30
6	65	52	44	38	60	49	42	36	44	38	33	39	34	30	34	30	27
7	60	47	39	34	56	45	37	32	40	34	29	35	30	27	31	27	24
8	56	43	35	30	52	41	34	29	36	30	26	32	27	24	28	24	21
9	52	39	32	27	49	37	30	26	33	28	23	30	25	21	26	22	19
10	49	36	29	24	45	34	28	23	31	25	21	27	23	19	24	20	18

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2727	2727	2727
5°	2732	2689	2707
10°	2710	2653	2671
15°	2670	2610	2614
20°	2616	2549	2555
25°	2563	2477	2487
30°	2496	2410	2401
35°	2433	2330	2310
40°	2355	2250	2224
45°	2277	2170	2135
50°	2192	2086	2032
55°	2103	1988	1938
60°	2002	1872	1830
65°	1893	1753	1703
70°	1753	1606	1566
75°	1559	1432	1439
80°	1327	1209	1197
85°	963	824	797

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 2277 cd/sqm

TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	345.2	2.3
10°-20°	971.2	6.4
20°-30°	1427.2	9.4
30°-40°	1657.6	10.9
40°-50°	1655.6	10.9
50°-60°	1443.6	9.5
60°-70°	1067.2	7.0
70°-80°	603.8	4.0
80°-90°	165.3	1.1
90°-100°	129.1	0.9
100°-110°	410.2	2.7
110°-120°	702.0	4.6
120°-130°	923.3	6.1
130°-140°	1036.4	6.8
140°-150°	1016.3	6.7
150°-160°	852.5	5.6
160°-170°	565.4	3.7
170°-180°	197.6	1.3
0°-30°	2743.6	18.1
0°-40°	4401.2	29.0
0°-60°	7500.4	49.4
0°-90°	9336.7	61.5
90°-120°	1241.4	8.2
90°-150°	4217.4	27.8
90°-180°	5833.0	38.5
0°-180°	15169.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3667	3667	3667	3667	3667	
5°	3667	3654	3615	3643	3636	348
15°	3491	3470	3424	3438	3421	983
25°	3160	3132	3072	3078	3072	1454
35°	2726	2691	2634	2613	2595	1702
45°	2218	2194	2140	2102	2088	1712
55°	1679	1658	1615	1573	1555	1501
65°	1132	1111	1076	1044	1026	1119
75°	592	586	568	547	554	632
85°	144	141	138	127	124	161
90°	2	23	62	58	60	15
95°	92	109	113	113	109	102
105°	379	384	388	391	391	400
115°	704	715	712	710	704	697
125°	1025	1040	1035	1030	1028	916
135°	1325	1345	1349	1347	1342	1024
145°	1609	1622	1632	1634	1627	1005
155°	1840	1845	1851	1860	1854	847
165°	2002	2000	2000	2012	2004	565
175°	2083	2078	2074	2086	2076	198
180°	2086	2086	2086	2086	2086	

TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3667.4	3667.4	3667.4	3667.4	3667.4
2.5°	3688.7	3671.0	3632.1	3667.4	3660.6
5°	3667.4	3653.5	3614.6	3642.7	3635.9
7.5°	3642.7	3621.7	3582.7	3611.2	3604.1
10°	3604.1	3579.4	3537.1	3565.2	3554.7
12.5°	3551.0	3530.0	3487.7	3505.3	3498.2
15°	3491.1	3470.2	3424.1	3438.3	3420.8
17.5°	3417.0	3396.1	3350.0	3367.6	3350.0
20°	3335.8	3314.9	3265.5	3275.9	3262.1
22.5°	3255.0	3223.3	3177.2	3177.2	3170.1
25°	3159.6	3131.6	3071.7	3078.4	3071.7
27.5°	3053.7	3029.0	2983.4	2972.9	2955.3
30°	2948.2	2919.8	2867.0	2856.5	2842.3
32.5°	2835.2	2814.3	2757.8	2736.5	2722.2
35°	2726.0	2690.8	2634.3	2613.0	2595.4
37.5°	2602.5	2570.7	2514.2	2489.5	2471.9
40°	2475.7	2447.2	2390.7	2359.4	2345.1
42.5°	2352.2	2323.7	2267.7	2232.1	2211.2
45°	2218.3	2193.6	2140.4	2101.9	2087.7
47.5°	2087.7	2063.0	2006.5	1967.6	1946.6
50°	1950.0	1932.4	1883.0	1833.6	1816.1
52.5°	1816.1	1791.4	1745.7	1706.9	1682.2
55°	1678.8	1657.5	1615.2	1572.8	1555.3
57.5°	1541.1	1523.5	1477.5	1435.2	1421.0
60°	1403.4	1389.5	1340.1	1301.2	1290.8
62.5°	1269.5	1244.8	1209.6	1174.4	1160.2
65°	1132.1	1110.8	1075.7	1043.8	1026.3
67.5°	991.1	973.1	941.7	917.1	902.8
70°	860.5	846.3	814.5	789.8	776.0
72.5°	726.6	712.3	694.8	670.1	659.6
75°	592.3	585.6	567.6	546.6	553.7
77.5°	472.6	458.3	451.2	440.7	430.3
80°	352.8	349.1	341.9	331.5	324.4
82.5°	239.9	239.9	236.5	222.2	222.2
85°	144.4	141.1	137.7	126.9	123.5
87.5°	63.6	56.5	49.4	38.9	35.2
90°	1.9	22.6	61.6	57.9	59.8
92.5°	39.0	52.9	54.8	56.6	56.6
95°	91.8	109.4	112.6	112.6	109.4
97.5°	152.9	169.2	176.2	176.2	176.2
100°	223.3	237.8	242.8	242.8	240.9
102.5°	297.5	308.2	315.2	317.1	315.2
105°	378.7	383.7	387.5	390.7	390.7
107.5°	459.2	466.7	466.7	468.0	459.2
110°	537.2	547.3	547.3	547.3	542.2



TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	621.5	632.2	630.3	625.3	621.5
115°	704.5	714.6	711.5	709.6	704.5
117.5°	786.9	800.7	792.0	786.9	781.9
120°	869.9	883.8	869.9	869.9	864.3
122.5°	945.4	963.0	954.3	949.2	945.4
125°	1024.7	1040.4	1035.4	1029.8	1027.9
127.5°	1102.1	1121.6	1114.7	1107.2	1102.1
130°	1174.4	1197.1	1194.0	1190.2	1183.2
132.5°	1255.6	1273.2	1274.4	1265.7	1260.6
135°	1325.4	1344.9	1348.7	1346.7	1341.7
137.5°	1403.4	1419.1	1422.2	1421.0	1413.5
140°	1472.0	1487.7	1496.5	1496.5	1489.6
142.5°	1542.4	1558.1	1563.1	1565.0	1558.1
145°	1609.1	1621.7	1631.8	1633.6	1626.8
147.5°	1668.9	1684.6	1692.2	1695.3	1688.4
150°	1730.5	1741.2	1748.1	1753.8	1748.1
152.5°	1785.2	1795.9	1804.7	1811.7	1804.7
155°	1839.9	1844.9	1850.7	1859.5	1853.8
157.5°	1887.2	1890.9	1894.0	1906.7	1897.8
160°	1929.3	1933.1	1935.0	1945.6	1938.1
162.5°	1968.3	1968.3	1970.2	1982.1	1973.3
165°	2001.6	1999.7	1999.7	2012.3	2003.5
167.5°	2031.8	2026.2	2026.2	2038.7	2030.0
170°	2054.5	2049.5	2047.6	2060.1	2049.5
172.5°	2070.2	2065.1	2063.2	2075.9	2065.1
175°	2082.7	2077.7	2074.0	2086.5	2075.9
177.5°	2089.7	2084.6	2080.9	2091.6	2080.9
180°	2086.5	2086.5	2086.5	2086.5	2086.5

TEST NUMBER: P927099

CATALOG NUMBER: DFN2DIP-HX4F0-100D070US830-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.76	12.73	12.61	13.61	14.70	11.33	12.30	12.18	13.18	14.27
	3H	13.43	14.31	14.29	15.19	16.31	12.96	13.83	13.82	14.71	15.84
	4H	14.02	14.85	14.90	15.74	16.87	13.55	14.38	14.43	15.27	16.40
	6H	14.43	15.19	15.32	16.09	17.23	13.95	14.72	14.84	15.61	16.76
	8H	14.54	15.26	15.44	16.18	17.32	14.06	14.79	14.96	15.70	16.85
	12H	14.59	15.28	15.50	16.19	17.36	14.11	14.80	15.01	15.71	16.88
4H	2H	12.24	13.06	13.12	13.95	15.09	11.89	12.72	12.78	13.61	14.74
	3H	14.11	14.80	15.01	15.72	16.87	13.72	14.41	14.62	15.33	16.48
	4H	14.83	15.46	15.74	16.38	17.55	14.43	15.06	15.33	15.97	17.15
	6H	15.36	15.90	16.28	16.84	18.02	14.95	15.49	15.87	16.43	17.61
	8H	15.51	16.02	16.43	16.95	18.14	15.10	15.60	16.02	16.54	17.73
	12H	15.59	16.05	16.53	17.00	18.19	15.16	15.62	16.11	16.58	17.77
8H	4H	15.04	15.55	15.96	16.48	17.67	14.68	15.19	15.60	16.12	17.31
	6H	15.68	16.10	16.63	17.07	18.26	15.31	15.73	16.26	16.71	17.90
	8H	15.90	16.27	16.86	17.24	18.44	15.53	15.90	16.49	16.87	18.08
	12H	16.04	16.37	17.00	17.33	18.58	15.65	15.98	16.62	16.94	18.19
12H	4H	15.03	15.49	15.97	16.44	17.64	14.68	15.14	15.62	16.09	17.28
	6H	15.71	16.08	16.67	17.05	18.25	15.36	15.73	16.32	16.70	17.90
	8H	15.96	16.28	16.92	17.24	18.50	15.60	15.93	16.56	16.89	18.14