

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P927646

Luminaire Tested: DFN2DIP-HX4F0-070D080US840-RLLONL

Issue Date: 12/12/2024

Test Information

Test Method: LM-79-2019
Report Number: P927646
REPORT IS A COMBINATION OF REPORTS P900898 AND P896187
Test Lab: INNOVATION CENTER
Issue Date: 12/12/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX4F0-070D080US840-RLLONL
Description: 4 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14005.9 lumens
Efficiency: N/A
Efficacy: 112.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.54' x L: 4.09' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 124.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9972
Total Harmonic Distortion (THDi): 0.128
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	105	105	105	105	96	96	96	96	79	79	79	64	64	64	50	50	50
1	97	92	89	85	88	85	82	79	70	68	66	57	55	54	44	44	43
2	88	81	75	70	81	75	70	65	62	58	55	50	48	46	40	38	37
3	81	72	65	59	74	66	60	55	55	51	47	45	42	39	36	33	32
4	74	64	56	50	68	59	52	47	49	44	40	40	37	34	32	30	28
5	68	57	49	43	62	53	46	41	44	39	35	36	33	30	29	26	24
6	63	51	43	38	57	47	40	35	40	35	31	33	29	26	26	24	22
7	58	46	39	33	53	43	36	31	36	31	27	30	26	23	24	21	19
8	54	42	35	29	49	39	32	28	33	28	24	28	24	21	22	20	17
9	50	38	31	26	46	36	29	25	30	25	22	25	22	19	21	18	16
10	47	35	28	24	43	33	27	22	28	23	20	24	20	17	19	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2172	2172	2172
5°	2176	2138	2152
10°	2155	2096	2082
15°	2125	2027	1974
20°	2086	1932	1841
25°	2046	1825	1713
30°	1992	1715	1550
35°	1940	1598	1407
40°	1886	1476	1243
45°	1824	1340	1095
50°	1759	1204	950
55°	1692	1057	811
60°	1614	905	667
65°	1525	750	601
70°	1416	605	544
75°	1280	533	495
80°	1083	448	430
85°	757	300	324

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1824 cd/sqm

TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	273.8	2.0
10°-20°	751.6	5.4
20°-30°	1055.3	7.5
30°-40°	1150.3	8.2
40°-50°	1057.3	7.5
50°-60°	830.3	5.9
60°-70°	540.5	3.9
70°-80°	278.2	2.0
80°-90°	75.8	0.5
90°-100°	89.9	0.6
100°-110°	335.1	2.4
110°-120°	888.8	6.3
120°-130°	1474.2	10.5
130°-140°	1565.9	11.2
140°-150°	1455.3	10.4
150°-160°	1170.1	8.4
160°-170°	754.0	5.4
170°-180°	259.5	1.9
0°-30°	2080.7	14.9
0°-40°	3231.0	23.1
0°-60°	5118.6	36.5
0°-90°	6013.1	42.9
90°-120°	1313.9	9.4
90°-150°	5809.3	41.5
90°-180°	7993.0	57.1
0°-180°	14005.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2922	2922	2922	2922	2922	
5°	2922	2908	2874	2898	2890	277
15°	2779	2750	2660	2610	2583	783
25°	2522	2438	2263	2155	2115	1160
35°	2173	2038	1806	1639	1581	1360
45°	1777	1599	1322	1134	1071	1372
55°	1351	1145	859	701	650	1207
65°	912	698	460	370	362	904
75°	486	301	212	193	190	514
85°	114	58	50	50	50	130
90°	2	24	39	49	53	13
95°	128	63	77	87	85	152
105°	600	659	120	142	150	641
115°	1134	1168	1217	304	162	1117
125°	1604	1630	1667	1681	1687	1430
135°	1985	2016	2034	2054	2050	1533
145°	2302	2300	2334	2348	2338	1440
155°	2535	2517	2541	2553	2537	1168
165°	2671	2659	2665	2679	2665	755
175°	2732	2718	2722	2736	2717	260
180°	2726	2726	2726	2726	2726	

TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2921.5	2921.5	2921.5	2921.5	2921.5
2.5°	2934.6	2921.5	2892.3	2918.9	2913.6
5°	2921.5	2908.2	2873.8	2897.6	2889.7
7.5°	2897.6	2881.9	2844.9	2855.2	2842.1
10°	2865.9	2847.4	2794.6	2786.5	2770.8
12.5°	2826.3	2802.5	2731.0	2715.3	2686.1
15°	2778.7	2749.5	2659.7	2609.5	2583.2
17.5°	2723.1	2680.8	2569.7	2511.6	2469.3
20°	2659.7	2606.7	2474.6	2408.7	2350.3
22.5°	2591.0	2530.2	2376.7	2286.9	2247.4
25°	2522.3	2437.6	2263.1	2154.8	2115.0
27.5°	2440.4	2350.3	2157.3	2033.1	1972.2
30°	2353.1	2252.5	2040.9	1906.3	1834.8
32.5°	2268.4	2146.7	1930.1	1771.4	1705.1
35°	2173.3	2038.4	1805.9	1639.3	1580.9
37.5°	2080.8	1935.2	1689.5	1506.8	1441.0
40°	1982.8	1824.4	1567.7	1380.1	1311.3
42.5°	1882.5	1713.3	1446.2	1250.4	1184.6
45°	1776.7	1599.4	1322.0	1134.1	1070.7
47.5°	1676.3	1488.6	1203.1	1015.2	957.1
50°	1565.2	1377.6	1086.6	904.1	848.8
52.5°	1456.6	1258.3	975.6	801.1	750.9
55°	1350.9	1144.7	859.1	700.7	650.5
57.5°	1242.7	1031.1	756.2	608.1	565.8
60°	1131.6	920.0	647.7	513.1	470.7
62.5°	1023.2	811.8	555.1	428.4	407.3
65°	912.2	697.9	460.1	370.3	362.1
67.5°	806.4	592.1	370.3	325.1	317.3
70°	695.3	489.1	306.6	280.2	269.5
72.5°	589.6	393.8	256.4	235.4	230.0
75°	486.4	301.2	211.5	193.0	190.4
77.5°	383.4	214.0	166.6	155.9	150.7
80°	288.1	153.4	126.8	116.4	116.4
82.5°	200.8	103.2	87.2	81.9	81.9
85°	113.6	58.1	50.2	50.2	50.2
87.5°	42.3	21.0	21.0	18.5	18.5
90°	1.9	23.6	39.4	49.4	53.2
92.5°	49.4	41.5	47.4	51.3	53.2
95°	128.1	63.0	76.8	86.9	84.8
97.5°	230.7	69.1	100.5	106.6	108.5
100°	349.3	79.0	112.5	128.1	132.1
102.5°	479.4	475.5	116.4	137.9	144.1
105°	599.7	659.0	120.4	142.0	150.0
107.5°	739.8	789.0	124.4	145.9	153.9
110°	874.1	915.3	345.4	148.0	155.8

TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1000.3	1035.7	1002.2	151.8	157.9
115°	1134.3	1167.8	1217.2	303.8	161.9
117.5°	1250.7	1290.1	1323.8	1041.5	524.8
120°	1381.0	1410.5	1446.1	1469.8	1203.4
122.5°	1491.3	1523.0	1562.6	1574.3	1576.4
125°	1603.8	1629.5	1667.0	1680.8	1686.7
127.5°	1706.4	1734.0	1763.8	1783.4	1785.3
130°	1803.1	1834.7	1856.3	1878.1	1876.2
132.5°	1901.8	1927.5	1949.1	1966.9	1965.0
135°	1984.7	2016.3	2033.8	2053.8	2049.8
137.5°	2071.4	2095.0	2114.9	2134.6	2128.8
140°	2156.1	2172.1	2193.7	2211.5	2201.6
142.5°	2227.4	2241.2	2266.7	2282.5	2272.6
145°	2302.3	2300.2	2333.7	2347.6	2337.7
147.5°	2367.3	2361.4	2394.8	2404.7	2397.0
150°	2430.5	2416.7	2448.3	2460.0	2450.2
152.5°	2483.7	2468.0	2497.4	2509.5	2495.6
155°	2535.0	2517.4	2541.1	2552.8	2537.1
157.5°	2576.4	2560.8	2578.5	2592.4	2576.4
160°	2612.0	2600.1	2612.0	2623.8	2609.9
162.5°	2643.5	2631.7	2641.5	2655.4	2637.6
165°	2671.1	2659.4	2665.3	2679.0	2665.3
167.5°	2692.8	2680.9	2687.0	2700.8	2683.0
170°	2710.7	2698.7	2702.7	2716.6	2698.7
172.5°	2722.4	2710.7	2714.6	2728.5	2710.7
175°	2732.2	2718.4	2722.4	2736.2	2716.6
177.5°	2736.2	2722.4	2724.4	2738.3	2720.5
180°	2726.4	2726.4	2726.4	2726.4	2726.4



TEST NUMBER: P927646

CATALOG NUMBER: DFN2DIP-HX4F0-070D080US840-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	9.15	9.92	10.17	10.95	12.32	5.12	5.89	6.14	6.92	8.29
	3H	10.82	11.51	11.85	12.55	13.94	6.30	7.00	7.34	8.03	9.42
	4H	11.43	12.08	12.47	13.12	14.52	6.75	7.41	7.80	8.45	9.85
	6H	11.85	12.45	12.90	13.49	14.90	7.07	7.68	8.13	8.72	10.13
	8H	11.97	12.55	13.03	13.60	15.01	7.16	7.74	8.22	8.80	10.20
	12H	12.03	12.58	13.09	13.63	15.06	7.21	7.75	8.27	8.80	10.23
4H	2H	9.16	9.81	10.21	10.85	12.25	5.71	6.36	6.76	7.40	8.80
	3H	10.98	11.53	12.04	12.59	14.01	7.06	7.60	8.11	8.67	10.08
	4H	11.67	12.17	12.74	13.23	14.66	7.60	8.10	8.67	9.16	10.59
	6H	12.19	12.62	13.26	13.70	15.12	8.02	8.45	9.09	9.53	10.96
	8H	12.36	12.76	13.44	13.83	15.28	8.15	8.55	9.22	9.62	11.07
	12H	12.45	12.82	13.55	13.90	15.35	8.21	8.57	9.30	9.66	11.11
8H	4H	11.64	12.04	12.71	13.11	14.55	7.88	8.28	8.95	9.35	10.80
	6H	12.20	12.53	13.30	13.65	15.09	8.40	8.73	9.49	9.84	11.28
	8H	12.42	12.71	13.52	13.81	15.27	8.59	8.88	9.69	9.98	11.44
	12H	12.56	12.81	13.66	13.90	15.40	8.71	8.96	9.81	10.06	11.56
12H	4H	11.59	11.95	12.68	13.03	14.48	7.88	8.24	8.97	9.33	10.78
	6H	12.18	12.47	13.28	13.57	15.03	8.45	8.74	9.55	9.83	11.29
	8H	12.40	12.65	13.50	13.74	15.24	8.66	8.91	9.76	10.00	11.50