

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P927818

Luminaire Tested: DFN2DIP-HX4F0-120D060US840-RLLONL

Issue Date: 12/12/2024

Test Information

Test Method: LM-79-2019
Report Number: P927818
REPORT IS A COMBINATION OF REPORTS P900872 AND P896187
Test Lab: INNOVATION CENTER
Issue Date: 12/12/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX4F0-120D060US840-RLLONL
Description: 4 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 16298.2 lumens
Efficiency: N/A
Efficacy: 95.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.54' x L: 4.09' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 170.2
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9954
Total Harmonic Distortion (THDi): 0.076
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	91	91	91	79	79	79	68	68	68
1	101	97	93	90	95	91	88	85	80	78	76	71	69	67	61	60	59
2	93	86	80	75	87	81	75	71	71	67	64	63	60	57	55	52	51
3	85	76	69	63	80	72	65	60	63	58	54	56	52	49	49	46	44
4	78	68	60	54	73	64	57	52	57	51	47	50	46	43	44	41	38
5	72	61	53	47	67	57	50	45	51	45	41	46	41	37	40	37	34
6	67	55	47	41	62	52	45	39	46	41	36	41	37	33	37	33	30
7	62	50	42	36	58	47	40	35	42	36	32	38	33	30	34	30	27
8	58	45	38	32	54	43	36	31	39	33	29	35	30	27	31	27	24
9	54	42	34	29	51	40	33	28	36	30	26	32	27	24	29	25	22
10	50	38	31	26	47	37	30	25	33	28	24	30	25	22	27	23	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3724	3724	3724
5°	3730	3665	3688
10°	3694	3594	3569
15°	3643	3475	3383
20°	3576	3312	3156
25°	3508	3129	2936
30°	3415	2941	2657
35°	3325	2739	2412
40°	3233	2530	2132
45°	3126	2298	1877
50°	3016	2063	1628
55°	2901	1813	1390
60°	2767	1551	1144
65°	2614	1285	1030
70°	2428	1037	932
75°	2195	915	849
80°	1857	768	736
85°	1299	515	555

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3126 cd/sqm

TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	469.4	2.9
10°-20°	1288.5	7.9
20°-30°	1809.0	11.1
30°-40°	1972.0	12.1
40°-50°	1812.5	11.1
50°-60°	1423.4	8.7
60°-70°	926.5	5.7
70°-80°	476.9	2.9
80°-90°	125.3	0.8
90°-100°	67.4	0.4
100°-110°	251.3	1.5
110°-120°	666.6	4.1
120°-130°	1105.6	6.8
130°-140°	1174.4	7.2
140°-150°	1091.5	6.7
150°-160°	877.5	5.4
160°-170°	565.5	3.5
170°-180°	194.6	1.2
0°-30°	3566.9	21.9
0°-40°	5538.9	34.0
0°-60°	8774.8	53.8
0°-90°	10303.6	63.2
90°-120°	985.4	6.0
90°-150°	4357.0	26.7
90°-180°	5995.0	36.8
0°-180°	16298.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	5008	5008	5008	5008	5008	
5°	5008	4986	4926	4967	4954	475
15°	4763	4713	4560	4473	4428	1342
25°	4324	4179	3880	3694	3626	1989
35°	3726	3494	3096	2810	2710	2332
45°	3046	2742	2266	1944	1835	2352
55°	2316	1962	1473	1201	1115	2069
65°	1564	1196	789	635	621	1550
75°	834	516	363	331	326	882
85°	195	100	86	86	86	224
90°	1	18	30	37	40	15
95°	96	47	58	65	64	114
105°	450	494	90	106	112	481
115°	851	876	913	228	121	838
125°	1203	1222	1250	1261	1265	1073
135°	1488	1512	1525	1540	1537	1150
145°	1727	1725	1750	1761	1753	1080
155°	1901	1888	1906	1915	1903	876
165°	2003	1995	1999	2009	1999	566
175°	2049	2039	2042	2052	2037	195
180°	2045	2045	2045	2045	2045	

TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	5008.2	5008.2	5008.2	5008.2	5008.2
2.5°	5030.8	5008.2	4958.2	5003.9	4994.7
5°	5008.2	4985.6	4926.4	4967.3	4953.9
7.5°	4967.3	4940.3	4876.9	4894.7	4872.1
10°	4913.0	4881.3	4790.8	4776.9	4750.0
12.5°	4845.1	4804.3	4681.6	4654.8	4604.8
15°	4763.4	4713.4	4559.5	4473.4	4428.3
17.5°	4668.2	4595.6	4405.2	4305.7	4233.1
20°	4559.5	4468.7	4242.2	4129.2	4029.1
22.5°	4441.7	4337.4	4074.3	3920.4	3852.7
25°	4324.0	4178.7	3879.6	3693.9	3625.7
27.5°	4183.5	4029.1	3698.3	3485.3	3380.9
30°	4033.9	3861.4	3498.8	3267.9	3145.3
32.5°	3888.7	3680.0	3308.8	3036.7	2923.2
35°	3725.8	3494.4	3095.7	2810.2	2710.1
37.5°	3567.0	3317.5	2896.2	2583.2	2470.2
40°	3399.2	3127.6	2687.6	2365.9	2248.0
42.5°	3227.0	2937.1	2479.4	2143.7	2030.7
45°	3045.8	2741.9	2266.3	1944.2	1835.4
47.5°	2873.6	2552.0	2062.4	1740.3	1640.7
50°	2683.2	2361.5	1862.9	1549.8	1455.1
52.5°	2497.1	2157.1	1672.4	1373.3	1287.3
55°	2315.9	1962.4	1472.9	1201.2	1115.1
57.5°	2130.2	1767.7	1296.4	1042.5	969.9
60°	1939.8	1577.2	1110.3	879.5	806.9
62.5°	1754.2	1391.6	951.6	734.3	698.2
65°	1563.8	1196.4	788.7	634.8	620.8
67.5°	1382.5	1015.1	634.8	557.3	543.9
70°	1192.1	838.6	525.6	480.4	462.1
72.5°	1010.8	675.2	439.5	403.4	394.3
75°	833.8	516.4	362.6	330.8	326.5
77.5°	657.4	366.9	285.7	267.4	258.2
80°	493.9	263.1	217.3	199.5	199.5
82.5°	344.3	176.9	149.6	140.4	140.4
85°	194.8	99.6	86.0	86.0	86.0
87.5°	72.6	36.0	36.0	31.7	31.7
90°	1.4	17.8	29.5	37.1	39.9
92.5°	37.1	31.1	35.4	38.5	39.9
95°	96.1	47.3	57.7	65.2	63.6
97.5°	173.1	51.8	75.3	80.0	81.4
100°	261.9	59.2	84.3	96.1	99.1
102.5°	359.5	356.7	87.3	103.5	108.0
105°	449.8	494.2	90.3	106.4	112.5
107.5°	554.9	591.7	93.3	109.5	115.4
110°	655.6	686.5	259.0	111.1	116.8

TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	750.2	776.7	751.6	113.8	118.4
115°	850.8	875.9	913.0	227.9	121.4
117.5°	938.0	967.6	992.8	781.2	393.5
120°	1035.8	1057.9	1084.6	1102.3	902.6
122.5°	1118.5	1142.2	1171.9	1180.7	1182.3
125°	1202.9	1222.2	1250.2	1260.6	1265.0
127.5°	1279.8	1300.5	1322.8	1337.6	1339.0
130°	1352.3	1376.1	1392.2	1408.6	1407.2
132.5°	1426.3	1445.6	1461.8	1475.1	1473.7
135°	1488.5	1512.3	1525.4	1540.3	1537.3
137.5°	1553.5	1571.2	1586.2	1600.9	1596.6
140°	1617.1	1629.1	1645.3	1658.6	1651.2
142.5°	1670.5	1680.9	1700.1	1711.8	1704.4
145°	1726.8	1725.1	1750.3	1760.7	1753.3
147.5°	1775.4	1771.0	1796.1	1803.5	1797.7
150°	1822.9	1812.5	1836.2	1845.0	1837.6
152.5°	1862.8	1851.0	1873.1	1882.1	1871.7
155°	1901.3	1888.0	1905.8	1914.6	1902.8
157.5°	1932.4	1920.5	1933.9	1944.3	1932.4
160°	1959.0	1950.0	1959.0	1967.8	1957.5
162.5°	1982.5	1973.8	1981.1	1991.5	1978.2
165°	2003.3	1994.6	1998.9	2009.3	1998.9
167.5°	2019.6	2010.7	2015.3	2025.7	2012.2
170°	2033.0	2024.0	2027.1	2037.4	2024.0
172.5°	2041.8	2033.0	2036.0	2046.4	2033.0
175°	2049.2	2038.8	2041.8	2052.1	2037.4
177.5°	2052.1	2041.8	2043.3	2053.7	2040.4
180°	2044.7	2044.7	2044.7	2044.7	2044.7

TEST NUMBER: P927818

CATALOG NUMBER: DFN2DIP-HX4F0-120D060US840-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.87	13.82	13.71	14.68	15.75	8.84	9.79	9.68	10.65	11.72
	3H	14.56	15.41	15.41	16.28	17.37	10.04	10.89	10.90	11.76	12.86
	4H	15.17	15.97	16.04	16.85	17.96	10.50	11.30	11.37	12.18	13.29
	6H	15.60	16.34	16.48	17.22	18.34	10.83	11.57	11.71	12.45	13.57
	8H	15.73	16.43	16.62	17.33	18.45	10.92	11.62	11.81	12.52	13.65
	12H	15.80	16.46	16.69	17.36	18.51	10.97	11.64	11.87	12.53	13.68
4H	2H	12.90	13.70	13.78	14.58	15.69	9.45	10.25	10.33	11.13	12.24
	3H	14.74	15.41	15.63	16.32	17.44	10.82	11.48	11.70	12.39	13.51
	4H	15.44	16.05	16.34	16.95	18.10	11.37	11.98	12.27	12.88	14.03
	6H	15.96	16.49	16.88	17.41	18.57	11.80	12.32	12.71	13.25	14.40
	8H	16.14	16.63	17.06	17.55	18.72	11.93	12.42	12.84	13.34	14.51
	12H	16.24	16.68	17.18	17.62	18.79	12.00	12.44	12.94	13.38	14.55
8H	4H	15.42	15.91	16.33	16.83	17.99	11.66	12.15	12.57	13.07	14.24
	6H	15.99	16.39	16.93	17.36	18.52	12.18	12.59	13.13	13.55	14.72
	8H	16.21	16.56	17.16	17.52	18.70	12.38	12.73	13.33	13.69	14.87
	12H	16.35	16.67	17.31	17.61	18.85	12.50	12.82	13.46	13.76	15.00
12H	4H	15.38	15.81	16.31	16.75	17.93	11.67	12.11	12.60	13.05	14.22
	6H	15.97	16.32	16.92	17.28	18.46	12.23	12.59	13.19	13.55	14.73
	8H	16.19	16.51	17.15	17.45	18.69	12.45	12.77	13.41	13.71	14.95

END OF REPORT