

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P902910

Luminaire Tested: DFN2DIP-PN2F0-050D020US830-RLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P902910
REPORT IS A COMBINATION OF REPORTS P899468 AND P896349
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-050D020US830-RLLFLL
Description: 2 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5674.1 lumens
Efficiency: N/A
Efficacy: 84.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 67
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9821
Total Harmonic Distortion (THDi): 0.08
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	112	112	112	112	106	106	106	106	95	95	95	85	85	85	75	75	75
1	103	99	95	92	97	94	90	88	84	82	79	76	74	72	67	66	65
2	94	87	81	76	89	83	78	73	75	71	67	67	64	61	60	58	56
3	87	77	70	64	82	74	67	62	67	61	57	60	56	53	54	51	48
4	80	69	61	55	75	66	59	53	60	54	49	54	49	46	49	45	42
5	74	62	54	48	69	59	52	46	54	48	43	49	44	40	44	40	37
6	68	56	48	42	64	54	46	41	49	43	38	44	39	36	40	36	33
7	63	51	43	37	60	49	41	36	45	38	34	41	36	32	37	33	30
8	59	47	39	33	56	45	37	32	41	35	31	37	32	29	34	30	27
9	55	43	35	30	52	41	34	29	38	32	28	35	30	26	32	28	24
10	52	39	32	27	49	38	31	27	35	29	25	32	27	24	30	25	22

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4219	4219	4219
5°	4219	4143	4172
10°	4170	4052	4030
15°	4106	3910	3815
20°	4023	3717	3552
25°	3938	3502	3299
30°	3827	3283	2980
35°	3717	3048	2700
40°	3605	2806	2380
45°	3476	2539	2090
50°	3342	2270	1808
55°	3201	1983	1537
60°	3038	1685	1259
65°	2849	1384	1127
70°	2621	1102	1010
75°	2333	954	907
80°	1920	775	768
85°	1256	483	546

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3476 cd/sqm

TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLFL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	182.5	3.2
10°-20°	501.1	8.8
20°-30°	703.6	12.4
30°-40°	766.9	13.5
40°-50°	704.9	12.4
50°-60°	553.6	9.8
60°-70°	360.3	6.4
70°-80°	185.5	3.3
80°-90°	49.0	0.9
90°-100°	36.9	0.6
100°-110°	117.2	2.1
110°-120°	200.6	3.5
120°-130°	263.8	4.6
130°-140°	296.1	5.2
140°-150°	290.4	5.1
150°-160°	243.6	4.3
160°-170°	161.5	2.8
170°-180°	56.5	1.0
0°-30°	1387.2	24.4
0°-40°	2154.2	38.0
0°-60°	3412.7	60.1
0°-90°	4007.5	70.6
90°-120°	354.7	6.3
90°-150°	1205.0	21.2
90°-180°	1667.0	29.4
0°-180°	5674.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1948	1948	1948	1948	1948	
5°	1948	1939	1916	1932	1927	185
15°	1853	1833	1773	1740	1722	522
25°	1682	1625	1509	1437	1410	773
35°	1449	1359	1204	1093	1054	907
45°	1185	1066	881	756	714	915
55°	901	763	573	467	434	805
65°	608	465	307	247	242	603
75°	324	201	141	129	127	343
85°	76	39	34	34	34	87
90°	1	6	18	16	17	6
95°	26	31	32	32	31	29
105°	108	110	111	112	112	114
115°	201	204	203	203	201	199
125°	293	297	296	294	294	262
135°	379	384	385	385	383	293
145°	460	463	466	467	465	287
155°	526	527	529	531	530	242
165°	572	571	571	575	572	161
175°	595	594	593	596	593	57
180°	596	596	596	596	596	

TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLFL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1947.8	1947.8	1947.8	1947.8	1947.8
2.5°	1956.5	1947.8	1928.3	1946.1	1942.5
5°	1947.8	1939.0	1916.0	1931.8	1926.7
7.5°	1931.8	1921.4	1896.7	1903.7	1894.8
10°	1910.7	1898.4	1863.2	1857.8	1847.3
12.5°	1884.3	1868.5	1820.8	1810.3	1790.8
15°	1852.6	1833.2	1773.3	1739.8	1722.2
17.5°	1815.5	1787.3	1713.3	1674.5	1646.2
20°	1773.3	1738.0	1649.8	1605.9	1567.0
22.5°	1727.5	1686.9	1584.6	1524.8	1498.4
25°	1681.6	1625.1	1508.8	1436.6	1410.0
27.5°	1627.0	1567.0	1438.3	1355.5	1314.9
30°	1568.9	1501.8	1360.7	1270.9	1223.2
32.5°	1512.4	1431.3	1286.9	1181.0	1136.9
35°	1449.0	1359.1	1204.0	1092.9	1054.0
37.5°	1387.2	1290.2	1126.4	1004.7	960.7
40°	1322.0	1216.4	1045.2	920.1	874.3
42.5°	1255.1	1142.3	964.2	833.7	789.8
45°	1184.6	1066.4	881.4	756.1	713.8
47.5°	1117.6	992.5	802.1	676.8	638.1
50°	1043.6	918.4	724.5	602.8	565.9
52.5°	971.2	839.0	650.4	534.1	500.7
55°	900.7	763.2	572.8	467.1	433.7
57.5°	828.5	687.5	504.2	405.5	377.2
60°	754.4	613.4	431.8	342.0	313.8
62.5°	682.2	541.2	370.1	285.6	271.5
65°	608.1	465.3	306.7	246.9	241.5
67.5°	537.6	394.8	246.9	216.8	211.5
70°	463.6	326.1	204.4	186.8	179.7
72.5°	393.1	262.6	171.0	156.9	153.4
75°	324.3	200.9	141.0	128.7	127.0
77.5°	255.6	142.7	111.1	104.0	100.4
80°	192.1	102.3	84.5	77.6	77.6
82.5°	133.9	68.8	58.2	54.6	54.6
85°	75.8	38.7	33.5	33.5	33.5
87.5°	28.3	14.0	14.0	12.3	12.3
90°	0.6	6.5	17.6	16.5	17.1
92.5°	11.1	15.1	15.6	16.2	16.2
95°	26.2	31.3	32.1	32.1	31.3
97.5°	43.6	48.4	50.3	50.3	50.3
100°	63.8	68.0	69.4	69.4	68.8
102.5°	85.0	88.0	90.0	90.6	90.0
105°	108.2	109.6	110.7	111.6	111.6
107.5°	131.2	133.4	133.4	133.7	131.2
110°	153.5	156.4	156.4	156.4	155.0

TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	177.6	180.6	180.1	178.6	177.6
115°	201.3	204.2	203.3	202.7	201.3
117.5°	224.9	228.8	226.3	224.9	223.4
120°	248.5	252.5	248.5	248.5	246.9
122.5°	270.1	275.1	272.7	271.3	270.1
125°	292.8	297.3	295.9	294.3	293.7
127.5°	314.9	320.5	318.5	316.3	314.9
130°	335.5	342.0	341.1	340.1	338.1
132.5°	358.7	363.8	364.1	361.7	360.1
135°	378.7	384.3	385.3	384.8	383.3
137.5°	401.0	405.5	406.4	406.0	403.9
140°	420.6	425.1	427.6	427.6	425.7
142.5°	440.7	445.2	446.7	447.1	445.2
145°	459.8	463.4	466.3	466.7	464.8
147.5°	476.8	481.4	483.5	484.4	482.4
150°	494.5	497.5	499.5	501.1	499.5
152.5°	510.1	513.1	515.7	517.6	515.7
155°	525.8	527.2	528.8	531.3	529.7
157.5°	539.2	540.3	541.2	544.8	542.2
160°	551.3	552.3	552.9	555.9	553.7
162.5°	562.4	562.4	562.9	566.4	563.8
165°	571.9	571.4	571.4	575.0	572.5
167.5°	580.5	578.9	578.9	582.5	580.0
170°	587.0	585.6	585.0	588.6	585.6
172.5°	591.5	590.0	589.6	593.1	590.0
175°	595.1	593.7	592.6	596.2	593.1
177.5°	597.1	595.7	594.6	597.6	594.6
180°	596.2	596.2	596.2	596.2	596.2

TEST NUMBER: P902910

CATALOG NUMBER: DFN2DIP-PN2F0-050D020US830-RLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.77	14.81	14.54	15.59	16.53	9.74	10.77	10.51	11.56	12.50
	3H	15.44	16.37	16.22	17.16	18.14	10.93	11.85	11.71	12.64	13.62
	4H	16.05	16.92	16.85	17.72	18.71	11.38	12.25	12.17	13.05	14.03
	6H	16.46	17.27	17.27	18.07	19.08	11.69	12.49	12.50	13.30	14.30
	8H	16.59	17.35	17.41	18.18	19.18	11.78	12.54	12.60	13.37	14.37
	12H	16.65	17.37	17.47	18.19	19.22	11.82	12.55	12.65	13.37	14.40
4H	2H	13.81	14.68	14.61	15.48	16.47	10.35	11.22	11.15	12.02	13.01
	3H	15.63	16.36	16.45	17.19	18.20	11.70	12.42	12.51	13.26	14.26
	4H	16.32	16.98	17.14	17.81	18.84	12.24	12.90	13.06	13.73	14.76
	6H	16.83	17.39	17.67	18.25	19.29	12.65	13.22	13.49	14.08	15.11
	8H	16.99	17.52	17.84	18.37	19.42	12.77	13.30	13.62	14.16	15.20
	12H	17.09	17.56	17.95	18.43	19.49	12.84	13.31	13.70	14.19	15.24
8H	4H	16.30	16.83	17.14	17.68	18.73	12.52	13.05	13.37	13.90	14.95
	6H	16.85	17.29	17.72	18.18	19.23	13.02	13.46	13.90	14.36	15.41
	8H	17.05	17.44	17.94	18.33	19.40	13.20	13.59	14.09	14.48	15.55
	12H	17.19	17.53	18.07	18.41	19.53	13.32	13.66	14.20	14.54	15.66
12H	4H	16.26	16.73	17.12	17.61	18.66	12.53	13.01	13.40	13.88	14.94
	6H	16.82	17.21	17.71	18.10	19.17	13.07	13.46	13.95	14.35	15.41
	8H	17.04	17.38	17.92	18.26	19.38	13.27	13.62	14.16	14.50	15.62

END OF REPORT