

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P908305

Luminaire Tested: DFN2DIP-PN2F0-020D020US840-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P908305
REPORT IS A COMBINATION OF REPORTS P900981 AND P897905
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-020D020US840-FLLONL
Description: 2 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3999.1 lumens
Efficiency: N/A
Efficacy: 123.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 32.3
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.099
Total Harmonic Distortion (THDi): 0.979
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	107	107	107	107	99	99	99	99	83	83	83	69	69	69	56	56	56
1	98	93	90	86	90	86	83	80	73	71	68	61	59	58	50	48	47
2	89	82	75	70	82	76	70	66	64	60	57	53	51	48	44	42	40
3	81	72	64	59	75	66	60	55	56	52	48	47	44	41	39	36	34
4	74	64	56	50	68	59	52	47	50	45	41	42	38	35	35	32	29
5	68	57	48	42	63	53	45	40	45	39	35	38	34	30	31	28	26
6	63	51	43	37	58	47	40	35	40	35	31	34	30	27	28	25	23
7	58	46	38	32	53	43	36	30	37	31	27	31	27	23	26	23	20
8	54	42	34	29	50	39	32	27	33	28	24	28	24	21	24	20	18
9	50	38	30	25	46	35	29	24	31	25	21	26	22	19	22	19	16
10	47	35	28	23	43	33	26	22	28	23	19	24	20	17	20	17	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1702	1702	1702
5°	1702	1675	1687
10°	1686	1649	1662
15°	1658	1618	1624
20°	1622	1576	1585
25°	1586	1528	1540
30°	1541	1482	1484
35°	1499	1429	1424
40°	1447	1375	1368
45°	1395	1321	1310
50°	1338	1264	1243
55°	1278	1198	1181
60°	1211	1121	1110
65°	1137	1040	1026
70°	1042	941	935
75°	913	823	848
80°	755	672	688
85°	512	425	432

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1395 cd/sqm

TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	74.0	1.8
10°-20°	208.1	5.2
20°-30°	305.8	7.6
30°-40°	355.2	8.9
40°-50°	354.8	8.9
50°-60°	309.4	7.7
60°-70°	228.7	5.7
70°-80°	129.4	3.2
80°-90°	35.4	0.9
90°-100°	22.5	0.6
100°-110°	83.8	2.1
110°-120°	222.2	5.6
120°-130°	368.6	9.2
130°-140°	391.5	9.8
140°-150°	363.9	9.1
150°-160°	292.5	7.3
160°-170°	188.5	4.7
170°-180°	64.9	1.6
0°-30°	587.9	14.7
0°-40°	943.2	23.6
0°-60°	1607.3	40.2
0°-90°	2000.7	50.0
90°-120°	328.5	8.2
90°-150°	1452.4	36.3
90°-180°	1998.0	50.0
0°-180°	3999.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	786	786	786	786	786	
5°	786	783	775	781	779	75
15°	748	744	734	737	733	211
25°	677	671	658	660	658	312
35°	584	577	564	560	556	365
45°	475	470	459	450	447	367
55°	360	355	346	337	333	322
65°	243	238	231	224	220	240
75°	127	126	122	117	119	135
85°	31	30	30	27	26	35
90°	0	6	10	12	13	4
95°	32	16	19	22	21	38
105°	150	165	30	35	38	160
115°	284	292	304	76	40	279
125°	401	407	417	420	422	358
135°	496	504	508	514	512	383
145°	576	575	584	587	584	360
155°	634	629	635	638	634	292
165°	668	665	666	670	666	189
175°	683	680	681	684	679	65
180°	682	682	682	682	682	

TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	785.9	785.9	785.9	785.9	785.9
2.5°	790.4	786.7	778.3	785.9	784.5
5°	785.9	782.9	774.6	780.6	779.1
7.5°	780.6	776.1	767.8	773.9	772.3
10°	772.3	767.1	758.0	764.0	761.7
12.5°	760.9	756.5	747.4	751.1	749.6
15°	748.1	743.7	733.8	736.8	733.1
17.5°	732.3	727.8	717.9	721.6	717.9
20°	714.9	710.3	699.7	702.1	699.0
22.5°	697.5	690.7	680.9	680.9	679.3
25°	677.1	671.1	658.2	659.6	658.2
27.5°	654.4	649.1	639.3	637.1	633.3
30°	631.8	625.7	614.4	612.2	609.0
32.5°	607.5	603.1	591.0	586.4	583.4
35°	584.2	576.6	564.5	560.0	556.1
37.5°	557.7	550.9	538.8	533.5	529.7
40°	530.5	524.4	512.3	505.6	502.5
42.5°	504.0	498.0	485.9	478.4	473.8
45°	475.3	470.1	458.7	450.4	447.4
47.5°	447.4	442.1	430.0	421.6	417.2
50°	417.9	414.1	403.5	392.9	389.2
52.5°	389.2	383.8	374.1	365.8	360.5
55°	359.7	355.2	346.1	337.1	333.3
57.5°	330.2	326.5	316.6	307.6	304.5
60°	300.7	297.8	287.2	278.8	276.6
62.5°	272.1	266.7	259.2	251.7	248.6
65°	242.6	238.0	230.6	223.7	219.9
67.5°	212.4	208.5	201.8	196.5	193.5
70°	184.4	181.4	174.5	169.3	166.3
72.5°	155.7	152.7	148.9	143.6	141.4
75°	126.9	125.5	121.6	117.1	118.7
77.5°	101.3	98.3	96.6	94.4	92.2
80°	75.6	74.8	73.3	71.0	69.5
82.5°	51.4	51.4	50.7	47.7	47.7
85°	30.9	30.2	29.5	27.2	26.5
87.5°	13.6	12.1	10.6	8.4	7.6
90°	0.5	6.0	9.8	12.3	13.3
92.5°	12.3	10.4	11.8	12.8	13.3
95°	32.0	15.8	19.2	21.7	21.2
97.5°	57.7	17.3	25.1	26.7	27.2
100°	87.4	19.7	28.1	32.0	33.0
102.5°	119.9	118.9	29.1	34.5	36.1
105°	150.0	164.7	30.1	35.4	37.5
107.5°	185.0	197.2	31.1	36.5	38.5
110°	218.5	228.8	86.3	37.1	39.0

TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	250.0	258.9	250.5	38.0	39.5
115°	283.6	292.0	304.4	75.9	40.5
117.5°	312.7	322.6	330.9	260.4	131.2
120°	345.3	352.6	361.5	367.5	300.8
122.5°	372.8	380.7	390.6	393.5	394.2
125°	401.0	407.4	416.8	420.2	421.7
127.5°	426.7	433.5	441.0	445.9	446.4
130°	450.8	458.7	464.1	469.6	469.1
132.5°	475.4	481.9	487.3	491.7	491.3
135°	496.2	504.1	508.5	513.5	512.5
137.5°	517.9	523.8	528.8	533.7	532.2
140°	539.1	543.1	548.5	552.9	550.5
142.5°	556.8	560.4	566.7	570.7	568.2
145°	575.6	575.1	583.5	586.9	584.5
147.5°	591.9	590.4	598.7	601.2	599.3
150°	607.6	604.2	612.1	615.0	612.6
152.5°	621.0	617.0	624.4	627.4	623.9
155°	633.8	629.3	635.3	638.2	634.3
157.5°	644.2	640.3	644.7	648.1	644.2
160°	653.1	650.1	653.1	656.0	652.6
162.5°	660.9	657.9	660.5	663.9	659.4
165°	667.8	664.9	666.3	669.8	666.3
167.5°	673.3	670.2	671.8	675.3	670.8
170°	677.7	674.7	675.7	679.1	674.7
172.5°	680.6	677.7	678.7	682.2	677.7
175°	683.1	679.6	680.6	684.1	679.1
177.5°	684.1	680.6	681.2	684.6	680.1
180°	681.7	681.7	681.7	681.7	681.7

TEST NUMBER: P908305

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US840-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	9.01	9.87	9.96	10.84	12.11	8.57	9.43	9.53	10.40	11.67
	3H	10.65	11.42	11.61	12.40	13.69	10.17	10.94	11.13	11.92	13.21
	4H	11.22	11.95	12.20	12.94	14.24	10.74	11.47	11.72	12.46	13.76
	6H	11.61	12.28	12.60	13.27	14.58	11.12	11.79	12.11	12.78	14.10
	8H	11.70	12.34	12.70	13.35	14.66	11.22	11.86	12.21	12.86	14.18
	12H	11.74	12.35	12.75	13.35	14.69	11.25	11.86	12.25	12.86	14.20
4H	2H	9.46	10.19	10.45	11.18	12.48	9.11	9.84	10.10	10.83	12.13
	3H	11.30	11.91	12.30	12.93	14.24	10.90	11.51	11.90	12.53	13.84
	4H	12.00	12.56	13.00	13.56	14.90	11.58	12.14	12.59	13.15	14.49
	6H	12.49	12.98	13.51	14.01	15.34	12.07	12.55	13.09	13.59	14.92
	8H	12.63	13.08	13.65	14.11	15.46	12.21	12.66	13.23	13.68	15.03
	12H	12.70	13.10	13.73	14.14	15.50	12.26	12.67	13.30	13.71	15.07
8H	4H	12.18	12.63	13.20	13.66	15.01	11.81	12.26	12.83	13.29	14.64
	6H	12.79	13.16	13.83	14.23	15.58	12.42	12.79	13.46	13.85	15.20
	8H	13.00	13.32	14.05	14.38	15.74	12.62	12.94	13.67	14.00	15.36
	12H	13.12	13.40	14.17	14.45	15.86	12.72	13.01	13.77	14.05	15.46
12H	4H	12.17	12.57	13.20	13.61	14.97	11.81	12.21	12.84	13.25	14.61
	6H	12.82	13.14	13.87	14.19	15.56	12.45	12.78	13.50	13.83	15.20
	8H	13.04	13.33	14.10	14.38	15.79	12.67	12.96	13.73	14.01	15.42