

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P911032

Luminaire Tested: DFN2DIP-PN2F0-020D020US850-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P911032
REPORT IS A COMBINATION OF REPORTS P899461 AND P896349
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-020D020US850-FLLFLL
Description: 2 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4158.8 lumens
Efficiency: N/A
Efficacy: 128.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 32.3
Input Voltage (V): 120
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: 0.099
Total Harmonic Distortion (THDi): 0.979
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P911032
CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

Luminous Intensity Polar Plot





TEST NUMBER: P911032
 CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	108	108	108	108	100	100	100	100	85	85	85	71	71	71	59	59	59	59	59	59	53
1	98	94	90	87	91	87	84	81	74	72	70	63	61	59	52	51	50	52	51	50	45
2	90	82	76	71	83	76	71	66	65	61	58	55	52	50	46	44	42	46	44	42	37
3	82	72	65	59	75	67	61	55	58	53	49	49	45	42	41	38	36	41	38	36	32
4	75	64	56	50	69	60	52	47	51	46	41	43	39	36	36	33	31	36	33	31	27
5	69	57	49	43	63	53	46	40	46	40	36	39	35	31	33	29	27	33	29	27	24
6	63	51	43	37	58	48	40	35	41	36	31	35	31	27	30	26	24	30	26	24	21
7	59	46	38	33	54	43	36	31	37	32	28	32	28	24	27	24	21	27	24	21	18
8	54	42	34	29	50	39	32	27	34	29	24	29	25	22	25	21	19	25	21	19	16
9	51	38	31	26	47	36	29	24	31	26	22	27	23	19	23	20	17	23	20	17	15
10	47	35	28	23	44	33	26	22	29	23	20	25	21	18	21	18	15	21	18	15	13

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1869	1869	1869
5°	1869	1839	1853
10°	1851	1810	1825
15°	1821	1777	1783
20°	1781	1731	1740
25°	1742	1678	1691
30°	1692	1628	1629
35°	1646	1569	1564
40°	1589	1510	1502
45°	1532	1451	1439
50°	1470	1388	1365
55°	1404	1316	1297
60°	1330	1231	1219
65°	1248	1142	1127
70°	1145	1033	1027
75°	1003	903	931
80°	830	738	755
85°	562	467	474

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 1532 cd/sqm



TEST NUMBER: P911032

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	81.2	2.0
10°-20°	228.6	5.5
20°-30°	335.9	8.1
30°-40°	390.1	9.4
40°-50°	389.6	9.4
50°-60°	339.7	8.2
60°-70°	251.1	6.0
70°-80°	142.1	3.4
80°-90°	39.5	0.9
90°-100°	43.4	1.0
100°-110°	137.9	3.3
110°-120°	236.0	5.7
120°-130°	310.4	7.5
130°-140°	348.4	8.4
140°-150°	341.7	8.2
150°-160°	286.6	6.9
160°-170°	190.1	4.6
170°-180°	66.4	1.6
0°-30°	645.7	15.5
0°-40°	1035.8	24.9
0°-60°	1765.1	42.4
0°-90°	2197.8	52.8
90°-120°	417.3	10.0
90°-150°	1417.8	34.1
90°-180°	1961.0	47.2
0°-180°	4158.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	863	863	863	863	863	
5°	863	860	851	857	856	82
15°	822	817	806	809	805	231
25°	744	737	723	724	723	342
35°	642	633	620	615	611	401
45°	522	516	504	495	491	403
55°	395	390	380	370	366	353
65°	266	261	253	246	242	263
75°	139	138	134	129	130	149
85°	34	33	32	30	29	38
90°	1	8	21	19	20	4
95°	31	37	38	38	37	34
105°	127	129	130	131	131	134
115°	237	240	239	238	237	234
125°	344	350	348	346	346	308
135°	446	452	453	453	451	344
145°	541	545	549	549	547	338
155°	619	620	622	625	623	285
165°	673	672	672	676	674	190
175°	700	699	697	701	698	67
180°	701	701	701	701	701	



TEST NUMBER: P911032

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	863.0	863.0	863.0	863.0	863.0
2.5°	868.0	863.9	854.7	863.0	861.5
5°	863.0	859.8	850.6	857.3	855.6
7.5°	857.3	852.3	843.2	849.8	848.2
10°	848.2	842.4	832.4	839.0	836.5
12.5°	835.6	830.8	820.8	824.9	823.2
15°	821.5	816.7	805.8	809.1	805.0
17.5°	804.1	799.3	788.4	792.5	788.4
20°	785.1	780.1	768.4	771.0	767.6
22.5°	766.0	758.6	747.7	747.7	746.0
25°	743.6	736.9	722.8	724.4	722.8
27.5°	718.6	712.9	702.1	699.7	695.5
30°	693.8	687.1	674.7	672.3	668.8
32.5°	667.2	662.3	649.0	644.0	640.7
35°	641.6	633.2	619.9	614.9	610.7
37.5°	612.5	605.0	591.7	585.9	581.7
40°	582.6	575.9	562.6	555.3	551.8
42.5°	553.5	546.8	533.7	525.3	520.3
45°	522.0	516.2	503.7	494.6	491.3
47.5°	491.3	485.5	472.2	463.0	458.1
50°	458.9	454.8	443.2	431.5	427.4
52.5°	427.4	421.5	410.8	401.7	395.9
55°	395.0	390.0	380.1	370.2	366.0
57.5°	362.6	358.5	347.7	337.8	334.4
60°	330.3	327.0	315.4	306.2	303.8
62.5°	298.8	292.9	284.7	276.4	273.0
65°	266.4	261.4	253.2	245.6	241.5
67.5°	233.2	229.0	221.6	215.8	212.5
70°	202.5	199.2	191.6	185.9	182.7
72.5°	171.0	167.7	163.5	157.7	155.3
75°	139.4	137.8	133.5	128.6	130.3
77.5°	111.2	107.9	106.1	103.7	101.3
80°	83.1	82.2	80.5	78.0	76.3
82.5°	56.4	56.4	55.7	52.3	52.3
85°	33.9	33.2	32.4	29.8	29.1
87.5°	15.0	13.3	11.6	9.2	8.3
90°	0.7	7.7	20.7	19.4	20.1
92.5°	13.1	17.7	18.4	19.1	19.1
95°	30.8	36.8	37.8	37.8	36.8
97.5°	51.3	56.9	59.2	59.2	59.2
100°	75.1	80.0	81.6	81.6	81.0
102.5°	100.0	103.6	105.9	106.6	105.9
105°	127.3	129.0	130.3	131.3	131.3
107.5°	154.4	156.9	156.9	157.4	154.4
110°	180.7	184.0	184.0	184.0	182.3



TEST NUMBER: P911032

CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	208.9	212.5	211.9	210.2	208.9
115°	236.9	240.2	239.2	238.5	236.9
117.5°	264.6	269.3	266.3	264.6	262.8
120°	292.4	297.1	292.4	292.4	290.6
122.5°	317.8	323.7	320.8	319.2	317.8
125°	344.5	349.8	348.1	346.2	345.6
127.5°	370.5	377.1	374.7	372.2	370.5
130°	394.8	402.5	401.3	400.1	397.8
132.5°	422.1	428.1	428.4	425.5	423.7
135°	445.6	452.1	453.4	452.8	451.0
137.5°	471.8	477.1	478.2	477.8	475.2
140°	494.8	500.2	503.2	503.2	500.8
142.5°	518.6	523.8	525.6	526.1	523.8
145°	541.0	545.2	548.6	549.2	546.8
147.5°	561.0	566.4	568.9	569.9	567.6
150°	581.8	585.3	587.7	589.5	587.7
152.5°	600.2	603.7	606.7	609.1	606.7
155°	618.6	620.3	622.1	625.1	623.3
157.5°	634.5	635.7	636.8	641.0	638.0
160°	648.7	649.9	650.5	654.1	651.5
162.5°	661.7	661.7	662.3	666.4	663.4
165°	672.9	672.3	672.3	676.5	673.6
167.5°	683.0	681.1	681.1	685.4	682.5
170°	690.7	689.0	688.4	692.6	689.0
172.5°	696.0	694.2	693.7	697.9	694.2
175°	700.2	698.6	697.2	701.4	697.9
177.5°	702.6	700.9	699.6	703.1	699.6
180°	701.4	701.4	701.4	701.4	701.4



TEST NUMBER: P911032
 CATALOG NUMBER: DFN2DIP-PN2F0-020D020US850-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	9.59	10.47	10.52	11.42	12.65	9.15	10.04	10.08	10.99	12.22
	3H	11.23	12.02	12.17	12.98	14.24	10.75	11.55	11.69	12.50	13.76
	4H	11.80	12.56	12.76	13.52	14.78	11.32	12.08	12.28	13.04	14.30
	6H	12.19	12.88	13.16	13.85	15.13	11.70	12.40	12.67	13.37	14.64
	8H	12.29	12.95	13.26	13.93	15.21	11.80	12.46	12.78	13.45	14.72
	12H	12.33	12.96	13.31	13.94	15.24	11.84	12.47	12.82	13.45	14.74
4H	2H	10.04	10.79	11.00	11.76	13.02	9.69	10.45	10.66	11.41	12.67
	3H	11.89	12.51	12.86	13.51	14.78	11.49	12.12	12.46	13.11	14.39
	4H	12.58	13.16	13.57	14.15	15.45	12.17	12.75	13.15	13.73	15.03
	6H	13.08	13.58	14.08	14.59	15.89	12.66	13.16	13.66	14.17	15.47
	8H	13.22	13.69	14.22	14.69	16.00	12.80	13.26	13.80	14.27	15.58
	12H	13.29	13.71	14.30	14.72	16.04	12.85	13.27	13.87	14.29	15.61
8H	4H	12.77	13.24	13.77	14.24	15.55	12.40	12.87	13.40	13.87	15.18
	6H	13.38	13.76	14.40	14.81	16.12	13.01	13.39	14.03	14.44	15.75
	8H	13.59	13.93	14.62	14.96	16.29	13.21	13.54	14.24	14.58	15.91
	12H	13.71	14.00	14.74	15.03	16.40	13.31	13.61	14.34	14.63	16.01
12H	4H	12.76	13.17	13.77	14.19	15.51	12.40	12.81	13.41	13.83	15.15
	6H	13.41	13.74	14.44	14.78	16.11	13.04	13.38	14.07	14.41	15.74
	8H	13.63	13.93	14.67	14.96	16.33	13.26	13.56	14.30	14.59	15.96