

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P913781

Luminaire Tested: DFN2DIP-PN2F0-030D020US927-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P913781
REPORT IS A COMBINATION OF REPORTS P900983 AND P897905
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-030D020US927-FLLONL
Description: 2 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3921.3 lumens
Efficiency: N/A
Efficacy: 89.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 43.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9972
Total Harmonic Distortion (THDi): 0.128
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	102	102	102	102	89	89	89	77	77	77	65	65	65
1	100	96	92	88	93	90	86	83	78	75	73	67	66	64	58	56	55
2	91	84	77	72	85	78	73	68	68	64	61	59	56	53	51	49	47
3	83	73	66	60	77	69	62	57	60	55	51	52	48	45	45	42	40
4	76	65	57	51	71	61	54	48	54	48	44	47	42	39	40	37	34
5	70	58	50	44	65	55	47	42	48	42	38	42	37	34	36	33	30
6	64	52	44	38	60	49	42	36	43	37	33	38	33	30	33	29	26
7	60	47	39	33	56	44	37	32	39	33	29	35	30	26	30	26	23
8	55	43	35	30	52	40	33	28	36	30	26	32	27	23	28	24	21
9	52	39	32	26	48	37	30	25	33	27	23	29	24	21	26	22	19
10	48	36	29	24	45	34	27	23	30	25	21	27	22	19	24	20	17

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2003	2003	2003
5°	2003	1971	1985
10°	1983	1940	1956
15°	1951	1904	1910
20°	1908	1855	1865
25°	1866	1798	1812
30°	1813	1744	1746
35°	1763	1681	1676
40°	1702	1618	1610
45°	1642	1554	1541
50°	1575	1487	1463
55°	1504	1410	1390
60°	1425	1319	1306
65°	1338	1223	1207
70°	1227	1108	1100
75°	1074	968	998
80°	889	791	809
85°	603	500	507

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1642 cd/sqm

TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	87.0	2.2
10°-20°	244.9	6.2
20°-30°	359.9	9.2
30°-40°	418.0	10.7
40°-50°	417.5	10.6
50°-60°	364.0	9.3
60°-70°	269.1	6.9
70°-80°	152.3	3.9
80°-90°	41.1	1.0
90°-100°	17.6	0.4
100°-110°	65.7	1.7
110°-120°	174.3	4.4
120°-130°	289.1	7.4
130°-140°	307.1	7.8
140°-150°	285.4	7.3
150°-160°	229.5	5.9
160°-170°	147.9	3.8
170°-180°	50.9	1.3
0°-30°	691.8	17.6
0°-40°	1109.8	28.3
0°-60°	1891.3	48.2
0°-90°	2353.7	60.0
90°-120°	257.7	6.6
90°-150°	1139.3	29.1
90°-180°	1568.0	40.0
0°-180°	3921.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	925	925	925	925	925	
5°	925	921	911	918	917	88
15°	880	875	863	867	862	248
25°	797	790	774	776	774	367
35°	687	678	664	659	654	429
45°	559	553	540	530	526	432
55°	423	418	407	397	392	378
65°	286	280	271	263	259	282
75°	149	148	143	138	140	159
85°	36	36	35	32	31	41
90°	0	5	8	10	10	4
95°	25	12	15	17	17	30
105°	118	129	24	28	29	126
115°	222	229	239	60	32	219
125°	315	320	327	330	331	281
135°	389	396	399	403	402	301
145°	452	451	458	460	458	282
155°	497	494	498	501	498	229
165°	524	522	523	526	523	148
175°	536	533	534	537	533	51
180°	535	535	535	535	535	

TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	924.7	924.7	924.7	924.7	924.7
2.5°	930.1	925.7	915.8	924.7	923.0
5°	924.7	921.2	911.4	918.5	916.8
7.5°	918.5	913.2	903.4	910.6	908.8
10°	908.8	902.5	891.9	899.0	896.4
12.5°	895.4	890.1	879.5	883.8	882.1
15°	880.3	875.0	863.4	867.0	862.5
17.5°	861.6	856.3	844.7	849.1	844.7
20°	841.1	835.8	823.4	826.0	822.5
22.5°	820.8	812.8	801.1	801.1	799.3
25°	796.7	789.6	774.5	776.3	774.5
27.5°	770.0	763.7	752.3	749.6	745.2
30°	743.4	736.3	722.9	720.3	716.7
32.5°	714.9	709.6	695.4	690.0	686.4
35°	687.4	678.5	664.2	658.9	654.4
37.5°	656.2	648.2	634.0	627.7	623.3
40°	624.2	617.1	602.8	594.9	591.4
42.5°	593.1	586.0	571.8	562.8	557.5
45°	559.4	553.1	539.7	530.0	526.4
47.5°	526.4	520.2	506.0	496.1	490.8
50°	491.7	487.3	474.8	462.4	458.0
52.5°	458.0	451.7	440.2	430.4	424.1
55°	423.3	418.0	407.3	396.6	392.2
57.5°	388.6	384.1	372.6	361.9	358.3
60°	353.9	350.4	337.9	328.1	325.5
62.5°	320.1	313.9	305.0	296.1	292.6
65°	285.5	280.1	271.2	263.2	258.8
67.5°	249.9	245.4	237.4	231.2	227.7
70°	217.0	213.4	205.4	199.2	195.7
72.5°	183.2	179.6	175.2	169.0	166.4
75°	149.3	147.7	143.1	137.8	139.7
77.5°	119.1	115.6	113.8	111.1	108.5
80°	89.0	88.0	86.2	83.6	81.8
82.5°	60.4	60.4	59.7	56.0	56.0
85°	36.4	35.6	34.7	32.0	31.1
87.5°	16.0	14.3	12.4	9.8	8.9
90°	0.4	4.7	7.7	9.7	10.5
92.5°	9.7	8.2	9.3	10.1	10.5
95°	25.1	12.4	15.1	17.0	16.6
97.5°	45.2	13.5	19.7	20.9	21.3
100°	68.5	15.4	22.0	25.1	25.9
102.5°	94.0	93.2	22.8	27.1	28.3
105°	117.6	129.2	23.6	27.8	29.4
107.5°	145.1	154.7	24.4	28.6	30.2
110°	171.4	179.5	67.7	29.1	30.6



TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	196.1	203.1	196.5	29.8	31.0
115°	222.4	229.0	238.8	59.6	31.8
117.5°	245.3	253.0	259.6	204.3	102.9
120°	270.8	276.6	283.6	288.3	236.0
122.5°	292.5	298.7	306.4	308.7	309.2
125°	314.6	319.6	326.9	329.6	330.8
127.5°	334.7	340.1	345.9	349.7	350.1
130°	353.6	359.8	364.1	368.4	368.0
132.5°	373.0	378.0	382.2	385.7	385.4
135°	389.3	395.5	398.9	402.8	402.0
137.5°	406.2	410.9	414.8	418.7	417.5
140°	422.9	426.0	430.2	433.7	431.8
142.5°	436.8	439.6	444.6	447.7	445.7
145°	451.5	451.1	457.7	460.4	458.5
147.5°	464.3	463.1	469.7	471.6	470.1
150°	476.7	474.0	480.1	482.4	480.5
152.5°	487.1	484.0	489.8	492.2	489.4
155°	497.2	493.7	498.4	500.7	497.6
157.5°	505.3	502.2	505.7	508.4	505.3
160°	512.3	509.9	512.3	514.6	511.9
162.5°	518.4	516.1	518.1	520.8	517.3
165°	523.9	521.6	522.7	525.5	522.7
167.5°	528.1	525.8	527.0	529.7	526.2
170°	531.6	529.3	530.0	532.7	529.3
172.5°	533.9	531.6	532.4	535.1	531.6
175°	535.8	533.1	533.9	536.6	532.7
177.5°	536.6	533.9	534.3	537.0	533.5
180°	534.7	534.7	534.7	534.7	534.7

TEST NUMBER: P913781

CATALOG NUMBER: DFN2DIP-PN2F0-030D020US927-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	10.44	11.40	11.31	12.29	13.41	10.01	10.97	10.87	11.85	12.98
	3H	12.09	12.95	12.97	13.85	15.00	11.61	12.47	12.49	13.37	14.52
	4H	12.67	13.48	13.57	14.39	15.54	12.19	13.00	13.08	13.91	15.06
	6H	13.06	13.81	13.97	14.72	15.89	12.57	13.33	13.48	14.23	15.40
	8H	13.16	13.87	14.07	14.80	15.97	12.67	13.39	13.59	14.32	15.48
	12H	13.20	13.88	14.12	14.81	16.00	12.71	13.39	13.63	14.31	15.51
4H	2H	10.91	11.72	11.81	12.62	13.78	10.56	11.37	11.46	12.28	13.43
	3H	12.76	13.44	13.67	14.37	15.54	12.36	13.04	13.27	13.97	15.14
	4H	13.46	14.08	14.38	15.01	16.21	13.05	13.67	13.97	14.60	15.79
	6H	13.96	14.50	14.90	15.45	16.65	13.54	14.08	14.48	15.03	16.23
	8H	14.10	14.60	15.04	15.55	16.76	13.68	14.18	14.62	15.13	16.34
	12H	14.17	14.62	15.13	15.59	16.81	13.74	14.19	14.70	15.16	16.37
8H	4H	13.65	14.15	14.59	15.10	16.31	13.29	13.79	14.22	14.73	15.95
	6H	14.27	14.68	15.23	15.67	16.88	13.89	14.31	14.86	15.30	16.51
	8H	14.47	14.84	15.45	15.82	17.05	14.09	14.46	15.07	15.44	16.67
	12H	14.60	14.92	15.57	15.89	17.17	14.20	14.52	15.18	15.49	16.77
12H	4H	13.64	14.09	14.60	15.06	16.28	13.28	13.73	14.24	14.70	15.92
	6H	14.29	14.66	15.26	15.64	16.87	13.93	14.30	14.90	15.27	16.50
	8H	14.52	14.84	15.50	15.82	17.09	14.15	14.48	15.13	15.45	16.72