

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P913807

Luminaire Tested: DFN2DIP-PN2F0-040D030US927-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P913807
REPORT IS A COMBINATION OF REPORTS P900996 AND P897905
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-040D030US927-RLONL
Description: 2 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5046.2 lumens
Efficiency: N/A
Efficacy: 86.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 58.1
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9613
Total Harmonic Distortion (THDi): 0.083
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P913807
CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLLONL

Luminous Intensity Polar Plot





TEST NUMBER: P913807
 CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	108	108	108	108	100	100	100	100	85	85	85	72	72	72	59	59	59	59	59	59	53
1	99	95	91	88	92	88	85	82	76	73	71	64	62	61	53	52	51	53	52	51	46
2	91	83	78	73	84	78	73	68	67	63	60	57	54	52	47	45	44	47	45	44	39
3	83	74	67	61	77	69	63	58	59	55	51	51	47	44	42	40	38	42	40	38	34
4	76	66	58	52	70	61	55	49	53	48	44	45	42	38	38	35	33	38	35	33	30
5	70	59	51	45	65	55	48	43	48	42	38	41	37	34	35	32	29	35	32	29	26
6	65	53	45	39	60	50	43	37	43	38	34	37	33	30	32	28	26	32	28	26	23
7	60	48	40	35	56	45	38	33	39	34	30	34	30	26	29	26	23	29	26	23	21
8	56	44	36	31	52	41	34	29	36	31	27	31	27	24	27	24	21	27	24	21	19
9	52	40	33	28	48	38	31	26	33	28	24	29	25	22	25	22	19	25	22	19	17
10	49	37	30	25	45	35	28	24	31	25	22	27	23	20	23	20	17	23	20	17	16

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2836	2836	2836
5°	2836	2785	2805
10°	2804	2725	2710
15°	2761	2629	2565
20°	2705	2499	2388
25°	2648	2355	2218
30°	2573	2207	2004
35°	2500	2049	1815
40°	2424	1887	1600
45°	2337	1707	1406
50°	2247	1526	1215
55°	2152	1334	1033
60°	2042	1133	847
65°	1916	930	757
70°	1762	741	679
75°	1568	641	610
80°	1290	521	516
85°	843	324	366

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 2337 cd/sqm



TEST NUMBER: P913807

CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	122.7	2.4
10°-20°	336.9	6.7
20°-30°	473.1	9.4
30°-40°	515.7	10.2
40°-50°	473.9	9.4
50°-60°	372.2	7.4
60°-70°	242.3	4.8
70°-80°	124.7	2.5
80°-90°	33.3	0.7
90°-100°	26.5	0.5
100°-110°	98.6	2.0
110°-120°	261.5	5.2
120°-130°	433.7	8.6
130°-140°	460.7	9.1
140°-150°	428.1	8.5
150°-160°	344.2	6.8
160°-170°	221.8	4.4
170°-180°	76.3	1.5
0°-30°	932.7	18.5
0°-40°	1448.4	28.7
0°-60°	2294.6	45.5
0°-90°	2694.8	53.4
90°-120°	386.5	7.7
90°-150°	1709.0	33.9
90°-180°	2351.0	46.6
0°-180°	5046.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1310	1310	1310	1310	1310	
5°	1310	1304	1288	1299	1296	124
15°	1246	1233	1192	1170	1158	351
25°	1131	1093	1014	966	948	520
35°	974	914	810	735	709	610
45°	796	717	593	508	480	615
55°	606	513	385	314	292	541
65°	409	313	206	166	162	405
75°	218	135	95	86	85	231
85°	51	26	22	22	22	58
90°	1	7	12	15	16	5
95°	38	18	23	26	25	45
105°	176	194	35	42	44	188
115°	334	344	358	89	48	329
125°	472	479	490	494	496	421
135°	584	593	598	604	603	451
145°	677	677	687	691	688	424
155°	746	741	748	751	746	344
165°	786	782	784	788	784	222
175°	804	800	801	805	799	76
180°	802	802	802	802	802	



TEST NUMBER: P913807

CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1309.6	1309.6	1309.6	1309.6	1309.6
2.5°	1315.6	1309.6	1296.6	1308.5	1306.1
5°	1309.6	1303.7	1288.2	1298.9	1295.5
7.5°	1298.9	1291.9	1275.3	1279.9	1274.1
10°	1284.8	1276.4	1252.8	1249.1	1242.1
12.5°	1267.0	1256.3	1224.2	1217.2	1204.1
15°	1245.6	1232.6	1192.3	1169.8	1158.0
17.5°	1220.8	1201.7	1151.9	1125.9	1106.9
20°	1192.3	1168.5	1109.3	1079.7	1053.6
22.5°	1161.5	1134.2	1065.4	1025.2	1007.5
25°	1130.7	1092.7	1014.5	966.0	948.1
27.5°	1094.0	1053.6	967.1	911.4	884.1
30°	1054.9	1009.7	914.9	854.5	822.5
32.5°	1016.9	962.3	865.2	794.1	764.4
35°	974.3	913.8	809.5	734.8	708.7
37.5°	932.8	867.5	757.3	675.5	645.9
40°	888.9	817.8	702.8	618.7	587.9
42.5°	843.8	768.0	648.3	560.5	531.0
45°	796.5	717.0	592.6	508.4	480.0
47.5°	751.5	667.3	539.3	455.1	429.0
50°	701.6	617.5	487.1	405.3	380.5
52.5°	653.0	564.1	437.4	359.1	336.6
55°	605.6	513.2	385.2	314.1	291.6
57.5°	557.1	462.2	339.0	272.6	253.7
60°	507.2	412.4	290.3	230.0	211.0
62.5°	458.8	363.9	248.8	192.0	182.6
65°	408.9	312.8	206.2	166.0	162.3
67.5°	361.6	265.5	166.0	145.8	142.2
70°	311.7	219.3	137.4	125.6	120.8
72.5°	264.4	176.6	114.9	105.5	103.1
75°	218.0	135.1	94.8	86.5	85.4
77.5°	171.9	95.9	74.7	69.9	67.5
80°	129.1	68.8	56.8	52.2	52.2
82.5°	90.1	46.3	39.1	36.7	36.7
85°	50.9	26.1	22.5	22.5	22.5
87.5°	19.0	9.4	9.4	8.3	8.3
90°	0.6	7.0	11.6	14.6	15.6
92.5°	14.6	12.2	13.9	15.1	15.6
95°	37.7	18.5	22.6	25.6	25.0
97.5°	67.9	20.4	29.5	31.4	31.9
100°	102.7	23.2	33.1	37.7	38.9
102.5°	141.0	139.9	34.2	40.6	42.4
105°	176.4	193.8	35.4	41.7	44.1
107.5°	217.6	232.1	36.6	42.9	45.3
110°	257.1	269.3	101.6	43.6	45.9



TEST NUMBER: P913807

CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	294.3	304.7	294.8	44.7	46.4
115°	333.7	343.6	358.1	89.4	47.6
117.5°	368.0	379.5	389.4	306.4	154.4
120°	406.2	414.9	425.4	432.4	354.0
122.5°	438.7	448.1	459.7	463.1	463.7
125°	471.8	479.3	490.4	494.5	496.2
127.5°	502.0	510.1	518.9	524.7	525.2
130°	530.4	539.8	546.1	552.5	552.0
132.5°	559.4	567.0	573.4	578.6	578.1
135°	583.8	593.2	598.3	604.2	603.0
137.5°	609.3	616.3	622.2	628.0	626.2
140°	634.3	639.0	645.3	650.5	647.7
142.5°	655.3	659.3	666.9	671.5	668.6
145°	677.3	676.7	686.6	690.6	687.7
147.5°	696.4	694.7	704.6	707.4	705.1
150°	715.0	711.0	720.3	723.7	720.8
152.5°	730.6	726.0	734.7	738.2	734.2
155°	745.8	740.6	747.5	751.0	746.4
157.5°	758.0	753.4	758.6	762.6	758.0
160°	768.4	764.9	768.4	771.9	767.8
162.5°	777.7	774.2	777.1	781.2	775.9
165°	785.8	782.4	784.1	788.1	784.1
167.5°	792.2	788.7	790.4	794.6	789.3
170°	797.4	793.9	795.1	799.2	793.9
172.5°	800.9	797.4	798.6	802.6	797.4
175°	803.7	799.7	800.9	804.9	799.2
177.5°	804.9	800.9	801.5	805.6	800.3
180°	802.1	802.1	802.1	802.1	802.1



TEST NUMBER: P913807
 CATALOG NUMBER: DFN2DIP-PN2F0-040D030US927-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	10.96	11.82	11.90	12.77	14.00	6.93	7.79	7.87	8.74	9.96
	3H	12.62	13.39	13.57	14.35	15.60	8.11	8.88	9.05	9.83	11.08
	4H	13.22	13.95	14.18	14.91	16.16	8.55	9.27	9.51	10.23	11.49
	6H	13.63	14.30	14.60	15.26	16.53	8.85	9.52	9.83	10.49	11.76
	8H	13.75	14.38	14.72	15.36	16.63	8.94	9.57	9.92	10.56	11.82
	12H	13.80	14.40	14.78	15.38	16.67	8.97	9.58	9.96	10.55	11.85
4H	2H	10.98	11.71	11.95	12.67	13.93	7.52	8.25	8.49	9.21	10.46
	3H	12.79	13.39	13.77	14.38	15.66	8.85	9.46	9.83	10.45	11.72
	4H	13.47	14.02	14.45	15.00	16.30	9.39	9.94	10.37	10.92	12.22
	6H	13.97	14.44	14.96	15.45	16.74	9.79	10.26	10.79	11.27	12.57
	8H	14.13	14.57	15.13	15.57	16.88	9.91	10.35	10.91	11.35	12.66
	12H	14.22	14.61	15.23	15.63	16.94	9.97	10.37	10.98	11.38	12.69
8H	4H	13.43	13.88	14.43	14.88	16.18	9.66	10.10	10.66	11.10	12.41
	6H	13.98	14.34	15.00	15.39	16.69	10.15	10.52	11.18	11.56	12.87
	8H	14.18	14.50	15.21	15.53	16.86	10.33	10.65	11.36	11.68	13.01
	12H	14.31	14.59	15.34	15.61	16.98	10.44	10.72	11.47	11.75	13.11
12H	4H	13.39	13.78	14.40	14.80	16.11	9.66	10.06	10.68	11.08	12.39
	6H	13.95	14.27	14.98	15.30	16.63	10.20	10.52	11.23	11.55	12.87
	8H	14.16	14.44	15.19	15.47	16.84	10.40	10.68	11.43	11.70	13.07