

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P913840

Luminaire Tested: DFN2DIP-PN2F0-060D020US927-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P913840
REPORT IS A COMBINATION OF REPORTS P899469 AND P896349
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-060D020US927-FLLFLL
Description: 2 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6107.7 lumens
Efficiency: N/A
Efficacy: 75.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 80.6
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.946
Total Harmonic Distortion (THDi): 0.132
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	114	114	114	114	108	108	108	108	98	98	98	89	89	89	81	81	81
1	104	99	95	92	99	95	91	88	86	84	81	79	77	75	72	70	68
2	95	87	80	75	90	83	77	72	76	71	67	69	66	62	63	60	58
3	86	76	69	63	82	73	66	61	67	61	57	61	57	53	56	52	49
4	79	68	59	53	75	65	57	52	60	53	48	55	50	45	50	46	42
5	73	61	52	46	69	58	50	44	53	47	42	49	44	39	45	41	37
6	67	55	46	40	64	52	45	39	48	42	37	45	39	35	41	36	33
7	62	49	41	35	59	48	40	34	44	37	33	41	35	31	37	33	29
8	58	45	37	31	55	43	36	31	40	34	29	37	32	28	34	30	26
9	54	41	33	28	52	40	32	27	37	31	26	34	29	25	32	27	24
10	51	38	30	25	48	37	30	25	34	28	24	32	26	23	30	25	22

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4006	4006	4006
5°	4006	3941	3971
10°	3967	3880	3911
15°	3902	3807	3821
20°	3817	3710	3729
25°	3732	3595	3624
30°	3627	3488	3492
35°	3527	3363	3353
40°	3405	3237	3219
45°	3283	3109	3083
50°	3149	2975	2925
55°	3009	2820	2779
60°	2850	2638	2611
65°	2675	2447	2414
70°	2453	2215	2200
75°	2149	1936	1994
80°	1778	1582	1618
85°	1206	1000	1015

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3283 cd/sqm

TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	174.1	2.9
10°-20°	489.8	8.0
20°-30°	719.8	11.8
30°-40°	836.0	13.7
40°-50°	834.9	13.7
50°-60°	728.0	11.9
60°-70°	538.2	8.8
70°-80°	304.5	5.0
80°-90°	81.8	1.3
90°-100°	31.0	0.5
100°-110°	98.5	1.6
110°-120°	168.6	2.8
120°-130°	221.7	3.6
130°-140°	248.9	4.1
140°-150°	244.1	4.0
150°-160°	204.7	3.4
160°-170°	135.8	2.2
170°-180°	47.5	0.8
0°-30°	1383.6	22.7
0°-40°	2219.6	36.3
0°-60°	3782.5	61.9
0°-90°	4707.0	77.1
90°-120°	298.1	4.9
90°-150°	1012.8	16.6
90°-180°	1401.0	22.9
0°-180°	6107.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1849	1849	1849	1849	1849	
5°	1849	1842	1823	1837	1834	176
15°	1760	1750	1727	1734	1725	496
25°	1593	1579	1549	1552	1549	733
35°	1375	1357	1328	1318	1309	858
45°	1119	1106	1079	1060	1053	863
55°	847	836	814	793	784	757
65°	571	560	542	526	518	564
75°	299	295	286	276	279	319
85°	73	71	69	64	62	81
90°	0	6	15	14	14	6
95°	22	26	27	27	26	25
105°	91	92	93	94	94	96
115°	169	172	171	170	169	167
125°	246	250	249	247	247	220
135°	318	323	324	323	322	246
145°	386	389	392	392	391	241
155°	442	443	444	447	445	203
165°	481	480	480	483	481	136
175°	500	499	498	501	498	48
180°	501	501	501	501	501	

TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1849.4	1849.4	1849.4	1849.4	1849.4
2.5°	1860.2	1851.3	1831.7	1849.4	1846.0
5°	1849.4	1842.5	1822.8	1837.0	1833.6
7.5°	1837.0	1826.5	1806.8	1821.1	1817.6
10°	1817.6	1805.1	1783.8	1797.9	1792.6
12.5°	1790.8	1780.2	1758.9	1767.8	1764.2
15°	1760.5	1750.0	1726.8	1734.0	1725.1
17.5°	1723.2	1712.7	1689.5	1698.3	1689.5
20°	1682.3	1671.7	1646.8	1652.1	1645.1
22.5°	1641.6	1625.5	1602.3	1602.3	1598.7
25°	1593.4	1579.3	1549.0	1552.4	1549.0
27.5°	1540.0	1527.6	1504.5	1499.3	1490.4
30°	1486.8	1472.4	1445.9	1440.6	1433.4
32.5°	1429.8	1419.3	1390.8	1380.0	1372.8
35°	1374.8	1357.0	1328.5	1317.7	1308.8
37.5°	1312.5	1296.4	1268.0	1255.4	1246.6
40°	1248.5	1234.1	1205.7	1189.9	1182.6
42.5°	1186.2	1171.9	1143.6	1125.7	1115.1
45°	1118.7	1106.2	1079.4	1060.0	1052.8
47.5°	1052.8	1040.4	1011.9	992.3	981.7
50°	983.4	974.5	949.7	924.7	915.8
52.5°	915.8	903.4	880.4	860.8	848.3
55°	846.6	835.8	814.5	793.2	784.3
57.5°	777.2	768.3	745.1	723.8	716.6
60°	707.7	700.8	675.9	656.2	650.9
62.5°	640.2	627.7	610.0	592.2	585.1
65°	570.9	560.2	542.5	526.4	517.5
67.5°	499.8	490.8	474.9	462.5	455.3
70°	434.0	426.8	410.7	398.3	391.3
72.5°	366.4	359.3	350.4	337.9	332.6
75°	298.7	295.3	286.2	275.7	279.2
77.5°	238.3	231.2	227.5	222.3	217.0
80°	177.9	176.0	172.5	167.2	163.6
82.5°	121.0	121.0	119.2	112.1	112.1
85°	72.8	71.1	69.4	63.9	62.3
87.5°	32.1	28.5	24.9	19.6	17.7
90°	0.5	5.5	14.8	13.9	14.3
92.5°	9.3	12.7	13.2	13.6	13.6
95°	22.0	26.3	27.0	27.0	26.3
97.5°	36.7	40.6	42.3	42.3	42.3
100°	53.6	57.1	58.3	58.3	57.8
102.5°	71.5	74.0	75.7	76.1	75.7
105°	90.9	92.1	93.1	93.8	93.8
107.5°	110.3	112.1	112.1	112.4	110.3
110°	129.0	131.4	131.4	131.4	130.2

TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	149.2	151.8	151.4	150.1	149.2
115°	169.2	171.6	170.9	170.4	169.2
117.5°	189.0	192.3	190.2	189.0	187.7
120°	208.9	212.2	208.9	208.9	207.6
122.5°	227.0	231.2	229.2	228.0	227.0
125°	246.1	249.9	248.7	247.3	246.8
127.5°	264.7	269.3	267.7	265.9	264.7
130°	282.0	287.5	286.7	285.8	284.2
132.5°	301.5	305.8	306.0	304.0	302.7
135°	318.3	323.0	323.8	323.4	322.2
137.5°	337.0	340.8	341.6	341.3	339.4
140°	353.5	357.3	359.4	359.4	357.7
142.5°	370.4	374.1	375.4	375.8	374.1
145°	386.4	389.4	391.9	392.3	390.6
147.5°	400.8	404.6	406.4	407.1	405.4
150°	415.6	418.1	419.8	421.1	419.8
152.5°	428.7	431.3	433.4	435.1	433.4
155°	441.9	443.1	444.4	446.6	445.2
157.5°	453.2	454.1	454.9	457.9	455.7
160°	463.3	464.2	464.7	467.2	465.4
162.5°	472.7	472.7	473.1	476.0	473.9
165°	480.7	480.2	480.2	483.2	481.2
167.5°	487.9	486.6	486.6	489.6	487.5
170°	493.4	492.2	491.7	494.7	492.2
172.5°	497.2	495.9	495.5	498.5	495.9
175°	500.2	499.0	498.0	501.1	498.5
177.5°	501.8	500.7	499.7	502.2	499.7
180°	501.1	501.1	501.1	501.1	501.1

TEST NUMBER: P913840

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US927-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	14.17	15.35	14.86	16.05	16.87	13.74	14.91	14.42	15.61	16.44
	3H	15.84	16.89	16.54	17.60	18.46	15.36	16.41	16.05	17.12	17.98
	4H	16.43	17.42	17.14	18.14	19.01	15.94	16.94	16.66	17.66	18.53
	6H	16.83	17.74	17.55	18.48	19.36	16.34	17.26	17.07	17.99	18.87
	8H	16.93	17.81	17.67	18.56	19.44	16.44	17.32	17.18	18.07	18.96
	12H	16.98	17.82	17.73	18.56	19.48	16.49	17.32	17.24	18.07	18.98
4H	2H	14.66	15.66	15.38	16.38	17.25	14.31	15.31	15.03	16.03	16.90
	3H	16.53	17.36	17.26	18.12	19.01	16.13	16.96	16.86	17.72	18.61
	4H	17.24	18.00	17.99	18.76	19.67	16.83	17.58	17.58	18.34	19.26
	6H	17.76	18.41	18.52	19.20	20.12	17.34	17.99	18.10	18.78	19.70
	8H	17.90	18.51	18.67	19.30	20.23	17.48	18.09	18.25	18.87	19.81
	12H	17.98	18.53	18.77	19.34	20.28	17.55	18.10	18.34	18.90	19.85
8H	4H	17.45	18.06	18.22	18.85	19.78	17.08	17.70	17.85	18.48	19.41
	6H	18.07	18.58	18.87	19.40	20.34	17.70	18.21	18.50	19.03	19.97
	8H	18.28	18.73	19.10	19.56	20.51	17.90	18.35	18.71	19.18	20.13
	12H	18.41	18.81	19.23	19.63	20.64	18.02	18.42	18.83	19.23	20.24
12H	4H	17.45	18.00	18.24	18.81	19.75	17.09	17.64	17.88	18.45	19.39
	6H	18.10	18.55	18.91	19.38	20.33	17.74	18.19	18.55	19.01	19.97
	8H	18.34	18.74	19.16	19.55	20.57	17.97	18.37	18.79	19.18	20.20