

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P916493

Luminaire Tested: DFN2DIP-PN2F0-020D030US930-FLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P916493
REPORT IS A COMBINATION OF REPORTS P900991 AND P897905
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-020D030US930-FLLONL
Description: 2 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4035.7 lumens
Efficiency: N/A
Efficacy: 114.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 35.2
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.099
Total Harmonic Distortion (THDi): 0.979
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	105	105	105	105	95	95	95	95	78	78	78	62	62	62	47	47	47
1	96	91	87	84	87	83	80	77	68	66	64	54	53	51	41	41	40
2	87	80	74	69	79	73	68	63	60	56	53	48	45	43	37	35	33
3	79	70	63	57	72	64	58	53	53	48	44	42	39	36	32	30	28
4	73	62	54	48	66	57	50	45	47	42	38	37	34	31	29	26	24
5	67	55	47	41	60	50	44	38	42	37	33	34	30	27	26	23	21
6	61	49	41	36	56	45	38	33	38	32	28	30	26	23	24	21	19
7	57	45	37	31	51	41	34	29	34	29	25	28	24	21	22	19	17
8	52	40	33	27	48	37	30	26	31	26	22	25	21	18	20	17	15
9	49	37	29	24	44	34	27	23	28	23	20	23	19	17	18	15	13
10	46	34	27	22	41	31	25	20	26	21	18	21	18	15	17	14	12

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1374	1374	1374
5°	1374	1352	1362
10°	1361	1331	1342
15°	1339	1306	1311
20°	1309	1273	1279
25°	1280	1233	1243
30°	1244	1197	1198
35°	1210	1154	1150
40°	1168	1110	1104
45°	1126	1067	1058
50°	1081	1021	1004
55°	1032	967	953
60°	978	905	896
65°	917	839	828
70°	842	760	755
75°	737	664	684
80°	611	543	555
85°	413	343	349

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1126 cd/sqm

TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	59.7	1.5
10°-20°	168.0	4.2
20°-30°	246.9	6.1
30°-40°	286.8	7.1
40°-50°	286.4	7.1
50°-60°	249.7	6.2
60°-70°	184.6	4.6
70°-80°	104.5	2.6
80°-90°	29.0	0.7
90°-100°	27.2	0.7
100°-110°	101.5	2.5
110°-120°	269.1	6.7
120°-130°	446.3	11.1
130°-140°	474.1	11.7
140°-150°	440.6	10.9
150°-160°	354.3	8.8
160°-170°	228.3	5.7
170°-180°	78.6	1.9
0°-30°	474.7	11.8
0°-40°	761.5	18.9
0°-60°	1297.6	32.2
0°-90°	1615.8	40.0
90°-120°	397.8	9.9
90°-150°	1758.9	43.6
90°-180°	2420.0	60.0
0°-180°	4035.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	634	634	634	634	634	
5°	634	632	625	630	629	60
15°	604	600	592	595	592	170
25°	547	542	531	533	531	252
35°	472	466	456	452	449	295
45°	384	380	370	364	361	296
55°	290	287	279	272	269	260
65°	196	192	186	181	178	194
75°	102	101	98	95	96	109
85°	25	24	24	22	21	28
90°	1	7	12	15	16	4
95°	39	19	23	26	26	46
105°	182	200	36	43	45	194
115°	343	354	368	92	49	338
125°	486	493	505	509	511	433
135°	601	610	616	622	621	464
145°	697	696	707	711	708	436
155°	768	762	769	773	768	354
165°	809	805	807	811	807	228
175°	827	823	824	828	822	79
180°	826	826	826	826	826	

TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	634.5	634.5	634.5	634.5	634.5
2.5°	638.1	635.1	628.4	634.5	633.3
5°	634.5	632.1	625.3	630.2	629.0
7.5°	630.2	626.6	619.9	624.8	623.5
10°	623.5	619.3	612.0	616.8	615.0
12.5°	614.3	610.7	603.4	606.4	605.2
15°	604.0	600.4	592.4	594.8	591.8
17.5°	591.2	587.6	579.6	582.6	579.6
20°	577.1	573.5	564.9	566.8	564.3
22.5°	563.1	557.7	549.7	549.7	548.5
25°	546.7	541.8	531.4	532.6	531.4
27.5°	528.3	524.1	516.2	514.4	511.3
30°	510.1	505.2	496.0	494.2	491.7
32.5°	490.5	486.9	477.1	473.4	471.0
35°	471.7	465.5	455.8	452.1	449.0
37.5°	450.3	444.7	435.0	430.7	427.6
40°	428.3	423.4	413.6	408.2	405.7
42.5°	406.9	402.0	392.3	386.2	382.5
45°	383.8	379.5	370.3	363.6	361.2
47.5°	361.2	356.9	347.2	340.4	336.8
50°	337.4	334.4	325.8	317.2	314.2
52.5°	314.2	309.9	302.0	295.3	291.1
55°	290.4	286.7	279.4	272.1	269.0
57.5°	266.6	263.6	255.6	248.3	245.8
60°	242.8	240.4	231.9	225.1	223.3
62.5°	219.6	215.3	209.3	203.2	200.7
65°	195.8	192.2	186.1	180.6	177.6
67.5°	171.5	168.4	162.9	158.7	156.2
70°	148.9	146.4	140.9	136.6	134.3
72.5°	125.7	123.3	120.2	115.9	114.1
75°	102.5	101.3	98.2	94.6	95.8
77.5°	81.8	79.3	78.0	76.2	74.4
80°	61.1	60.4	59.2	57.3	56.1
82.5°	41.5	41.5	40.9	38.5	38.5
85°	24.9	24.4	23.8	21.9	21.4
87.5°	11.0	9.8	8.6	6.8	6.1
90°	0.6	7.2	11.9	15.0	16.1
92.5°	15.0	12.6	14.3	15.6	16.1
95°	38.8	19.1	23.2	26.3	25.7
97.5°	69.9	21.0	30.4	32.3	32.9
100°	105.7	23.9	34.1	38.8	40.0
102.5°	145.1	144.0	35.2	41.7	43.6
105°	181.6	199.5	36.4	43.0	45.4
107.5°	224.0	238.9	37.7	44.2	46.6
110°	264.6	277.1	104.5	44.8	47.2

TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	302.9	313.6	303.5	46.0	47.8
115°	343.4	353.6	368.5	92.0	49.0
117.5°	378.7	390.6	400.8	315.4	158.9
120°	418.1	427.1	437.8	445.0	364.4
122.5°	451.5	461.1	473.1	476.6	477.3
125°	485.6	493.3	504.8	508.9	510.7
127.5°	516.7	525.0	534.0	540.0	540.5
130°	545.9	555.5	562.1	568.6	568.1
132.5°	575.8	583.6	590.1	595.5	594.9
135°	600.9	610.5	615.8	621.8	620.6
137.5°	627.1	634.3	640.3	646.3	644.5
140°	652.8	657.6	664.1	669.5	666.6
142.5°	674.4	678.6	686.3	691.0	688.1
145°	697.1	696.4	706.6	710.8	707.8
147.5°	716.7	714.9	725.1	728.1	725.7
150°	735.9	731.7	741.3	744.8	741.8
152.5°	751.9	747.2	756.2	759.8	755.6
155°	767.5	762.2	769.3	772.9	768.2
157.5°	780.1	775.3	780.7	784.9	780.1
160°	790.8	787.3	790.8	794.4	790.2
162.5°	800.4	796.8	799.8	804.0	798.6
165°	808.7	805.2	807.0	811.1	807.0
167.5°	815.3	811.7	813.5	817.7	812.4
170°	820.7	817.1	818.3	822.5	817.1
172.5°	824.3	820.7	821.9	826.1	820.7
175°	827.2	823.0	824.3	828.4	822.5
177.5°	828.4	824.3	824.9	829.1	823.7
180°	825.5	825.5	825.5	825.5	825.5

TEST NUMBER: P916493

CATALOG NUMBER: DFN2DIP-PN2F0-020D030US930-FLLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	7.26	8.04	8.30	9.09	10.49	6.82	7.60	7.86	8.65	10.05
	3H	8.90	9.59	9.94	10.65	12.07	8.42	9.11	9.46	10.17	11.59
	4H	9.47	10.13	10.53	11.18	12.62	8.98	9.65	10.04	10.70	12.13
	6H	9.85	10.46	10.92	11.52	12.96	9.36	9.97	10.43	11.03	12.47
	8H	9.94	10.52	11.02	11.60	13.04	9.45	10.03	10.53	11.11	12.55
	12H	9.98	10.53	11.06	11.60	13.06	9.49	10.04	10.56	11.11	12.57
4H	2H	7.70	8.37	8.77	9.42	10.85	7.35	8.01	8.42	9.07	10.50
	3H	9.54	10.09	10.61	11.17	12.62	9.14	9.69	10.21	10.77	12.22
	4H	10.23	10.74	11.31	11.81	13.28	9.82	10.32	10.90	11.40	12.87
	6H	10.72	11.16	11.81	12.26	13.72	10.30	10.74	11.39	11.83	13.30
	8H	10.86	11.27	11.95	12.36	13.83	10.44	10.84	11.53	11.93	13.41
	12H	10.92	11.29	12.03	12.39	13.87	10.49	10.86	11.59	11.96	13.44
8H	4H	10.41	10.82	11.50	11.91	13.38	10.04	10.45	11.13	11.54	13.01
	6H	11.02	11.35	12.13	12.48	13.96	10.64	10.98	11.75	12.11	13.58
	8H	11.22	11.52	12.34	12.63	14.12	10.84	11.13	11.96	12.25	13.74
	12H	11.34	11.59	12.46	12.70	14.23	10.94	11.20	12.06	12.31	13.84
12H	4H	10.39	10.76	11.50	11.86	13.34	10.03	10.40	11.14	11.50	12.98
	6H	11.04	11.33	12.16	12.45	13.94	10.68	10.97	11.79	12.08	13.58
	8H	11.26	11.52	12.38	12.63	14.16	10.89	11.15	12.01	12.26	13.79