

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P922027

Luminaire Tested: DFN2DIP-PN2F0-060D020US940-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P922027
REPORT IS A COMBINATION OF REPORTS P900990 AND P897905
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN2F0-060D020US940-RLLONL
Description: 2 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6313.3 lumens
Efficiency: N/A
Efficacy: 78.3 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.17' x L: 2.29' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 80.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.946
Total Harmonic Distortion (THDi): 0.132
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	112	112	112	112	107	107	107	107	96	96	96	86	86	86	76	76	76
1	103	99	95	92	98	94	91	88	85	82	80	76	75	73	69	67	66
2	95	87	81	76	90	83	78	73	75	71	68	68	65	62	61	59	57
3	87	78	70	65	82	74	67	62	67	62	58	61	57	53	55	52	49
4	80	69	61	55	76	66	59	54	60	54	50	55	50	46	50	46	43
5	74	62	54	48	70	59	52	47	54	48	44	50	45	41	45	41	38
6	68	56	48	42	65	54	46	41	49	43	39	45	40	36	41	37	34
7	63	51	43	38	60	49	42	36	45	39	34	41	36	32	38	34	30
8	59	47	39	34	56	45	38	33	41	35	31	38	33	29	35	31	27
9	55	43	35	30	52	41	34	30	38	32	28	35	30	26	32	28	25
10	52	40	32	28	49	38	31	27	35	29	25	33	28	24	30	26	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4789	4789	4789
5°	4789	4703	4736
10°	4734	4601	4575
15°	4661	4438	4331
20°	4567	4220	4033
25°	4471	3976	3745
30°	4345	3727	3383
35°	4220	3460	3065
40°	4093	3185	2702
45°	3946	2882	2373
50°	3794	2577	2052
55°	3634	2252	1744
60°	3449	1914	1429
65°	3235	1571	1279
70°	2975	1251	1147
75°	2649	1083	1030
80°	2179	880	872
85°	1425	547	619

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3946 cd/sqm

TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	207.2	3.3
10°-20°	568.9	9.0
20°-30°	798.7	12.7
30°-40°	870.7	13.8
40°-50°	800.3	12.7
50°-60°	628.5	10.0
60°-70°	409.1	6.5
70°-80°	210.6	3.3
80°-90°	54.8	0.9
90°-100°	19.8	0.3
100°-110°	74.0	1.2
110°-120°	196.2	3.1
120°-130°	325.4	5.2
130°-140°	345.7	5.5
140°-150°	321.3	5.1
150°-160°	258.3	4.1
160°-170°	166.4	2.6
170°-180°	57.3	0.9
0°-30°	1574.9	24.9
0°-40°	2445.6	38.7
0°-60°	3874.3	61.4
0°-90°	4548.8	72.1
90°-120°	290.0	4.6
90°-150°	1282.5	20.3
90°-180°	1765.0	28.0
0°-180°	6313.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2211	2211	2211	2211	2211	
5°	2211	2201	2175	2193	2187	210
15°	2103	2081	2013	1975	1955	593
25°	1909	1845	1713	1631	1601	878
35°	1645	1543	1367	1241	1197	1030
45°	1345	1211	1001	858	810	1039
55°	1022	866	650	530	492	914
65°	690	528	348	280	274	685
75°	368	228	160	146	144	389
85°	86	44	38	38	38	99
90°	0	5	9	11	12	6
95°	28	14	17	19	19	33
105°	132	145	27	31	33	141
115°	250	258	269	67	36	247
125°	354	360	368	371	372	316
135°	438	445	449	453	452	338
145°	508	508	515	518	516	318
155°	560	556	561	564	560	258
165°	590	587	588	592	588	167
175°	603	600	601	604	600	57
180°	602	602	602	602	602	

TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2211.3	2211.3	2211.3	2211.3	2211.3
2.5°	2221.3	2211.3	2189.1	2209.3	2205.3
5°	2211.3	2201.3	2175.1	2193.3	2187.3
7.5°	2193.3	2181.3	2153.3	2161.1	2151.2
10°	2169.2	2155.2	2115.3	2109.2	2097.2
12.5°	2139.3	2121.2	2067.1	2055.2	2033.1
15°	2103.2	2081.1	2013.1	1975.1	1955.2
17.5°	2061.2	2029.1	1945.0	1901.0	1869.0
20°	2013.1	1973.0	1873.0	1823.1	1779.0
22.5°	1961.1	1915.0	1798.9	1731.0	1701.0
25°	1909.2	1845.0	1713.0	1631.0	1600.9
27.5°	1847.2	1779.0	1632.9	1538.8	1492.8
30°	1781.1	1704.9	1544.8	1442.9	1388.7
32.5°	1717.0	1624.9	1461.0	1340.8	1290.7
35°	1645.0	1542.9	1366.9	1240.7	1196.6
37.5°	1574.9	1464.7	1278.8	1140.6	1090.7
40°	1500.8	1380.9	1186.6	1044.5	992.6
42.5°	1424.9	1296.8	1094.7	946.5	896.6
45°	1344.8	1210.6	1000.7	858.4	810.4
47.5°	1268.8	1126.8	910.6	768.4	724.4
50°	1184.7	1042.7	822.5	684.3	642.5
52.5°	1102.5	952.4	738.4	606.4	568.4
55°	1022.5	866.5	650.3	530.4	492.3
57.5°	940.6	780.4	572.4	460.3	428.2
60°	856.5	696.4	490.3	388.3	356.2
62.5°	774.5	614.5	420.2	324.2	308.3
65°	690.5	528.2	348.2	280.3	274.1
67.5°	610.4	448.2	280.3	246.1	240.1
70°	526.3	370.2	232.0	212.1	204.0
72.5°	446.3	298.1	194.0	178.2	174.1
75°	368.2	228.0	160.1	146.1	144.2
77.5°	290.3	162.0	126.1	118.1	114.0
80°	218.0	116.1	95.9	88.1	88.1
82.5°	152.0	78.1	66.0	62.0	62.0
85°	86.0	44.0	38.0	38.0	38.0
87.5°	32.1	16.0	16.0	14.0	14.0
90°	0.4	5.3	8.6	10.9	11.8
92.5°	10.9	9.2	10.4	11.3	11.8
95°	28.3	13.9	16.9	19.2	18.7
97.5°	50.9	15.2	22.2	23.5	24.0
100°	77.1	17.4	24.8	28.3	29.2
102.5°	105.8	105.0	25.7	30.5	31.8
105°	132.4	145.4	26.6	31.3	33.1
107.5°	163.4	174.2	27.5	32.2	34.0
110°	193.0	202.1	76.2	32.7	34.4

TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	220.8	228.6	221.2	33.5	34.9
115°	250.4	257.8	268.8	67.1	35.8
117.5°	276.1	284.8	292.2	230.0	115.8
120°	304.9	311.4	319.2	324.5	265.6
122.5°	329.2	336.2	344.9	347.5	348.0
125°	354.1	359.7	368.0	371.0	372.4
127.5°	376.7	382.8	389.4	393.7	394.1
130°	398.1	405.0	409.8	414.6	414.2
132.5°	419.8	425.5	430.3	434.2	433.8
135°	438.2	445.1	449.0	453.4	452.5
137.5°	457.3	462.5	466.9	471.3	469.9
140°	476.0	479.6	484.3	488.2	486.1
142.5°	491.7	494.8	500.4	503.9	501.7
145°	508.3	507.8	515.2	518.3	516.1
147.5°	522.6	521.3	528.7	530.8	529.1
150°	536.5	533.5	540.5	543.1	540.9
152.5°	548.3	544.8	551.3	554.0	550.9
155°	559.6	555.7	561.0	563.6	560.1
157.5°	568.8	565.3	569.3	572.3	568.8
160°	576.7	574.0	576.7	579.3	576.2
162.5°	583.5	580.9	583.2	586.2	582.3
165°	589.7	587.1	588.4	591.5	588.4
167.5°	594.5	591.8	593.2	596.3	592.3
170°	598.4	595.8	596.6	599.7	595.8
172.5°	601.0	598.4	599.3	602.4	598.4
175°	603.2	600.1	601.0	604.0	599.7
177.5°	604.0	601.0	601.5	604.5	600.6
180°	601.9	601.9	601.9	601.9	601.9

TEST NUMBER: P922027

CATALOG NUMBER: DFN2DIP-PN2F0-060D020US940-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	14.32	15.37	15.07	16.14	17.06	10.29	11.34	11.04	12.11	13.03
	3H	16.00	16.94	16.76	17.71	18.66	11.48	12.42	12.24	13.19	14.15
	4H	16.60	17.49	17.38	18.27	19.23	11.93	12.81	12.71	13.60	14.56
	6H	17.02	17.83	17.81	18.63	19.60	12.25	13.06	13.04	13.85	14.83
	8H	17.14	17.92	17.94	18.73	19.71	12.33	13.11	13.14	13.92	14.90
	12H	17.20	17.94	18.01	18.75	19.75	12.38	13.12	13.19	13.92	14.93
4H	2H	14.36	15.25	15.15	16.03	17.00	10.90	11.79	11.69	12.57	13.53
	3H	16.19	16.92	16.99	17.74	18.72	12.25	12.99	13.05	13.81	14.79
	4H	16.87	17.54	17.68	18.36	19.37	12.80	13.46	13.61	14.28	15.29
	6H	17.38	17.96	18.21	18.80	19.81	13.21	13.78	14.04	14.63	15.64
	8H	17.55	18.09	18.38	18.93	19.95	13.33	13.87	14.16	14.71	15.73
	12H	17.64	18.13	18.49	18.99	20.02	13.40	13.88	14.25	14.74	15.77
8H	4H	16.85	17.39	17.68	18.23	19.26	13.08	13.62	13.91	14.45	15.48
	6H	17.41	17.85	18.26	18.73	19.76	13.58	14.03	14.44	14.91	15.93
	8H	17.61	18.00	18.48	18.88	19.92	13.76	14.15	14.63	15.03	16.07
	12H	17.74	18.09	18.61	18.96	20.06	13.88	14.22	14.75	15.09	16.19
12H	4H	16.82	17.30	17.67	18.16	19.19	13.09	13.57	13.94	14.43	15.46
	6H	17.38	17.77	18.25	18.65	19.69	13.63	14.02	14.50	14.90	15.94
	8H	17.60	17.94	18.47	18.81	19.91	13.83	14.18	14.70	15.05	16.14

END OF REPORT