

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P908578

Luminaire Tested: DFN2DIP-PN3F0-090D040US840-RLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P908578
REPORT IS A COMBINATION OF REPORTS P899538 AND P896399
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN3F0-090D040US840-RLLFLL
Description: 3 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11300.4 lumens
Efficiency: N/A
Efficacy: 91.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 2.96' x L: 3.11' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 123
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9954
Total Harmonic Distortion (THDi): 0.076
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P908578
CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLLFLL

Luminous Intensity Polar Plot





TEST NUMBER: P908578
 CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	112	112	112	112	105	105	105	105	94	94	94	83	83	83	73	73	73	68				68
1	103	98	95	91	97	93	90	87	83	81	78	74	72	70	66	64	63	59				59
2	94	87	81	76	89	82	77	72	74	70	66	66	63	60	59	56	54	50				50
3	86	77	70	64	81	73	67	61	66	61	56	59	55	51	52	49	47	44				44
4	79	69	61	55	75	65	58	53	59	53	49	53	48	45	47	44	41	38				38
5	73	62	53	48	69	59	51	46	53	47	43	48	43	39	43	39	36	33				33
6	68	56	48	42	64	53	46	40	48	42	38	44	39	35	39	35	32	30				30
7	63	51	43	37	59	48	41	36	44	38	33	40	35	31	36	32	29	27				27
8	58	46	38	33	55	44	37	32	40	34	30	37	32	28	33	29	26	24				24
9	55	42	35	30	52	41	34	29	37	31	27	34	29	25	31	27	24	22				22
10	51	39	32	27	48	37	31	26	34	29	25	32	27	23	29	25	22	20				20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4391	4391	4391
5°	4396	4318	4347
10°	4350	4231	4204
15°	4287	4088	3984
20°	4205	3892	3714
25°	4121	3673	3453
30°	4010	3449	3123
35°	3900	3209	2834
40°	3789	2960	2502
45°	3659	2685	2201
50°	3525	2407	1908
55°	3385	2111	1626
60°	3222	1802	1337
65°	3035	1487	1201
70°	2808	1195	1084
75°	2522	1046	982
80°	2109	868	846
85°	1432	564	624

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 3659 cd/sqm



TEST NUMBER: P908578

CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLFL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	352.1	3.1
10°-20°	966.5	8.6
20°-30°	1356.9	12.0
30°-40°	1479.1	13.1
40°-50°	1359.4	12.0
50°-60°	1067.6	9.4
60°-70°	694.9	6.1
70°-80°	357.7	3.2
80°-90°	94.9	0.8
90°-100°	79.1	0.7
100°-110°	251.2	2.2
110°-120°	429.8	3.8
120°-130°	565.3	5.0
130°-140°	634.5	5.6
140°-150°	622.2	5.5
150°-160°	522.0	4.6
160°-170°	346.2	3.1
170°-180°	121.0	1.1
0°-30°	2675.4	23.7
0°-40°	4154.5	36.8
0°-60°	6581.5	58.2
0°-90°	7729.1	68.4
90°-120°	760.1	6.7
90°-150°	2582.2	22.9
90°-180°	3571.0	31.6
0°-180°	11300.4	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3756	3756	3756	3756	3756	
5°	3756	3739	3695	3726	3716	356
15°	3573	3535	3420	3355	3321	1007
25°	3243	3134	2910	2771	2720	1492
35°	2794	2621	2322	2108	2033	1749
45°	2284	2057	1700	1458	1377	1764
55°	1737	1472	1105	901	836	1552
65°	1173	897	592	476	466	1163
75°	625	387	272	248	245	661
85°	146	75	64	64	64	168
90°	1	14	38	35	37	11
95°	56	67	69	69	67	63
105°	232	235	237	239	239	245
115°	431	438	436	434	431	427
125°	627	637	634	630	629	561
135°	812	823	826	825	822	627
145°	985	993	999	1000	996	616
155°	1126	1130	1133	1138	1135	519
165°	1226	1224	1224	1232	1227	346
175°	1275	1272	1270	1278	1271	121
180°	1278	1278	1278	1278	1278	



TEST NUMBER: P908578

CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLFL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3756.4	3756.4	3756.4	3756.4	3756.4
2.5°	3773.4	3756.4	3718.8	3753.2	3746.3
5°	3756.4	3739.4	3695.1	3725.7	3715.6
7.5°	3725.7	3705.5	3657.9	3671.3	3654.3
10°	3685.0	3661.2	3593.4	3582.9	3562.7
12.5°	3634.1	3603.5	3511.5	3491.3	3453.7
15°	3572.8	3535.3	3419.9	3355.3	3321.4
17.5°	3501.4	3447.0	3304.1	3229.4	3175.0
20°	3419.9	3351.7	3181.8	3097.1	3022.0
22.5°	3331.5	3253.3	3056.0	2940.5	2889.7
25°	3243.2	3134.2	2909.9	2770.7	2719.5
27.5°	3137.9	3022.0	2773.9	2614.1	2535.9
30°	3025.7	2896.2	2624.2	2451.1	2359.1
32.5°	2916.7	2760.2	2481.7	2277.7	2192.5
35°	2794.5	2621.0	2322.0	2107.8	2032.8
37.5°	2675.4	2488.3	2172.3	1937.5	1852.8
40°	2549.6	2345.8	2015.8	1774.5	1686.2
42.5°	2420.4	2203.0	1859.6	1607.9	1523.1
45°	2284.5	2056.6	1699.8	1458.1	1376.6
47.5°	2155.4	1914.1	1546.9	1305.3	1230.6
50°	2012.6	1771.2	1397.2	1162.5	1091.4
52.5°	1873.0	1618.0	1254.5	1030.1	965.5
55°	1737.0	1471.9	1104.7	901.0	836.4
57.5°	1597.8	1325.9	972.4	781.9	727.5
60°	1454.9	1183.0	832.8	659.6	605.2
62.5°	1315.8	1043.8	713.8	550.8	523.7
65°	1172.9	897.4	591.5	476.1	465.6
67.5°	1036.9	761.3	476.1	418.0	407.9
70°	894.1	629.0	394.3	360.3	346.6
72.5°	758.1	506.3	329.6	302.6	295.8
75°	625.4	387.4	272.0	248.1	244.9
77.5°	493.0	275.2	214.2	200.6	193.7
80°	370.4	197.3	163.0	149.7	149.7
82.5°	258.2	132.7	112.2	105.3	105.3
85°	146.0	74.6	64.5	64.5	64.5
87.5°	54.4	27.1	27.1	23.8	23.8
90°	1.1	13.8	37.8	35.4	36.6
92.5°	23.8	32.3	33.5	34.6	34.6
95°	56.2	67.1	69.0	69.0	67.1
97.5°	93.6	103.6	107.9	107.9	107.9
100°	136.7	145.6	148.7	148.7	147.5
102.5°	182.2	188.7	193.0	194.1	193.0
105°	231.9	234.9	237.2	239.1	239.1
107.5°	281.1	285.8	285.8	286.5	281.1
110°	328.9	335.1	335.1	335.1	332.0



TEST NUMBER: P908578

CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLFL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	380.5	387.1	385.9	382.8	380.5
115°	431.3	437.6	435.6	434.4	431.3
117.5°	481.8	490.3	484.9	481.8	478.8
120°	532.7	541.1	532.7	532.7	529.2
122.5°	578.9	589.7	584.3	581.2	578.9
125°	627.4	637.0	634.0	630.5	629.3
127.5°	674.8	686.7	682.5	677.8	674.8
130°	719.0	733.0	731.0	728.7	724.5
132.5°	768.7	779.5	780.3	774.9	771.8
135°	811.5	823.4	825.8	824.6	821.5
137.5°	859.3	868.9	870.8	870.0	865.5
140°	901.2	910.9	916.3	916.3	912.0
142.5°	944.4	954.0	957.0	958.3	954.0
145°	985.2	992.9	999.1	1000.3	996.0
147.5°	1021.8	1031.4	1036.0	1037.9	1033.7
150°	1059.6	1066.1	1070.4	1073.8	1070.4
152.5°	1093.1	1099.5	1105.0	1109.2	1105.0
155°	1126.5	1129.6	1133.1	1138.5	1135.0
157.5°	1155.5	1157.7	1159.6	1167.4	1162.0
160°	1181.2	1183.6	1184.7	1191.2	1186.6
162.5°	1205.1	1205.1	1206.3	1213.6	1208.2
165°	1225.6	1224.4	1224.4	1232.0	1226.7
167.5°	1244.1	1240.5	1240.5	1248.3	1242.8
170°	1257.9	1254.8	1253.6	1261.3	1254.8
172.5°	1267.5	1264.5	1263.2	1271.0	1264.5
175°	1275.3	1272.1	1269.8	1277.5	1271.0
177.5°	1279.5	1276.4	1274.0	1280.6	1274.0
180°	1277.5	1277.5	1277.5	1277.5	1277.5



TEST NUMBER: P908578
 CATALOG NUMBER: DFN2DIP-PN3F0-090D040US840-RLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	13.82	14.82	14.60	15.63	16.61	9.78	10.79	10.57	11.59	12.58
	3H	15.50	16.40	16.30	17.22	18.23	10.98	11.88	11.78	12.69	13.71
	4H	16.11	16.96	16.93	17.79	18.81	11.43	12.28	12.25	13.10	14.13
	6H	16.54	17.32	17.37	18.15	19.19	11.76	12.54	12.59	13.37	14.41
	8H	16.67	17.41	17.51	18.26	19.30	11.85	12.59	12.69	13.44	14.48
	12H	16.73	17.44	17.58	18.28	19.35	11.90	12.60	12.74	13.45	14.51
4H	2H	13.85	14.70	14.68	15.53	16.55	10.39	11.24	11.22	12.07	13.09
	3H	15.69	16.40	16.53	17.25	18.30	11.75	12.46	12.59	13.32	14.36
	4H	16.39	17.03	17.23	17.88	18.95	12.30	12.94	13.15	13.80	14.87
	6H	16.90	17.46	17.77	18.34	19.41	12.73	13.28	13.59	14.16	15.23
	8H	17.08	17.60	17.95	18.47	19.56	12.85	13.37	13.72	14.25	15.33
	12H	17.18	17.64	18.07	18.54	19.63	12.92	13.39	13.81	14.28	15.37
8H	4H	16.36	16.88	17.23	17.76	18.84	12.59	13.11	13.46	13.98	15.07
	6H	16.93	17.36	17.83	18.27	19.36	13.11	13.54	14.00	14.45	15.54
	8H	17.14	17.52	18.05	18.43	19.53	13.30	13.67	14.20	14.59	15.69
	12H	17.29	17.62	18.19	18.52	19.68	13.42	13.75	14.33	14.65	15.81
12H	4H	16.32	16.79	17.21	17.68	18.77	12.60	13.07	13.49	13.96	15.05
	6H	16.91	17.28	17.81	18.19	19.30	13.16	13.54	14.06	14.45	15.55
	8H	17.13	17.46	18.04	18.36	19.52	13.37	13.70	14.28	14.61	15.76