

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P906131

Luminaire Tested: DFN2DIP-PN4F0-110D050US835-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P906131
REPORT IS A COMBINATION OF REPORTS P901162 AND P898053
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN4F0-110D050US835-RLLONL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14300.0 lumens
Efficiency: N/A
Efficacy: 94.1 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.74' x L: 3.94' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 151.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.996
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	111	111	111	111	104	104	104	104	92	92	92		81	81	81		70
1	102	98	94	91	96	92	89	86	82	79	77		72	70	69		63
2	93	86	80	75	88	81	76	72	72	68	65		64	61	58		56
3	86	76	69	63	80	72	66	61	64	59	55		57	53	50		50
4	79	68	60	54	74	64	57	52	58	52	48		51	47	43		46
5	72	61	53	47	68	58	51	45	52	46	42		46	42	38		41
6	67	55	47	41	63	52	45	40	47	41	37		42	37	34		38
7	62	50	42	37	59	48	40	35	43	37	33		39	34	30		35
8	58	46	38	33	55	44	36	32	39	34	29		36	31	27		32
9	54	42	34	29	51	40	33	28	36	31	27		33	28	25		30
10	51	39	31	27	48	37	30	26	34	28	24		31	26	23		28

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3319	3319	3319
5°	3324	3266	3287
10°	3291	3203	3181
15°	3246	3097	3016
20°	3186	2952	2814
25°	3124	2789	2618
30°	3042	2621	2370
35°	2961	2441	2152
40°	2879	2255	1902
45°	2784	2048	1675
50°	2685	1840	1454
55°	2582	1616	1241
60°	2462	1383	1022
65°	2325	1146	921
70°	2159	925	834
75°	1950	816	760
80°	1647	686	662
85°	1148	460	501

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2784 cd/sqm

TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	426.1	3.0
10°-20°	1169.7	8.2
20°-30°	1642.2	11.5
30°-40°	1790.1	12.5
40°-50°	1645.3	11.5
50°-60°	1292.1	9.0
60°-70°	841.1	5.9
70°-80°	432.9	3.0
80°-90°	113.5	0.8
90°-100°	55.7	0.4
100°-110°	207.4	1.5
110°-120°	550.1	3.8
120°-130°	912.4	6.4
130°-140°	969.2	6.8
140°-150°	900.8	6.3
150°-160°	724.2	5.1
160°-170°	466.6	3.3
170°-180°	160.6	1.1
0°-30°	3238.0	22.6
0°-40°	5028.1	35.2
0°-60°	7965.5	55.7
0°-90°	9353.0	65.4
90°-120°	813.2	5.7
90°-150°	3595.6	25.1
90°-180°	4947.0	34.6
0°-180°	14300.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4546	4546	4546	4546	4546	
5°	4546	4526	4472	4509	4497	431
15°	4324	4279	4139	4061	4020	1218
25°	3925	3793	3522	3353	3291	1805
35°	3382	3172	2810	2551	2460	2117
45°	2765	2489	2057	1765	1666	2135
55°	2102	1781	1337	1090	1012	1879
65°	1420	1086	716	576	564	1407
75°	757	469	329	300	296	801
85°	177	90	78	78	78	203
90°	1	15	24	31	33	14
95°	79	39	48	54	52	94
105°	371	408	74	88	93	397
115°	702	723	753	188	100	691
125°	993	1009	1032	1040	1044	885
135°	1228	1248	1259	1271	1269	949
145°	1425	1424	1444	1453	1447	891
155°	1569	1558	1573	1580	1570	723
165°	1653	1646	1650	1658	1650	467
175°	1691	1682	1685	1694	1681	161
180°	1687	1687	1687	1687	1687	

TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4546.3	4546.3	4546.3	4546.3	4546.3
2.5°	4566.8	4546.3	4500.9	4542.4	4534.1
5°	4546.3	4525.8	4472.1	4509.2	4497.0
7.5°	4509.2	4484.7	4427.1	4443.3	4422.7
10°	4459.9	4431.0	4349.0	4336.3	4311.9
12.5°	4398.3	4361.2	4249.9	4225.4	4180.0
15°	4324.1	4278.7	4139.0	4060.9	4019.8
17.5°	4237.7	4171.8	3998.9	3908.5	3842.6
20°	4139.0	4056.5	3850.9	3748.3	3657.5
22.5°	4032.1	3937.3	3698.6	3558.9	3497.3
25°	3925.1	3793.3	3521.8	3353.3	3291.3
27.5°	3797.7	3657.5	3357.2	3163.8	3069.1
30°	3661.9	3505.2	3176.1	2966.5	2855.2
32.5°	3530.1	3340.6	3003.6	2756.6	2653.6
35°	3382.1	3172.1	2810.3	2551.0	2460.2
37.5°	3238.1	3011.5	2629.1	2344.9	2242.4
40°	3085.7	2839.1	2439.7	2147.6	2040.7
42.5°	2929.4	2666.2	2250.7	1946.0	1843.4
45°	2764.9	2489.0	2057.3	1764.8	1666.2
47.5°	2608.6	2316.6	1872.2	1579.7	1489.4
50°	2435.7	2143.7	1691.1	1406.9	1320.9
52.5°	2266.8	1958.2	1518.2	1246.7	1168.5
55°	2102.2	1781.4	1337.0	1090.4	1012.3
57.5°	1933.8	1604.6	1176.8	946.4	880.4
60°	1760.9	1431.8	1007.9	798.4	732.5
62.5°	1592.4	1263.3	863.9	666.6	633.8
65°	1419.5	1086.0	715.9	576.2	563.5
67.5°	1255.0	921.5	576.2	505.9	493.7
70°	1082.1	761.3	477.1	436.1	419.5
72.5°	917.5	612.9	399.0	366.2	357.9
75°	756.9	468.8	329.1	300.3	296.4
77.5°	596.7	333.1	259.3	242.7	234.4
80°	448.3	238.8	197.3	181.2	181.2
82.5°	312.5	160.6	135.8	127.5	127.5
85°	176.8	90.4	78.1	78.1	78.1
87.5°	65.9	32.7	32.7	28.8	28.8
90°	1.2	14.6	24.4	30.6	32.9
92.5°	30.6	25.7	29.3	31.8	32.9
95°	79.3	39.0	47.6	53.8	52.5
97.5°	142.8	42.8	62.2	66.0	67.1
100°	216.2	48.9	69.6	79.3	81.8
102.5°	296.7	294.3	72.1	85.4	89.2
105°	371.2	407.9	74.5	87.9	92.8
107.5°	457.9	488.3	77.0	90.3	95.3
110°	541.0	566.5	213.7	91.6	96.4

TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	619.1	641.0	620.3	94.0	97.7
115°	702.1	722.8	753.4	188.1	100.2
117.5°	774.1	798.5	819.4	644.6	324.8
120°	854.7	873.0	895.0	909.7	744.8
122.5°	923.0	942.6	967.1	974.4	975.7
125°	992.6	1008.6	1031.8	1040.3	1044.0
127.5°	1056.1	1073.2	1091.7	1103.8	1105.0
130°	1116.0	1135.6	1148.9	1162.4	1161.3
132.5°	1177.1	1193.0	1206.3	1217.4	1216.2
135°	1228.4	1248.0	1258.8	1271.2	1268.7
137.5°	1282.0	1296.7	1309.0	1321.2	1317.6
140°	1334.5	1344.4	1357.7	1368.7	1362.7
142.5°	1378.6	1387.2	1403.0	1412.7	1406.6
145°	1425.0	1423.7	1444.4	1453.0	1446.9
147.5°	1465.2	1461.5	1482.3	1488.4	1483.6
150°	1504.3	1495.8	1515.3	1522.6	1516.5
152.5°	1537.2	1527.5	1545.8	1553.2	1544.6
155°	1569.0	1558.1	1572.7	1580.0	1570.3
157.5°	1594.6	1584.9	1595.9	1604.5	1594.6
160°	1616.7	1609.3	1616.7	1623.9	1615.4
162.5°	1636.1	1628.9	1634.9	1643.5	1632.5
165°	1653.2	1646.0	1649.6	1658.1	1649.6
167.5°	1666.7	1659.3	1663.1	1671.6	1660.6
170°	1677.7	1670.3	1672.8	1681.3	1670.3
172.5°	1685.0	1677.7	1680.2	1688.7	1677.7
175°	1691.1	1682.5	1685.0	1693.5	1681.3
177.5°	1693.5	1685.0	1686.3	1694.8	1683.8
180°	1687.4	1687.4	1687.4	1687.4	1687.4

TEST NUMBER: P906131

CATALOG NUMBER: DFN2DIP-PN4F0-110D050US835-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.65	13.63	13.47	14.46	15.50	8.62	9.59	9.44	10.43	11.46
	3H	14.34	15.21	15.18	16.06	17.12	9.82	10.69	10.65	11.53	12.60
	4H	14.96	15.78	15.81	16.64	17.71	10.27	11.10	11.12	11.95	13.02
	6H	15.39	16.15	16.25	17.01	18.10	10.60	11.36	11.47	12.22	13.31
	8H	15.52	16.24	16.39	17.12	18.21	10.70	11.42	11.57	12.30	13.39
	12H	15.59	16.28	16.47	17.15	18.26	10.75	11.43	11.62	12.31	13.42
4H	2H	12.69	13.51	13.54	14.36	15.44	9.23	10.05	10.09	10.91	11.98
	3H	14.53	15.21	15.40	16.10	17.19	10.60	11.28	11.46	12.16	13.25
	4H	15.23	15.85	16.11	16.74	17.85	11.15	11.77	12.03	12.65	13.77
	6H	15.76	16.29	16.65	17.20	18.32	11.58	12.11	12.47	13.02	14.14
	8H	15.94	16.44	16.83	17.34	18.47	11.71	12.21	12.61	13.11	14.24
	12H	16.04	16.49	16.96	17.41	18.55	11.78	12.23	12.70	13.15	14.29
8H	4H	15.21	15.71	16.11	16.61	17.75	11.44	11.94	12.34	12.84	13.98
	6H	15.79	16.20	16.71	17.14	18.27	11.97	12.38	12.89	13.32	14.46
	8H	16.00	16.37	16.94	17.31	18.46	12.16	12.52	13.09	13.46	14.61
	12H	16.15	16.47	17.09	17.40	18.60	12.29	12.61	13.22	13.54	14.74
12H	4H	15.17	15.62	16.08	16.54	17.68	11.45	11.90	12.37	12.82	13.96
	6H	15.76	16.13	16.69	17.06	18.21	12.02	12.38	12.95	13.32	14.47
	8H	15.99	16.31	16.92	17.24	18.44	12.24	12.56	13.17	13.49	14.69

END OF REPORT