

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P911560

Luminaire Tested: DFN2DIP-PN4F0-100D080US850-FLLFLL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P911560
REPORT IS A COMBINATION OF REPORTS P899693 AND P896497
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-PN4F0-100D080US850-FLLFLL
Description: 4 foot, Pentagon Define Geo, with Direct Frosted Lens, Indirect Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 18830.8 lumens
Efficiency: N/A
Efficacy: 118.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 3.74' x L: 3.94' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 158.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9952
Total Harmonic Distortion (THDi): 0.069
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFLL

Luminous Intensity Polar Plot



TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	109	109	109	109	102	102	102	102	88	88	88		75	75	75		64
1	100	95	91	88	93	89	86	82	77	75	72		66	65	63		56
2	91	83	77	72	84	78	72	68	68	64	60		58	55	52		50
3	83	73	66	60	77	69	62	57	60	55	50		52	48	44		44
4	76	65	57	51	70	61	54	48	53	47	43		46	42	38		39
5	70	58	50	43	65	54	47	41	48	42	37		41	37	33		35
6	64	52	44	38	60	49	41	36	43	37	32		37	33	29		32
7	59	47	39	33	55	44	37	32	39	33	29		34	29	26		29
8	55	43	35	29	51	40	33	28	36	30	26		31	26	23		27
9	51	39	31	26	48	37	30	25	33	27	23		29	24	21		25
10	48	36	28	24	45	34	27	23	30	25	21		27	22	19		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3150	3150	3150
5°	3155	3106	3128
10°	3129	3065	3086
15°	3083	3015	3020
20°	3021	2945	2953
25°	2959	2862	2875
30°	2882	2784	2776
35°	2808	2693	2671
40°	2718	2600	2572
45°	2628	2508	2470
50°	2529	2410	2352
55°	2426	2298	2244
60°	2309	2164	2119
65°	2182	2026	1973
70°	2020	1857	1815
75°	1795	1656	1671
80°	1525	1399	1394
85°	1103	955	932

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2628 cd/sqm

TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	406.1	2.2
10°-20°	1142.7	6.1
20°-30°	1679.4	8.9
30°-40°	1950.5	10.4
40°-50°	1948.1	10.3
50°-60°	1698.7	9.0
60°-70°	1255.7	6.7
70°-80°	710.4	3.8
80°-90°	195.5	1.0
90°-100°	173.6	0.9
100°-110°	551.7	2.9
110°-120°	944.1	5.0
120°-130°	1241.6	6.6
130°-140°	1393.7	7.4
140°-150°	1366.6	7.3
150°-160°	1146.4	6.1
160°-170°	760.3	4.0
170°-180°	265.7	1.4
0°-30°	3228.3	17.1
0°-40°	5178.7	27.5
0°-60°	8825.5	46.9
0°-90°	10987.1	58.3
90°-120°	1669.4	8.9
90°-150°	5671.3	30.1
90°-180°	7844.0	41.7
0°-180°	18830.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4315	4315	4315	4315	4315	
5°	4315	4299	4253	4286	4278	410
15°	4108	4083	4029	4046	4025	1157
25°	3718	3685	3614	3622	3614	1711
35°	3208	3166	3100	3075	3054	2003
45°	2610	2581	2518	2473	2456	2014
55°	1975	1950	1900	1851	1830	1766
65°	1332	1307	1266	1228	1208	1317
75°	697	689	668	643	652	744
85°	170	166	162	149	145	190
90°	3	30	83	78	80	18
95°	124	147	151	151	147	137
105°	509	516	521	525	525	537
115°	947	961	957	954	947	937
125°	1378	1399	1392	1385	1382	1231
135°	1782	1809	1814	1811	1804	1378
145°	2164	2181	2194	2197	2188	1352
155°	2474	2481	2489	2500	2493	1139
165°	2692	2689	2689	2706	2694	759
175°	2801	2794	2789	2806	2792	266
180°	2806	2806	2806	2806	2806	

TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4315.2	4315.2	4315.2	4315.2	4315.2
2.5°	4340.3	4319.6	4273.8	4315.2	4307.2
5°	4315.2	4298.9	4253.1	4286.2	4278.2
7.5°	4286.2	4261.4	4215.6	4249.1	4240.8
10°	4240.8	4211.8	4162.0	4195.0	4182.7
12.5°	4178.3	4153.6	4103.9	4124.6	4116.2
15°	4107.8	4083.2	4029.0	4045.7	4025.1
17.5°	4020.7	3996.1	3941.8	3962.6	3941.8
20°	3925.1	3900.5	3842.4	3854.7	3838.4
22.5°	3830.0	3792.7	3738.4	3738.4	3730.1
25°	3717.8	3684.8	3614.3	3622.2	3614.3
27.5°	3593.2	3564.1	3510.4	3498.1	3477.4
30°	3469.1	3435.6	3373.5	3361.2	3344.4
32.5°	3336.1	3311.5	3244.9	3219.9	3203.1
35°	3207.6	3166.2	3099.7	3074.6	3053.9
37.5°	3062.3	3024.8	2958.4	2929.3	2908.6
40°	2913.0	2879.5	2813.1	2776.2	2759.4
42.5°	2767.7	2734.2	2668.3	2626.4	2601.8
45°	2610.1	2581.1	2518.5	2473.2	2456.5
47.5°	2456.5	2427.5	2361.0	2315.1	2290.5
50°	2294.5	2273.8	2215.7	2157.6	2136.9
52.5°	2136.9	2107.9	2054.1	2008.4	1979.3
55°	1975.4	1950.3	1900.5	1850.7	1830.1
57.5°	1813.3	1792.6	1738.5	1688.8	1672.0
60°	1651.3	1635.0	1576.9	1531.1	1518.8
62.5°	1493.7	1464.7	1423.3	1381.9	1365.2
65°	1332.1	1307.1	1265.7	1228.2	1207.6
67.5°	1166.2	1145.0	1108.1	1079.1	1062.3
70°	1012.5	995.8	958.4	929.3	913.0
72.5°	854.9	838.2	817.6	788.5	776.1
75°	696.9	689.0	667.8	643.2	651.5
77.5°	556.1	539.3	530.9	518.6	506.3
80°	415.1	410.8	402.3	390.0	381.7
82.5°	282.2	282.2	278.2	261.5	261.5
85°	169.9	166.0	162.0	149.3	145.3
87.5°	74.9	66.4	58.1	45.8	41.4
90°	2.6	30.5	83.0	77.9	80.4
92.5°	52.5	71.1	73.6	76.1	76.1
95°	123.5	147.2	151.4	151.4	147.2
97.5°	205.6	227.6	236.9	236.9	236.9
100°	300.3	319.7	326.5	326.5	323.9
102.5°	400.1	414.5	423.7	426.3	423.7
105°	509.3	516.0	521.1	525.3	525.3
107.5°	617.5	627.7	627.7	629.4	617.5
110°	722.4	735.9	735.9	735.9	729.2

TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFLL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	835.7	850.2	847.6	840.8	835.7
115°	947.4	960.9	956.7	954.2	947.4
117.5°	1058.2	1076.8	1065.0	1058.2	1051.4
120°	1169.9	1188.5	1169.9	1169.9	1162.2
122.5°	1271.4	1295.1	1283.2	1276.5	1271.4
125°	1377.9	1399.1	1392.3	1384.7	1382.3
127.5°	1482.1	1508.2	1498.9	1488.8	1482.1
130°	1579.3	1609.7	1605.5	1600.5	1591.2
132.5°	1688.5	1712.1	1713.8	1702.0	1695.2
135°	1782.3	1808.6	1813.7	1811.1	1804.3
137.5°	1887.2	1908.4	1912.6	1910.9	1900.7
140°	1979.5	2000.5	2012.4	2012.4	2003.1
142.5°	2074.2	2095.3	2102.1	2104.7	2095.3
145°	2163.9	2180.7	2194.3	2196.8	2187.5
147.5°	2244.2	2265.4	2275.4	2279.8	2270.5
150°	2327.1	2341.4	2350.7	2358.4	2350.7
152.5°	2400.7	2415.1	2426.9	2436.3	2426.9
155°	2474.3	2481.1	2488.7	2500.5	2492.9
157.5°	2537.7	2542.8	2547.0	2563.9	2552.1
160°	2594.4	2599.5	2602.0	2616.4	2606.3
162.5°	2646.9	2646.9	2649.4	2665.5	2653.6
165°	2691.7	2689.1	2689.1	2706.1	2694.2
167.5°	2732.2	2724.7	2724.7	2741.6	2729.7
170°	2762.7	2756.0	2753.4	2770.4	2756.0
172.5°	2783.9	2777.2	2774.6	2791.5	2777.2
175°	2800.8	2794.0	2788.9	2805.9	2791.5
177.5°	2810.1	2803.3	2798.2	2812.6	2798.2
180°	2805.9	2805.9	2805.9	2805.9	2805.9

TEST NUMBER: P911560

CATALOG NUMBER: DFN2DIP-PN4F0-100D080US850-FLLFLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.00	12.94	12.88	13.85	14.99	11.56	12.50	12.44	13.41	14.55
	3H	13.67	14.52	14.56	15.43	16.60	13.19	14.03	14.08	14.94	16.12
	4H	14.26	15.06	15.17	15.98	17.16	13.78	14.58	14.69	15.49	16.67
	6H	14.67	15.41	15.59	16.33	17.53	14.18	14.91	15.10	15.84	17.03
	8H	14.78	15.48	15.71	16.42	17.61	14.29	14.99	15.21	15.93	17.12
	12H	14.83	15.50	15.76	16.43	17.65	14.33	15.00	15.26	15.93	17.15
4H	2H	12.47	13.27	13.39	14.19	15.37	12.12	12.92	13.04	13.84	15.02
	3H	14.35	15.02	15.27	15.96	17.16	13.95	14.61	14.87	15.56	16.76
	4H	15.07	15.68	16.00	16.62	17.84	14.65	15.26	15.59	16.20	17.42
	6H	15.59	16.12	16.54	17.08	18.31	15.17	15.69	16.12	16.66	17.88
	8H	15.74	16.23	16.70	17.20	18.43	15.32	15.81	16.27	16.77	18.00
	12H	15.82	16.27	16.79	17.24	18.49	15.38	15.83	16.35	16.80	18.05
8H	4H	15.27	15.76	16.22	16.72	17.96	14.90	15.39	15.85	16.35	17.59
	6H	15.91	16.32	16.89	17.32	18.55	15.53	15.94	16.51	16.94	18.18
	8H	16.13	16.49	17.12	17.48	18.74	15.75	16.11	16.74	17.10	18.35
	12H	16.27	16.59	17.26	17.57	18.87	15.87	16.18	16.86	17.17	18.47
12H	4H	15.26	15.70	16.23	16.68	17.92	14.90	15.34	15.87	16.32	17.56
	6H	15.94	16.30	16.93	17.29	18.54	15.58	15.94	16.56	16.93	18.18
	8H	16.19	16.50	17.18	17.49	18.79	15.82	16.13	16.81	17.12	18.42